

به نام خدا



# مرکز دانلود رایگان مهندسی متالورژی و مواد

[www.Iran-mavad.com](http://www.Iran-mavad.com)




# 2013 ASME Boiler and Pressure Vessel Code

AN INTERNATIONAL CODE

## III

# Rules for Construction of Nuclear Facility Components

## Division 1 — Subsection NB Class 1 Components



[www.iran-mavad.com](http://www.iran-mavad.com)

مرجع دانشجویان و مهندسين مواد

INTENTIONALLY LEFT BLANK



AN INTERNATIONAL CODE

# 2013 ASME Boiler & Pressure Vessel Code

2013 Edition

July 1, 2013



## RULES FOR CONSTRUCTION OF NUCLEAR FACILITY COMPONENTS

### Division 1 - Subsection NB

### Class 1 Components

ASME Boiler and Pressure Vessel Committee  
on Nuclear Power



The American Society of  
Mechanical Engineers

Two Park Avenue • New York, NY • 10016 USA

[www.iran-mavad.com](http://www.iran-mavad.com)

مرجع دانشجویان و مهندسين مواد



Date of Issuance: July 1, 2013

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes in this document are part of this American National Standard.



ASME collective membership mark



Certification Mark

The above ASME symbol is registered in the U.S. Patent Office.

“ASME” is the trademark of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Library of Congress Catalog Card Number: 56-3934  
Printed in the United States of America

Adopted by the Council of The American Society of Mechanical Engineers, 1914; latest edition 2013.

The American Society of Mechanical Engineers  
Two Park Avenue, New York, NY 10016-5990

Copyright © 2013 by  
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS  
All rights reserved

# TABLE OF CONTENTS

List of Sections .....	x
Foreword .....	xii
Statement of Policy on the Use of the Certification Mark and Code Authorization in Advertising .....	xiv
Statement of Policy on the Use of ASME Marking to Identify Manufactured Items .....	xiv
Submittal of Technical Inquiries to the Boiler and Pressure Vessel Standards Committees .....	xv
Personnel .....	xvii
Organization of Section III .....	xxxii
Summary of Changes .....	xxxv
List of Changes in Record Number Order .....	xxxvii
Cross-Referencing and Stylistic Changes in the Boiler and Pressure Vessel Code .....	xxxviii
<b>Article NB-1000 Introduction .....</b>	<b>1</b>
NB-1100 Scope .....	1
NB-1110 Aspects of Construction Covered by these Rules .....	1
NB-1120 Temperature Limits .....	1
NB-1130 Boundaries of Jurisdiction Applicable to this Subsection .....	1
NB-1140 Electrical and Mechanical Penetration Assemblies .....	2
<b>Article NB-2000 Material .....</b>	<b>7</b>
NB-2100 General Requirements for Material .....	7
NB-2110 Scope of Principal Terms Employed .....	7
NB-2120 Pressure-Retaining Material .....	7
NB-2130 Certification of Material .....	9
NB-2140 Welding Material .....	9
NB-2150 Material Identification .....	9
NB-2160 Deterioration of Material in Service .....	9
NB-2170 Heat Treatment to Enhance Impact Properties .....	9
NB-2180 Procedures for Heat Treatment of Material .....	9
NB-2190 Nonpressure-Retaining Material .....	9
NB-2200 Material Test Coupons and Specimens for Ferritic Steel Material .....	10
NB-2210 Heat Treatment Requirements .....	10
NB-2220 Procedure for Obtaining Test Coupons and Specimens for Quenched and Tempered Material .....	10
NB-2300 Fracture Toughness Requirements for Material .....	12
NB-2310 Material to be Impact Tested .....	12
NB-2320 Impact Test Procedures .....	12
NB-2330 Test Requirements and Acceptance Standards .....	13
NB-2340 Number of Impact Tests Required .....	14
NB-2350 Retests .....	15
NB-2360 Calibration of Instruments and Equipment .....	15
NB-2400 Welding Material .....	15
NB-2410 General Requirements .....	15
NB-2420 Required Tests .....	16
NB-2430 Weld Metal Tests .....	17
NB-2440 Storage and Handling of Welding Material .....	19
NB-2500 Examination and Repair of Pressure-retaining Material .....	19
NB-2510 Examination of Pressure-retaining Material .....	19
NB-2520 Examination After Quenching and Tempering .....	20
NB-2530 Examination and Repair of Plate .....	20
NB-2540 Examination and Repair of Forgings and Bars .....	22

NB-2550	Examination and Repair of Seamless and Welded (without Filler Metal) Tubular Products and Fittings .....	24
NB-2560	Examination and Repair of Tubular Products and Fittings Welded with Filler Metal ....	27
NB-2570	Examination and Repair of Statically and Centrifugally Cast Products .....	27
NB-2580	Examination of Bolts, Studs, and Nuts .....	33
NB-2600	Material Organizations' Quality System Programs .....	35
NB-2610	Documentation and Maintenance of Quality System Programs .....	35
NB-2700	Dimensional Standards .....	35
<b>Article NB-3000</b>	<b>Design</b> .....	36
NB-3100	General Design .....	36
NB-3110	Loading Criteria .....	36
NB-3120	Special Considerations .....	36
NB-3130	General Design Rules .....	37
NB-3200	Design by Analysis .....	41
NB-3210	Design Criteria .....	41
NB-3220	Stress Limits for other than Bolts .....	46
NB-3230	Stress Limits for Bolts .....	60
NB-3300	Vessel Design .....	61
NB-3310	General Requirements .....	61
NB-3320	Design Considerations .....	61
NB-3330	Openings and Reinforcement .....	62
NB-3340	Analysis of Vessels .....	70
NB-3350	Design of Welded Construction .....	70
NB-3360	Special Vessel Requirements .....	73
NB-3400	Pump Design .....	73
NB-3410	General Requirements for Centrifugal Pumps .....	73
NB-3420	Definitions .....	74
NB-3430	Design Requirements for Centrifugal Pumps .....	74
NB-3440	Design of Specific Pump Types .....	76
NB-3500	Valve Design .....	78
NB-3510	Acceptability .....	78
NB-3520	Design Considerations .....	80
NB-3530	General Rules .....	80
NB-3540	Design of Pressure-Retaining Parts .....	82
NB-3550	Cyclic Loading Requirements .....	96
NB-3560	Design Reports .....	96
NB-3590	Pressure Relief Valve Design .....	97
NB-3600	Piping Design .....	100
NB-3610	General Requirements .....	100
NB-3620	Design Considerations .....	103
NB-3630	Piping Design and Analysis Criteria .....	104
NB-3640	Pressure Design .....	105
NB-3650	Analysis of Piping Products .....	113
NB-3660	Design of Welds .....	120
NB-3670	Special Piping Requirements .....	120
NB-3680	Stress Indices and Flexibility Factors .....	122
NB-3690	Dimensional Requirements for Piping Products .....	136
<b>Article NB-4000</b>	<b>Fabrication and Installation</b> .....	137
NB-4100	General Requirements .....	137
NB-4110	Introduction .....	137
NB-4120	Certification of Materials and Fabrication by Certificate Holder .....	137
NB-4130	Repair of Material .....	138
NB-4200	Forming, Fitting, and Aligning .....	138
NB-4210	Cutting, Forming, and Bending .....	138
NB-4220	Forming Tolerances .....	139



NB-4230	Fitting and Aligning .....	141
NB-4240	Requirements for Weld Joints in Components .....	142
NB-4250	Welding end Transitions — Maximum Envelope .....	144
NB-4300	Welding Qualifications .....	150
NB-4310	General Requirements .....	150
NB-4320	Welding Qualifications, Records, and Identifying Stamps .....	151
NB-4330	General Requirements for Welding Procedure Qualification Tests .....	156
NB-4350	Special Qualification Requirements for Tube-to-Tubesheet Welds .....	159
NB-4360	Qualification Requirements for Welding Specially Designed Welded Seals .....	159
NB-4400	Rules Governing Making, Examining, and Repairing Welds .....	160
NB-4410	Precautions to be Taken Before Welding .....	160
NB-4420	Rules for Making Welded Joints .....	160
NB-4430	Welding of Attachments .....	162
NB-4440	Welding of Appurtenances .....	163
NB-4450	Repair of Weld Metal Defects .....	163
NB-4500	Brazing .....	166
NB-4510	Rules for Brazing .....	166
NB-4520	Brazing Qualification Requirements .....	166
NB-4530	Fitting and Aligning of Parts to be Brazed .....	168
NB-4540	Examination of Brazed Joints .....	168
NB-4600	Heat Treatment .....	168
NB-4610	Welding Preheat Requirements .....	168
NB-4620	Postweld Heat Treatment .....	168
NB-4630	Heat Treatment of Welds Other Than the Final Postweld Heat Treatment .....	175
NB-4650	Heat Treatment After Bending or Forming for Pipes, Pumps, and Valves .....	176
NB-4660	Heat Treatment of Electroslag Welds .....	176
NB-4700	Mechanical Joints .....	176
NB-4710	Bolting and Threading .....	176
NB-4720	Bolting Flanged Joints .....	176
NB-4730	Electrical and Mechanical Penetration Assemblies .....	176
<b>Article NB-5000</b>	<b>Examination .....</b>	<b>177</b>
NB-5100	General Requirements for Examination .....	177
NB-5110	Methods, Nondestructive Examination Procedures, and Cleaning .....	177
NB-5120	Time of Examination of Welds and Weld Metal Cladding .....	177
NB-5130	Examination of Weld Edge Preparation Surfaces .....	178
NB-5140	Examination of Welds and Adjacent Base Material .....	179
NB-5200	Required Examination of Welds for Fabrication and Preservice Baseline .....	179
NB-5210	Category a Vessel Welded Joints and Longitudinal Welded Joints in Other Components .	179
NB-5220	Category B Vessel Welded Joints and Circumferential Welded Joints in Piping, Pumps, and Valves .....	179
NB-5230	Category C Vessel Welded Joints and Similar Welded Joints in Other Components .....	179
NB-5240	Category D Vessel Welded Joints and Branch and Piping Connections in Other Components .....	179
NB-5250	Weld Metal Buildups to Form Nozzles, Branch and Piping Connections and for Closure Opening Reinforcement .....	180
NB-5260	Fillet, Partial Penetration, Socket, and Attachment Welded Joints .....	180
NB-5270	Special Welded Joints .....	180
NB-5280	Preservice Examination .....	181
NB-5300	Acceptance Standards .....	181
NB-5320	Radiographic Acceptance Standards .....	181
NB-5330	Ultrasonic Acceptance Standards .....	182
NB-5340	Magnetic Particle Acceptance Standards .....	182
NB-5350	Liquid Penetrant Acceptance Standards .....	182
NB-5360	Eddy Current Preservice Examination of Installed Nonferromagnetic Steam Generator Heat Exchanger Tubing .....	183
NB-5370	Visual Acceptance Standards for Brazed Joints .....	183

NB-5380	Bubble Formation Testing .....	183
NB-5400	Final Examination of Vessels .....	183
NB-5410	Examination After Hydrostatic Test .....	183
NB-5500	Qualifications and Certification of Nondestructive Examination Personnel .....	183
NB-5510	General Requirements .....	183
NB-5520	Personnel Qualification, Certification, and Verification .....	183
NB-5530	Records .....	184
<b>Article NB-6000</b>	<b>Testing .....</b>	<b>185</b>
NB-6100	General Requirements .....	185
NB-6110	Pressure Testing of Components, Appurtenances, and Systems .....	185
NB-6120	Preparation for Testing .....	186
NB-6200	Hydrostatic Tests .....	186
NB-6210	Hydrostatic Test Procedure .....	186
NB-6220	Hydrostatic Test Pressure Requirements .....	186
NB-6300	Pneumatic Tests .....	187
NB-6310	Pneumatic Testing Procedures .....	187
NB-6320	Pneumatic Test Pressure Requirements .....	187
NB-6400	Pressure Test Gages .....	187
NB-6410	.....	187
NB-6600	Special Test Pressure Situations .....	188
NB-6610	Components Designed for External Pressure .....	188
NB-6620	Pressure Testing of Combination Units .....	188
<b>Article NB-7000</b>	<b>Overpressure Protection .....</b>	<b>189</b>
NB-7100	General Requirements .....	189
NB-7110	Scope .....	189
NB-7120	Integrated Overpressure Protection .....	189
NB-7130	Verification of the Operation of Reclosing Pressure Relief Devices .....	189
NB-7140	Installation .....	189
NB-7150	Acceptable Pressure Relief Devices .....	190
NB-7160	Unacceptable Pressure Relief Devices .....	190
NB-7170	Permitted Use of Pressure Relief Devices .....	190
NB-7200	Overpressure Protection Report .....	191
NB-7210	Responsibility for Report .....	191
NB-7220	Content of Report .....	191
NB-7230	Certification of Report .....	191
NB-7240	Review of Report After Installation .....	192
NB-7250	Filing of Report .....	192
NB-7300	Relieving Capacity .....	192
NB-7310	Expected System Pressure Transient Conditions .....	192
NB-7320	Unexpected System Excess Pressure Transient Conditions .....	192
NB-7400	Set Pressures of Pressure Relief Devices .....	193
NB-7410	Set Pressure Limitations for Expected System Pressure Transient Conditions .....	193
NB-7420	Set Pressure Limitation for Unexpected System Excess Pressure Transient Conditions ..	193
NB-7500	Operating and Design Requirements for Pressure Relief Valves .....	193
NB-7510	Safety, Safety Relief, and Relief Valves .....	193
NB-7520	Pilot Operated Pressure Relief Valves .....	194
NB-7530	Power Actuated Pressure Relief Valves .....	195
NB-7540	Safety Valves and Pilot Operated Pressure Relief Valves with Auxiliary Actuating Devices	195
NB-7550	Alternative Test Media .....	196
NB-7600	Nonreclosing Pressure Relief Devices .....	197
NB-7610	Rupture Disk Devices .....	197
NB-7620	Installation .....	197
NB-7700	Certification .....	198
NB-7710	Responsibility for Certification of Pressure Relief Valves .....	198
NB-7720	Responsibility for Certification of Nonreclosing Pressure Relief Devices .....	198

NB-7730	Capacity Certification Pressure Relief Valves — Compressible Fluids .....	198
NB-7740	Capacity Certification of Pressure Relief Valves—Incompressible Fluids .....	201
NB-7800	Marking, Stamping With Certification Mark, and Data Reports .....	203
NB-7810	Pressure Relief Valves .....	203
NB-7820	Rupture Disk Devices .....	203
NB-7830	Certificate of Authorization to Use Certification Mark .....	204
<b>Article NB-8000</b>	<b>Nameplates, Stamping with Certification Mark, and Reports .....</b>	<b>205</b>
NB-8100	General Requirements .....	205

## FIGURES

NB-1132.2-1	Attachments in the Component Support Load Path That Do Not Perform a Pressure-Retaining Function .....	3
NB-1132.2-2	Attachments That Do Not Perform a Pressure-Retaining Function and Are Not in the Component Support Load Path (Nonstructural Attachments) .....	4
NB-1132.2-3	Attachments That Perform a Pressure-Retaining Function .....	5
NB-1132.2-4	Attachments Within the Reactor Pressure Vessel (Core Support Structures) That Do Not Perform a Pressure-Retaining Function .....	6
NB-2433.1-1	Weld Metal Delta Ferrite Content .....	20
NB-2552-1	Axial Propagation of Sound in Tube Wall .....	25
NB-2575.2-1	Typical Pressure-Retaining Parts of Pumps and Valves .....	32
NB-3213-1	Examples of Reversing and Nonreversing Dynamic Loads .....	45
NB-3221-1	Stress Categories and Limits of Stress Intensity for Design Conditions .....	50
NB-3222-1	Stress Categories and Limits of Stress Intensity for Level A and Level B Service Limits .....	51
NB-3224-1	Stress Categories and Limits of Stress Intensity for Level C Service Limits .....	56
NB-3332.2-1	Chart for Determining Value of $F$ .....	63
NB-3338.2(a)-1	Direction of Stress Components .....	65
NB-3338.2(a)-2	Nozzle Dimensions .....	66
NB-3339.1(b)-1	Examples of Acceptable Transition Details .....	68
NB-3339.4-1	Limits of Reinforcing Zone .....	69
NB-3351-1	Welded Joint Locations Typical of Categories A, B, C, and D .....	71
NB-3352-1	Typical Butt Joints .....	72
NB-3361-1	Category A and B Joints Between Sections of Unequal Thickness .....	73
NB-3423-1	Typical Single Volute Casing .....	74
NB-3423-2	Typical Double Volute Casing .....	75
NB-3433.4-1	Minimum Tangential Inlet and Outlet Wall Thickness .....	75
NB-3441.1-1	Type A Pump .....	76
NB-3441.1-2	Type A Pump .....	76
NB-3441.2-1	Type B Pump .....	76
NB-3441.3-1	Type C Pump .....	77
NB-3441.3-2	Type C Pump .....	77
NB-3441.4(a)-1	Type D Pump .....	78
NB-3441.5-1	Type E Pump .....	78
NB-3441.6(a)-1	Type F Pump .....	78
NB-3544.1(a)-1	Fillets and Corners .....	84
NB-3544.1(c)-1	Ring Grooves .....	84
NB-3544.3-1	Lugs and Protuberances .....	85
NB-3544.7-1	Flat Wall Limitation .....	86
NB-3545.1(a)-1	Pressure Area Method .....	87
NB-3545.2(a)-1	Critical Sections of Valve Bodies .....	90
NB-3545.2(c)-1	Model for Determining Secondary Stress in Valve Crotch Region .....	92
NB-3545.2(c)-3	Thermal Stress Index Versus Thickness Continuity Run or Branch .....	93
NB-3545.2(c)-4	Secondary Stress Index Versus Thickness Discontinuity Run or Branch .....	94
NB-3545.2(c)-5	$C_4$ Versus $T_{e1}/t_e$ .....	95
NB-3545.2(c)-6	Stress Index for Thermal Fatigue .....	95
NB-3591.1-1	Typical Pressure Relief Devices .....	98
NB-3591.1-2	Typical Pressure Relief and Safety Relief Devices .....	99



NB-3594.3-1	Valve Nozzle .....	101
NB-3622-1	Examples of Reversing and Nonreversing Dynamic Loads .....	104
NB-3643.3(a)-1	Branch Connection Nomenclature .....	108
NB-3643.3(a)-2	Typical Reinforcement of Openings .....	109
NB-3643.3(a)-3	Typical Reinforced Extruded Outlet .....	110
NB-3644(b)-1	Miter Joint Geometry .....	112
NB-3647.2-1	Types of Permanent Blanks .....	114
NB-3653.2(b)-1	Decomposition of Temperature Distribution Range .....	117
NB-3683.1(c)-1	.....	125
NB-3683.1(d)-1	.....	126
NB-3683.6-1	.....	129
NB-3684-1	Direction of Stress Components .....	131
NB-3685.2-1	Elbow Nomenclature .....	134
NB-3686.1-1	.....	134
NB-3686.2-1	.....	135
NB-3686.5-1	Branch Connections in Straight Pipe .....	135
NB-3686.6-1	Reducers .....	136
NB-4221.1-1	Maximum Difference in Cross-Sectional Diameters .....	139
NB-4221.2(a)-1	Maximum Permissible Deviation From a True Circular Form .....	140
NB-4221.2(a)-2	Maximum Arc Length for Determining Plus or Minus Deviation .....	141
NB-4233(a)-1	Butt Weld Alignment and Mismatch Tolerances for Unequal I.D. and O.D. When Components Are Welded From One Side and Fairing Is Not Performed .....	143
NB-4243-1	Acceptable Full Penetration Weld Details for Category C Joints (NB-3352.3) .....	145
NB-4244(a)-1	Nozzles Joined by Full Penetration Butt Welds .....	146
NB-4244(b)-1	Nozzles Joined by Full Penetration Corner Welds .....	147
NB-4244(c)-1	Deposited Weld Metal Used as Reinforcement of Openings for Nozzles .....	148
NB-4244(d)-1	Partial Penetration Nozzles .....	149
NB-4244(d)-2	Partial Penetration Nozzle for Coaxial Cylinders .....	150
NB-4244(e)-1	Oblique Connections .....	151
NB-4246(a)-1	Typical Piping Branch Connections Joined by Full Penetration Welds .....	152
NB-4246(b)-1	Typical Piping Branch Connections Joined by a Fillet Weld or a Partial Penetration Weld .....	153
NB-4250-1	Welding end Transitions — Maximum Envelope .....	154
NB-4250-2	Component to Pipe Weld .....	155
NB-4250-3	Pipe to Pipe Weld .....	155
NB-4427-1	Fillet and Socket Weld Details and Dimensions .....	162
NB-4433-1	Types of Attachment Welds .....	164
NB-4440-1	Appurtenance Weld Joint Details Size NPS 2 (DN 50) and Smaller .....	165
NB-4511-1	Brazed Connections for Appurtenances and Piping, NPS 1 (DN 25) and Less .....	167
NB-4622.9(d)(1)-1	Dissimilar Metal Repair Cavity Measurement .....	175

## TABLES

NB-2332(a)-1	Required $C_v$ Values for Piping, Pumps, and Valves .....	14
NB-2333-1	Required $C_v$ Values for Bolting Material .....	14
NB-2432.1-1	Sampling of Welding Materials for Chemical Analysis .....	18
NB-2432.2(a)-1	Chemical Analysis for Reactor Vessel Welding Material .....	19
NB-2432.2(a)-2	Chemical Analysis for Welding Material for Other Than Reactor Vessel Welds .....	19
NB-2571-1	Required Examinations .....	28
NB-3217-1	Classification of Stress Intensity in Vessels for Some Typical Cases .....	47
NB-3217-2	Classification of Stress Intensity in Piping, Typical Cases .....	49
NB-3228.5(b)-1	Values of $m$ , $n$ , and $T_{max}$ for Various Classes of Permitted Materials .....	60
NB-3338.2(c)-1	Stress Indices for Nozzles .....	67
NB-3339.3-1	Required Minimum Reinforcing Area $A_r$ .....	68
NB-3339.7(c)-1	Stress Indices for Internal Pressure Loading .....	70
NB-3641.1(a)-1	Values of $A$ .....	106
NB-3642.1(b)-1	Bend Radius Versus Thickness .....	107
NB-3681(a)-1	Stress Indices for Use With Equations in NB-3650 .....	123

NB-3685.1-1	Curved Pipe or Welding End Elbows, Internal Pressure .....	132
NB-3685.1-2	Curved Pipe or Welding End Elbows, Moment Loading ( $\lambda \geq 0.2$ ) .....	133
NB-4232-1	Maximum Allowable Offset in Final Welded Joints .....	142
NB-4524-1	Maximum Design Temperatures for Brazing Filler Metal .....	168
NB-4622.1-1	Mandatory Requirements for Postweld Heat Treatment of Welds .....	169
NB-4622.4(c)-1	Alternative Holding Temperatures and Times .....	170
NB-4622.7(b)-1	Exemptions to Mandatory PWHT .....	171
NB-5111-1	Thickness, IQI Designations, Essential Holes, and Wire Diameters .....	178
<b>ENDNOTES</b> .....		207

## LIST OF SECTIONS

### SECTIONS

- I Rules for Construction of Power Boilers
- II Materials
  - Part A — Ferrous Material Specifications
  - Part B — Nonferrous Material Specifications
  - Part C — Specifications for Welding Rods, Electrodes, and Filler Metals
  - Part D — Properties (Customary)
  - Part D — Properties (Metric)
- III Rules for Construction of Nuclear Facility Components
  - Subsection NCA — General Requirements for Division 1 and Division 2
  - Appendices
  - Division 1
    - Subsection NB — Class 1 Components
    - Subsection NC — Class 2 Components
    - Subsection ND — Class 3 Components
    - Subsection NE — Class MC Components
    - Subsection NF — Supports
    - Subsection NG — Core Support Structures
    - Subsection NH — Class 1 Components in Elevated Temperature Service
  - Division 2 — Code for Concrete Containments
  - Division 3 — Containments for Transportation and Storage of Spent Nuclear Fuel and High Level Radioactive Material and Waste
  - Division 5 — High Temperature Reactors
- IV Rules for Construction of Heating Boilers
- V Nondestructive Examination
- VI Recommended Rules for the Care and Operation of Heating Boilers
- VII Recommended Guidelines for the Care of Power Boilers
- VIII Rules for Construction of Pressure Vessels
  - Division 1
  - Division 2 — Alternative Rules
  - Division 3 — Alternative Rules for Construction of High Pressure Vessels
- IX Welding and Brazing Qualifications
- X Fiber-Reinforced Plastic Pressure Vessels
- XI Rules for Inservice Inspection of Nuclear Power Plant Components
- XII Rules for Construction and Continued Service of Transport Tanks



## **INTERPRETATIONS**

ASME issues written replies to inquiries concerning interpretation of technical aspects of the Code.

Interpretations of the Code are posted in January and July at <http://cstools.asme.org/interpretations.cfm>. Any Interpretations issued during the previous two calendar years are included with the publication of the applicable Section of the Code. Interpretations of Section III, Divisions 1 and 2 and Section III Appendices are included with Subsection NCA.

## **CODE CASES**

The Boiler and Pressure Vessel Code committees meet regularly to consider proposed additions and revisions to the Code and to formulate Cases to clarify the intent of existing requirements or provide, when the need is urgent, rules for materials or constructions not covered by existing Code rules. Those Cases that have been adopted will appear in the appropriate 2013 Code Cases book: "Boilers and Pressure Vessels" or "Nuclear Components." Supplements will be sent automatically to the purchasers of the Code Cases books up to the publication of the 2015 Code.

## FOREWORD

(This Foreword is provided as an aid to the user and is not part of the rules of this Code.)

In 1911, The American Society of Mechanical Engineers established the Boiler and Pressure Vessel Committee to formulate standard rules for the construction of steam boilers and other pressure vessels. In 2009, the Boiler and Pressure Vessel Committee was superseded by the following committees:

- (a) Committee on Power Boilers (I)
- (b) Committee on Materials (II)
- (c) Committee on Construction of Nuclear Facility Components (III)
- (d) Committee on Heating Boilers (IV)
- (e) Committee on Nondestructive Examination (V)
- (f) Committee on Pressure Vessels (VIII)
- (g) Committee on Welding and Brazing (IX)
- (h) Committee on Fiber-Reinforced Plastic Pressure Vessels (X)
- (i) Committee on Nuclear Inservice Inspection (XI)
- (j) Committee on Transport Tanks (XII)

Where reference is made to "the Committee" in this Foreword, each of these committees is included individually and collectively.

The Committee's function is to establish rules of safety relating only to pressure integrity, which govern the construction\* of boilers, pressure vessels, transport tanks, and nuclear components, and the inservice inspection of nuclear components and transport tanks. The Committee also interprets these rules when questions arise regarding their intent. This Code does not address other safety issues relating to the construction of boilers, pressure vessels, transport tanks, or nuclear components, or the inservice inspection of nuclear components or transport tanks. Users of the Code should refer to the pertinent codes, standards, laws, regulations, or other relevant documents for safety issues other than those relating to pressure integrity. Except for Sections XI and XII, and with a few other exceptions, the rules do not, of practical necessity, reflect the likelihood and consequences of deterioration in service related to specific service fluids or external operating environments. In formulating the rules, the Committee considers the needs of users, manufacturers, and inspectors of pressure vessels. The objective of the rules is to afford reasonably certain protection of life and property, and to provide a margin for deterioration in service to give a reasonably long, safe period of usefulness. Advancements in design and materials and evidence of experience have been recognized.

This Code contains mandatory requirements, specific prohibitions, and nonmandatory guidance for construction activities and inservice inspection and testing activities. The Code does not address all aspects of these activities and those aspects that are not specifically addressed should not be considered prohibited. The Code is not a handbook and cannot replace education, experience, and the use of engineering judgment. The phrase *engineering judgement* refers to technical judgments made by knowledgeable engineers experienced in the application of the Code. Engineering judgments must be consistent with Code philosophy, and such judgments must never be used to overrule mandatory requirements or specific prohibitions of the Code.

The Committee recognizes that tools and techniques used for design and analysis change as technology progresses and expects engineers to use good judgment in the application of these tools. The designer is responsible for complying with Code rules and demonstrating compliance with Code equations when such equations are mandatory. The Code neither requires nor prohibits the use of computers for the design or analysis of components constructed to the requirements of the Code. However, designers and engineers using computer programs for design or analysis are cautioned that they are responsible for all technical assumptions inherent in the programs they use and the application of these programs to their design.

The rules established by the Committee are not to be interpreted as approving, recommending, or endorsing any proprietary or specific design, or as limiting in any way the manufacturer's freedom to choose any method of design or any form of construction that conforms to the Code rules.

The Committee meets regularly to consider revisions of the rules, new rules as dictated by technological development, Code Cases, and requests for interpretations. Only the Committee has the authority to provide official interpretations of this Code. Requests for revisions, new rules, Code Cases, or interpretations shall be addressed to the Secretary in writing

\* *Construction*, as used in this Foreword, is an all-inclusive term comprising materials, design, fabrication, examination, inspection, testing, certification, and pressure relief.

and shall give full particulars in order to receive consideration and action (see Submittal of Technical Inquiries to the Boiler and Pressure Vessel Standards Committees). Proposed revisions to the Code resulting from inquiries will be presented to the Committee for appropriate action. The action of the Committee becomes effective only after confirmation by ballot of the Committee and approval by ASME. Proposed revisions to the Code approved by the Committee are submitted to the American National Standards Institute (ANSI) and published at <http://cstools.asme.org/csconnect/public/index.cfm?PublicReview=Revisions> to invite comments from all interested persons. After public review and final approval by ASME, revisions are published at regular intervals in Editions of the Code.

The Committee does not rule on whether a component shall or shall not be constructed to the provisions of the Code. The scope of each Section has been established to identify the components and parameters considered by the Committee in formulating the Code rules.

Questions or issues regarding compliance of a specific component with the Code rules are to be directed to the ASME Certificate Holder (Manufacturer). Inquiries concerning the interpretation of the Code are to be directed to the Committee. ASME is to be notified should questions arise concerning improper use of an ASME Certification Mark.

When required by context in this Section, the singular shall be interpreted as the plural, and vice versa, and the feminine, masculine, or neuter gender shall be treated as such other gender as appropriate.



## **STATEMENT OF POLICY ON THE USE OF THE CERTIFICATION MARK AND CODE AUTHORIZATION IN ADVERTISING**

ASME has established procedures to authorize qualified organizations to perform various activities in accordance with the requirements of the ASME Boiler and Pressure Vessel Code. It is the aim of the Society to provide recognition of organizations so authorized. An organization holding authorization to perform various activities in accordance with the requirements of the Code may state this capability in its advertising literature.

Organizations that are authorized to use the Certification Mark for marking items or constructions that have been constructed and inspected in compliance with the ASME Boiler and Pressure Vessel Code are issued Certificates of Authorization. It is the aim of the Society to maintain the standing of the Certification Mark for the benefit of the users, the enforcement jurisdictions, and the holders of the Certification Mark who comply with all requirements.

Based on these objectives, the following policy has been established on the usage in advertising of facsimiles of the Certification Mark, Certificates of Authorization, and reference to Code construction. The American Society of Mechanical Engineers does not “approve,” “certify,” “rate,” or “endorse” any item, construction, or activity and there shall be no statements or implications that might so indicate. An organization holding the Certification Mark and/or a Certificate of Authorization may state in advertising literature that items, constructions, or activities “are built (produced or performed) or activities conducted in accordance with the requirements of the ASME Boiler and Pressure Vessel Code,” or “meet the requirements of the ASME Boiler and Pressure Vessel Code.” An ASME corporate logo shall not be used by any organization other than ASME.

The Certification Mark shall be used only for stamping and nameplates as specifically provided in the Code. However, facsimiles may be used for the purpose of fostering the use of such construction. Such usage may be by an association or a society, or by a holder of the Certification Mark who may also use the facsimile in advertising to show that clearly specified items will carry the Certification Mark. General usage is permitted only when all of a manufacturer’s items are constructed under the rules.

## **STATEMENT OF POLICY ON THE USE OF ASME MARKING TO IDENTIFY MANUFACTURED ITEMS**

The ASME Boiler and Pressure Vessel Code provides rules for the construction of boilers, pressure vessels, and nuclear components. This includes requirements for materials, design, fabrication, examination, inspection, and stamping. Items constructed in accordance with all of the applicable rules of the Code are identified with the official Certification Mark described in the governing Section of the Code.

Markings such as “ASME,” “ASME Standard,” or any other marking including “ASME” or the Certification Mark shall not be used on any item that is not constructed in accordance with all of the applicable requirements of the Code.

Items shall not be described on ASME Data Report Forms nor on similar forms referring to ASME that tend to imply that all Code requirements have been met when, in fact, they have not been. Data Report Forms covering items not fully complying with ASME requirements should not refer to ASME or they should clearly identify all exceptions to the ASME requirements.

# (13) SUBMITTAL OF TECHNICAL INQUIRIES TO THE BOILER AND PRESSURE VESSEL STANDARDS COMMITTEES

## 1 INTRODUCTION

(a) The following information provides guidance to Code users for submitting technical inquiries to the committees. See Guideline on the Approval of New Materials Under the ASME Boiler and Pressure Vessel Code in Section II, Parts C and D for additional requirements for requests involving adding new materials to the Code. Technical inquiries include requests for revisions or additions to the Code rules, requests for Code Cases, and requests for Code Interpretations, as described below.

(1) *Code Revisions.* Code revisions are considered to accommodate technological developments, address administrative requirements, incorporate Code Cases, or to clarify Code intent.

(2) *Code Cases.* Code Cases represent alternatives or additions to existing Code rules. Code Cases are written as a question and reply, and are usually intended to be incorporated into the Code at a later date. When used, Code Cases prescribe mandatory requirements in the same sense as the text of the Code. However, users are cautioned that not all jurisdictions or owners automatically accept Code Cases. The most common applications for Code Cases are:

(-a) to permit early implementation of an approved Code revision based on an urgent need

(-b) to permit the use of a new material for Code construction

(-c) to gain experience with new materials or alternative rules prior to incorporation directly into the Code

(3) *Code Interpretations.* Code Interpretations provide clarification of the meaning of existing rules in the Code, and are also presented in question and reply format. Interpretations do not introduce new requirements. In cases where existing Code text does not fully convey the meaning that was intended, and revision of the rules is required to support an interpretation, an Intent Interpretation will be issued and the Code will be revised.

(b) The Code rules, Code Cases, and Code Interpretations established by the committees are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Code rules.

(c) Inquiries that do not comply with these provisions or that do not provide sufficient information for a committee's full understanding may result in the request being returned to the inquirer with no action.

## 2 INQUIRY FORMAT

Submittals to a committee shall include:

(a) *Purpose.* Specify one of the following:

(1) revision of present Code rules

(2) new or additional Code rules

(3) Code Case

(4) Code Interpretation

(b) *Background.* Provide the information needed for the committee's understanding of the inquiry, being sure to include reference to the applicable Code Section, Division, Edition, Addenda (if applicable), paragraphs, figures, and tables. Preferably, provide a copy of the specific referenced portions of the Code.

(c) *Presentations.* The inquirer may desire or be asked to attend a meeting of the committee to make a formal presentation or to answer questions from the committee members with regard to the inquiry. Attendance at a committee meeting shall be at the expense of the inquirer. The inquirer's attendance or lack of attendance at a meeting shall not be a basis for acceptance or rejection of the inquiry by the committee.

### 3 CODE REVISIONS OR ADDITIONS

Requests for Code revisions or additions shall provide the following:

(a) *Proposed Revisions or Additions.* For revisions, identify the rules of the Code that require revision and submit a copy of the appropriate rules as they appear in the Code, marked up with the proposed revision. For additions, provide the recommended wording referenced to the existing Code rules.

(b) *Statement of Need.* Provide a brief explanation of the need for the revision or addition.

(c) *Background Information.* Provide background information to support the revision or addition, including any data or changes in technology that form the basis for the request that will allow the committee to adequately evaluate the proposed revision or addition. Sketches, tables, figures, and graphs should be submitted as appropriate. When applicable, identify any pertinent paragraph in the Code that would be affected by the revision or addition and identify paragraphs in the Code that reference the paragraphs that are to be revised or added.

### 4 CODE CASES

Requests for Code Cases shall provide a Statement of Need and Background Information similar to that defined in 3(b) and 3(c), respectively, for Code revisions or additions. The urgency of the Code Case (e.g., project underway or imminent, new procedure, etc.) must be defined and it must be confirmed that the request is in connection with equipment that will bear the Certification Mark, with the exception of Section XI applications. The proposed Code Case should identify the Code Section and Division, and be written as a *Question* and a *Reply* in the same format as existing Code Cases. Requests for Code Cases should also indicate the applicable Code Editions and Addenda (if applicable) to which the proposed Code Case applies.

### 5 CODE INTERPRETATIONS

(a) Requests for Code Interpretations shall provide the following:

(1) *Inquiry.* Provide a condensed and precise question, omitting superfluous background information and, when possible, composed in such a way that a “yes” or a “no” *Reply*, with brief provisos if needed, is acceptable. The question should be technically and editorially correct.

(2) *Reply.* Provide a proposed *Reply* that will clearly and concisely answer the *Inquiry* question. Preferably, the *Reply* should be “yes” or “no,” with brief provisos if needed.

(3) *Background Information.* Provide any background information that will assist the committee in understanding the proposed *Inquiry* and *Reply*.

(b) Requests for Code Interpretations must be limited to an interpretation of a particular requirement in the Code or a Code Case. The committee cannot consider consulting type requests such as the following:

(1) a review of calculations, design drawings, welding qualifications, or descriptions of equipment or parts to determine compliance with Code requirements;

(2) a request for assistance in performing any Code-prescribed functions relating to, but not limited to, material selection, designs, calculations, fabrication, inspection, pressure testing, or installation;

(3) a request seeking the rationale for Code requirements.

### 6 SUBMITTALS

Submittals to and responses from the committees shall meet the following:

(a) *Submittal.* Inquiries from Code users shall be in English and preferably be submitted in typewritten form; however, legible handwritten inquiries will also be considered. They shall include the name, address, telephone number, fax number, and e-mail address, if available, of the inquirer and be mailed to the following address:

Secretary  
ASME Boiler and Pressure Vessel Committee  
Two Park Avenue  
New York, NY 10016-5990

As an alternative, inquiries may be submitted via e-mail to: SecretaryBPV@asme.org.

(b) *Response.* The Secretary of the appropriate committee shall acknowledge receipt of each properly prepared inquiry and shall provide a written response to the inquirer upon completion of the requested action by the committee.

# PERSONNEL

## ASME Boiler and Pressure Vessel Standards Committees, Subgroups, and Working Groups

January 1, 2013

### TECHNICAL OVERSIGHT MANAGEMENT COMMITTEE (TOMC)

J. G. Feldstein, <i>Chair</i>	J. F. Henry
T. P. Pastor, <i>Vice Chair</i>	G. G. Karcher
J. S. Brzuszkiewicz, <i>Staff Secretary</i>	W. M. Lundy
R. W. Barnes	J. R. Mackay
R. J. Basile	U. R. Miller
J. E. Batey	W. E. Norris
T. L. Bedeaux	G. C. Park
D. L. Berger	M. D. Rana
D. A. Canonico	B. W. Roberts
A. Chaudouet	S. C. Roberts
R. P. Deubler	F. J. Schaaf, Jr.
D. A. Douin	A. Selz
R. E. Gimple	B. F. Shelley
M. Gold	W. J. Sperko
T. E. Hansen	R. W. Swayne

### HONORARY MEMBERS (MAIN COMMITTEE)

F. P. Barton	M. H. Jawad
R. J. Cepulich	A. J. Justin
T. M. Cullen	W. G. Knecht
W. D. Doty	J. LeCoff
J. R. Farr	T. G. McCarty
G. E. Feigel	G. C. Millman
R. C. Griffin	R. A. Moen
O. F. Hedden	R. F. Reedy, Sr.

### ADMINISTRATIVE COMMITTEE

J. G. Feldstein, <i>Chair</i>	J. F. Henry
T. P. Pastor, <i>Vice Chair</i>	U. R. Miller
J. S. Brzuszkiewicz, <i>Staff Secretary</i>	G. C. Park
R. W. Barnes	M. D. Rana
J. E. Batey	B. F. Shelley
T. L. Bedeaux	W. J. Sperko
D. L. Berger	

### MARINE CONFERENCE GROUP

H. N. Patel, <i>Chair</i>	G. Nair
J. S. Brzuszkiewicz, <i>Staff Secretary</i>	J. D. Reynolds
J. G. Hungerbuhler, Jr.	

### CONFERENCE COMMITTEE

D. A. Douin — Ohio, <i>Secretary</i>	K. T. Lau — Alberta, Canada
J. T. Amato — Minnesota	B. E. Logan — Massachusetts
B. P. Anthony — Rhode Island	W. McGivney — New York
R. D. Austin — Arizona	S. V. Nelson — Colorado
G. Baumgardner — Michigan	C. C. Novak — Illinois
W. K. Brigham — New Hampshire	T. Oda — Washington
C. W. Bryan — Tennessee	W. R. Owens — Louisiana
M. A. Burns — Florida	R. P. Pate — Alabama
J. H. Burpee — Maine	R. L. Perry — Nevada
C. B. Cantrell — Nebraska	J. F. Porcella — West Virginia
D. C. Cook — California	D. C. Price — Yukon Territories, Canada
B. J. Crawford — Georgia	D. Pringnitz — Oklahoma
E. L. Creaser — New Brunswick, Canada	R. S. Pucek — Wisconsin
W. E. Crider, Jr. — Vermont	R. D. Reetz — North Dakota
P. L. Dodge — Nova Scotia, Canada	C. F. Reyes — California
S. Donovan — Northwest Territories, Canada	T. W. Rieger — Manitoba, Canada
D. Eastman — Newfoundland and Labrador, Canada	K. A. Rudolph — Hawaii
B. Fierheller — Manitoba, Canada	M. J. Ryan — Illinois
C. Fulton — Alaska	M. H. Sansone — New York
G. M. Given, Jr. — North Carolina	T. S. Scholl — Ontario, Canada
M. Graham — Oregon	G. Scribner — Missouri
R. J. Handy — Kentucky	C. S. Selinger — Saskatchewan, Canada
D. R. Hannon — Arkansas	R. Spiker — North Carolina
E. G. Hilton — Virginia	T. Stewart — Montana
I. M. Hinkle — South Dakota	R. K. Sturm — Utah
E. Hurd — British Columbia, Canada	S. R. Townsend — Prince Edward Island, Canada
D. T. Jagger — Ohio	W. Vallance — Michigan
D. J. Jenkins — Kansas	M. J. Verhagen — Wisconsin
A. P. Jones — Texas	M. Washington — New Jersey
L. R. Kline — Pennsylvania	K. L. Watson — Mississippi
M. R. Klosterman — Iowa	R. W. Whitman, Jr. — Delaware
K. J. Kraft — Maryland	D. J. Willis — Indiana

### INTERNATIONAL INTEREST REVIEW GROUP

V. Felix	C. Minu
Y.-G. Kim	T. S. G. Narayannen
S. H. Leong	Y.-W. Park
W. Lin	R. Reynaga
O. F. Manafa	P. Williamson

#### PROJECT TEAM ON HYDROGEN TANKS

A. P. Amato, <i>Staff Secretary</i>	E. Uptis
F. L. Brown	C. T. I. Webster
D. A. Canonico	W. Yoru
D. C. Cook	R. C. Biel, <i>Contributing Member</i>
J. Coursen	M. Duncan, <i>Contributing Member</i>
J. W. Felbaum	D. R. Frikken, <i>Contributing Member</i>
N. L. Newhouse	L. E. Hayden, Jr., <i>Contributing Member</i>
A. S. Olivares	K. T. Lau, <i>Contributing Member</i>
G. B. Rawls, Jr.	K. Nibur, <i>Contributing Member</i>
B. F. Shelley	K. Oyamada, <i>Contributing Member</i>
J. R. Sims, Jr.	C. H. Rivkin, <i>Contributing Member</i>
N. Sirosch	C. San Marchi, <i>Contributing Member</i>
J. H. Smith	B. Somerday, <i>Contributing Member</i>
S. Staniszewski	
T. Tahara	
D. W. Treadwell	

#### Subgroup on General Requirements (BPV I)

R. E. McLaughlin, <i>Chair</i>	D. Tompkins
T. E. Hansen, <i>Vice Chair</i>	S. V. Torkildson
F. Massi, <i>Secretary</i>	D. E. Tuttle
P. D. Edwards	M. Wadkinson
W. L. Lowry	R. V. Wielgoszinski
E. M. Ortman	D. J. Willis
J. T. Pillow	C. F. Jeerings, <i>Contributing Member</i>

#### Subgroup on Heat Recovery Steam Generators (BPV I)

T. E. Hansen, <i>Chair</i>	C. T. McDaris
S. V. Torkildson, <i>Secretary</i>	B. W. Moore
J. L. Arnold	Y. Oishi
J. P. Bell	E. M. Ortman
B. G. Carson	R. D. Schueler, Jr.
L. R. Douglas	D. Tompkins
J. Gertz	B. C. Turczynski
G. B. Komora	

#### COMMITTEE ON POWER BOILERS (BPV I)

D. L. Berger, <i>Chair</i>	F. Massi
R. E. McLaughlin, <i>Vice Chair</i>	P. A. Molvie
U. D'Urso, <i>Staff Secretary</i>	Y. Oishi
J. L. Arnold	E. M. Ortman
S. W. Cameron	J. T. Pillow
D. A. Canonico	B. W. Roberts
K. K. Coleman	R. D. Schueler, Jr.
P. D. Edwards	J. M. Tanzosh
P. Fallouey	D. E. Tuttle
J. G. Feldstein	R. V. Wielgoszinski
G. W. Galanes	D. J. Willis
T. E. Hansen	G. Ardizzioia, <i>Delegate</i>
J. F. Henry	H. Michael, <i>Delegate</i>
J. S. Hunter	D. N. French, <i>Honorary Member</i>
W. L. Lowry	T. C. McGough, <i>Honorary Member</i>
J. R. MacKay	R. L. Williams, <i>Honorary Member</i>

#### Subgroup on Locomotive Boilers (BPV I)

L. Moedinger, <i>Chair</i>	G. M. Ray
S. M. Butler, <i>Secretary</i>	J. E. Rimmasch
P. Boschan	R. D. Schueler, Jr.
J. Braun	R. B. Stone
R. C. Franzen, Jr.	M. W. Westland
D. W. Griner	W. L. Withuhn
S. D. Jackson	R. Yuill
M. A. Janssen	R. D. Reetz, <i>Contributing Member</i>
S. A. Lee	

#### Subgroup on Materials (BPV I)

G. W. Galanes, <i>Chair</i>	O. X. Li
K. K. Coleman, <i>Vice Chair</i>	J. R. MacKay
J. S. Hunter, <i>Secretary</i>	F. Masuyama
S. H. Bowes	D. W. Rahoi
D. A. Canonico	B. W. Roberts
P. Fallouey	J. M. Tanzosh
K. L. Hayes	J. Vattappilly
J. F. Henry	

#### Subgroup on Design (BPV I)

P. A. Molvie, <i>Chair</i>	B. W. Moore
J. Vattappilly, <i>Secretary</i>	D. A. Olson
D. I. Anderson	R. D. Schueler, Jr.
P. Dhorajia	S. V. Torkildson
J. P. Glaspie	M. Wadkinson
G. B. Komora	C. F. Jeerings, <i>Contributing Member</i>
J. C. Light	

#### Subgroup on Piping (BPV I)

D. Tompkins, <i>Chair</i>	G. W. Galanes
B. Mollitor, <i>Secretary</i>	T. E. Hansen
D. L. Berger	T. G. Kosmatka
J. A. Byers	W. L. Lowry
P. D. Edwards	F. Massi

#### Subgroup on Fabrication and Examination (BPV I)

J. T. Pillow, <i>Chair</i>	J. Hainsworth
J. L. Arnold, <i>Secretary</i>	T. E. Hansen
G. W. Galanes, <i>Secretary</i>	C. T. McDaris
D. L. Berger	R. E. McLaughlin
S. W. Cameron	R. J. Newell
K. Craver	Y. Oishi
G. T. Dunker	R. V. Wielgoszinski
P. F. Gilston	

#### Subgroup on Solar Boilers (BPV I)

J. S. Hunter, <i>Chair</i>	J. C. Light
S. V. Torkildson, <i>Secretary</i>	Y. Magen
G. W. Galanes	F. Massi
R. E. Hearne	M. J. Slater
D. J. Koza	J. T. Trimble, Jr.

**Task Group on Modernization of BPVC Section I**

D. I. Anderson, <i>Chair</i>	R. E. McLaughlin
U. D'Urso, <i>Staff Secretary</i>	P. A. Molvie
J. L. Arnold	E. M. Ortman
S. W. Cameron	J. T. Pillow
G. W. Galanes	B. W. Roberts
J. P. Glaspie	D. E. Tuttle
J. F. Henry	

**Subgroup on International Material Specifications (BPV II)**

A. Chaudouet, <i>Chair</i>	M. Ishikawa
O. X. Li, <i>Vice Chair</i>	W. M. Lundy
T. F. Miskell, <i>Secretary</i>	A. R. Nywening
S. W. Cameron	R. D. Schueler, Jr.
D. A. Canonico	E. Uptis
P. Fallouey	O. Oldani, <i>Delegate</i>
A. F. Garbolevsky	H. Lorenz, <i>Contributing Member</i>
D. O. Henry	

**COMMITTEE ON MATERIALS (BPV II)**

J. F. Henry, <i>Chair</i>	M. J. Slater
D. W. Rahoi, <i>Vice Chair</i>	R. C. Sutherlin
N. Lobo, <i>Staff Secretary</i>	R. W. Swindeman
F. Abe	J. M. Tanzosh
A. Appleton	D. Tyler
J. Cameron	D. Kwon, <i>Delegate</i>
D. A. Canonico	O. Oldani, <i>Delegate</i>
A. Chaudouet	W. R. Apblett, Jr., <i>Contributing Member</i>
P. Fallouey	H. D. Bushfield, <i>Contributing Member</i>
J. R. Foulds	M. L. Nayyar, <i>Contributing Member</i>
D. W. Gandy	E. G. Nisbett, <i>Contributing Member</i>
M. H. Gilkey	E. Uptis, <i>Contributing Member</i>
M. Gold	T. M. Cullen, <i>Honorary Member</i>
J. F. Grubb	W. D. Doty, <i>Honorary Member</i>
J. A. Hall	W. D. Edsall, <i>Honorary Member</i>
M. Katcher	G. C. Hsu, <i>Honorary Member</i>
F. Masuyama	R. A. Moen, <i>Honorary Member</i>
R. K. Nanstad	C. E. Spaeder, Jr., <i>Honorary Member</i>
B. W. Roberts	A. W. Zeuthen, <i>Honorary Member</i>
E. Shapiro	
M. H. Skillingberg	

**Subgroup on Nonferrous Alloys (BPV II)**

R. C. Sutherlin, <i>Chair</i>	L. Paul
H. Anada	D. W. Rahoi
J. Calland	W. Ren
D. Denis	E. Shapiro
M. H. Gilkey	M. H. Skillingberg
J. F. Grubb	D. Tyler
A. Heino	R. Zawierucha
M. Katcher	W. R. Apblett, Jr., <i>Contributing Member</i>
J. Kissell	H. D. Bushfield, <i>Contributing Member</i>
T. M. Malota	
J. A. McMaster	

**Subgroup on Physical Properties (BPV II)**

J. F. Grubb, <i>Chair</i>	P. Fallouey
H. D. Bushfield	E. Shapiro
D. Denis	

**Subgroup on Strength, Ferrous Alloys (BPV II)**

J. M. Tanzosh, <i>Chair</i>	K. Kimura
M. J. Slater, <i>Secretary</i>	F. Masuyama
F. Abe	D. W. Rahoi
H. Anada	B. W. Roberts
D. A. Canonico	J. P. Shingledecker
A. Di Rienzo	R. W. Swindeman
P. Fallouey	T. P. Vassallo, Jr.
J. R. Foulds	W. R. Apblett, Jr., <i>Contributing Member</i>
M. Gold	H. Murakami, <i>Contributing Member</i>
J. A. Hall	
J. F. Henry	

**Subgroup on External Pressure (BPV II)**

R. W. Mikitka, <i>Chair</i>	M. H. Jawad
D. L. Kurle, <i>Vice Chair</i>	C. R. Thomas
J. A. A. Morrow, <i>Secretary</i>	M. Wadkinson
L. F. Campbell	M. Katcher, <i>Contributing Member</i>
D. S. Griffin	C. H. Sturgeon, <i>Contributing Member</i>
J. F. Grubb	
J. R. Harris III	

**Subgroup on Strength of Weldments (BPV II & BPV IX)**

W. F. Newell, Jr., <i>Chair</i>	J. F. Henry
S. H. Bowes	D. W. Rahoi
K. K. Coleman	B. W. Roberts
P. D. Flenner	J. P. Shingledecker
J. R. Foulds	W. J. Sperko
D. W. Gandy	J. P. Swezy, Jr.
M. Gold	J. M. Tanzosh
K. L. Hayes	

**Subgroup on Ferrous Specifications (BPV II)**

A. Appleton, <i>Chair</i>	W. C. Mack
S. Hochreiter, <i>Secretary</i>	J. K. Mahaney
B. M. Dingman	A. S. Melilli
M. J. Dosdourian	E. G. Nisbett
P. Fallouey	K. E. Orie
J. D. Fritz	J. Shick
T. Graham	E. Uptis
J. M. Grocki	J. D. Wilson
J. F. Grubb	P. Wittenbach
K. M. Hottle	R. Zawierucha
D. S. Janikowski	R. M. Davison, <i>Contributing Member</i>
L. J. Lavezzi	

**Working Group on Materials Database (BPV II)**

R. W. Swindeman, <i>Chair</i>	B. W. Roberts
N. Lobo, <i>Staff Secretary</i>	R. C. Sutherlin
F. Abe	D. Andrei, <i>Contributing Member</i>
J. R. Foulds	W. Hoffelner, <i>Contributing Member</i>
M. Gold	T. Lazar, <i>Contributing Member</i>
J. F. Henry	D. T. Peters, <i>Contributing Member</i>
M. Katcher	W. Ren, <i>Contributing Member</i>



**China International Working Group (BPV II)**

T. Xu, <i>Secretary</i>	G. Yang
W. Fang	R. Ye
S. Huo	L. Yin
S. Li	H. Zhang
M. Lu	X.-H. Zhang
B. Shou	Yingkai Zhang
S. Tan	Yong Zhang
C. Wang	Q. Zhao
X. Wang	S. Zhao
Z. Wu	R. Zhou
F. Yang	J. Zou

**Subgroup on Component Design (BPV III)**

R. S. Hill III, <i>Chair</i>	R. J. Masterson
T. M. Adams, <i>Vice Chair</i>	D. E. Matthews
S. Pellet, <i>Secretary</i>	W. N. McLean
G. A. Antaki	J. C. Minichiello
S. Asada	T. Nagata
C. W. Bruny	A. N. Nguyen
J. R. Cole	E. L. Pleins
A. A. Dermenjian	I. Saito
R. P. Deubler	G. C. Slagis
P. Hirschberg	J. D. Stevenson
R. I. Jetter	J. P. Tucker
R. B. Keating	K. R. Wichman
H. Kobayashi	C. Wilson
R. A. Ladefian	J. Yang
K. A. Manoly	D. F. Landers, <i>Contributing Member</i>

**COMMITTEE ON CONSTRUCTION OF NUCLEAR FACILITY COMPONENTS (III)**

R. W. Barnes, <i>Chair</i>	M. N. Mitchell
J. R. Cole, <i>Vice Chair</i>	M. Morishita
A. Byk, <i>Staff Secretary</i>	D. K. Morton
T. Adams	T. Nagata
A. Appleton	R. F. Reedy, Sr.
W. H. Borter	I. Saito
T. D. Burchell	C. T. Smith
R. P. Deubler	W. K. Sowder, Jr.
A. C. Eberhardt	W. J. Sperko
B. A. Erler	J. D. Stevenson
G. M. Foster	K. R. Wichman
R. S. Hill III	C. S. Withers
W. Hoffelner	Y. H. Choi, <i>Delegate</i>
R. M. Jesse	T. Ius, <i>Delegate</i>
R. I. Jetter	H.-T. Wang, <i>Delegate</i>
R. B. Keating	C. C. Kim, <i>Contributing Member</i>
G. H. Koo	E. B. Branch, <i>Honorary Member</i>
V. Kostarev	G. D. Cooper, <i>Honorary Member</i>
W. C. LaRochelle	W. D. Doty, <i>Honorary Member</i>
K. A. Manoly	D. F. Landers, <i>Honorary Member</i>
D. E. Matthews	R. A. Moen, <i>Honorary Member</i>
W. N. McLean	C. J. Pieper, <i>Honorary Member</i>
J. C. Minichiello	

**Working Group on Supports (SG-D) (BPV III)**

R. J. Masterson, <i>Chair</i>	A. N. Nguyen
U. S. Bandyopadhyay, <i>Secretary</i>	I. Saito
K. Avrithi	J. R. Stinson
T. H. Baker	T. G. Terryah
F. J. Birch	G. Z. Tokarski
R. P. Deubler	C.-I. Wu

**Working Group on Core Support Structures (SG-D) (BPV III)**

J. Yang, <i>Chair</i>	H. S. Mehta
J. F. Kielb, <i>Secretary</i>	M. D. Snyder
F. G. Al-Chammas	A. Tsirigotis
D. Keck	J. T. Land, <i>Contributing Member</i>

**Working Group on Design Methodology (SG-D) (BPV III)**

R. B. Keating, <i>Chair</i>	D. H. Roarty
S. D. Snow, <i>Secretary</i>	E. A. Rodriguez
K. Avrithi	P. K. Shah
R. D. Blevins	J. D. Stevenson
M. R. Breach	A. Tsirigotis
D. L. Caldwell	S. Wang
H. T. Harrison III	T. M. Wiger
P. Hirschberg	K. Wright
M. Kassir	J. Yang
J. Kim	M. K. Au-Yang, <i>Contributing Member</i>
H. Kobayashi	D. F. Landers, <i>Contributing Member</i>
J. F. McCabe	W. S. Lapay, <i>Contributing Member</i>
A. N. Nguyen	
W. D. Reinhardt	

**Subgroup on Containment Systems for Spent Fuel and High-Level Waste Transport Packagings (BPV III)**

G. M. Foster, <i>Chair</i>	D. W. Lewis
G. J. Solovey, <i>Vice Chair</i>	P. E. McConnell
D. K. Morton, <i>Secretary</i>	A. B. Meichler
G. Abramczyk	R. E. Nickell
D. J. Ammerman	E. L. Pleins
G. Bjorkman	T. Saegusa
W. H. Borter	N. M. Simpson
G. R. Cannell	R. H. Smith
R. S. Hill III	J. D. Stevenson
S. Horowitz	C. J. Temus

**Working Group on Design of Division 3 Containments (SG-D) (BPV III)**

E. L. Pleins, <i>Chair</i>	D. K. Morton
D. J. Ammerman	C. J. Temus
G. Bjorkman	I. D. McInnes, <i>Contributing Member</i>
S. Horowitz	R. E. Nickell, <i>Contributing Member</i>
D. W. Lewis	H. P. Shrivastava, <i>Contributing Member</i>
J. C. Minichiello	

**Working Group on Piping (SG-D) (BPV III)**

G. A. Antaki, <i>Chair</i>	J. F. McCabe
G. Z. Tokarski, <i>Secretary</i>	J. C. Minichiello
T. M. Adams	I.-K. Nam
C. Basavaraju	E. R. Nelson
J. Catalano	A. N. Nguyen
F. Claeys	M. S. Sills
J. R. Cole	G. C. Slagis
R. G. Gilada	N. C. Sutherland
M. A. Gray	E. A. Wais
R. W. Haupt	C.-I. Wu
P. Hirschberg	D. F. Landers, <i>Contributing Member</i>
M. Kassab	J. J. Martinez, <i>Contributing Member</i>
J. Kawahata	R. D. Patel, <i>Contributing Member</i>
R. B. Keating	N. J. Shah, <i>Contributing Member</i>
V. Kostarev	E. C. Rodabaugh, <i>Honorary Member</i>
Y. Liu	

**Working Group on Probabilistic Methods in Design (SG-D) (BPV III)**

R. S. Hill III, <i>Chair</i>	A. McNeill III
N. A. Palm, <i>Secretary</i>	M. Morishita
T. Asayama	P. J. O'Regan
K. Avrithi	I. Saito
B. M. Ayyub	A. Tsirigotis
M. R. Graybeal	R. M. Wilson
D. O. Henry	D. Hofer, <i>Contributing Member</i>
S. D. Kulat	

**Working Group on Pumps (SG-D) (BPV III)**

R. A. Ladefian, <i>Chair</i>	M. Higuchi
P. W. Behnke	J. W. Leavitt
R. E. Cornman, Jr.	S. Mauvais
M. D. Eftychiou	R. A. Patrick
A. Fraser	J. Sulley
M. A. Gaydon	R. Udo
R. Ghanbari	A. G. Washburn

**Working Group on Valves (SG-D) (BPV III)**

J. P. Tucker, <i>Chair</i>	C. A. Mizer
J. O'Callaghan, <i>Secretary</i>	K. E. Reid II
G. A. Jolly	S. N. Shields
J. Klein	H. R. Sonderegger
W. N. McLean	P. Vock
T. A. McMahon	

**Working Group on Vessels (SG-D) (BPV III)**

D. E. Matthews, <i>Chair</i>	D. Keck
R. M. Wilson, <i>Secretary</i>	O.-S. Kim
C. Basavaraju	K. Matsunaga
C. W. Bruny	P. K. Shah
J. V. Gregg, Jr.	C. Turlyo
W. J. Heilker	D. Vlaicu
W. T. Jessup, Jr.	W. F. Weitze
A. Kalnins	T. Yamazaki
R. B. Keating	

**Special Working Group on Environmental Effects (SG-D) (BPV III)**

W. Culp, <i>Chair</i>	J. E. Nestell
B. D. Frew, <i>Secretary</i>	W. Z. Novak
K. Avrithi	M. S. Shelton
W. J. Heilker	Y. H. Choi, <i>Delegate</i>
R. S. Hill III	

**Subgroup on General Requirements (BPV III & 3C)**

R. P. McIntyre, <i>Chair</i>	W. C. LaRochelle
L. M. Plante, <i>Secretary</i>	M. R. Minick
V. Apostolescu	E. C. Renaud
A. Appleton	D. J. Roszman
J. R. Berry	C. T. Smith
J. V. Gardiner	W. K. Sowder, Jr.
G. Gratti	G. E. Szabatura
J. W. Highlands	T. G. Terryah
G. L. Hollinger	D. M. Vickery
G. V. Imbro	C. S. Withers
K. A. Kavanagh	H. Michael, <i>Delegate</i>

**Working Group on Duties and Responsibilities (SG-GR) (BPV III)**

J. V. Gardiner, <i>Chair</i>	K. A. Kavanagh
G. L. Hollinger, <i>Secretary</i>	L. M. Plante
J. R. Berry	D. J. Roszman
Y. Diaz-Castillo	S. Scardigno
E. L. Farrow	T. G. Terryah
G. Gratti	

**Working Group on Quality Assurance, Certification, and Stamping (SG-GR) (BPV III)**

C. T. Smith, <i>Chair</i>	M. R. Minick
C. S. Withers, <i>Secretary</i>	R. B. Patel
V. Apostolescu	E. C. Renaud
A. Appleton	J. Rogers
S. Bell	W. K. Sowder, Jr.
B. K. Bobo	J. F. Strunk
S. M. Goodwin	M. F. Sullivan
J. W. Highlands	G. E. Szabatura
R. P. McIntyre	D. M. Vickery

**Special Working Group on Regulatory Interface (BPV III)**

G. V. Imbro, <i>Chair</i>	J. A. Schulz
S. Bell, <i>Secretary</i>	R. R. Stevenson
A. Cardillo	D. Terao
A. A. Dermenjian	M. L. Wilson
K. Matsunaga	R. A. Yonekawa
D. E. Matthews	

**Subgroup on Materials, Fabrication, and Examination (BPV III)**

R. M. Jessee, <i>Chair</i>	M. Lau
S. Hunter, <i>Secretary</i>	H. Murakami
W. H. Bortor	J. Ossmann
G. R. Cannell	C. Pearce
R. H. Davis	N. M. Simpson
G. M. Foster	W. J. Sperko
B. D. Frew	J. R. Stinson
G. B. Georgiev	J. F. Strunk
S. E. Gingrich	K. B. Stuckey
C. C. Kim	H. Michael, <i>Delegate</i>

**Subgroup on Pressure Relief (BPV III)**

J. F. Ball, *Chair*  
A. L. Szeglin

D. G. Thibault

**Executive Committee on Strategy and Project Management  
(BPV III, Divisions 1 and 2)**

J. R. Cole, *Chair*  
C. A. Sanna, *Staff Secretary*  
T. Adams  
R. W. Barnes  
B. K. Bobo  
N. Broom  
B. A. Erler  
C. M. Faigy  
R. S. Hill III  
E. V. Imbro  
R. M. Jessee  
R. B. Keating

G. H. Koo  
K. A. Manoly  
D. K. Morton  
J. Ramirez  
R. F. Reedy, Sr.  
C. T. Smith  
W. K. Sowder, Jr.  
Y. Urabe  
C. S. Withers  
C. Yan  
M. F. Sullivan, *Contributing Member*

**Special Working Group for New Advanced Light Water Reactor Plant  
Construction Issues (BPV III)**

E. L. Pleins, *Chair*  
M. C. Scott, *Secretary*  
A. Cardillo  
B. Gilligan  
J. Honcharik  
G. V. Imbro  
Y. Katsura  
O.-S. Kim  
M. Kris

J. C. Minichiello  
D. W. Sandusky  
C. A. Sanna  
R. R. Stevenson  
E. R. Willis  
M. L. Wilson  
J. Yan  
J. A. Schulz, *Contributing Member*

**Subgroup on Editing and Review (BPV III)**

D. K. Morton, *Chair*  
R. L. Bratton  
R. P. Deubler  
A. C. Eberhardt  
R. I. Jetter  
J. C. Minichiello

L. M. Plante  
R. F. Reedy, Sr.  
W. K. Sowder, Jr.  
J. D. Stevenson  
C. Wilson

**Subgroup on Management Resources (BPV III)**

R. M. Jessee, *Chair*  
J. F. Bernardo  
L. C. Cadwallader  
J. B. Carr  
M. Cusick  
H. S. Farrow  
S. Fincher  
J. Fink  
L. Hartless  
M. A. Hayes, Jr.  
M. Hokazono  
B. N. Juarez  
Y. S. Kim

J. M. Lyons  
B. McGlone  
A. A. Mostala  
M. Osterfoss  
J. D. Pasek  
C. Pearce  
J. Rogers  
B. S. Sandhu  
V. Suri  
Z. Taylor  
J. Webb, Jr.  
R. A. West  
R. Z. Ziegler

**China International Working Group (BPV III)**

J. Yan, *Chair*  
W. Tang, *Vice Chair*  
C. A. Sanna, *Staff Secretary*  
Y. He, *Secretary*  
H. Ge  
Z. Han  
J. Jian  
Y. Jing  
F. Kai  
D. Kang  
Y. Lee  
X. Li  
B. Liang  
H. Lin  
S. Lin  
J. Liu  
S. Liu  
W. Liu  
K. Mao

G. Sun  
G. Tang  
Y. Tu  
Y. Wang  
H. Wu  
X. Wu  
Z. Wu  
S. Xue  
Z. Yan  
C. Ye  
Z. Yin  
S. Zaozhan  
G. Zhang  
K. Zhang  
W. Zhang  
G. Zhao  
W. Zhao  
Y. Zhong  
Z. Zhong

**Working Group on International Meetings (BPV III)**

R. S. Hill III, *Chair*  
A. Byk, *Staff Secretary*  
T. D. Burchell  
J. R. Cole  
R. L. Crane

G. M. Foster  
M. N. Mitchell  
R. F. Reedy, Sr.  
C. A. Sanna  
C. T. Smith

**Korea International Working Group (BPV III)**

G. H. Koo, *Chair*  
H. S. Byun  
J.-Y. Hong  
N.-S. Huh  
S. S. Hwang  
C. Jang  
I. I. Jeong  
H. J. Kim  
J. Kim  
O.-S. Kim  
Y.-B. Kim  
D. Kwon

B. Lee  
D. Lee  
S. Lee  
D. J. Lim  
I.-K. Nam  
B. Noh  
C.-K. Oh  
C. Park  
J.-S. Park  
S. Song  
O. Yoo

**Subgroup on Polyethylene Pipe (BPV III)**

T. M. Adams, *Chair*  
D. Burwell, *Secretary*  
W. I. Adams  
C. Basavaraju  
S. J. Boros  
J. M. Craig  
E. L. Farrow  
E. M. Focht  
M. Golliet  
A. N. Haddad  
P. Krishnaswamy  
M. Lashley  
E. Lever

K. Lively  
M. Martin  
E. W. McElroy  
D. P. Munson  
T. M. Musto  
J. E. O'Sullivan  
F. J. Schaaf, Jr.  
H. E. Svetlik  
M. Troughton  
D. M. Vickery  
Z. J. Zhou  
L. J. Petroff, *Alternate*  
S. Sandstrum, *Alternate*

#### Working Group on Research and Development

A. N. Haddad, <i>Chair</i>	K. Lively
W. I. Adams	K. A. Manoly
A. Amato	L. Mizell
S. J. Boros	D. P. Munson
J. M. Craig	T. M. Musto
E. M. Focht	F. J. Schaaf, Jr.
R. M. Jessee	M. Troughton
D. Keller	Z. J. Zhou
M. Lamborn	L. J. Petroff, <i>Alternate</i>
S. Lefler	S. Sandstrum, <i>Alternate</i>
E. Lever	

#### Working Group on Nondestructive Examination and Fusion of HDPE (BPV III)

M. Lashley, <i>Chair</i>	R. M. Jessee
W. H. Borter	M. D. Moles
J. M. Craig	F. J. Schaaf, Jr.
N. Y. Faransso	J. C. Spanner, Jr.
N. A. Finney	Z. J. Zhou
J. F. Halley	D. K. Zimmerman

#### Working Group on High Temperature Gas-Cooled Reactors (BPV III)

J. E. Nestell, <i>Chair</i>	T. R. Lupold
N. Broom	S. N. Malik
T. D. Burchell	D. L. Marriott
R. S. Hill III	D. K. Morton
W. Hoffelner	T.-L. Sham
E. V. Imbro	Y. Tachibana
R. I. Jetter	T. Yuhara
Y. W. Kim	

#### Subgroup on Graphite Core Components (BPV III)

T. D. Burchell, <i>Chair</i>	S. T. Gonczy
M. N. Mitchell, <i>Vice Chair</i>	M. P. Hindley
C. A. Sanna, <i>Staff Secretary</i>	Y. Katoh
R. L. Bratton, <i>Secretary</i>	N. N. Nemeth
T. Albers	T. Oku
A. Appleton	J. Ossmann
S.-H. Chi	M. Roemmler
A. Covac	N. Salstrom
M. W. Davies	T. Shibata
S. W. Doms	M. Srinivasan
S. F. Duffy	A. G. Steer
B. D. Frew	S. Wendel
O. Gelineau	S. Yu

#### Subgroup on Industry Experience for New Plants (BPV III & BPV XI)

G. M. Foster, <i>Chair</i>	O.-S. Kim
J. T. Lindberg, <i>Chair</i>	K. Matsunaga
H. L. Gustin, <i>Secretary</i>	D. E. Matthews
V. L. Armentrout	R. E. McLaughlin
T. L. Chan	J. Ossmann
D. R. Graham	E. L. Pleins
P. J. Hennessey	D. W. Sandusky
D. O. Henry	D. M. Swann
J. Honcharik	T. Tsuruta
E. V. Imbro	E. R. Willis
C. G. Kim	S. M. Yee

#### Subgroup on Fusion Energy Devices (BPV III)

W. K. Sowder, Jr., <i>Chair</i>	S. Lee
D. Andrei, <i>Staff Secretary</i>	G. Li
D. J. Roszman, <i>Secretary</i>	X. Li
R. W. Barnes	P. Mokaria
M. Higuchi	S. J. Salvador
G. Holtmeier	M. Trosen
K. A. Kavanagh	I. J. Zatz
H. J. Kim	

#### Subgroup on High-Temperature Reactors (BPV III)

M. Morishita, <i>Chair</i>	W. Hoffelner
R. I. Jetter, <i>Vice Chair</i>	G. H. Koo
T.-L. Sham, <i>Secretary</i>	D. K. Morton
N. Broom	J. E. Nestell
T. D. Burchell	N. N. Ray

#### Working Group on High Temperature Liquid-Cooled Reactors (BPV III)

T.-L. Sham, <i>Chair</i>	R. I. Jetter
T. Asayama, <i>Secretary</i>	G. H. Koo
R. W. Barnes	M. Li
P. Carter	S. Majumdar
C. M. Faigy	M. Morishita
W. Hoffelner	J. E. Nestell
A. B. Hull	D. K. Williams

#### Subgroup on Elevated Temperature Design (BPV III)

R. I. Jetter, <i>Chair</i>	A. B. Hull
T.-L. Sham, <i>Secretary</i>	M. H. Jawad
J. J. Abou-Hanna	G. H. Koo
T. Asayama	W. J. Koves
C. Becht IV	M. Li
F. W. Brust	S. Majumdar
P. Carter	D. L. Marriott
J. F. Cervenka	T. E. McGreevy
D. S. Griffin	J. E. Nestell
B. F. Hantz	W. J. O'Donnell
W. Hoffelner	R. W. Swindeman

#### Working Group on High Temperature Flaw Evaluation (BPV III)

F. W. Brust, <i>Chair</i>	D. L. Rudland
N. Broom	P. J. Rush
P. Carter	D.-J. Shim
W. Hoffelner	S. X. Xu
S. N. Malik	

#### Working Group on Allowable Stress Criteria (BPV III)

R. W. Swindeman, <i>Chair</i>	J. E. Nestell
M. Li, <i>Secretary</i>	W. Ren
J. R. Foulds	B. W. Roberts
K. Kimura	T.-I. Sham
S. N. Malik	

#### Working Group on Analysis Methods (BPV III)

P. Carter, <i>Chair</i>	S. Krishnamurthy
M. R. Beach	T.-I. Sham
R. I. Jetter	D. K. Williams

**Working Group on Creep-Fatigue and Negligible Creep (BPV III)**

T. Asayama, <i>Chair</i>	G. H. Koo
M. Li, <i>Secretary</i>	S. N. Malik
F. W. Brust	T.-I. Sham
R. I. Jetter	

**Subgroup on Fatigue Strength (BPV III)**

W. J. O'Donnell, <i>Chair</i>	G. Kharshafdjian
S. A. Adams	S. Majumdar
G. S. Chakrabarti	S. N. Malik
T. M. Damiani	R. Nayal
P. R. Donavin	D. H. Roarty
S. R. Gosselin	M. S. Shelton
R. J. Gurdal	G. Taxacher
C. F. Heberling II	A. Tsirigotis
C. E. Hinnant	K. Wright
D. P. Jones	H. H. Ziada

**Working Group on Environmental Fatigue Evaluation Methods (BPV III)**

T. M. Adams	H. S. Mehta
S. Asada	J.-S. Park
K. Avrithi	V. S. Ready
J. R. Cole	D. H. Roarty
C. M. Faidy	I. Saito
T. D. Gilman	D. Vlaicu
S. R. Gosselin	W. F. Weitze
M. A. Gray	K. Wright
Y. He	

**Subcommittee on Design (BPV III)**

R. P. Deubler, <i>Chair</i>	R. A. Ladefian
G. L. Hollinger, <i>Secretary</i>	K. A. Manoly
T. M. Adams	R. J. Masterson
G. A. Antaki	D. E. Matthews
R. L. Bratton	M. N. Mitchell
R. S. Hill III	W. J. O'Donnell
P. Hirschberg	E. L. Pleins
M. H. Jawad	J. P. Tucker
R. I. Jetter	J. Yang
R. B. Keating	

**Special Working Group on HDPE Design of Components (BPV III)**

T. M. Adams, <i>Chair</i>	E. W. McElroy
T. M. Musto, <i>Secretary</i>	J. C. Minichiello
W. I. Adams	D. P. Munson
T. A. Bacon	J. Ossmann
C. Basavaraju	L. J. Petroff
D. Burwell	H. E. Svetlik
P. Krishnaswamy	K. Lively
M. Martin	L. Mizell

**Special Working Group on Computational Modeling for Explicit Dynamics (BPV III)**

G. Bjorkman, <i>Chair</i>	P. Y.-K. Shih
D. J. Ammerman, <i>Secretary</i>	S. D. Snow
G. Broz	C.-F. Tso
J. Jordan	M. C. Yaksh
D. Molitoris	U. Zencker
J. Piottter	

**Subgroup on Elevated Temperature Construction (BPV III)**

M. H. Jawad, <i>Chair</i>	R. I. Jetter
B. Mollitor, <i>Secretary</i>	S. Krishnamurthy
D. I. Anderson	D. L. Marriott
R. G. Brown	M. N. Mitchell
J. P. Glaspie	D. K. Morton
B. F. Hantz	C. Nadarajah

**Subcommittee on General Requirements (BPV III)**

W. C. LaRochelle, <i>Chair</i>	L. M. Plante
A. Appleton, <i>Secretary</i>	C. T. Smith
J. V. Gardiner	D. M. Vickery
R. P. McIntyre	

**JOINT ACI-ASME COMMITTEE ON CONCRETE COMPONENTS FOR NUCLEAR SERVICE (BPV 3C)**

A. C. Eberhardt, <i>Chair</i>	N. Orbovic
C. T. Smith, <i>Vice Chair</i>	B. B. Scott
A. Byk, <i>Staff Secretary</i>	J. D. Stevenson
N. Alchaar	J. F. Strunk
J. F. Artuso	T. Tonyan
C. J. Bang	T. J. Ahl, <i>Contributing Member</i>
F. Farzam	T. D. Al-Shawaf, <i>Contributing Member</i>
P. S. Ghosal	B. A. Erler, <i>Contributing Member</i>
M. F. Hessheimer	J. Gutierrez, <i>Contributing Member</i>
B. D. Hovis	T. E. Johnson, <i>Contributing Member</i>
T. C. Inman	T. Muraki, <i>Contributing Member</i>
O. Jovall	M. R. Senecal, <i>Contributing Member</i>
N.-H. Lee	M. K. Thumm, <i>Contributing Member</i>
J. McLean	
J. Munshi	

**Working Group on Design (BPV 3C)**

J. Munshi, <i>Chair</i>	T. C. Inman
N. Alchaar	O. Jovall
S. Bae	N.-H. Lee
L. J. Colarusso	J. D. Stevenson
J. Colinares	T. E. Johnson, <i>Contributing Member</i>
A. C. Eberhardt	B. R. Laskewitz, <i>Contributing Member</i>
F. Farzam	M. K. Thumm, <i>Contributing Member</i>
P. S. Ghosal	
M. F. Hessheimer	
B. D. Hovis	

**Working Group on Materials, Fabrication, and Examination (BPV 3C)**

J. F. Artuso, <i>Chair</i>	B. B. Scott
P. S. Ghosal, <i>Vice Chair</i>	C. T. Smith
M. Allam	J. F. Strunk
A. C. Eberhardt	T. Tonyan
J. Gutierrez	

**Working Group on Modernization (BPV 3C)**

O. Jovall, <i>Chair</i>	J.-B. Damage
J. McLean, <i>Secretary</i>	N. Orbovic
A. Adediran	C. T. Smith
N. Alchaar	M. A. Ugalde
J. F. Artuso	S. Wang
J. J. Braun	U. Ricklefs, <i>Contributing Member</i>
J. Colinares	

**COMMITTEE ON HEATING BOILERS (BPV IV)**

T. L. Bedeaux, <i>Chair</i>	P. A. Molvie
J. A. Hall, <i>Vice Chair</i>	B. W. Moore
G. Moino, <i>Staff Secretary</i>	R. E. Olson
J. Calland	T. M. Parks
J. P. Chicoine	M. Wadkinson
C. M. Dove	R. V. Wielgoszinski
B. G. French	H. Michael, <i>Delegate</i>
A. Heino	D. Picart, <i>Delegate</i>
B. J. Iske	J. L. Kleiss, <i>Alternate</i>
D. J. Jenkins	M. T. Roby, <i>Alternate</i>
M. R. Klosterman	W. L. Haag, Jr., <i>Honorary Member</i>
K. M. McTague	

**COMMITTEE ON NONDESTRUCTIVE EXAMINATION (BPV V)**

J. E. Batey, <i>Chair</i>	R. W. Kruzic
F. B. Kovacs, <i>Vice Chair</i>	J. R. McGimpsey
J. S. Brzuszkiewicz, <i>Staff Secretary</i>	M. D. Moles
S. J. Akrin	A. B. Nagel
C. A. Anderson	T. L. Plasek
A. S. Birks	F. J. Sattler
P. L. Brown	G. M. Gatti, <i>Delegate</i>
M. A. Burns	X. Guiping, <i>Delegate</i>
B. Caccamise	B. D. Laite, <i>Alternate</i>
N. Y. Faransso	H. C. Graber, <i>Honorary Member</i>
N. A. Finney	O. F. Hedden, <i>Honorary Member</i>
A. F. Garbolevsky	J. R. MacKay, <i>Honorary Member</i>
G. W. Hembree	T. G. McCarty, <i>Honorary Member</i>
J. W. Houf	

**Subgroup on Care and Operation of Heating Boilers (BPV IV)**

M. Wadkinson, <i>Chair</i>	M. R. Klosterman
T. L. Bedeaux	P. A. Molvie
J. Calland	B. W. Moore
J. A. Hall	T. M. Parks

**Subgroup on General Requirements/Personnel Qualifications and Inquiries (BPV V)**

F. B. Kovacs, <i>Chair</i>	N. A. Finney
S. J. Akrin	G. W. Hembree
C. A. Anderson	J. W. Houf
J. E. Batey	J. P. Swezy, Jr., <i>Contributing Member</i>
A. S. Birks	
N. Y. Faransso	

**Subgroup on Cast Iron Boilers (BPV IV)**

K. M. McTague, <i>Chair</i>	B. G. French
T. L. Bedeaux, <i>Vice Chair</i>	J. A. Hall
J. P. Chicoine	J. L. Kleiss
C. M. Dove	M. R. Klosterman
J. M. Downs	M. T. Roby, <i>Alternate</i>

**Subgroup on Surface Examination Methods (BPV V)**

S. J. Akrin, <i>Chair</i>	S. Johnson
A. S. Birks	R. W. Kruzic
P. L. Brown	B. D. Laite
B. Caccamise	L. E. Mullins
N. Y. Faransso	A. B. Nagel
N. Farenbaugh	F. J. Sattler
N. A. Finney	G. M. Gatti, <i>Delegate</i>
G. W. Hembree	

**Subgroup on Materials (BPV IV)**

J. A. Hall, <i>Chair</i>	B. J. Iske
M. Wadkinson, <i>Vice Chair</i>	J. L. Kleiss
J. Calland	E. Rightmier
J. M. Downs	

**Subgroup on Volumetric Methods (BPV V)**

G. W. Hembree, <i>Chair</i>	S. Johnson
S. J. Akrin	F. B. Kovacs
J. E. Batey	R. W. Kruzic
P. L. Brown	J. R. McGimpsey
B. Caccamise	M. D. Moles
N. Y. Faransso	L. E. Mullins
N. A. Finney	A. B. Nagel
A. F. Garbolevsky	T. L. Plasek
J. F. Halley	F. J. Sattler
R. W. Hardy	G. M. Gatti, <i>Delegate</i>

**Subgroup on Water Heaters (BPV IV)**

J. Calland, <i>Chair</i>	K. M. McTague
J. P. Chicoine	R. E. Olson
B. G. French	T. E. Trant
B. J. Iske	M. T. Roby, <i>Alternate</i>

**Working Group on Acoustic Emissions (SG-VM) (BPV V)**

N. Y. Faransso, <i>Chair</i>	S. R. Doctor
J. E. Batey, <i>Vice Chair</i>	R. K. Miller

**Subgroup on Welded Boilers (BPV IV)**

J. Calland, <i>Chair</i>	P. A. Molvie
T. L. Bedeaux	R. E. Olson
B. G. French	M. Wadkinson
J. L. Kleiss	R. V. Wielgoszinski
M. R. Klosterman	J.-M. Andre, <i>Contributing Member</i>

**Working Group on Radiography (SG-VM) (BPV V)**

F. B. Kovacs, <i>Chair</i>	S. Johnson
S. J. Akrin	R. W. Kruzic
J. E. Batey	B. D. Laite
P. L. Brown	S. Mango
B. Caccamise	J. R. McGimpsey
N. Y. Faransso	R. J. Mills
A. F. Garbolevsky	A. B. Nagel
R. W. Hardy	T. L. Plasek
G. W. Hembree	



**Working Group on Ultrasonics (SG-VM) (BPV V)**

N. A. Finney, <i>Chair</i>	R. W. Kruzic
J. F. Halley, <i>Vice Chair</i>	B. D. Laite
B. Caccamise	M. D. Moles
K. J. Chizen	L. E. Mullins
N. Y. Faransso	A. B. Nagel
O. F. Hedden	F. J. Sattler
S. Johnson	

**Working Group on Design-By-Analysis (BPV III)**

B. F. Hantz, <i>Chair</i>	A. Mann
T. W. Norton, <i>Secretary</i>	G. A. Miller
R. G. Brown	C. Nadarajah
R. D. Dixon	M. D. Rana
C. E. Hinnant	T. G. Seipp
M. H. Jawad	S. Terada
S. Krishnamurthy	

**Working Group on Guided Wave Ultrasonic Testing (SG-VM) (BPV V)**

N. Y. Faransso, <i>Chair</i>	G. M. Light
J. E. Batey, <i>Vice Chair</i>	M. D. Moles
D. Alleyne	P. Mudge
J. F. Halley	M. J. Quarry
S. Johnson	J. Vanvelsor

**Subgroup on Fabrication and Inspection (BPV VIII)**

C. D. Rodery, <i>Chair</i>	P. L. Sturgill
J. P. Swezy, Jr., <i>Vice Chair</i>	T. Tahara
B. R. Morelock, <i>Secretary</i>	E. A. Whittle
J. L. Arnold	K. Oyamada, <i>Delegate</i>
L. F. Campbell	R. Uebel, <i>Delegate</i>
H. E. Gordon	W. J. Bees, <i>Corresponding Member</i>
D. I. Morris	E. Uptis, <i>Corresponding Member</i>
M. J. Pischke	W. S. Jacobs, <i>Contributing Member</i>
M. J. Rice	J. Lee, <i>Contributing Member</i>
B. F. Shelley	

**COMMITTEE ON PRESSURE VESSELS (VIII)**

U. R. Miller, <i>Chair</i>	M. J. Pischke
R. J. Basile, <i>Vice Chair</i>	M. D. Rana
S. J. Rossi, <i>Staff Secretary</i>	G. B. Rawls, Jr.
T. Schellens, <i>Staff Secretary</i>	F. L. Richter
V. Bogosian	S. C. Roberts
J. Cameron	C. D. Rodery
A. Chaudouet	A. Selz
D. B. DeMichael	J. R. Sims, Jr.
J. P. Glaspie	E. Soltow
M. Gold	D. A. Swanson
J. F. Grubb	J. P. Swezy, Jr.
L. E. Hayden, Jr.	S. Terada
G. G. Karcher	E. Uptis
K. T. Lau	P. A. McGowan, <i>Delegate</i>
R. Mahadeen	H. Michael, <i>Delegate</i>
R. W. Mikitka	K. Oyamada, <i>Delegate</i>
K. Mokhtarian	M. E. Papponetti, <i>Delegate</i>
C. C. Neely	D. Rui, <i>Delegate</i>
T. W. Norton	T. Tahara, <i>Delegate</i>
T. P. Pastor	W. S. Jacobs, <i>Contributing Member</i>
D. T. Peters	

**Subgroup on General Requirements (BPV VIII)**

S. C. Roberts, <i>Chair</i>	C. C. Neely
D. B. DeMichael, <i>Vice Chair</i>	A. S. Olivares
F. L. Richter, <i>Secretary</i>	J. C. Sowinski
R. J. Basile	P. Speranza
V. Bogosian	D. B. Stewart
D. T. Davis	D. A. Swanson
J. P. Glaspie	R. Uebel
L. E. Hayden, Jr.	A. H. Gibbs, <i>Delegate</i>
K. T. Lau	K. Oyamada, <i>Delegate</i>
M. D. Lower	

**Taskgroup on U-2(g) (BPV VIII)**

S. R. Babka	R. F. Reedy, Sr.
R. J. Basile	S. C. Roberts
D. K. Chandiramani	J. R. Sims, Jr.
R. Mahadeen	D. Srnic
U. R. Miller	D. A. Swanson
T. W. Norton	R. Uebel
T. P. Pastor	K. K. Tam

**Subgroup on Design (BPV VIII)**

R. J. Basile, <i>Chair</i>	S. C. Roberts
J. C. Sowinski, <i>Vice Chair</i>	C. D. Rodery
M. D. Lower, <i>Secretary</i>	S. C. Shah
O. A. Barsky	D. A. Swanson
M. R. Breach	J. Vattappilly
F. L. Brown	R. A. Whipple
J. R. Farr	A. A. Gibbs, <i>Delegate</i>
B. F. Hantz	K. Oyamada, <i>Delegate</i>
C. E. Hinnant	M. E. Papponetti, <i>Delegate</i>
M. H. Jawad	M. Faulkner, <i>Corresponding Member</i>
D. L. Kurler	C. S. Hinson, <i>Corresponding Member</i>
R. W. Mikitka	W. S. Jacobs, <i>Corresponding Member</i>
U. R. Miller	A. Selz, <i>Corresponding Member</i>
K. Mokhtarian	K. K. Tam, <i>Corresponding Member</i>
T. P. Pastor	
M. D. Rana	
G. B. Rawls, Jr.	

**Subgroup on Heat Transfer Equipment (BPV VIII)**

R. Mahadeen, <i>Chair</i>	P. Matkovics
G. Auriolles, Sr., <i>Vice Chair</i>	S. Mayeux
F. E. Jehrio, <i>Secretary</i>	U. R. Miller
S. R. Babka	T. W. Norton
J. H. Barbee	K. Oyamada
O. A. Barsky	D. Srnic
I. G. Campbell	A. M. Voytko
A. Chaudouet	R. P. Wiberg
M. D. Clark	F. Osweiller, <i>Corresponding Member</i>
J. I. Gordon	S. Yokell, <i>Corresponding Member</i>
M. J. Holtz	R. Tiwari, <i>Contributing Member</i>
G. G. Karcher	S. M. Caldwell, <i>Honorary Member</i>
D. L. Kurler	
B. J. Lerch	

**Subgroup on High Pressure Vessels (BPV VIII)**

D. T. Peters, *Chair*  
 R. T. Hallman, *Vice Chair*  
 A. P. Maslowski, *Staff Secretary*  
 L. P. Antalffy  
 R. C. Biel  
 P. N. Chaku  
 R. Cordes  
 R. D. Dixon  
 L. Fridlund  
 D. M. Fryer  
 A. H. Honza  
 M. M. James  
 J. A. Kapp  
 J. Keltjens  
 A. K. Khare  
 S. C. Mordre

G. T. Nelson  
 E. A. Rodriguez  
 E. D. Roll  
 J. R. Sims, Jr.  
 D. L. Stang  
 F. W. Tatar  
 S. Terada  
 J. L. Traud  
 R. Wink  
 K. J. Young  
 K. Oyamada, *Delegate*  
 R. M. Hoshman, *Contributing Member*  
 G. J. Mraz, *Contributing Member*  
 D. J. Burns, *Honorary Member*  
 E. H. Perez, *Honorary Member*

**Task Group on Design (BPV VIII)**

J. Keltjens, *Chair*  
 R. C. Biel  
 D. J. Burns  
 R. Cordes  
 R. D. Dixon  
 L. Fridlund  
 D. M. Fryer  
 R. T. Hallman  
 S. C. Mordre  
 G. T. Nelson  
 E. H. Perez  
 D. T. Peters  
 E. D. Roll  
 K. C. Simpson  
 J. R. Sims, Jr.  
 D. L. Stang  
 S. Terada  
 J. L. Traud  
 R. Wink

**Task Group on Materials (BPV VIII)**

F. W. Tatar, *Chair*  
 L. P. Antalffy  
 P. N. Chaku  
 M. M. James  
 J. A. Kapp  
 A. K. Khare

**Subgroup on Materials (BPV VIII)**

J. F. Grubb, *Chair*  
 J. Cameron, *Vice Chair*  
 P. G. Wittenbach, *Secretary*  
 A. Di Rienzo  
 J. D. Fritz  
 M. Gold  
 M. Katcher  
 W. M. Lundy  
 D. W. Rahoi

R. C. Sutherlin  
 E. Uptis  
 K. Xu  
 K. Oyamada, *Delegate*  
 E. G. Nisbett, *Corresponding Member*  
 G. S. Dixit, *Contributing Member*  
 J. A. McMaster, *Contributing Member*

**Task Group on Impulsively Loaded Vessels (BPV VIII)**

E. A. Rodriguez, *Chair*  
 P. O. Leslie, *Secretary*  
 G. A. Antaki  
 J. K. Asahina  
 D. D. Barker  
 D. W. Bowman  
 A. M. Clayton  
 J. E. Didlake, Jr.  
 T. A. Duffey  
 B. L. Haroldsen  
 H. L. Heaton  
 D. Hilding  
 K. W. King  
 R. Kitamura  
 R. A. Leishear  
 R. E. Nickell  
 F. Ohlson  
 C. Romero  
 N. Rushton  
 J. E. Shepherd  
 Q. Dong, *Corresponding Member*  
 M. Yip, *Corresponding Member*  
 C. R. Vaught, *Alternate*

**Subgroup on Toughness (BPV II & BPV VIII)**

D. A. Swanson, *Chair*  
 J. P. Swezy, Jr., *Vice Chair*  
 J. L. Arnold  
 R. J. Basile  
 J. Cameron  
 H. E. Gordon  
 W. S. Jacobs  
 D. L. Kurler

K. Mokhtarian  
 C. C. Neely  
 M. D. Rana  
 F. L. Richter  
 E. Uptis  
 J. Vattappilly  
 K. Xu  
 K. Oyamada, *Delegate*

**COMMITTEE ON WELDING AND BRAZING (BPV IX)**

W. J. Sperko, *Chair*  
 D. A. Bowers, *Vice Chair*  
 S. J. Rossi, *Staff Secretary*  
 M. Bernasek  
 R. K. Brown, Jr.  
 M. L. Carpenter  
 J. G. Feldstein  
 P. D. Flenner  
 R. M. Jessee  
 J. S. Lee  
 W. M. Lundy  
 T. Melfi  
 W. F. Newell, Jr.  
 B. R. Newmark  
 A. S. Olivares  
 M. J. Pischke  
 M. J. Rice  
 M. B. Sims  
 M. J. Stanko  
 J. P. Swezy, Jr.  
 P. L. Van Fosson  
 R. R. Young  
 A. Roza, *Delegate*  
 M. Consonni, *Contributing Member*  
 S. A. Jones, *Contributing Member*  
 W. D. Doty, *Honorary Member*  
 S. D. Reynolds, Jr., *Honorary Member*

**Special Working Group on Graphite Pressure Equipment (BPV VIII)**

E. Soltow, *Chair*  
 G. C. Becherer  
 T. F. Bonn  
 F. L. Brown  
 R. W. Dickerson  
 S. Malone  
 M. R. Minick  
 A. A. Stupica

**Subgroup on Brazing (BPV IX)**

M. J. Pischke, *Chair*  
 E. W. Beckman  
 L. F. Campbell  
 M. L. Carpenter  
 A. F. Garbolevsky  
 J. P. Swezy, Jr.

**Special Working Group on Bolted Flanged Joints (BPV VIII)**

R. W. Mikitka, *Chair*  
 G. D. Bibel  
 W. Brown  
 W. J. Koves  
 M. Morishita  
 J. R. Payne  
 G. B. Rawls, Jr.  
 M. S. Shelton

**Subgroup on General Requirements (BPV IX)**

B. R. Newmark, *Chair*  
 E. W. Beckman  
 G. Chandler  
 P. R. Evans  
 A. Howard  
 R. M. Jessee  
 A. S. Olivares  
 D. K. Peetz  
 H. B. Porter  
 P. L. Sturgill  
 K. R. Willens  
 E. W. Woelfel  
 E. Molina, *Delegate*

**Subgroup on Materials (BPV IX)**

M. Bernasek, <i>Chair</i>	T. Melfi
T. Anderson	M. J. Pischke
J. L. Arnold	C. E. Sainz
M. L. Carpenter	W. J. Sperko
E. Cutlip	M. J. Stanko
S. S. Fiore	P. L. Sturgill
S. E. Gingrich	R. R. Young
R. M. Jessee	V. G. V. Giunto, <i>Delegate</i>
C. C. Kim	

**Subgroup on Performance Qualification (BPV IX)**

D. A. Bowers, <i>Chair</i>	K. L. Hayes
M. J. Rice, <i>Secretary</i>	J. S. Lee
V. A. Bell	W. M. Lundy
M. A. Boring	E. G. Reichelt
R. B. Corbit	M. B. Sims
P. D. Flenner	

**Subgroup on Plastic Fusing (BPV IX)**

M. L. Carpenter, <i>Chair</i>	J. E. O'Sullivan
D. Burwell	E. G. Reichelt
J. M. Craig	M. J. Rice
A. N. Haddad	P. L. Sturgill
K. L. Hayes	J. P. Swezy, Jr.
R. M. Jessee	E. W. Woelfel
E. Lever	J. C. Minichiello
E. W. McElroy	C. W. Rowley

**Subgroup on Procedure Qualification (BPV IX)**

D. A. Bowers, <i>Chair</i>	A. S. Olivares
M. J. Rice, <i>Secretary</i>	S. Raghunathan
M. Bernasek	M. B. Sims
M. A. Boring	W. J. Sperko
R. K. Brown, Jr.	S. A. Sprague
W. M. Lundy	J. P. Swezy, Jr.
J. R. McGimpsey	P. L. Van Fosson
W. F. Newell, Jr.	T. C. Wiesner

**COMMITTEE ON FIBER-REINFORCED PLASTIC PRESSURE VESSELS (BPV X)**

D. Eisberg, <i>Chair</i>	D. L. Keeler
P. D. Stumpf, <i>Staff Secretary</i>	B. M. Linnemann
F. L. Brown	N. L. Newhouse
J. L. Bustillos	D. J. Painter
T. W. Cowley	G. Ramirez
I. L. Dinovo	J. R. Richter
T. J. Fowler	B. F. Shelley
M. R. Gorman	F. W. Van Name
D. H. Hodgkinson	D. O. Yancey, Jr.
L. E. Hunt	P. H. Ziehl

**COMMITTEE ON NUCLEAR INSERVICE INSPECTION (BPV XI)**

G. C. Park, <i>Chair</i>	D. W. Lamond
R. W. Swayne, <i>Vice Chair</i>	G. A. Lofthus
R. A. Yonekawa, <i>Vice Chair</i>	J. E. O'Sullivan
R. L. Crane, <i>Staff Secretary</i>	R. K. Rhyne
J. M. Agold	D. A. Scarth
V. L. Armentrout	F. J. Schaaf, Jr.
W. H. Bamford	J. C. Spanner, Jr.
T. L. Chan	G. L. Stevens
R. C. Cipolla	D. E. Waskey
D. D. Davis	J. G. Weicks
G. H. DeBoo	C. J. Wirtz
R. L. Dyle	T. Yuhara
E. V. Farrell, Jr.	H. D. Chung, <i>Delegate</i>
E. L. Farrow	C. Ye, <i>Delegate</i>
E. B. Gerlach	R. A. West, <i>Contributing Member</i>
R. E. Gimple	J. Hakii, <i>Alternate</i>
T. J. Griesbach	J. T. Lindberg, <i>Alternate</i>
K. Hasegawa	W. E. Norris, <i>Alternate</i>
D. O. Henry	C. D. Cowfer, <i>Honorary Member</i>
R. D. Kerr	F. E. Gregor, <i>Honorary Member</i>
S. D. Kulat	O. F. Hedden, <i>Honorary Member</i>
G. L. Lagleder	P. C. Riccardella, <i>Honorary Member</i>

**Executive Committee (BPV XI)**

R. A. Yonekawa, <i>Chair</i>	S. D. Kulat
G. C. Park, <i>Vice Chair</i>	J. T. Lindberg
R. L. Crane, <i>Staff Secretary</i>	W. E. Norris
W. H. Bamford	R. K. Rhyne
R. L. Dyle	J. C. Spanner, Jr.
M. J. Ferlisi	G. L. Stevens
E. B. Gerlach	R. W. Swayne
R. E. Gimple	

**Subgroup on Evaluation Standards (SG-ES) (BPV XI)**

W. H. Bamford, <i>Chair</i>	D. R. Lee
G. L. Stevens, <i>Secretary</i>	R. O. McGill
H. D. Chung	H. S. Mehta
R. C. Cipolla	M. A. Mitchell
G. H. DeBoo	K. Miyazaki
R. L. Dyle	R. Pace
B. R. Ganta	S. Ranganath
T. J. Griesbach	D. A. Scarth
K. Hasegawa	T. V. Vo
K. Hojo	K. R. Wichman
D. N. Hopkins	S. X. Xu
K. Koyama	

**Working Group on Flaw Evaluation (SG-ES) (BPV XI)**

R. C. Cipolla, <i>Chair</i>	H. S. Mehta
S. X. Xu, <i>Secretary</i>	G. A. Miessi
W. H. Bamford	K. Miyazaki
B. Bezensek	R. K. Qashu
H. D. Chung	S. Ranganath
G. H. DeBoo	H. Rathbun
B. R. Ganta	P. J. Rush
R. G. Gilada	D. A. Scarth
H. L. Gustin	W. L. Server
F. D. Hayes	N. J. Shah
P. H. Hoang	T. V. Vo
K. Hojo	K. R. Wichman
D. N. Hopkins	G. M. Wilkowski
K. Koyama	D. L. Rudland, <i>Alternate</i>
D. R. Lee	

**Working Group on Operating Plant Criteria (SG-ES) (BPV XI)**

T. J. Griesbach, <i>Chair</i>	H. S. Mehta
D. V. Sommerville, <i>Secretary</i>	M. A. Mitchell
W. H. Bamford	R. Pace
H. Behnke	N. A. Palm
T. L. Dickson	S. Ranganath
R. L. Dyle	W. L. Server
S. R. Gosselin	D. P. Weakland
M. Hayashi	T. Hardin, <i>Alternate</i>

**Working Group on Pipe Flaw Evaluation (SG-ES) (BPV XI)**

D. A. Scarth, <i>Chair</i>	D. N. Hopkins
G. M. Wilkowski, <i>Secretary</i>	E. J. Houston
T. A. Bacon	K. Kashima
W. H. Bamford	R. O. McGill
B. Bezensek	H. S. Mehta
H. D. Chung	G. A. A. Miessi
R. C. Cipolla	K. Miyazaki
N. G. Cofie	D. L. Rudland
J. M. Davis	P. J. Rush
G. H. DeBoo	D.-J. Shim
B. R. Ganta	T. V. Vo
L. F. Goyette	B. Wasiluk
K. Hasegawa	S. X. Xu
P. H. Hoang	H. Rathbun, <i>Alternate</i>
K. Hojo	

**Subgroup on Nondestructive Examination (SG-NDE) (BPV XI)**

J. C. Spanner, Jr., <i>Chair</i>	J. T. Lindberg
G. A. Lofthus, <i>Secretary</i>	T. R. Lupold
T. L. Chan	G. R. Perkins
C. B. Cheezem	S. A. Sabo
D. R. Cordes	F. J. Schaaf, Jr.
F. E. Dohmen	R. V. Swain
M. E. Gothard	G. Tang
D. O. Henry	C. J. Wirtz

**Working Group on Personnel Qualification and Surface Visual and Eddy Current Examination (SG-NDE) (BPV XI)**

J. T. Lindberg, <i>Chair</i>	J. C. Spanner, Jr.
D. R. Cordes, <i>Secretary</i>	J. T. Timm
S. E. Cumblidge	M. C. Weatherly
N. Farenbaugh	M. L. Whytsell
D. O. Henry	C. J. Wirtz
J. W. Houf	

**Working Group on Procedure Qualification and Volumetric Examination (SG-NDE) (BPV XI)**

G. A. Lofthus, <i>Chair</i>	K. J. Hacker
G. R. Perkins, <i>Secretary</i>	D. B. King
M. T. Anderson	D. A. Kull
M. Briley	C. A. Nove
C. B. Cheezem	S. A. Sabo
A. D. Chockie	R. V. Swain
M. Dennis	B. A. Thigpen
S. R. Doctor	S. J. Todd
F. E. Dohmen	D. K. Zimmerman
M. E. Gothard	

**Subgroup on Repair/Replacement Activities (SG-RRR) (BPV XI)**

E. B. Gerlach, <i>Chair</i>	R. D. Kerr
E. V. Farrell, Jr., <i>Secretary</i>	S. L. McCracken
S. B. Brown	B. R. Newton
R. E. Cantrell	J. E. O'Sullivan
G. G. Elder	R. R. Stevenson
P. D. Fisher	R. W. Swayne
J. M. Gamber	D. L. Tilly
R. E. Gimple	D. E. Waskey
D. R. Graham	J. G. Weicks
R. A. Hermann	R. A. Yonekawa
K. J. Karwoski	E. G. Reichelt, <i>Alternate</i>

**Working Group on Welding and Special Repair Processes (SG-RRR) (BPV XI)**

D. E. Waskey, <i>Chair</i>	C. C. Kim
D. J. Tilly, <i>Secretary</i>	M. Lau
R. E. Cantrell	S. L. McCracken
S. J. Findlan	D. B. Meredith
P. D. Fisher	B. R. Newton
M. L. Hall	J. E. O'Sullivan
R. A. Hermann	R. E. Smith
K. J. Karwoski	J. G. Weicks

**Working Group on Nonmetals Repair/Replacement Activities (SG-RRR) (BPV XI)**

J. E. O'Sullivan, <i>Chair</i>	B. B. Raji
S. Schuessler, <i>Secretary</i>	E. G. Reichelt
E. W. McElroy	F. J. Schaaf, Jr.
T. M. Musto	Z. J. Zhou

**Task Group on Repair by Carbon Fiber Composites (WGN-MRR) (BPV XI)**

J. E. O'Sullivan, <i>Chair</i>	B. B. Raji
M. Golliet	F. J. Schaaf, Jr.
E. W. McElroy	

**Working Group on Design and Programs (SG-RRR) (BPV XI)**

G. G. Elder, <i>Chair</i>	E. B. Gerlach
S. B. Brown, <i>Secretary</i>	D. R. Graham
O. Bhatti	G. F. Harttraft
R. Clow	T. E. Hiss
J. W. Collins	H. Malinkowski
R. R. Croft	M. A. Pyne
E. V. Farrell, Jr.	R. R. Stevenson
S. K. Fisher	R. W. Swayne
J. M. Gamber	R. A. Yonekawa

**Subgroup on Water-Cooled Systems (SG-WCS) (BPV XI)**

S. D. Kulat, <i>Chair</i>	P. J. Hennessey
N. A. Palm, <i>Secretary</i>	D. W. Lamond
J. M. Agold	A. McNeill III
V. L. Armentrout	T. Nomura
J. M. Boughman	W. E. Norris
S. T. Chesworth	G. C. Park
D. D. Davis	J. E. Staffiera
H. Q. Do	H. M. Stephens, Jr.
E. L. Farrow	R. Turner
M. J. Ferlisi	H. L. Graves III, <i>Alternate</i>

**Task Group on High Strength Nickel Alloys Issues (SG-WCS) (BPV XI)**

V. L. Armentrout, <i>Chair</i>	K. Koyama
B. L. Montgomery, <i>Secretary</i>	M. Lashley
W. H. Bamford	G. C. Park
P. R. Donavin	J. M. Shuping
R. L. Dyle	J. C. Spanner, Jr.
G. G. Elder	K. B. Stuckey
R. E. Gimple	E. J. Sullivan, Jr.
R. Hardies	D. P. Weakland

**Working Group on Containment (SG-WCS) (BPV XI)**

J. E. Staffiera, <i>Chair</i>	D. J. Naus
H. M. Stephens, Jr., <i>Secretary</i>	F. Poteet III
P. S. Ghosal	A. A. Reyes-Cruz
D. H. Goche	E. A. Rodriguez
H. L. Graves III	G. Thomas
H. T. Hill	S. G. Brown, <i>Alternate</i>
R. D. Hough	W. E. Norris, <i>Alternate</i>
C. N. Krishnaswamy	

**Working Group on Inspection of Systems and Components (SG-WCS) (BPV XI)**

J. M. Agold, <i>Chair</i>	K. W. Hall
H. Q. Do, <i>Secretary</i>	K. M. Hoffman
V. L. Armentrout	S. D. Kulat
C. Cueto-Felgueroso	T. Nomura
R. E. Day	J. C. Nygaard
M. J. Ferlisi	R. Rishel
R. Fougereousse	C. M. Ross

**Working Group on Pressure Testing (SG-WCS) (BPV XI)**

D. W. Lamond, <i>Chair</i>	T. R. Lupold
J. M. Boughman, <i>Secretary</i>	J. K. McClanahan
Y.-K. Chung	B. L. Montgomery
T. Coste	S. A. Norman
J. A. Doughty	P. N. Passalugo
R. E. Hall	J. A. Stevenson

**Task Group on Buried Components Inspection and Testing (WG-PT) (BPV XI)**

D. W. Lamond, <i>Chair</i>	A. Lee
J. M. Boughman, <i>Secretary</i>	E. J. Maloney
C. Blackwelder	M. Moenssens
B. Clark III	J. Ossmann
G. C. Coker	P. N. Passalugo
R. E. Day	J. H. Riley
R. Hardies	D. M. Swann
T. Ivy	

**Working Group on Risk-Informed Activities (SGW-CS) (BPV XI)**

M. A. Pyne, <i>Chair</i>	K. W. Hall
S. T. Chesworth, <i>Secretary</i>	S. D. Kulat
J. M. Agold	D. W. Lamond
C. Cueto-Felgueroso	R. K. Mattu
H. Q. Do	A. McNeill III
R. Fougereousse	P. J. O'Regan
M. R. Graybeal	N. A. Palm
R. Haessler	D. Vetter
J. Hakii	J. C. Younger

**Special Working Group on Editing and Review (BPV XI)**

R. W. Swayne, <i>Chair</i>	J. E. Staffiera
C. E. Moyer	D. J. Tilly
K. R. Rao	C. J. Wirtz

**Special Working Group on Nuclear Plant Aging Management (BPV XI)**

T. A. Meyer, <i>Chair</i>	A. B. Meichler
B. R. Snyder, <i>Secretary</i>	R. E. Nickell
S. Asada	K. Sakamoto
D. V. Burgess	W. L. Server
Y.-K. Chung	R. L. Turner
D. D. Davis	G. G. Young
R. L. Dyle	Z. Zhong
A. L. Hiser, Jr.	C. E. Carpenter, <i>Alternate</i>

**Working Group on General Requirements (BPV XI)**

R. K. Rhyne, <i>Chair</i>	K. M. Herman
E. J. Maloney, <i>Secretary</i>	R. K. Mattu
T. L. Chan	C. E. Moyer
E. L. Farrow	D. J. Potter
R. Fox	R. L. Williams
P. J. Hennessey	

**Special Working Group on Reliability and Integrity Management Program (BPV XI)**

F. J. Schaaf, Jr., <i>Chair</i>	D. R. Lee
M. A. Lockwood, <i>Secretary</i>	R. K. Miller
N. Broom	P. M. Mills
S. R. Doctor	M. N. Mitchell
J. Fletcher	A. T. Roberts III
M. R. Graybeal	T. Roney
J. Grimm	R. W. Swayne
A. B. Hull	

**COMMITTEE ON TRANSPORT TANKS (BPV XII)**

M. D. Rana, <i>Chair</i>	J. R. McGimpsey
N. J. Paulick, <i>Vice Chair</i>	M. Pitts
T. Schellens, <i>Staff Secretary</i>	T. A. Rogers
A. N. Antoniou	A. Selz
J. A. Byers	S. Staniszewski
W. L. Garfield	A. P. Varghese
C. H. Hochman	M. R. Ward
G. G. Karcher	M. D. Pham, <i>Contributing Member</i>

**Subgroup on Design and Materials (BPV XII)**

A. P. Varghese, <i>Chair</i>	N. J. Paulick
R. C. Sallash, <i>Secretary</i>	M. D. Rana
D. K. Chandiramani	T. A. Rogers
P. Chilukuri	A. Selz
T. Hitchcock	M. R. Ward
G. G. Karcher	K. Xu
T. P. Lokey	J. Zheng, <i>Corresponding Member</i>
S. L. McWilliams	M. D. Pham, <i>Contributing Member</i>

**Subgroup on Fabrication, Inspection, and Continued Service  
(BPV XII)**

M. Pitts, <i>Chair</i>	K. Mansker
P. Chilukuri, <i>Secretary</i>	J. R. McGimpsey
S. E. Benet	A. S. Olivares
J. A. Byers	R. C. Sallash
W. L. Garfield	S. Staniszewski
T. P. Lokey	L. H. Strouse, <i>Contributing Member</i>

**Subgroup on General Requirements (BPV XII)**

W. L. Garfield, <i>Chair</i>	M. Pitts
S. E. Benet, <i>Secretary</i>	T. Rummel
T. W. Alexander	R. C. Sallash
A. N. Antoniou	S. Staniszewski
J. L. Freiler	K. L. Gilmore, <i>Contributing Member</i>
C. H. Hochman	L. H. Strouse, <i>Contributing Member</i>
J. R. McGimpsey	

**Subgroup on Nonmandatory Appendices (BPV XII)**

T. A. Rogers, <i>Chair</i>	D. G. Shelton
S. Staniszewski, <i>Secretary</i>	M. R. Ward
S. E. Benet	D. D. Brusewitz, <i>Contributing Member</i>
P. Chilukuri	J. L. Conley, <i>Contributing Member</i>
R. Hayworth	T. Eubanks, <i>Contributing Member</i>
K. Mansker	T. Hitchcock, <i>Contributing Member</i>
S. L. McWilliams	A. Selz, <i>Contributing Member</i>
N. J. Paulick	A. P. Varghese, <i>Contributing Member</i>
M. Pitts	
R. C. Sallash	

**COMMITTEE ON BOILER AND PRESSURE VESSEL CONFORMITY  
ASSESSMENT (CBPVCA)**

P. D. Edwards, <i>Chair</i>	R. V. Wielgoszinski
K. I. Baron, <i>Staff Secretary</i>	S. F. Harrison, Jr., <i>Contributing Member</i>
S. W. Cameron	V. Bogosian, <i>Alternate</i>
M. A. DeVries	D. C. Cook, <i>Alternate</i>
T. E. Hansen	D. W. King, <i>Alternate</i>
D. J. Jenkins	B. L. Krasium, <i>Alternate</i>
K. T. Lau	W. C. LaRochelle, <i>Alternate</i>
L. E. McDonald	P. F. Martin, <i>Alternate</i>
K. M. McTague	K. McPhie, <i>Alternate</i>
D. Miller	M. R. Minick, <i>Alternate</i>
B. R. Morelock	I. Powell, <i>Alternate</i>
J. D. O'Leary	R. Pulliam, <i>Alternate</i>
T. M. Parks	M. T. Roby, <i>Alternate</i>
B. C. Turczynski	J. A. West, <i>Alternate</i>
D. E. Tuttle	A. J. Spencer, <i>Honorary Member</i>
E. A. Whittle	

**COMMITTEE ON NUCLEAR CERTIFICATION (CNC)**

W. C. LaRochelle, <i>Chair</i>	M. F. Sullivan, <i>Contributing Member</i>
R. R. Stevenson, <i>Vice Chair</i>	S. Andrews, <i>Alternate</i>
E. Suarez, <i>Staff Secretary</i>	V. Bogosian, <i>Alternate</i>
J. DeKleine	P. D. Edwards, <i>Alternate</i>
G. Gobbi	D. P. Gobbi, <i>Alternate</i>
S. M. Goodwin	K. M. Hottle, <i>Alternate</i>
J. W. Highlands	K. A. Kavanagh, <i>Alternate</i>
K. A. Huber	B. G. Kovarik, <i>Alternate</i>
J. C. Krane	M. A. Lockwood, <i>Alternate</i>
R. P. McIntyre	R. J. Luymes, <i>Alternate</i>
M. R. Minick	J. Oyler, <i>Alternate</i>
L. M. Plante	M. Paris, <i>Alternate</i>
H. B. Prasse	D. W. Stepp, <i>Alternate</i>
T. E. Quaka	A. Torosyan, <i>Alternate</i>
C. T. Smith	E. A. Whittle, <i>Alternate</i>
D. M. Vickery	H. L. Wiger, <i>Alternate</i>
C. S. Withers	
S. Yang	

**COMMITTEE ON SAFETY VALVE REQUIREMENTS (BPV-SVR)**

J. A. West, <i>Chair</i>	R. J. Doelling
D. B. DeMichael, <i>Vice Chair</i>	J. P. Glaspie
C. E. O'Brien, <i>Staff Secretary</i>	S. F. Harrison, Jr.
J. F. Ball	W. F. Hart
S. Cammeresi	D. Miller
J. A. Cox	T. Patel
R. D. Danzy	Z. Wang

**Subgroup on Design (BPV-SVR)**

R. D. Danzy, <i>Chair</i>	D. Miller
C. E. Beair	T. Patel
J. A. Conley	J. A. West
R. J. Doelling	

**Subgroup on General Requirements (BPV-SVR)**

D. B. DeMichael, <i>Chair</i>	S. T. French
J. F. Ball	J. P. Glaspie
G. Brazier	J. W. Richardson
J. Burgess	D. E. Tuttle

**Subgroup on Testing (BPV-SVR)**

J. A. Cox, <i>Chair</i>	W. F. Hart
J. E. Britt	B. K. Nutter
S. Cammeresi	C. Sharpe
J. W. Dickson	Z. Wang
G. D. Goodson	A. Wilson

**U.S. Technical Advisory Group ISO/TC 185 Safety Relief Valves**

T. J. Bevilacqua, <i>Chair</i>	D. B. DeMichael
C. E. O'Brien, <i>Staff Secretary</i>	D. Miller
J. F. Ball	B. K. Nutter
G. Brazier	J. A. West



## ORGANIZATION OF SECTION III

### 1 GENERAL

Section III consists of Division 1, Division 2, Division 3, and Division 5. These Divisions are broken down into Subsections and are designated by capital letters preceded by the letter “N” for Division 1, by the letter “C” for Division 2, by the letter “W” for Division 3, and by the letter “H” for Division 5. Each Subsection is published separately, with the exception of those listed for Divisions 2, 3, and 5.

- Subsection NCA — General Requirements for Division 1 and Division 2
- Appendices
- Division 1
  - Subsection NB — Class 1 Components
  - Subsection NC — Class 2 Components
  - Subsection ND — Class 3 Components
  - Subsection NE — Class MC Components
  - Subsection NF — Supports
  - Subsection NG — Core Support Structures
  - Subsection NH — Class 1 Components in Elevated Temperature Service
- Division 2 — Code for Concrete Containments
  - Subsection CC — Concrete Containments
- Division 3 — Containments for Transportation and Storage of Spent Nuclear Fuel and High Level Radioactive Material and Waste
  - Subsection WA — General Requirements for Division 3
  - Subsection WB — Class TC Transportation Containments
  - Subsection WC — Class SC Storage Containments
- Division 5 — High Temperature Reactors
  - Subsection HA — General Requirements
    - Subpart A — Metallic Materials
    - Subpart B — Graphite Materials
    - Subpart C — Composite Materials
  - Subsection HB — Class A Metallic Pressure Boundary Components
    - Subpart A — Low Temperature Service
    - Subpart B — Elevated Temperature Service
  - Subsection HC — Class B Metallic Pressure Boundary Components
    - Subpart A — Low Temperature Service
    - Subpart B — Elevated Temperature Service
  - Subsection HF — Class A and B Metallic Supports
    - Subpart A — Low Temperature Service
  - Subsection HG — Class A Metallic Core Support Structures
    - Subpart A — Low Temperature Service
    - Subpart B — Elevated Temperature Service
  - Subsection HH — Class A Nonmetallic Core Support Structures
    - Subpart A — Graphite Materials
    - Subpart B — Composite Materials

### 2 SUBSECTIONS

Subsections are divided into Articles, subarticles, paragraphs, and, where necessary, subparagraphs and subsubparagraphs.

### 3 ARTICLES

Articles are designated by the applicable letters indicated above for the Subsections followed by Arabic numbers, such as NB-1000. Where possible, Articles dealing with the same topics are given the same number in each Subsection, except NCA, in accordance with the following general scheme:

Article Number	Title
1000	Introduction or Scope
2000	Material
3000	Design
4000	Fabrication and Installation
5000	Examination
6000	Testing
7000	Overpressure Protection
8000	Nameplates, Stamping With Certification Mark, and Reports

The numbering of Articles and the material contained in the Articles may not, however, be consecutive. Due to the fact that the complete outline may cover phases not applicable to a particular Subsection or Article, the rules have been prepared with some gaps in the numbering.

### 4 SUBARTICLES

Subarticles are numbered in units of 100, such as NB-1100.

### 5 SUBSUBARTICLES

Subsubarticles are numbered in units of 10, such as NB-2130, and generally have no text. When a number such as NB-1110 is followed by text, it is considered a paragraph.

### 6 PARAGRAPHS

Paragraphs are numbered in units of 1, such as NB-2121.

### 7 SUBPARAGRAPHS

Subparagraphs, when they are *major* subdivisions of a paragraph, are designated by adding a decimal followed by one or more digits to the paragraph number, such as NB-1132.1. When they are *minor* subdivisions of a paragraph, subparagraphs may be designated by lowercase letters in parentheses, such as NB-2121(a).

### 8 SUBSUBPARAGRAPHS

Subsubparagraphs are designated by adding lowercase letters in parentheses to the *major* subparagraph numbers, such as NB-1132.1(a). When further subdivisions of *minor* subparagraphs are necessary, subsubparagraphs are designated by adding Arabic numerals in parentheses to the subparagraph designation, such as NB-2121(a)(1).

### 9 REFERENCES

References used within Section III generally fall into one of the following four categories:

(a) *References to Other Portions of Section III.* When a reference is made to another Article, subarticle, or paragraph, all numbers subsidiary to that reference shall be included. For example, reference to NB-3000 includes all material in Article NB-3000; reference to NB-3200 includes all material in subarticle NB-3200; reference to NB-3230 includes all paragraphs, NB-3231 through NB-3236.

(b) *References to Other Sections.* Other Sections referred to in Section III are the following:

(1) *Section II, Materials.* When a requirement for a material, or for the examination or testing of a material, is to be in accordance with a specification such as SA-105, SA-370, or SB-160, the reference is to material specifications in Section II. These references begin with the letter "S."

(2) *Section V, Nondestructive Examination.* Section V references begin with the letter "T" and relate to the nondestructive examination of material or welds.

(3) *Section IX, Welding and Brazing Qualifications.* Section IX references begin with the letter "Q" and relate to welding and brazing requirements.

(4) *Section XI, Rules for Inservice Inspection of Nuclear Power Plant Components.* When a reference is made to inservice inspection, the rules of Section XI shall apply.

*(c) Reference to Specifications and Standards Other Than Published in Code Sections*

(1) Specifications for examination methods and acceptance standards to be used in connection with them are published by the American Society for Testing and Materials (ASTM). At the time of publication of Section III, some such specifications were not included in Section II of this Code. A reference to ASTM E94 refers to the specification so designated by and published by ASTM, 100 Barr Harbor Drive, West Conshohocken, PA 19428.

(2) Dimensional standards covering products such as valves, flanges, and fittings are sponsored and published by The American Society of Mechanical Engineers and approved by the American National Standards Institute. When a product is to conform to such a standard, for example ASME B16.5, the standard is approved by the American National Standards Institute. The applicable year of issue is that suffixed to its numerical designation in Table NCA-7100-1, for example ASME B16.5-2003. Standards published by The American Society of Mechanical Engineers are available from ASME, 22 Law Drive, P.O. Box 2900, Fairfield, NJ 07007-2900.

(3) Dimensional and other types of standards covering products such as valves, flanges, and fittings are also published by the Manufacturers Standardization Society of the Valve and Fittings Industry and are known as Standard Practices. When a product is required by these rules to conform to a Standard Practice, for example MSS SP-100, the Standard Practice referred to is published by the Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS), 127 Park Street, NE, Vienna, VA 22180. The applicable year of issue of such a Standard Practice is that suffixed to its numerical designation in Table NCA-7100-1, for example MSS SP-89-2003.

(4) Specifications for welding and brazing materials are published by the American Welding Society (AWS), 8669 Doral Boulevard, Suite 130, Doral, FL 33166. Specifications of this type are incorporated in Section II and are identified by the AWS designation with the prefix "SF," for example SFA-5.1.

(5) Standards applicable to the design and construction of tanks and flanges are published by the American Petroleum Institute and have designations such as API-605. When documents so designated are referred to in Section III, for example API-605-1988, they are standards published by the American Petroleum Institute and are listed in Table NCA-7100-1.

*(d) References to Appendices.* Section III uses two types of appendices that are designated as either Section III Appendices or Subsection Appendices. Either of these appendices is further designated as either Mandatory or Nonmandatory for use. Mandatory Appendices are referred to in the Section III rules and contain requirements that must be followed in construction. Nonmandatory Appendices provide additional information or guidance when using Section III.

(1) Section III Appendices are contained in a separate book titled "Appendices." These appendices have the potential for multiple subsection applicability. Mandatory Appendices are designated by a Roman numeral followed, when appropriate, by Arabic numerals to indicate various articles, subarticles, and paragraphs of the appendix, such as II-1500 or XIII-2131. Nonmandatory Appendices are designated by a capital letter followed, when appropriate, by Arabic numerals to indicate various articles, subarticles, and paragraphs of the appendix, such as D-1200 or Y-1440.

(2) Subsection Appendices are specifically applicable to just one subsection and are contained within that subsection. Subsection-specific mandatory and nonmandatory appendices are numbered in the same manner as Section III Appendices, but with a subsection identifier (e.g., NF, NH, D2, etc.) preceding either the Roman numeral or the capital letter for a unique designation. For example, NF-II-1100 or NF-A-1200 would be part of a Subsection NF mandatory or nonmandatory appendix, respectively. For Subsection CC, D2-IV-1120 or D2-D-1330 would be part of a Subsection CC mandatory or nonmandatory appendix, respectively.

---

\* The American National Standards Institute (ANSI) was formerly known as the American Standards Association. Standards approved by the Association were designated by the prefix "ASA" followed by the number of the standard and the year of publication. More recently, the American National Standards Institute was known as the United States of America Standards Institute. Standards were designated by the prefix "USAS" followed by the number of the standard and the year of publication. While the letters of the prefix have changed with the name of the organization, the numbers of the standards have remained unchanged.

## SUMMARY OF CHANGES

The 2013 Edition of this Code contains revisions in addition to the 2010 Edition with 2011 Addenda.

After publication of the 2013 Edition, Errata to the BPV Code may be posted on the ASME Web site to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in the BPV Code. Such Errata shall be used on the date posted.

Information regarding Special Notices and Errata is published on the ASME Web site under the BPVC Resources page at <http://www.asme.org/kb/standards/publications/bpvc-resources>.

Changes given below are identified on the pages by a margin note, **(13)**, placed next to the affected area.

The Record Numbers listed below are explained in more detail in "List of Changes in Record Number Order" following this Summary of Changes.

<i>Page</i>	<i>Location</i>	<i>Change (Record Number)</i>
x	List of Sections	Revised (12-749)
xii	Foreword	Revised in its entirety (09-760)
xv	Submittal of Technical Inquiries to the Boiler and Pressure Vessel Standards Committees	Revised (12-1641)
xvii	Personnel	Updated
xxxii	Organization of Section III	Revised (12-749)
xxxviii	Cross-Referencing and Stylistic Changes in the Boiler and Pressure Vessel Code	Added
49	Table NB-3217-2	Second, third, fourth, and sixth rows under last four columns corrected by errata (12-989)
50	Figure NB-3221-1	At the bottom of the image, above " $P_L + P_b$ ," direction of arrow corrected by errata (11-2129)
51	Figure NB-3222-1	(1) Corrected by errata (11-2129) (2) In Note (2), " $P_B$ " corrected by errata to read " $P_b$ " (12-989) (3) In the fourth sentence of Note (7), the word "peak" corrected by errata to read "total" (11-2129)
56	Figure NB-3224-1	(1) Corrected by errata (11-2129) (2) In Note (2), " $\pi_{lt}$ , $\pi_{lr}$ , and $\pi_{rt}$ " corrected by errata to read " $\sigma_{lt}$ , $\sigma_{lr}$ , $\sigma_{rt}$ " (11-2129) (3) In Note (3), " $0.9S_r$ " corrected by errata to read " $0.9S_y$ " (11-2129)
61	NB-3232.3	In subpara. (c), the word "fused" corrected by errata to read "used" (12-989)
80	NB-3526.3	(1) " $P_{ed}$ " corrected by errata to read " $P_{eb}$ " (12-1706) (2) " $Q_T$ " corrected by errata to read " $Q_{T3}$ " (12-2298)
83	NB-3542	Revised (12-304)
105	NB-3641.1	Definition of $P_a$ revised (10-1402)
117	NB-3654.1	Revised (10-1402)
118	NB-3655.1	Revised (10-1402)

<i>Page</i>	<i>Location</i>	<i>Change (Record Number)</i>
118	NB-3656	(1) Subparagraph (a)(1) revised (10-1402) (2) Subparagraph (b)(1) revised (10-1821) (3) In subpara. (b)(3), equation and definition of $P_D$ revised (10-1821) (4) In the second paragraph of subpara. (b)(5)(-b), "with $S$ , taken as $S_m$ " corrected by errata to read "with allowable $6S_m$ , replaced by $3S_m$ " (12-1313)
122	NB-3682	Second paragraph of subpara. (a) revised (11-1361)
124	NB-3683.1	First paragraph of subpara. (a) revised (12-441)
126	NB-3683.2	First paragraph revised (12-441)
127	NB-3683.4	Subparagraph (c)(2) revised (11-714)
129	NB-3683.6	Subparagraph (d) added (10-1736)
130	NB-3683.7	First paragraph revised (10-1736)
136	NB-3686.6	Added (10-1736)
136	Figure NB-3686.6-1	Added (10-1736)
148	Figure NB-4244(c)-1	General Notes revised (11-298)
169	Table NB-4622.1-1	Second entry in fifth column and all entries in sixth column revised (11-936)
171	Table NB-4622.7(b)-1	(1) Entries for P-No. 4 and P-Nos. 5A, 5B, and 5C revised (12-920) (2) Note (4) revised (11-1093)
179	NB-5243	Subparagraph (a) revised (11-298)
180	NB-5244	Revised (11-298)
180	NB-5245	Revised (11-298)
180	NB-5246	Revised (11-298)
180	NB-5250	Added (11-298)
199	NB-7734.2	In subpara. (a), nomenclature below last equation, cross-reference in parentheses revised (12-749)

**NOTE:** Volume 62 of the Interpretations to Section III, Divisions 1 and 2 of the ASME Boiler and Pressure Vessel Code follows the last page of Subsection NCA.

## LIST OF CHANGES IN RECORD NUMBER ORDER

Record Number	Change
09-760	Added an introductory subtitle clarifying the purpose and limitations of the Foreword. Revised history paragraph to recognize the realignment of the BPV into several BPVs. Deleted the paragraph on tolerances. Made editorial changes to recognize the new committee structure. Deleted words addressing governing code editions. Deleted paragraph concerning materials. Deleted the paragraph dealing with what the committee considers in the formulation of these rules.
10-1402	Revised definition of $P_a$ in NB-3641.1 and added $P_a$ calculation basis in NB-3654.1, NB-3655.1, NB-3655.2(a)(1), and NB-3656(a)(1).
10-1736	More accurate and less conservative expressions for the $C_2$ and $K_2$ stress indices for reducers are provided, on the condition that additional geometric requirements are met for the fabrication of the reducers. The revised indices are given as an alternative, in case the geometric requirements cannot be met.
10-1821	Changed $P_D$ to $P_E$ in NB-3656(b)(3).
11-298	Figure NB-4244(c)-1: added Note (b) to clarify Step 1 examination time of performance. NB-5243(a): clarified requirements. NB-5244(a): clarified and corrected requirements and added surface exam of accessible portion of weld buildup after final nozzle or connection welding. NB-5244(b): corrected requirements. NB-5245: requirements; sketches (a), (b), and (c) inserted in the third line, sketch (d) inserted in the next to last line. NB-5246: clarified requirements. NB-5250: added to address nozzle/branch/pipe connection weld buildups and weld buildups not associated with subsequent nozzle welding per BPV III-XI Industry Experience Item 10-007. NB-3683.4(c)(2): in the formula for $C_2$ , use the pipe side weld leg length for $C_x$ instead of the smallest leg length, provided that the fitting side leg meets the requirements of Figure NB-4427-1.
11-714	In NB-3683.4(c)(2), in the formula for $C_2$ , use the pipe side weld leg length for $C_x$ instead of the smallest leg length, provided that the fitting side leg meets the requirements of Fig. NB-4427-1.
11-936	Editorial clarifications/revisions were made to Table NB-4622.1-1.
11-1093	Deleted Note (4) from Table NB-4622.7(b)-1.
11-1361	Removed last sentence of NB-3682.
11-2129	Errata corrections. See Summary of Changes for details.
12-304	Removed “, except that the inside diameter $d_m$ shall be the larger of the basic valve body inside diameter in the region near the welding ends” from NB-3542.
12-441	Deleted ASME B16.28 from NB-3683.1, NB-3683.2, and NB-3683.7.
12-749	Changed the existing Division 1 Appendices to Section III Appendices and added a reference table addressing each Section III Appendix and each Division/Subsection. Revised pages from Section III Subsections to reflect that the Division 1 Appendices no longer exist. Revised Appendices that remain specific to just a single subsection (Subsections NH and CC) to identify their association within that Subsection and to eliminate any duplicate appendix callouts. Made minor editorial and errata corrections
12-920	Revised PWHT exemption tables for P4, P5A, P5B, and P5C to state all welds meeting the exemption requirements to be exempt from PWHT. Previously, the code listed circumferential butt welds, socket welds, and attachment welds to be exempt. The proposed change is similar to what is currently allowed for ASME B31.1 and ASME B31.3.
12-989	Errata corrections. See Summary of Changes for details.
12-1313	Errata corrections. See Summary of Changes for details.
12-1641	Deleted “— Mandatory” from “Submittal of Technical Inquiries to the Boiler and Pressure Vessel Committee — Mandatory” in the front matter.
12-1706	Errata corrections. See Summary of Changes for details.
12-1878	Deleted the “Scope” page from the front matter of Division 5 and incorporated the pertinent information into the “Section III Organization” pages.
12-2111	Errata corrections. See Summary of Changes for details.
12-2298	Errata corrections. See Summary of Changes for details.



## (13) CROSS-REFERENCING AND STYLISTIC CHANGES IN THE BOILER AND PRESSURE VESSEL CODE

There have been structural and stylistic changes to BPVC, starting with the 2011 Addenda, that should be noted to aid navigating the contents. The following is an overview of the changes:

### Subparagraph Breakdowns/Nested Lists Hierarchy

- First-level breakdowns are designated as (a), (b), (c), etc., as in the past.
- Second-level breakdowns are designated as (1), (2), (3), etc., as in the past.
- Third-level breakdowns are now designated as (-a), (-b), (-c), etc.
- Fourth-level breakdowns are now designated as (-1), (-2), (-3), etc.
- Fifth-level breakdowns are now designated as (+a), (+b), (+c), etc.
- Sixth-level breakdowns are now designated as (+1), (+2), etc.

### Footnotes

With the exception of those included in the front matter (roman-numbered pages), all footnotes are treated as endnotes. The endnotes are referenced in numeric order and appear at the end of each BPVC section/subsection.

### Submittal of Technical Inquiries to the Boiler and Pressure Vessel Standards Committees

*Submittal of Technical Inquiries to the Boiler and Pressure Vessel Standards Committees* has been moved to the front matter. This information now appears in all Boiler Code Sections (except for Code Case books).

### Cross-References

It is our intention to establish cross-reference link functionality in the current edition and moving forward. To facilitate this, cross-reference style has changed. Cross-references within a subsection or subarticle will not include the designator/identifier of that subsection/subarticle. Examples follow:

- *(Sub-)Paragraph Cross-References.* The cross-references to subparagraph breakdowns will follow the hierarchy of the designators under which the breakdown appears.
  - If subparagraph (-a) appears in X.1(c)(1) and is referenced in X.1(c)(1), it will be referenced as (-a).
  - If subparagraph (-a) appears in X.1(c)(1) but is referenced in X.1(c)(2), it will be referenced as (1)(-a).
  - If subparagraph (-a) appears in X.1(c)(1) but is referenced in X.1(e)(1), it will be referenced as (c)(1)(-a).
  - If subparagraph (-a) appears in X.1(c)(1) but is referenced in X.2(c)(2), it will be referenced as X.1(c)(1)(-a).
- *Equation Cross-References.* The cross-references to equations will follow the same logic. For example, if eq. (1) appears in X.1(a)(1) but is referenced in X.1(b), it will be referenced as eq. (a)(1)(1). If eq. (1) appears in X.1(a)(1) but is referenced in a different subsection/subarticle/paragraph, it will be referenced as eq. X.1(a)(1)(1).

## ARTICLE NB-1000 INTRODUCTION

### NB-1100 SCOPE

#### NB-1110 ASPECTS OF CONSTRUCTION COVERED BY THESE RULES

(a) Subsection NB contains rules for the material, design, fabrication, examination, testing, overpressure relief, marking, stamping, and preparation of reports by the Certificate Holder of items which are intended to conform to the requirements for Class 1 construction.

(b) The rules of Subsection NB cover the requirements for strength and pressure integrity of items, the failure of which would violate the pressure-retaining boundary. The rules cover initial construction requirements, but do not cover deterioration which may occur in service as a result of corrosion, radiation effects, or instability of material. NCA-1130 gives further limitations to the rules of this Subsection.

#### NB-1120 TEMPERATURE LIMITS

The rules of Subsection NB shall not be used for items which are to be subjected to metal temperatures that exceed the temperature limit in the applicability column shown in Section II, Part D, Subpart 1, Tables 2A, 2B, and 4 for design stress intensity values. Above those temperatures, the creep and stress rupture characteristics of materials permitted to be used become significant factors which are not presently covered by the rules of this Subsection. Fatigue design curves and specified methods for fatigue analysis are not applicable above 700°F (370°C) for materials covered by Figs. I-9.1 and I-9.4, and above 800°F (425°C) for materials covered by Figs. I-9.2 and I-9.3.

#### NB-1130 BOUNDARIES OF JURISDICTION APPLICABLE TO THIS SUBSECTION

##### NB-1131 Boundary of Components

The Design Specification shall define the boundary of a component to which piping or another component is attached. The boundary shall not be closer to a vessel, tank, pump, or valve than:

(a) the first circumferential joint in welded connections (the connecting weld shall be considered part of the piping);

(b) the face of the first flange in bolted connections (the bolts shall be considered part of the piping);

(c) the first threaded joint in screwed connections.

### NB-1132 Boundary Between Components and Attachments

#### NB-1132.1 Attachments.

(a) An *attachment* is an element in contact with or connected to the inside or outside of the pressure-retaining portion of a component.

(b) Attachments may have either a pressure-retaining or a nonpressure-retaining function.

(1) Attachments with a pressure-retaining function include items such as pressure boundary stiffeners, and branch pipe and vessel opening reinforcement.

(2) Attachments with a nonpressure-retaining function include items such as:

(-a) valve guides, thermal sleeves, and turning vanes

(-b) core support structures, internal structures, or other permanent structures within the reactor pressure vessel; and

(-c) vessel saddles, support and shear lugs, brackets, pipe clamps, trunnions, skirts, and other items in the support load path.

(c) Attachments may also have either a structural or nonstructural function.

(1) Attachments with a structural function (structural attachments):

(-a) perform a pressure-retaining function;

(-b) are core support structures, internal structures, or other permanent structures within the reactor pressure vessel; or

(-c) are in the support load path.

(2) Attachments with a nonstructural function (non-structural attachments):

(-a) do not perform a pressure-retaining function;

(-b) are not in the support load path;

(-c) may be permanent or temporary.

Nonstructural attachments include items such as nameplates, insulation supports, and locating and lifting lugs.

**NB-1132.2 Jurisdictional Boundary.** The jurisdictional boundary between a pressure-retaining component and an attachment defined in the Design Specification shall not be any closer to the pressure-retaining portion of the component than as defined in (a) through (g) below. [Figures NB-1132.2-1](#) through [NB-1132.2-4](#) are provided as an aid in defining the boundary and construction requirements of this Subsection.

(a) Attachments cast or forged with the component and weld buildup on the component surface shall be considered part of the component.

(b) Attachments, welds, and fasteners having a pressure-retaining function shall be considered part of the component.

(c) Except as provided in (d) and (e) below, the boundary between a pressure-retaining component and an attachment not having a pressure-retaining function shall be at the surface of the component.

(d) The first connecting weld of a nonpressure-retaining structural attachment to a component shall be considered part of the component unless the weld is more than  $2t$  from the pressure-retaining portion of the component, where  $t$  is the nominal thickness of the pressure-retaining material. Beyond  $2t$  from the pressure-retaining portion of the component, the first weld shall be considered part of the attachment.

(e) The first connecting weld of a welded nonstructural attachment to a component shall be considered part of the attachment. At or within  $2t$  from the pressure-retaining portion of the component, the first connecting weld shall conform to NB-4430.


(f) Mechanical fasteners used to connect a nonpressure-retaining attachment to the component shall be considered part of the attachment.

(g) The boundary may be located further from the pressure-retaining portion of the component than as defined in (a) through (f) above when specified in the Design Specification.

#### **NB-1140 ELECTRICAL AND MECHANICAL PENETRATION ASSEMBLIES**

Electrical and mechanical penetration assemblies shall be constructed in accordance with the rules for vessels, except that the design and the material performing the electrical conducting and insulating functions need not meet the requirements of this Subsection.

**Figure NB-1132.2-1**  
**Attachments in the Component Support Load Path That Do Not Perform a Pressure-Retaining Function**




- ① Component shall conform to Subsection NB.
- ② Pressure retaining portion of the component.
- ③ Jurisdictional boundary (heavy line).
- ④ Cast or forged attachment or weld buildup shall conform to Subsection NB.
- ⑤ Beyond  $2t$  from the pressure retaining portion of the component, the design rules of NF-3000 may be used as a substitute for the design rules of NB-3000.
- ⑥ At or within  $2t$  from the pressure retaining portion of the component, the first connecting weld shall conform to Subsection NB.
- ⑦ Beyond  $2t$  from the pressure retaining portion of the component or beyond the first connecting weld, the attachment shall conform to Subsection NF [see Note (1)].
- ⑧ Bearing, clamped, or fastened attachment shall conform to Subsection NF [see Note (1)].
- ⑨ Attachment connection shall conform to Subsection NF [see Note (1)].
- ⑩ At or within  $2t$  from the pressure retaining portion of the component, the interaction effects of the attachment shall be considered in accordance with NB-3135.
- ⑪ Drilled holes shall conform to Subsection NB.

GENERAL NOTE: These sketches are intended to show jurisdictional concepts and should not be considered as recommended configurations.

**NOTE:**

(1) If the attachment is an intervening element [NF-1110(c)], material, design, and connections, as appropriate, are outside Code jurisdiction.


**Figure NB-1132.2-2**  
**Attachments That Do Not Perform a Pressure-Retaining Function and Are Not in the Component Support Load Path (Nonstructural Attachments)**



- ① Component shall conform to Subsection NB.
- ② Pressure retaining portion of the component.
- ③ Jurisdictional boundary (heavy line).
- ④ Cast or forged attachment or weld buildup shall conform to Subsection NB.
- ⑤ At or within  $2t$  from the pressure retaining portion of the component, the material of the first welded nonstructural attachment shall conform to NB-2190; design is outside Code jurisdiction.
- ⑥ At or within  $2t$  from the pressure retaining portion of the component, the first connecting weld shall conform to NB-4430.
- ⑦ Beyond  $2t$  from the pressure retaining portion of the component, the nonstructural attachment is outside Code jurisdiction.
- ⑧ Bearing, clamped, or fastened nonstructural attachment is outside Code jurisdiction.
- ⑨ Nonstructural attachment connection is outside Code jurisdiction.
- ⑩ At or within  $2t$  from the pressure retaining portion of the component, the interaction effects of the nonstructural attachment shall be considered in accordance with NB-3135.
- ⑪ Drilled holes shall conform to Subsection NB.


GENERAL NOTE: These sketches are intended to show jurisdictional concepts and should not be considered as recommended configurations.

**Figure NB-1132.2-3**  
**Attachments That Perform a Pressure-Retaining Function**



GENERAL NOTE: These sketches are intended to show jurisdictional concepts and should not be considered as recommended configurations.

**Figure NB-1132.2-4**  
**Attachments Within the Reactor Pressure Vessel (Core Support Structures) That Do Not Perform a Pressure-Retaining Function**



- ① Reactor pressure vessel conforms to Subsection NB.
- ② Pressure retaining portion of the reactor pressure vessel.
- ③ Jurisdictional boundary (heavy line).
- ④ Cast or forged attachment or weld buildup shall conform to Subsection NB.
- ⑤ Beyond  $2t$  from the pressure retaining portion of the reactor pressure vessel, the design rules of NG-3000 may be used as a substitute for the design rules of NB-3000.
- ⑥  $2t$  or within  $2t$  from the pressure retaining portion of the reactor pressure vessel, the first connecting weld shall conform to Subsection NB.
- ⑦ Beyond  $2t$  from the pressure retaining portion of the reactor pressure vessel or beyond the first connecting weld, the attachment shall conform to Subsection NG [see Note (1)].
- ⑧ Bearing, clamped, or fastened attachment shall conform to Subsection NG [see Note (1)].
- ⑨ Attachment connection shall conform to Subsection NG [see Note (1)].
- ⑩ At or within  $2t$  from the pressure retaining portion of the component, the interaction effects of the attachment on the reactor pressure vessel shall be considered in accordance with NB-3135.
- ⑪ Drilled holes within the jurisdictional boundary shall conform to Subsection NB.

GENERAL NOTE: These sketches are intended to show jurisdictional concepts and should not be considered as recommended configurations.

NOTE:

- (1) If the attachment is an internal structure (NG-1122), material, design, and connections, as appropriate, are outside Code jurisdiction except when the core support structure Design Specification requires the internal structure to conform to Subsection NG.



## ARTICLE NB-2000 MATERIAL

### NB-2100 GENERAL REQUIREMENTS FOR MATERIAL

#### NB-2110 SCOPE OF PRINCIPAL TERMS EMPLOYED

(a) The term *material* as used in this Subsection is defined in NCA-1220. The term *Material Organization* is defined in NCA-9000.

(b) The term *pressure-retaining material* as used in this Subsection applies to items such as vessel shells, heads, and nozzles; pipes, tubes, and fittings; valve bodies, bonnets, and disks; pump casings and covers; and bolting which joins pressure-retaining items.

(c) The requirements of this Article make reference to the term *thickness*. For the purpose intended, the following definitions of nominal thickness apply:

(1) *plate*: the thickness is the dimension of the short transverse direction.

(2) *forgings*: the thickness is the dimension defined as follows:

(-a) *hollow forgings*: the nominal thickness is measured between the inside and outside surfaces (radial thickness).

(-b) *disk forgings* (axial length less than the outside diameter): the nominal thickness is the axial length.

(-c) *flat ring forgings* (axial length less than the radial thickness): for axial length  $\leq 2$  in. (50 mm), the axial length is the nominal thickness. For axial length  $> 2$  in. (50 mm), the radial thickness is the nominal thickness.

(-d) *rectangular solid forgings*: the least rectangular dimension is the nominal thickness.

(3) *castings*

(-a) Thickness  $t$  for fracture toughness testing is defined as the nominal pipe wall thickness of the connecting piping.

(-b) Thickness  $t$  for heat treatment purposes is defined as the thickness of the pressure-retaining wall of the casting, excluding flanges and sections designated by the designer as nonpressure retaining.

### NB-2120 PRESSURE-RETAINING MATERIAL

#### NB-2121 Permitted Material Specifications

(a) Pressure-retaining material shall conform to the requirements of one of the specifications for material given in Section II, Part D, Subpart 1, Tables 2A and 2B, including

all applicable footnotes in the table, and to all of the requirements of this Article which apply to the product form in which the material is used.

(b) The requirements of this Article do not apply to material for items not associated with the pressure-retaining function of a component, such as shafts, stems, trim, spray nozzles, bearings, bushings, springs, and wear plates, nor to seals, packing, gaskets, valve seats, and ceramic insulating material and special alloys used as seal material in electrical penetration assemblies.

(c) Material made to specifications other than those specified in Section II, Part D, Subpart 1, Tables 2A and 2B may be used for the following applications:

(1) safety valve disks and nozzles, when the nozzles are internally contained by the external body structure;

(2) control valve disks and cages, when the valves function for flow control only;

(3) line valve disks in valves whose inlet connections are NPS 2 (DN 50) and smaller.

(d) Material for instrument line fittings and valves, NPS 1 (DN 25) and less, may be of material made to specifications other than those listed in Section II, Part D, Subpart 1, Tables 2A and 2B, provided that the fittings are in conformance with the requirements of NB-3671.4, the valves meet the requirements of NB-3500, and the material is determined to be adequate for the service conditions by the piping system designer for fittings.

(e) Welding and brazing material used in the manufacture of items shall comply with an SFA specification in Section II, Part C, except as otherwise permitted in Section IX, and shall also comply with the applicable requirements of this Article. The requirements of this Article do not apply to material used as backing rings or backing strips in welded joints.

(f) The requirements of this Article do not apply to hard surfacing or corrosion-resistant weld metal overlay that is 10% or less of the thickness of the base material (NB-3122).

### NB-2122 Special Requirements Conflicting With Permitted Material Specifications

Special requirements stipulated in this Article shall apply in lieu of the requirements of the material specification wherever the special requirements conflict with the material specification requirements (NCA-3856). Where the special requirements include an examination, test, or treatment which is also required by the material specification, the examination, test, or treatment need be

performed only once. Required nondestructive examinations shall be performed as specified for each product form in [NB-2500](#). Any examination, repair, test, or treatment required by the material specification or by this Article may be performed by the Material Organization or the Certificate Holder as provided in [NB-4121](#). Any hydrostatic or pneumatic pressure test required by a material specification need not be performed, provided the material is identified as not having been pressure tested and it is subsequently pressure tested in the system in accordance with [NB-6114](#), except where the location of the material in the component or the installation would prevent performing any nondestructive examination required by the material specification to be performed subsequent to the hydrostatic or pneumatic test.

(a) The stress rupture test of SA-453 and SA-638 for Grade 660 (UNS S66286) is not required for design temperatures of 800°F (427°C) and below.

#### **NB-2124 Size Ranges**

Material outside the limits of size or thickness given in any specification in Section II may be used if the material is in compliance with the other requirements of the specification and no size limitation is given in the rules for construction. In those specifications in which chemical composition or mechanical properties are indicated to vary with size or thickness, any material outside the specification range shall be required to conform to the composition and mechanical properties shown for the nearest specified range (NCA-3856).

#### **NB-2125 Fabricated Hubbed Flanges**

Fabricated hubbed flanges shall be in accordance with the following:

(a) Hubbed flanges may be machined from a hot rolled or forged billet. The axis of the finished flange shall be parallel to the long axis of the original billet. (This is not intended to imply that the axis of the finished flange and the original billet must be concentric.)

(b) Hubbed flanges, except as permitted in (a) above, shall not be machined from plate or bar stock material unless the material has been formed into a ring, and further provided that:

(1) in a ring formed from plate, the original plate surfaces are parallel to the axis of the finished flange (this is not intended to imply that the original plate surface must be present in the finished flange);

(2) the joints in the ring are welded butt joints that conform to the requirements of this Section. Thickness to be used to determine postweld heat treatment and radiography requirements shall be the lesser of  $t$ , or  $(A - B)/2$ , where these symbols are as defined in XI-3130.

(c) The back of the flange and the outer surface of the hub shall be examined by the magnetic particle method or the liquid penetrant method in accordance with [NB-2540](#) to ensure that these surfaces are free from defects.

#### **NB-2126 Finned Tubes**

**NB-2126.1 Integrally Finned Tubes.** Integrally finned tubes may be made from tubes that conform to one of the specifications for tubes listed in Section II, Part D, Subpart 1, Tables 2A and 2B, and to all of the special requirements of this Article which apply to that product form. In addition, the following requirements shall apply:

(a) The requirements of [NB-2550](#) shall be met by the tube before finning.

(b) The tubes after finning shall conform to the applicable heat treatment requirements of the basic material specification.

(c) The design stress intensity values, design values of yield strength, and tensile strength values shall be those given in Section II, Part D, Subpart 1, Tables 2A and 2B, and Subpart 2, Tables Y-1, Y-2, and U, respectively, for the tube material from which the finned tube is made.

(d) After finning, each tube shall be subjected to one of the following tests:

(1) an internal pneumatic pressure test at not less than 250 psi (1.7 MPa) without evidence of leakage. The test method, such as immersion of the tube underwater during the test, shall permit visual detection of any leakage.

(2) an individual tube hydrostatic test at 1.25 times the Design Pressure which permits complete examination of the tube for leakage.

(e) A visual examination shall be performed after finning. Material having discontinuities, such as laps, seams, or cracks, is unacceptable.

**NB-2126.2 Welded Finned Tubes.** Welded finned tubes may be made from P-No.1 and P-No. 8 tubular products (pipe or tubing) that conform to one of the specifications for tubes listed in Section II, Part D, Subpart 1, Table 2A, and to all of the special requirements of this Article which apply to that product form. Heat transfer fins shall be of the same P-Number as the tube and shall be attached by a machine welding process, such as the electric resistance welding or the high frequency resistance welding process. In addition, the following requirements shall apply:

(a) The heat transfer fins need not be certified material. The material for the heat transfer fins shall be identified and suitable for welding; however, Certified Material Test Reports are not required.

(b) The machine welding process used to weld the heat transfer fins to the tubular material shall be performed in accordance with a Welding Procedure Specification.

(c) The procedure qualification shall require that a minimum of 12 cross-sections through the weld zone shall be examined at 5× minimum magnification. There shall be no cracks in the base material or weld; and the weld penetration shall be limited to 20% of the nominal tube wall thickness.

(d) For P-No. 1 material, the weld that attaches the fins to the tubing shall be heat treated after welding to a minimum temperature of 1,000°F (540°C).

(e) The fin is not considered to provide any support to the tube under pressure loading.

#### **NB-2127 Seal Membrane Material**

Seal membrane material (NB-4360) shall conform to the requirements of one of the material specifications listed in Section II, Part D, Subpart 1, Tables 2A and 2B. The requirements of NB-2500 are applicable for the appropriate product form when the material thickness is greater than  $\frac{1}{4}$  in. (6 mm).

#### **NB-2128 Bolting Material**

(a) Material for bolts and studs shall conform to the requirements of one of the specifications listed in Section II, Part D, Subpart 1, Table 4. Material for nuts shall conform to SA-194 or to the requirements of one of the specifications for nuts or bolting listed in Section II, Part D, Subpart 1, Table 4.

(b) The use of washers is optional. When used, they shall be made of wrought material with mechanical properties compatible with the nuts with which they are to be employed.

#### **NB-2130 CERTIFICATION OF MATERIAL**

All material used in construction of components shall be certified as required in NCA-3861 and NCA-3862. Certified Material Test Reports are required for pressure-retaining material except as provided by NCA-3861. A Certificate of Compliance may be provided in lieu of a Certified Material Test Report for all other material. Copies of all Certified Material Test Reports and Certificates of Compliance applicable to material used in a component shall be furnished with the material.

#### **NB-2140 WELDING MATERIAL**

For the requirements governing the material to be used for welding, see NB-2400.

#### **NB-2150 MATERIAL IDENTIFICATION**

The identification of pressure-retaining material and materials welded thereto shall meet the requirements of NCA-3856. Material for small items shall be controlled during manufacture and installation of a component so that they are identifiable as acceptable material at all times. Welding and brazing material shall be controlled during the repair of material and the manufacture and installation so that they are identifiable as acceptable until the material is actually consumed in the process (NB-4122).

#### **NB-2160 DETERIORATION OF MATERIAL IN SERVICE**

Consideration of deterioration of material caused by service is generally outside the scope of this Subsection. It is the responsibility of the Owner to select material suitable for the conditions stated in the Design Specifications (NCA-3250), with specific attention being given to the effects of service conditions upon the properties of the material. Special consideration shall be given to the influence of elements such as copper and phosphorus on the effects of irradiation on the properties of material (including welding material) in the core belt line region of the reactor vessel. Any special requirement shall be specified in the Design Specifications (NCA-3252 and NB-3124). When so specified, the check analysis shall be made in accordance with the base metal specification and in accordance with NB-2420 for the welding material.

#### **NB-2170 HEAT TREATMENT TO ENHANCE IMPACT PROPERTIES**

Carbon steels, low alloy steels, and high alloy chromium (Series 4XX) steels may be heat treated by quenching and tempering to enhance their impact properties. Postweld heat treatment of the component at a temperature of not less than 1,100°F (595°C) may be considered to be the tempering phase of the heat treatment.

#### **NB-2180 PROCEDURES FOR HEAT TREATMENT OF MATERIAL**

When heat treating temperature or time is required by the material specification and the rules of this Subsection, the heat treating shall be performed in temperature-surveyed and temperature-calibrated furnaces or the heat treating shall be controlled by measurement of material temperature by thermocouples in contact with the material or attached to blocks in contact with the material or by calibrated pyrometric instruments. Heat treating shall be performed under furnace loading conditions such that the heat treatment is in accordance with the material specification and the rules of this Subsection.

#### **NB-2190 NONPRESSURE-RETAINING MATERIAL**

(a) Material in the component support load path and not performing a pressure-retaining function (see NB-1130) welded to pressure-retaining material shall meet the requirements of NF-2000.

(b) Material not performing a pressure-retaining function and not in the component support load path (non-structural attachments) welded at or within  $2t$  of the pressure-retaining portion of the component need not comply with NB-2000 or NF-2000 provided the requirements of NB-4430 are met.

(c) Structural steel rolled shapes, which are permitted by this Subsection to be furnished with a Certificate of Compliance, may be repaired by welding using the welders, documentation, and examination requirements specified in SA-6.

## **NB-2200 MATERIAL TEST COUPONS AND SPECIMENS FOR FERRITIC STEEL MATERIAL**

### **NB-2210 HEAT TREATMENT REQUIREMENTS**

#### **NB-2211 Test Coupon Heat Treatment for Ferritic Material<sup>1</sup>**

Where ferritic steel material is subjected to heat treatment during fabrication or installation of a component, the material used for the tensile and impact test specimens shall be heat treated in the same manner as the component, except that test coupons and specimens for P-No. 1 Group Nos. 1 and 2 material with a nominal thickness of 2 in. (50 mm) or less are not required to be so heat treated. The Certificate Holder shall provide the Material Organization with the temperature and heating and cooling rate to be used. In the case of postweld heat treatment, the total time at temperature or temperatures for the test material shall be at least 80% of the total time at temperature or temperatures during actual postweld heat treatment of the material, and the total time at temperature or temperatures for the test material, coupon, or specimen may be performed in a single cycle.

#### **NB-2212 Test Coupon Heat Treatment for Quenched and Tempered Material**

**NB-2212.1 Cooling Rates.** Where ferritic steel material is subjected to quenching from the austenitizing temperature, the test coupons representing that material shall be cooled at a rate similar to and no faster than the main body of the material except in the case of certain forgings and castings (NB-2223.2 and NB-2226). This rule shall apply to coupons taken directly from the material as well as to separate test coupons representing the material, and one of the general procedures described in NB-2212.2 or one of the specific procedures described in NB-2220 shall be used for each product form.

**NB-2212.2 General Procedures.** One of the general procedures stipulated in (a), (b), and (c) below may be applied to quenched and tempered material or test coupons representing the material, provided the specimens are taken relative to the surface of the product in accordance with NB-2220. Further specific details of the methods to be used shall be the obligation of the Material Organization and the Certificate Holder.

(a) Any procedure may be used which can be demonstrated to produce a cooling rate in the test material which matches the cooling rate of the main body of the product at the region midway between midthickness and the surface

( $\frac{1}{4}t$ ) and no nearer any heat-treated edge than a distance equal to the nominal thickness  $t$  being quenched within 25°F (14°C) and 20 sec at all temperatures after cooling begins from the austenitizing temperature.

(b) If cooling rate data for the material and cooling rate control devices for the test specimens are available, the test specimens may be heat treated in the device to represent the material, provided that the provisions of (a) above are met.

(c) When any of the specific procedures described in NB-2220 are used, faster cooling rates at the edges may be compensated for by

(1) taking the test specimens at least  $t$  from a quenched edge, where  $t$  equals the material thickness;

(2) attaching a steel pad at least  $t$  wide by a partial penetration weld (which completely seals the buffered surface) to the edge where specimens are to be removed; or

(3) using thermal barriers or insulation at the edge where specimens are to be removed.

It shall be demonstrated (and this information shall be included in the Certified Material Test Report) that the cooling rates are equivalent to (a) or (b) above.

## **NB-2220 PROCEDURE FOR OBTAINING TEST COUPONS AND SPECIMENS FOR QUENCHED AND TEMPERED MATERIAL**

### **NB-2221 General Requirements**

The procedure for obtaining test coupons and specimens for quenched and tempered material is related to the product form. Coupon and specimen location and the number of tension test specimens shall be in accordance with the material specifications, except as required by the following paragraphs. References to dimensions signify nominal values.

### **NB-2222 Plates**

**NB-2222.1 Number of Tension Test Coupons.** The number of tension test coupons required shall be in accordance with the material specification and with SA-20, except that from carbon steel plates weighing 42,000 lb (19 000 kg) and over and alloy steel plates weighing 40,000 lb (18 000 kg) and over, two tension test coupons shall be taken, one representing the top end of the plate and one representing the bottom end of the plate.

**NB-2222.2 Orientation and Location of Coupons.** Coupons shall be taken so that specimens shall have their longitudinal axes at least  $\frac{1}{4}t$  from a rolled surface and with the midlength of the specimen at least  $t$  from any heat-treated edge, where  $t$  is the nominal thickness of the material.

**NB-2222.3 Requirements for Separate Test Coupons.** Where a separate test coupon is used to represent the component material, it shall be of sufficient size to ensure that the cooling rate of the region from which the test coupons are removed represents the cooling rate of the



material at least  $\frac{1}{4}t$  deep and  $t$  from any edge of the product. Unless cooling rates applicable to the bulk pieces or product are simulated in accordance with NB-2212.2(b), the dimensions of the coupon shall be not less than  $3t \times 3t \times t$ , where  $t$  is the nominal material thickness.

## NB-2223 Forgings

**NB-2223.1 Location of Coupons.** Coupons shall be taken so that specimens shall have their longitudinal axes at least  $\frac{1}{4}t$  from any surface and with the midlength of the specimens at least  $t$  from any second surface, where  $t$  is the maximum heat-treated thickness. A thermal buffer as described in NB-2212.2(c) may be used to achieve these conditions, unless cooling rates applicable to the bulk forgings are simulated as otherwise provided in NB-2212.2.

**NB-2223.2 Very Thick and Complex Forgings.** Test coupons for forgings which are both very thick and complex, such as contour nozzles, thick tubesheets, flanges, nozzles, pump and valve bodies, and other complex forgings that are contour shaped or machined to essentially the finished product configuration prior to heat treatment may be removed from prolongations or other stock provided on the product. The Certificate Holder shall specify the surfaces of the finished product subjected to high tensile stresses in service. The coupons shall be taken so that specimens shall have their longitudinal axes at a distance below the nearest heat-treated surface, equivalent at least to the greatest distance that the indicated high tensile stress surface will be from the nearest surface during heat treatment, and with the midlength of the specimens a minimum of twice this distance from a second heat-treated surface. In any case, the longitudinal axes of the specimens shall not be nearer than  $\frac{3}{4}$  in. (19 mm) to any heat-treated surface and the midlength of the specimens shall be at least  $1\frac{1}{2}$  in. (38 mm) from any second heat-treated surface.

**NB-2223.3 Coupons From Separately Produced Test Forgings.** Test coupons representing forgings from one heat and one heat treatment lot may be taken from a separately forged piece under the conditions given in (a) through (e) below.

(a) The separate test forging shall be of the same heat of material and shall be subjected to substantially the same reduction and working as the production forging it represents.

(b) The separate test forging shall be heat treated in the same furnace charge and under the same conditions as the production forging.

(c) The separate test forging shall be of the same nominal thickness as the production forging.

(d) Test coupons for simple forgings shall be taken so that specimens shall have their longitudinal axes at the region midway between midthickness and the surface, and with the midlength of the specimens no nearer any heat-treated edge than a distance equal to the forging thickness, except when the thickness-length ratio of the

production forging does not permit, in which case a production forging shall be used as the test forging and the midlength of the specimens shall be at the midlength of the test forging.

(e) Test coupons for complex forgings shall be taken in accordance with NB-2223.2.

**NB-2223.4 Test Specimens for Forgings.** When test specimens for forgings are to be taken under the applicable specification, the Inspector shall have the option of witnessing the selection, placing an identifying stamping on them, and witnessing the testing of these specimens.

## NB-2224 Bar and Bolting Material

(a) *Bars.* Coupons shall be taken so that specimens shall have their longitudinal axes at least  $\frac{1}{4}t$  from the outside or rolled surface and with the midlength of the specimens at least  $t$  from a heat-treated end, where  $t$  is either the bar diameter or thickness.

(b) *Bolting.* For bolting materials, tests shall be made of either full-size bolts or test coupons as required by the base specification. The gage length of the tension specimens and the area under the notch of Charpy specimens shall be at least one diameter or thickness from the heat-treated end.

## NB-2225 Tubular Products and Fittings

**NB-2225.1 Location of Coupons.** Coupons shall be taken so that specimens shall have their longitudinal axes at least  $\frac{1}{4}t$  from the inside or outside surface and with the midlength of the specimens at least  $t$  from a heat-treated end, where  $t$  is the nominal wall thickness of the tubular product.

**NB-2225.2 Separately Produced Coupons Representing Fittings.** Separately produced test coupons representing fittings may be used. When separately produced coupons are used, the requirements of NB-2223.3 shall be met.

## NB-2226 Tensile Test Specimen Location (for Quenched and Tempered Ferritic Steel Castings)

NOTE: Users of this requirement should note that the hardenability of some grades may limit the usable section size.

(a) This section applies only to quenched and tempered ferritic steel castings with a thickness  $t$  exceeding 2 in. (50 mm) where  $t$  is the thickness of the pressure-retaining wall of the casting, excluding flanges and sections designated by the designer as nonpressure-retaining. The order, inquiry, and drawing shall designate what the thickness  $t$  is for the casting.

(b) One of the following shall apply:

(1) The longitudinal centering of the thickness of the tension test specimen shall be taken at least  $\frac{1}{4}t$  from the  $t$  dimension surface. For cylindrical castings, the longitudinal center line of the specimens shall be taken at least  $\frac{1}{4}t$  from the outside or inside surface and the gage length at least  $t$  from the as-heat-treated end.

(2) Where separately cast test coupons are used, their dimensions shall be not less than  $3t \times 3t \times t$  and each specimen cut from it shall meet the requirements of (b)(1) above. The test coupon shall be of the same heat of steel and shall receive substantially the same casting practices as the production casting it represents. (Centrifugal castings may be represented by statically cast coupons.) The test coupon shall be heat treated under the same conditions as the production casting(s). The  $t$  dimension of the test coupon shall be the same maximum thickness  $t$  as defined in (a) above. Where separate test blocks require reheat treatment, thermal buffers in accordance with (b)(1) above may be used.

(3) Where specimens are to be removed from the body of the casting, a steel, thermal buffer pad  $1t \times 1t \times$  at least  $3t$  shall be joined to the casting surface by a partial penetration weld completely sealing the buffered surface prior to the heat treatment process. The test specimens shall be removed from the casting in a location adjacent to the center third of the buffer pad. They shall be located at a minimum distance of  $\frac{1}{2}$  in. (13 mm) from the buffered surface and  $\frac{1}{4}t$  from the other heat-treated surfaces.

(4) Where specimens are to be removed from the body of the casting, thermal insulation or other thermal barriers shall be used during the heat treatment process adjacent to the casting edge where specimens are to be removed. It shall be demonstrated that the cooling rate of the test specimen is no faster than that of specimens taken by the method described in (b)(1) above. This information shall be included in the test reports.

(5) Where castings are cast or machined to essentially the finished product configuration prior to heat treatment, the test specimens shall be removed from a casting prolongation or other stock on the product at a location below the nearest heat-treated surface indicated on the order. The specimens shall be located with their longitudinal axes a distance below the nearest heat-treated surface equivalent to at least the greatest distance that the indicated high tensile stress surface will be from the nearest heat-treated surface and with their midlength a minimum of twice this distance from a second heat-treated surface. In any case, the longitudinal axes of the test specimens shall be no nearer than  $\frac{1}{4}$  in. (6 mm) to a heat-treated surface and the midlength shall be at least  $1\frac{1}{2}$  in. (38 mm) from a second heat-treated surface. The component manufacturer shall specify the surfaces of the finished product subjected to high tensile stress in service.

## **NB-2300 FRACTURE TOUGHNESS REQUIREMENTS FOR MATERIAL**

### **NB-2310 MATERIAL TO BE IMPACT TESTED**

#### **NB-2311 Material for Which Impact Testing Is Required**

(a) Pressure-retaining material and material welded thereto shall be impact tested in accordance with the requirements of this Subarticle, except that the material listed in (1) through (7) below is not to be impact tested as a requirement of this Subsection:

(1) material with a nominal section thickness of  $\frac{5}{8}$  in. (16 mm) and less where the thicknesses shall be taken as defined in (-a) through (-e) below:

(-a) for pumps, valves, and fittings, use the largest nominal pipe wall thickness of the connecting pipes;

(-b) for vessels and tanks, use the nominal thickness of the shell or head, as applicable;

(-c) for nozzles or parts welded to vessels, use the lesser of the vessel shell thickness to which the item is welded or the maximum radial thickness of the item exclusive of integral shell butt welding projections;

(-d) for flat heads, tubesheets, or flanges, use the maximum shell thickness associated with the butt welding hub;

(-e) for integral fittings used to attach process piping to the containment vessel or a containment vessel nozzle, use the larger nominal thickness of the pipe connections;

(2) bolting, including studs, nuts, and bolts, with a nominal size of 1 in. (25 mm) and less

(3) bars with a nominal cross-sectional area of 1 in.<sup>2</sup> (650 mm<sup>2</sup>) and less;

(4) all thicknesses of material for a pipe, tube, fittings, pumps, and valves with a nominal pipe size NPS 6 (DN 150) and smaller;

(5) material for pumps, valves, and fittings with all pipe connections of  $\frac{5}{8}$  in. (16 mm) nominal wall thickness and less;

(6) austenitic stainless steels, including precipitation hardened austenitic Grade 660 (UNS S66286);

(7) nonferrous material.

(b) Drop weight tests are not required for the martensitic high alloy chromium (Series 4XX) steels and precipitation hardening steels listed in Section II, Part D, Subpart 1, Table 2A. The other requirements of NB-2332 apply for these steels. For nominal wall thicknesses greater than  $2\frac{1}{2}$  in. (64 mm), the required Charpy V-notch values shall be 40 mils (1 mm) lateral expansion.

## **NB-2320 IMPACT TEST PROCEDURES**

### **NB-2321 Types of Tests**

**NB-2321.1 Drop Weight Tests.** The drop weight test, when required, shall be performed in accordance with ASTM E208. Specimen types P-No. 1, P-No. 2, or P-No. 3

may be used. The results, orientation, and location of all tests performed to meet the requirements of NB-2330 shall be reported in the Certified Material Test Report.

**NB-2321.2 Charpy V-Notch Tests.** The Charpy V-notch test ( $C_v$ ), when required, shall be performed in accordance with SA-370. Specimens shall be in accordance with SA-370, Figure 11, Type A. A test shall consist of a set of three full-size 10 mm × 10 mm specimens. The lateral expansion and absorbed energy, as applicable, and the test temperature, as well as the orientation and location of all tests performed to meet the requirements of NB-2330 shall be reported in the Certified Material Test Report.

## NB-2322 Test Specimens

**NB-2322.1 Location of Test Specimens.** Impact test specimens for quenched and tempered material shall be removed from the locations in each product form specified in NB-2220 for tensile test specimens. For material in other heat-treated conditions, impact test specimens shall be removed from the locations specified for tensile test specimens in the material specification. For all material, the number of tests shall be in accordance with NB-2340. For bolting, the  $C_v$  impact test specimen shall be taken with the longitudinal axis of the specimen located at least one-half radius or 1 in. (25 mm) below the surface plus the machining allowance per side, whichever is less. The fracture plane of the specimens shall be at least one diameter or thickness from the heat-treated end. When the studs, nuts, or bolts are not of sufficient length, the midlength of the specimen shall be at the midlength of the studs, nuts, or bolts. The studs, nuts, or bolts selected to provide test coupon material shall be identical with respect to the quenched contour and size except for length, which shall equal or exceed the length of the represented studs, nuts, or bolts.

### NB-2322.2 Orientation of Impact Test Specimens.

(a) Specimens for  $C_v$  impact tests shall be oriented as follows:

(1) Specimens for forgings, other than bolting and bars used for pressure-retaining parts of vessels, pumps, and valves, shall be oriented in a direction normal to the principal direction in which the material was worked. Specimens are neither required nor prohibited from the thickness direction.

(2) Specimens from material for pipe, tube, and fittings, except for those made from plate and castings, shall be oriented in the axial direction. Specimens from pipe material used for nozzles in vessels shall be oriented in a direction normal to the principal direction in which the material was worked, other than the thickness direction.

(3) Specimens from bolting material and bars shall be oriented in the axial direction.

(4) Specimens for all plate material, including that used for pipe, tube, and fittings, shall be oriented in a direction normal to the principal rolling direction, other than thickness direction.

(5) Specimens for cast material shall have their axes oriented the same as the axes of the tensile specimens (NB-2226).

(6) In cases (1) through (5) above, the notch of the  $C_v$  specimen shall be normal to the surface of the material.

(b) Specimens for drop weight tests may have their axes oriented in any direction. The orientation used shall be reported in the Certified Material Test Report.

## NB-2330 TEST REQUIREMENTS AND ACCEPTANCE STANDARDS<sup>2</sup>

### NB-2331 Material for Vessels

Pressure-retaining material for vessels, other than bolting, shall be tested as follows:

(a) Establish a reference temperature  $RT_{NDT}$ ; this shall be done as follows:

(1) Determine a temperature  $T_{NDT}$  that is at or above the nil-ductility transition temperature by drop weight tests.

(2) At a temperature not greater than  $T_{NDT} + 60^\circ\text{F}$  ( $T_{NDT} + 33^\circ\text{C}$ ), each specimen of the  $C_v$  test (NB-2321.2) shall exhibit at least 35 mils (0.89 mm) lateral expansion and not less than 50 ft-lb (68 J) absorbed energy. Retesting in accordance with NB-2350 is permitted. When these requirements are met,  $T_{NDT}$  is the reference temperature  $RT_{NDT}$ .

(3) In the event that the requirements of (2) above are not met, conduct additional  $C_v$  tests in groups of three specimens (NB-2321.2) to determine the temperature  $T_{C_v}$  at which they are met. In this case the reference temperature  $RT_{NDT} = T_{C_v} - 60^\circ\text{F}$  ( $T_{C_v} - 33^\circ\text{C}$ ). Thus, the reference temperature  $RT_{NDT}$  is the higher of  $T_{NDT}$  and  $[T_{C_v} - 60^\circ\text{F}$  ( $T_{C_v} - 33^\circ\text{C}$ )].

(4) When a  $C_v$  test has not been performed at  $T_{NDT} + 60^\circ\text{F}$  ( $T_{NDT} + 33^\circ\text{C}$ ), or when the  $C_v$  test at  $T_{NDT} + 60^\circ\text{F}$  ( $T_{NDT} + 33^\circ\text{C}$ ) does not exhibit a minimum of 50 ft-lb (68 J) and 35 mils (0.89 mm) lateral expansion, a temperature representing a minimum of 50 ft-lb (68 J) and 35 mils (0.89 mm) lateral expansion may be obtained from a full  $C_v$  impact curve developed from the minimum data points of all the  $C_v$  tests performed.

(b) Apply the procedures of (a) to (1), (2), and (3) below:

(1) the base material;<sup>3</sup>

(2) the base material, the heat affected zone, and weld metal from the weld procedure qualification tests in accordance with NB-4330;

(3) the weld metal of NB-2431.

(c) Bars having a width or diameter of 2 in. (50 mm) and less which prohibit obtaining drop weight test specimens shall be tested in accordance with NB-2332.



(d) Some nozzles or appurtenances in vessels, regardless of product form, have insufficient material for obtaining impact tests after heat treatment (except postweld heat treatment). In this case, it is not necessary to perform both the drop weight and transverse  $C_v$  impact tests as required by (a). Instead, this material may be tested by only using axial  $C_v$  specimens. The three  $C_v$  specimens so removed shall be tested at a temperature lower than or equal to the lowest service temperature but no higher than the required  $RT_{NDT} + 60^\circ\text{F}$  ( $RT_{NDT} + 33^\circ\text{C}$ ) for the vessel material to which the nozzle or appurtenance is attached. Each specimen shall exhibit at least 35 mils (0.89 mm) lateral expansion and not less than 50 ft-lb (68 J) absorbed energy.

(e) Consideration shall be given to the effects of irradiation (NB-3124) on material toughness properties in the core belt line region of the reactor vessel. The Design Specifications shall include additional requirements, as necessary, to ensure adequate fracture toughness for the service lifetime of the vessel. The toughness properties may be verified in service periodically by a material surveillance program using the methods of ASTM E185 and the material conditions monitored by the inservice inspection requirements of Section XI.

(f) Consideration shall be given to the test temperature requirements of hydrostatic testing of the vessel (NB-6212).

### NB-2332 Material for Piping, Pumps, and Valves, Excluding Bolting Material

(a) Pressure-retaining material, other than bolting, with nominal wall thickness  $2\frac{1}{2}$  in. (64 mm) and less for piping (pipe and tubes) and material for pumps, valves, and fittings with all pipe connections of nominal wall thickness  $2\frac{1}{2}$  in. (64 mm) and less shall be tested as required in (1) and (2) below.

(1) Test three  $C_v$  specimens at a temperature lower than or equal to the lowest service temperature as established in the design specification (NB-3211). All three specimens shall meet the requirements of Table NB-2332(a)-1.

Table NB-2332(a)-1 Required $C_v$ Values for Piping, Pumps, and Valves	
Nominal Wall Thickness, in. (mm) [Note (1)]	Lateral Expansion, mils (mm)
$\frac{5}{8}$ (16) or less	No test required
Over $\frac{5}{8}$ to $\frac{3}{4}$ (16 to 19), incl.	20 (0.50)
Over $\frac{3}{4}$ to $1\frac{1}{2}$ (19 to 38), incl.	25 (0.64)
Over $1\frac{1}{2}$ to $2\frac{1}{2}$ (38 to 64), incl.	40 (1.00)
NOTE: (1) For pumps, valves, and fittings, use the nominal pipe wall thickness of the connecting piping.	

(2) Apply the procedures of (a) to

(-a) the base material;<sup>3</sup>

(-b) the base material, the heat-affected zone, and weld metal from the weld procedure qualification tests in accordance with NB-4330; and

(-c) the weld metal of NB-2431.

(b) Pressure-retaining material, other than bolting, with nominal wall thickness over  $2\frac{1}{2}$  in. (64 mm) for piping (pipe and tubes) and material for pumps, valves, and fittings with any pipe connections of nominal wall thickness greater than  $2\frac{1}{2}$  in. (64 mm) shall meet the requirements of NB-2331. The lowest service temperature shall not be lower than  $RT_{NDT} + 100^\circ\text{F}$  ( $56^\circ\text{C}$ ) unless a lower temperature is justified by following methods similar to those contained in Appendix G.

### NB-2333 Bolting Material

For bolting material, including studs, nuts, and bolts, test three  $C_v$  specimens at a temperature no higher than the preload temperature or the lowest service temperature, whichever is less. All three specimens shall meet the requirements of Table NB-2333-1.

### NB-2340 NUMBER OF IMPACT TESTS REQUIRED

#### NB-2341 Plates

One test shall be made from each plate as heat treated. Where plates are furnished in the unheat-treated condition and qualified by heat-treated test specimens, one test shall be made for each plate as-rolled. The term *as-rolled* refers to the plate rolled from a slab or directly from an ingot, not to its heat-treated condition.

#### NB-2342 Forgings and Castings

(a) Where the weight of an individual forging or casting is less than 1,000 lb (450 kg), one test shall be made to represent each heat in each heat treatment lot.

(b) When heat treatment is performed in a continuous type furnace with suitable temperature controls and equipped with recording pyrometers so that complete heat treatment records are available, a heat treatment charge shall be considered as the lesser of a continuous run not exceeding 8 hr duration or a total weight, so treated, not exceeding 2,000 lb (900 kg).

Table NB-2333-1 Required $C_v$ Values for Bolting Material		
Nominal Diameter, in. (mm)	Lateral Expansion, mils (mm)	Absorbed Energy, ft-lb (J)
1 (25) or less	No test required	No test required
Over 1 to 4 (25 to 100), incl.	25 (0.64)	No requirements
Over 4 (100)	25 (0.64)	45 (61)

(c) One test shall be made for each forging or casting of 1,000 lb (450 kg) to 10,000 lb (4 500 kg) in weight.

(d) As an alternative to (c), a separate test forging or casting may be used to represent forgings or castings of different sizes in one heat and heat treat lot, provided the test piece is a representation of the greatest thickness in the heat treat lot. In addition, test forgings shall have been subjected to substantially the same reduction and working as the forgings represented.

(e) Forgings or castings larger than 10,000 lb (4 500 kg) shall have two tests per part for Charpy V-notch and one test for drop weights. The location of drop weight or  $C_v$  impact test specimens shall be selected so that an equal number of specimens is obtained from positions in the forging or casting 180 deg apart.

(f) As an alternative to (e) for static castings, a separately cast test coupon [NB-2226(b)(2)] may be used; one test shall be made for Charpy V-notch and one test for drop weight.

#### NB-2343 Bars

One test shall be made for each lot of bars with cross-sectional area greater than 1 in.<sup>2</sup> (650 mm<sup>2</sup>), where a lot is defined as one heat of material heat treated in one charge or as one continuous operation, not to exceed 6,000 lb (2 700 kg).

#### NB-2344 Tubular Products and Fittings

On products which are seamless or welded without filler metal, one test shall be made from each lot. On products which are welded with filler metal, one additional test with the specimens taken from the weld area shall also be made on each lot. A lot shall be defined as stated in the applicable material specification, but in no case shall a lot consist of products from more than one heat of material and of more than one diameter, with the nominal thickness of any product included not exceeding that to be impact tested by more than  $\frac{1}{4}$  in. (6 mm); such a lot shall be in a single heat treatment load or in the same continuous run in a continuous furnace controlled within a 50°F (28°C) range and equipped with recording pyrometers.

#### NB-2345 Bolting Material

One test shall be made for each lot of material, where a lot is defined as one heat of material heat treated in one charge or as one continuous operation, not to exceed in weight (mass) the following:

Diameter	Weight
1 $\frac{3}{4}$ in. (44 mm) and less	1,500 lb (400 kg)
Over 1 $\frac{3}{4}$ in. to 2 $\frac{1}{2}$ in. (44 mm to 64 mm)	3,000 lb (1 350 kg)
Over 2 $\frac{1}{2}$ in. to 5 in. (64 mm to 125 mm)	6,000 lb (2 700 kg)
Over 5 in. (125 mm)	10,000 lb (4 500 kg)

#### NB-2346 Test Definitions

Unless otherwise stated in NB-2341 through NB-2345, the term *one test* is defined to include the combination of the drop weight test and the  $C_v$  test when  $RT_{NDT}$  is required [NB-2331 and NB-2332(b)] and only the  $C_v$  test when determination of  $RT_{NDT}$  is not required [NB-2332(a) and NB-2333].

#### NB-2350 RETESTS

(a) For  $C_v$  tests required by NB-2330, one retest at the same temperature may be conducted provided the requirements of (1) through (3) below are met:

(1) the average value of the test results meets the minimum requirements;

(2) not more than one specimen per test is below the minimum requirements;

(3) the specimen not meeting the minimum requirements is not lower than 10 ft-lb (14 J) or 5 mils (0.13 mm) below the specified requirements.

(b) A retest consists of two additional specimens taken as near as practicable to the failed specimens. For acceptance of the retest, both specimens shall meet the minimum requirements.

#### NB-2360 CALIBRATION OF INSTRUMENTS AND EQUIPMENT

Calibration of temperature instruments and  $C_v$  impact test machines used in impact testing shall be performed at the frequency given in (a) and (b) below.

(a) Temperature instruments used to control the test temperature of specimens shall be calibrated and the results recorded to meet the requirements of NCA-3858.2 at least once in each 3-month interval.

(b)  $C_v$  impact test machines shall be calibrated and the results recorded to meet the requirements of NCA-3858.2. The calibrations shall be performed using the frequency and methods outlined in ASTM E23 and employing standard specimens obtained from the National Institute of Standards and Technology, or any supplier of subcontracted calibration services accredited in accordance with the requirements of NCA-3126 and NCA-3855.3(c).

#### NB-2400 WELDING MATERIAL

##### NB-2410 GENERAL REQUIREMENTS

(a) All welding material used in the construction and repair of components or material, except welding material used for cladding or hard surfacing, shall conform to the requirements of the welding material specification or to the requirements for other welding material as permitted in Section IX. In addition, welding material shall conform to the requirements stated in this Subarticle and to the rules covering identification in NB-2150.

(b) The Certificate Holder shall provide the organization performing the testing with the information listed below, as applicable.

- (1) welding process;
- (2) SFA Specification and classification;
- (3) other identification if no SFA Specification applies;
- (4) minimum tensile strength [NB-2431.1(e)] in the as-welded or heat-treated condition or both [NB-2431.1(c)];
- (5) drop weight test for material as-welded or heat treated, or both (NB-2332);
- (6) Charpy V-notch test for material as-welded or heat treated, or both (NB-2331); the test temperature and the lateral expansion or the absorbed energy shall be provided;
- (7) the preheat and interpass temperatures to be used during welding of the test coupon [NB-2431.1(c)];
- (8) postweld heat treatment time, temperature range, and maximum cooling rate, if the production weld will be heat treated [NB-2431.1(c)];
- (9) elements for which chemical analysis is required per the SFA Specification or Welding Procedure Specification and NB-2432;
- (10) minimum delta ferrite (NB-2433).

## NB-2420 REQUIRED TESTS

The required tests shall be conducted for each lot of covered, flux cored, or fabricated electrodes; for each heat of bare electrodes, rod, or wire for use with the OFW, GMAW, GTAW, PAW, and EGW (electro gas welding) processes (Section IX, QW-492); for each heat of consumable inserts; for each combination of heat of bare electrodes and lot of submerged arc flux; for each combination of lot of fabricated electrodes and lot of submerged arc flux; for each combination of heat of bare electrodes or lot of fabricated electrodes, and dry blend of supplementary powdered filler metal, and lot of submerged arc flux; or for each combination of heat of bare electrodes and lot of electros slag flux. Tests performed on welding material in the qualification of weld procedures will satisfy the testing requirements for the lot, heat, or combination of heat and batch of welding material used, provided the tests required by NB-4000 and this Subarticle are made and the results conform to the requirements of this Article. The definitions in (a) through (h) below apply.

(a) A *dry batch of covering mixture* is defined as the quantity of dry covering ingredients mixed at one time in one mixing vessel; a dry batch may be used singly or may be subsequently subdivided into quantities to which the liquid binders may be added to produce a number of wet mixes [(c) below].

(b) A *dry blend* is defined as one or more dry batches mixed in a mixing vessel and combined proportionately to produce a uniformity of mixed ingredients equal to that obtained by mixing the same total amount of dry ingredients at one time in one mixing vessel.

(c) A *wet mix* is defined as the combination of a dry batch or dry blend [(a) and (b) above, respectively], and liquid binder ingredients at one time in one mixing vessel.

(d) A *lot of covered, flux-cored, or fabricated electrodes* is defined as the quantity of electrodes produced from the same combination of heat of metal and dry batch, dry blend, or chemically controlled mixes of flux or core materials. Alternatively, a lot of covered, flux-cored, or fabricated electrodes may be considered one type and size of electrode, produced in a continuous period, not to exceed 24 hr and not to exceed 100,000 lb (45,000 kg), from chemically controlled tube, wire, or strip and a dry batch, a dry blend, or chemically controlled mixes of flux, provided each container of welding material is coded for identification and traceable to the production period, the shift, line, and the analysis range of both the mix and the rod, tube, or strip used to make the electrode.

(1) *Chemically controlled tube, wire, or strip* is defined as consumable tube, wire, or strip material supplied on coils with a maximum of one splice per coil that has been chemically analyzed to ensure that the material conforms to the electrode manufacturer's chemical control limits for the specific type of electrode. Both ends of each coil shall be chemically analyzed, except that those coils which are splice free need only be analyzed on one end of the coil.

(2) *Chemically controlled mixes of flux* are defined as flux material that has been chemically analyzed to ensure that it conforms to the percent allowable variation from the electrode manufacturer's standard for each chemical element for that type electrode. A chemical analysis shall be made on each mix made in an individual mixing vessel after blending.

(e) A *heat of bare electrode, rod, wire, or consumable insert* is defined as the material produced from the same melt of metal.

(f) Alternatively, for carbon and low alloy steel bare electrode, rod, wire, or consumable inserts for use with SAW, OFW, GMAW, GTAW, PAW, and EGW processes, a *heat* may be defined as either the material produced from the same melt of metal or the material produced from one type and size of wire when produced in a continuous period [not to exceed 24 hr and not to exceed 100,000 lb (45,000 kg)] from chemically controlled wire, subject to requirements of (1), (2), and (3) below.

(1) For the chemical control of the product of the rod mill, coils shall be limited to a maximum of one splice prior to processing the wire. Chemical analysis shall be made from a sample taken from both ends of each coil of mill-coiled rod furnished by mills permitting spliced coil practice of one splice maximum per coil. A chemical analysis need be taken from only one end of rod coils furnished by mills prohibiting spliced coil practice.

(2) Carbon, manganese, silicon, and other intentionally added elements shall be identified to ensure that the material conforms to the SFA or user's material specification.

(3) Each container of wire shall be coded for identification and traceability to the lot, production period, shift, line, and analysis of rod used to make the wire.

(g) A lot of submerged arc or electroslag flux is defined as the quantity of flux produced from the same combination of raw materials under one production schedule.

(h) A dry blend of supplementary powdered filler metal is defined as one or more mixes of material produced in a continuous period, not to exceed 24 hr and not to exceed 20,000 lb (9 000 kg) from chemically controlled mixes of powdered filler metal, provided each container of powdered metal is coded for identification and traceable to the production period, the shift, and the mixing vessel. A chemically controlled mix of powdered filler metal is defined as powdered filler metal material that has been chemically analyzed to assure that it conforms to the percent allowable variation from the powdered filler metal manufacturer's standard, for each chemical element, for that type of powdered filler metal. A chemical analysis shall be made on each mix made in an individual mixing vessel after blending. The chemical analysis range of the supplemental powdered filler shall be the same as that of the welding electrode, and the ratio of powder to electrode used to make the test coupon shall be the maximum permitted for production welding.

## NB-2430 WELD METAL TESTS

### NB-2431 Mechanical Properties Test

Tensile and impact tests shall be made, in accordance with this paragraph, of welding materials which are used to join P-Nos. 1, 3, 4, 5, 6, 7, 9, and 11 base materials in any combination, with the exceptions listed in (a) through (d) below:

(a) austenitic stainless steel and nonferrous welding material used to join the listed P-Numbers;

(b) consumable inserts (backing filler material);

(c) welding material used for GTAW root deposits with a maximum of two layers;

(d) welding material to be used for the welding of base material exempted from impact testing by NB-2311 shall likewise be exempted from the impact testing required by NB-2330 and this paragraph.

**NB-2431.1 General Test Requirements.** The welding test coupon shall be made in accordance with (a) through (f) below, using each process with which the weld material will be used in production welding.

(a) Test coupons shall be of sufficient size and thickness such that the test specimens required herein can be removed.

(b) The weld metal to be tested for all processes except electroslag welding shall be deposited in such a manner as to eliminate substantially the influence of the base material on the results of the tests. Weld metal to be used with the electroslag process shall be deposited in such a manner as to conform to one of the applicable Welding Proce-

dures Specifications (WPS) for production welding. The base material shall conform to the requirements of Section IX, QW-403.1 or QW-403.4, as applicable.

(c) The welding of the test coupon shall be performed within the range of preheat and interpass temperatures that will be used in production welding. Coupons shall be tested in the as-welded condition, or they shall be tested in the applicable postweld heat-treated condition when the production welds are to be postweld heat treated. The postweld heat treatment holding time<sup>1</sup> shall be at least 80% of the maximum time to be applied to the weld metal in production application. The total time for postweld heat treatment of the test coupon may be applied in one heating cycle. The cooling rate from the postweld heat treatment temperature shall be of the same order as that applicable to the weld metal in the component. In addition, weld coupons for weld metal to be used with the electroslag process, which are tested in the as-welded condition or following a postweld heat treatment within the holding temperature ranges of Tables NB-4622.1-1 or NB-4622.4(c)-1, shall have a thickness within the range of 0.5 to 1.1 times the thickness of the welds to be made in production. Electroslag weld coupons to be tested following a postweld heat treatment, which will include heating the coupon to a temperature above the Holding Temperature Range of Table NB-4622.1-1 for the type of material being tested, shall have a thickness within the range of 0.9 to 1.1 times the thickness of the welds to be made in production.

(d) The tensile specimens, and the C<sub>v</sub> impact specimens where required, shall be located and prepared in accordance with the requirements of SFA-5.1 or the applicable SFA specification. Drop weight impact test specimens, where required, shall be oriented so that the longitudinal axis is transverse to the weld with the notch in the weld face or in a plane parallel to the weld face. For impact specimen preparation and testing, the applicable parts of NB-2321.1 and NB-2321.2 shall apply. The longitudinal axis of the specimen shall be at a minimum depth of  $\frac{1}{4}t$  from a surface, where  $t$  is the thickness of the test weld.

(e) One all weld metal tensile specimen shall be tested and shall meet the specified minimum tensile strength requirements of the base material specification. When base materials of different specifications are to be welded, the tensile strength requirements shall conform to the specified minimum tensile strength requirements of either of the base material specifications.

(f) Impact specimens of the weld metal shall be tested where impact tests are required for either of the base materials of the production weld. The weld metal shall conform to the parts of NB-2331(a) or NB-2332 applicable to the base material. Where different requirements exist for the two base materials, the weld metal may conform to either of the two requirements.



**NB-2431.2 Standard Test Requirements.** In lieu of the use of the General Test Requirements specified in [NB-2431.1](#), tensile and impact tests may be made in accordance with this subparagraph where they are required for mild and low alloy steel covered electrodes; the material combinations to require weld material testing, as listed in [NB-2431](#), shall apply for this Standard Test Requirements option. The limitations and testing under this Standard Test option shall be in accordance with (a) through (f) below.

(a) Testing to the requirements of this subparagraph shall be limited to electrode classifications included in Specifications SFA-5.1 or SFA-5.5.

(b) The test assembly required by SFA-5.1 or SFA-5.5, as applicable, shall be used for test coupon preparation, except that it shall be increased in size to obtain the number of  $C_v$  specimens and the drop weight test specimens required by [NB-2331\(a\)](#) or [NB-2332](#), where applicable.

(c) The welding of the test coupon shall conform to the requirements of the SFA Specification for the classification of electrode being tested. Coupons shall be tested in the as-welded condition and also in the postweld heat-treated condition. The PWHT temperatures shall be in accordance with [Table NB-4622.1-1](#) for the applicable P-Number equivalent. The time at PWHT temperature shall be 8 hr. (This qualifies PWHT of 10 hr or less.) When the PWHT of the production weld exceeds 10 hr, or the PWHT temperature is other than that required above, the general test of [NB-2431.1](#) shall be used.

(d) The tensile and  $C_v$  specimens shall be located and prepared in accordance with the requirements of SFA-5.1 or SFA-5.5, as applicable. Drop weight impact test specimens, where required, shall be located and oriented as specified in [NB-2431.1\(d\)](#).

(e) One all weld metal tensile specimen shall be tested and shall meet the specified minimum tensile strength requirement of the SFA Specification for the applicable electrode classification.

(f) The requirements of [NB-2431.1\(f\)](#) shall be applicable to the impact testing of this option.

## NB-2432 Chemical Analysis Test

Chemical analysis of filler metal or weld deposits shall be made in accordance with [NB-2420](#) and as required by the following subparagraphs.

**NB-2432.1 Test Method.** The chemical analysis test shall be performed in accordance with this subparagraph and [Table NB-2432.1-1](#), and the results shall conform to [NB-2432.2](#).

(a) A-No. 8 welding material to be used with GTAW and PAW processes and any other welding material to be used with any GTAW, PAW, or GMAW process shall have chemical analysis performed either on the filler metal or on a weld deposit made with the filler metal in accordance with (c) or (d) below.

**Table NB-2432.1-1  
Sampling of Welding Materials for Chemical Analysis**

	GTAW/PAW	GMAW	All Other Processes
A-No. 8 filler metal	Filler metal or weld deposit	Weld deposit	Weld deposit
All other filler metal	Filler metal or weld deposit	Filler metal or weld deposit	Weld deposit

(b) A-No. 8 welding material to be used with other than the GTAW and PAW processes and other welding material to be used with other than the GTAW, PAW, or GMAW process shall have chemical analysis performed on a weld deposit of the material or combination of materials being certified in accordance with (c) or (d) below. The removal of chemical analysis samples shall be from an undiluted weld deposit made in accordance with (c) below. As an alternative, the deposit shall be made in accordance with (d) below for material that will be used for corrosion-resistant overlay cladding. Where the Welding Procedure Specification or the welding material specification specifies percentage composition limits for analysis, it shall state that the specified limits apply for the filler metal analysis, the undiluted weld deposit analysis, or *in situ* cladding deposit analysis in conformance with the above required certification testing.

(c) The preparation of samples for chemical analysis of undiluted weld deposits shall comply with the method given in the applicable SFA Specification. Where a weld deposit method is not provided by the SFA specification, the sample shall be removed from a weld pad, groove, or other test weld<sup>4</sup> made using the welding process that will be followed when the welding material or combination of welding materials being certified is consumed. The weld for A-No. 8 material to be used with the GMAW or EGW process shall be made using the shielding gas composition specified in the Welding Procedure Specifications that will be followed when the material is consumed. The test sample for ESW shall be removed from the weld metal of the mechanical properties test coupon. Where a chemical analysis is required for a welding material which does not have a mechanical properties test requirement, a chemical analysis test coupon shall be prepared as required by [NB-2431.1\(c\)](#), except that heat treatment of the coupon is not required and the weld coupon thickness requirements of [NB-2431.1\(c\)](#) do not apply.

(d) The alternative method provided in (b) above for the preparation of samples for chemical analysis of welding material to be used for corrosion resistant overlay cladding shall require a test weld made in accordance with the essential variables of the Welding Procedure

Specification that will be followed when the welding material is consumed. The test weld shall be made in conformance with the requirements of Section IX, QW-214.1. The removal of chemical analysis samples shall conform with QW-453 for the minimum thickness for which the welding procedure specification is qualified.

#### **NB-2432.2 Requirements for Chemical Analysis.**

The chemical elements to be determined, the composition requirements of the weld metal, and the recording of results of the chemical analysis shall be in accordance with (a) through (c) below.

(a) See below.

(1) All welding material to be used in the reactor vessel shall be analyzed for the elements listed in [Table NB-2432.2\(a\)-1](#).

(2) All welding material of ferrous alloys A-No. 8 and A-No. 9 (Section IX, QW-442) to be used in other components shall be analyzed for the elements listed in [Table NB-2432.2\(a\)-2](#) and for any other elements specified in the welding material specification referenced by the WPS or in the WPS.

(3) All other welding material shall be analyzed for the elements specified in either the welding material specification referenced by the WPS or in the WPS.

(b) The chemical composition of the weld metal or filler metal shall conform to the welding material specification for elements having specified percentage composition limits. Where the Welding Procedure Specification contains a modification of the composition limits of SFA or other referenced welding material specifications, or provides limits for additional elements, these composition limits of the welding procedure specification shall apply for acceptability.

(c) The results of the chemical analysis shall be reported in accordance with NCA-3862.1. Elements listed in [Table NB-2432.2\(a\)-1](#) or [Table NB-2432.2\(a\)-2](#) but not specified in the welding material specification or WPS shall be reported for information only.

#### **NB-2433 Delta Ferrite Determination**

A determination of delta ferrite shall be performed on A-No. 8 weld material (Section IX, QW-442) backing filler metal (consumable inserts); bare electrode, rod, or wire filler metal; or weld metal, except that delta ferrite deter-

**Table NB-2432.2(a)-2  
Chemical Analysis for Welding Material for  
Other Than Reactor Vessel Welds**

Material	Elements
Chromium-Nickel	C, Cr, Mo, Ni, Mn, Si, Cb
stainless steels	+ Ta

minations are not required for SFA-5.9 and SFA-5.4, Type 16-8-2, or A-No. 8 weld filler metal to be used for weld metal cladding.

**NB-2433.1 Method.** Delta ferrite determinations of welding material, including consumable insert material, shall be made using a magnetic measuring instrument and weld deposits made in accordance with (b) below. Alternatively, the delta ferrite determinations for welding materials may be performed by the use of chemical analysis of [NB-2432](#) in conjunction with [Figure NB-2433.1-1](#).

(a) Calibration of magnetic instruments shall conform to AWS-A4.2.

(b) The weld deposit for magnetic delta ferrite determination shall be made in accordance with [NB-2432.1\(c\)](#).

(c) A minimum of six ferrite readings shall be taken on the surface of the weld deposit. The readings obtained shall be averaged to a single Ferrite Number (FN).

**NB-2433.2 Acceptance Standards.** The minimum acceptable delta ferrite shall be 5FN. The results of the delta ferrite determination shall be included in the Certified Material Test Report of [NB-2130](#) or [NB-4120](#).

#### **NB-2440 STORAGE AND HANDLING OF WELDING MATERIAL**

Suitable storage and handling of electrodes, flux, and other welding material shall be maintained. Precautions shall be taken to minimize absorption of moisture by fluxes and cored, fabricated, and coated electrodes.

#### **NB-2500 EXAMINATION AND REPAIR OF PRESSURE-RETAINING MATERIAL**


##### **NB-2510 EXAMINATION OF PRESSURE-RETAINING MATERIAL**

(a) Pressure-retaining material and material welded thereto shall be examined by nondestructive methods applicable to the material and product form as required by the rules of this Subarticle, except for pumps and valves with inlet piping connections NPS 2 (DN 50) and less. Seamless pipe, tubes, and fittings, NPS 1 (DN 25) and less, need not be examined by the rules of this Subarticle. The NPS 1 (DN 25) size exemption does not apply to heat exchanger tubing.

**Table NB-2432.2(a)-1  
Chemical Analysis for Reactor Vessel Welding  
Material**

Materials	Elements
Carbon and low alloy materials	C, Cr, Mo, Ni, Mn, Si, P, S, V, Cu
Chromium and Cr-Ni stainless material	C, Cr, Mo, Ni, Mn, Si, P, S, V, Cb + Ta, Ti, Cu

**Figure NB-2433.1-1**  
**Weld Metal Delta Ferrite Content**



**GENERAL NOTES:**

- (a) The actual nitrogen content is preferred. If this is not available, the following applicable nitrogen value shall be used:
- (1) GMAW welds—0.08%, except that when self-shielding flux cored electrodes are used—0.12%.
  - (2) Welds made using other processes—0.06%.
- (b) This diagram is identical to the WRC-1992 Diagram, except that the solidification mode lines have been removed for ease of use.

(b) For forged and cast pumps and valves with inlet piping connections over NPS 2 (DN 50), up to and including NPS 4 (DN 100), magnetic particle or liquid penetrant examinations may be performed in lieu of volumetric examination, except that the welding ends for cast pumps and valves shall be radiographed for a minimum distance of  $t$  (when  $t$  is the design section thickness of the weld) from the final welding end.

(c) The requirements of this Subarticle for repair by welding, including examination of the repair welds, shall be met wherever repair welds are made to pressure-retaining material and material welded thereto. The exceptions in (a) and (b) above do not apply to repair welds.

**NB-2520 EXAMINATION AFTER QUENCHING AND TEMPERING**

Ferritic steel products that have their properties enhanced by quenching and tempering shall be examined by the methods specified in this Subarticle for each product form after the quenching and tempering phase of the heat treatment.

**NB-2530 EXAMINATION AND REPAIR OF PLATE**

**NB-2531 Required Examination**

All plates 2 in. (50 mm) nominal thickness and less used for piping, pumps, and valves shall be examined by the angle beam ultrasonic method in accordance with NB-2532.2. All plates for vessels and all plates greater than 2 in. (50 mm) thickness shall be examined by the straight beam ultrasonic method in accordance with NB-2532.1.



**NB-2532 Examination Procedures**

**NB-2532.1 Straight Beam Examination.** The requirements for straight beam examination shall be in accordance with SA-578, Specification for Straight Beam Wave Ultrasonic Testing and Inspection of Plain and Clad Steel Plates for Special Applications, as shown in Section V, except that the extent of examination and the acceptance standards to be applied are given in (a) and (b) below.

(a) *Extent of Examination.* One hundred percent of one major plate surface shall be covered by moving the search unit in parallel paths with not less than a 10% overlap.

(b) *Acceptance Standards*

(1) Any area where one or more imperfections produce a continuous total loss of back reflection accompanied by continuous indications on the same plane that cannot be encompassed within a circle whose diameter is 3 in. (75 mm) or one-half of the plate thickness, whichever is greater, is unacceptable.

(2) In addition, two or more imperfections smaller than described in (1) above shall be unacceptable unless separated by a minimum distance equal to the greatest diameter of the larger imperfection, or unless they may be collectively encompassed by the circle described in (1) above.

**NB-2532.2 Angle Beam Examination.** The requirements for angle beam examination shall be in accordance with SA-577, Specification for Ultrasonic Beam Wave Inspection of Steel Plates, as shown in Section V and supplemented by (a) and (b) below. The calibration notch, extent of examination, and acceptance standards to be applied are given in (a) through (c) below.

(a) *Calibration.* Angle beam examination shall be calibrated from a notch.

(b) *Extent of Examination.* One hundred percent of one major plate surface shall be covered by moving the search unit in parallel paths with not less than 10% overlap.

(c) *Acceptance Standards.* Material which shows one or more imperfections which produce indications exceeding in amplitude the indication from the calibration notch is unacceptable unless additional exploration by the straight beam method shows the imperfections are laminar in nature and are acceptable in accordance with NB-2532.1(b).

**NB-2537 Time of Examination**

Acceptance examinations shall be performed at the time of manufacture as required in (a) through (c) below.

(a) Ultrasonic examination shall be performed after rolling to size and after heat treatment, except for postweld heat treatment.

(b) Radiographic examination of repair welds, when required, may be performed prior to any required postweld heat treatment.

(c) Magnetic particle or liquid penetrant examination of repair welds shall be performed after final heat treatment, except that the examination may be performed prior to postweld heat treatment of P-No.1 material 2 in. (50 mm) and less nominal thickness.

**NB-2538 Elimination of Surface Defects**

Surface defects shall be removed by grinding or machining, provided the requirements of (a) through (d) below are met.

(a) The depression, after defect elimination, is blended uniformly into the surrounding surface.

(b) After defect elimination, the area is examined by the magnetic particle method in accordance with NB-2545 or the liquid penetrant method in accordance with NB-2546 to ensure that the defect has been removed or reduced to an imperfection of acceptable size.

(c) Areas ground to remove oxide scale or other mechanically caused impressions for appearance or to facilitate proper ultrasonic testing need not be examined by the magnetic particle or liquid penetrant test method.

(d) When the elimination of the defect reduces the thickness of the section below the minimum required to satisfy Article NB-3000, the product shall be repaired in accordance with NB-2539.

**NB-2539 Repair by Welding**

The Material Organization may repair by welding material from which defects have been removed, provided the depth of the repair cavity does not exceed one-third the nominal thickness and the requirements of the following subparagraphs are met. Prior approval of the Certificate Holder shall be obtained for the repair of plates to be used in the manufacture of vessels.

**NB-2539.1 Defect Removal.** The defect shall be removed or reduced to an imperfection of acceptable size by suitable mechanical or thermal cutting or gouging methods and the cavity prepared for repair (NB-4211.1).

**NB-2539.2 Qualification of Welding Procedures and Welders.** The welding procedure and welders or welding operators shall be qualified in accordance with Article NB-4000 and Section IX.

**NB-2539.3 Blending of Repaired Areas.** After repair, the surface shall be blended uniformly into the surrounding surface.

**NB-2539.4 Examination of Repair Welds.** Each repair weld shall be examined by the magnetic particle method (NB-2545) or by the liquid penetrant method (NB-2546). In addition, when the depth of the repair cavity exceeds the lesser of  $\frac{3}{8}$  in. (10 mm) or 10% of the section thickness, the repair weld shall be radiographed after repair in accordance with NB-5110 and to the acceptance standards of NB-5320. The image quality indicator (IQI)

and the acceptance standards for radiographic examination of repair welds shall be based on the section thickness at the repair area.

**NB-2539.5 Heat Treatment After Repairs.** The product shall be heat treated after repair in accordance with the heat treatment requirements of [NB-4620](#).

**NB-2539.6 Material Report Describing Defects and Repairs.** Each defect repair exceeding in depth the lesser of  $\frac{3}{8}$  in. (10 mm) or 10% of the section thickness shall be described in the Certified Material Test Report. The Certified Material Test Report for each piece shall include a chart which shows the location and size of the prepared cavity, the welding material identification, the welding procedure, the heat treatment, and the examination results, including radiographs.

**NB-2539.7 Repair of Cladding by Welding.** The Material Organization may repair defects in cladding by welding, provided the requirements of (a) through (d) below are met.

(a) *Qualification of Welding Procedures and Welders.* The welding procedure and the welders or welding operators shall be qualified in accordance with [Article NB-4000](#) and with Section IX.

(b) *Defect Removal and Examination of Cavity.* The defect shall be removed, and the cavity prepared for repair shall be examined by the liquid penetrant method ([NB-2546](#)).

(c) *Examination of Repaired Areas.* The repaired area shall be examined by a liquid penetrant method ([NB-2546](#)).

(d) *Report of Repairs.* Each defect repair shall be described in the Certified Material Test Report for each piece, including a chart which shows the location and size of the repair, the welding material identification, welding procedure, heat treatment, and examination results.

## **NB-2540 EXAMINATION AND REPAIR OF FORGINGS AND BARS**

### **NB-2541 Required Examinations**

(a) Forgings and bars shall be examined by the ultrasonic method in accordance with [NB-2542](#), except forgings or sections of forgings which have coarse grains, or configurations which do not yield meaningful examination results by ultrasonic methods, shall be examined by radiographic methods in accordance with Section V, Article 2, using the acceptance standards of [NB-5320](#). In addition, all external surfaces and accessible internal surfaces shall be examined by a magnetic particle method ([NB-2545](#)) or a liquid penetrant method ([NB-2546](#)).

(b) Forged flanges and fittings, such as elbows, tees, and couplings, shall be examined in accordance with the requirements of [NB-2550](#).

(c) Bar material used for bolting shall be examined in accordance with [NB-2580](#).

(d) Forgings and forged or rolled bars which are to be bored to form tubular products or fittings shall be examined in accordance with the requirements of [NB-2550](#) after boring.

(e) Forgings and forged or rolled bars, which will subsequently be bored to form pump and valve parts, shall be examined in accordance with (a) after boring.

### **NB-2542 Ultrasonic Examination**

**NB-2542.1 Examination Procedure.** All forgings in the rough-forged or finished condition, and bars, shall be examined in accordance with Article 5 of Section V and the following supplemental requirements. The techniques of (a) through (d) below are required, as applicable.

(a) Forgings may be examined by the use of alternative ultrasonic methods which utilize distance amplitude corrections, provided the acceptance standards are shown to be equivalent to those listed in [NB-2542.2](#).

(b) Cylindrical section bars shall be scanned from the entire external circumference.

(c) Noncylindrical section bars shall be scanned in two perpendicular directions to the maximum extent possible (through each pair of parallel sides).

(d) Bar products do not require recording and reporting of indications smaller than the acceptance standard, except when so specified for specialized applications.

### **NB-2542.2 Acceptance Standards.**

(a) *Straight Beam General Rule.* A forging shall be unacceptable if the results of straight beam examinations show one or more reflectors which produce indications accompanied by a complete loss of back reflection not associated with or attributable to geometric configurations. Complete loss of back reflection is assumed when the back reflection falls below 5% of full calibration screen height.

(b) *Straight Beam Special Rule for Vessel Shell Sections*

(1) A ring forging made to fine grain melting practice and used for vessel shell sections shall be unacceptable if the results of the straight beam radial examination show one or more reflectors producing a continuous complete loss of back reflection accompanied by continuous indications on the same plane that cannot be encompassed with a circle whose diameter is 3 in. (75 mm) or one-half of the wall thickness, whichever is greater.

(2) In addition, two or more reflectors smaller than described in (1) above shall be unacceptable unless separated by a minimum distance equal to the greatest diameter of the larger reflector or unless they may be collectively encompassed by the circle described in (1) above.

(c) *Angle Beam Rule.* A forging shall be unacceptable if the results of angle beam examinations show one or more reflectors which produce indications exceeding in amplitude the indication from the appropriate calibration notches.

**NB-2545 Magnetic Particle Examination**

**NB-2545.1 Examination Procedure.** The procedure for magnetic particle examination shall be in accordance with the methods of Article 7, Section V. In lieu of magnetic particle examination methods required by the material specification, magnetic particle examination using the alternating current yoke technique is permitted in accordance with Article 7, Section V, when performed on final machined surfaces of the material.

**NB-2545.2 Evaluation of Indications.**

(a) Mechanical discontinuities at the surface are revealed by the retention of the examination medium. All indications are not necessarily defects, however, since certain metallurgical discontinuities and magnetic permeability variations may produce similar indications which are not relevant.

(b) Any indication in excess of the NB-2545.3 acceptance standards, which is believed to be nonrelevant, shall be reexamined by the same or other nondestructive examination methods to verify whether or not actual defects are present. Surface conditioning may precede the reexamination. Nonrelevant indications which would mask defects are unacceptable.

(c) Relevant indications are indications which result from imperfections. Linear indications are indications in which the length is more than three times the width. Rounded indications are indications which are circular or elliptical with the length equal to or less than three times the width.

**NB-2545.3 Acceptance Standards.**

(a) Only imperfections producing indications with major dimensions greater than  $\frac{1}{16}$  in. (1.5 mm) shall be considered relevant imperfections.

(b) Imperfections producing the following relevant indications are unacceptable:

(1) any linear indications greater than  $\frac{1}{16}$  in. (1.5 mm) long for material less than  $\frac{5}{8}$  in. (16 mm) thick, greater than  $\frac{1}{8}$  in. (3 mm) long for material from  $\frac{5}{8}$  in. (16 mm) thick to under 2 in. (50 mm) thick, and  $\frac{3}{16}$  in. (5 mm) long for material 2 in. (50 mm) thick and greater;

(2) rounded indications with dimensions greater than  $\frac{1}{8}$  in. (3 mm) for thicknesses less than  $\frac{5}{8}$  in. (16 mm) and greater than  $\frac{3}{16}$  in. (5 mm) for thicknesses  $\frac{5}{8}$  in. (16 mm) and greater;

(3) four or more relevant indications in a line separated by  $\frac{1}{16}$  in. (1.5 mm) or less edge to edge;

(4) ten or more relevant indications in any 6 in.<sup>2</sup> (4 000 mm<sup>2</sup>) of area whose major dimension is no more than 6 in. (150 mm) with the dimensions taken in the most unfavorable location relative to the indications being evaluated.

**NB-2546 Liquid Penetrant Examination**

**NB-2546.1 Examination Procedure.** The procedure for liquid penetrant examination shall be in accordance with the methods of Section V, Article 6.

**NB-2546.2 Evaluation of Indications.**

(a) Mechanical discontinuities at the surface are revealed by bleeding out of the penetrant; however, localized surface discontinuities, such as may occur from machining marks, surface conditions, or an incomplete bond between base metal and cladding, may produce similar indications which are not relevant.

(b) Any indication in excess of the NB-2546.3 acceptance standards, which is believed to be nonrelevant, shall be reexamined to verify whether or not actual defects are present. Surface conditioning may precede the reexamination. Nonrelevant indications and broad areas of pigmentation, which would mask defects, are unacceptable.

(c) Relevant indications are indications which result from imperfections. Linear indications are indications in which the length is more than three times the width. Rounded indications are indications which are circular or elliptical with the length equal to or less than three times the width.

**NB-2546.3 Acceptance Standards.**

(a) Only imperfections producing indications with major dimensions greater than  $\frac{1}{16}$  in. (1.5 mm) shall be considered relevant imperfections.

(b) Imperfections producing the following relevant indications are unacceptable:

(1) any linear indications greater than  $\frac{1}{16}$  in. (1.5 mm) long for material less than  $\frac{5}{8}$  in. (16 mm) thick, greater than  $\frac{1}{8}$  in. (3 mm) long for material from  $\frac{5}{8}$  in. (16 mm) thick to under 2 in. (50 mm) thick, and  $\frac{3}{16}$  in. (5 mm) long for material 2 in. (50 mm) thick and greater;

(2) rounded indications with dimensions greater than  $\frac{1}{8}$  in. (3 mm) for thicknesses less than  $\frac{5}{8}$  in. (16 mm) and greater than  $\frac{3}{16}$  in. (5 mm) for thicknesses  $\frac{5}{8}$  in. (16 mm) and greater;

(3) four or more relevant indications in a line separated by  $\frac{1}{16}$  in. (1.5 mm) or less edge to edge;

(4) ten or more relevant indications in any 6 in.<sup>2</sup> (4 000 mm<sup>2</sup>) of area whose major dimension is no more than 6 in. (150 mm) with the dimensions taken in the most unfavorable location relative to the indications being evaluated.

**NB-2547 Time of Examination**

Acceptance examinations, including those for repair welds, shall be performed at the time of manufacture as required in (a) through (f) below.

(a) Ultrasonic examination may be performed at any time after forging [NB-2541(d)], and the maximum practical volume, including weld repairs, if required, shall be examined after final heat treatment, excluding postweld heat treatment.

(b) Radiographic examination of repair welds, if required, may be performed prior to any required postweld heat treatment.

(c) Magnetic particle or liquid penetrant examination shall be performed in the finished condition, except repair welds of P-No. 1 material, 2 in. (50 mm) nominal thickness and less, may be examined prior to postweld heat treatment.

(d) Forgings and rolled bars which are to be bored or turned to form tubular parts or fittings shall be examined after boring or turning, except for threading.

(e) Forgings and forged or rolled bars which will subsequently be bored or turned to form pump and valve parts shall be examined after boring or turning, except for threading.

(f) The requirement for surface examination may be postponed for bars, 1 in. (25 mm) and less in diameter, [NB-2541(a)] for material used to fabricate tube plugs for heat exchangers. Bar material, 1 in. (25 mm) and less in diameter, shall be surface-examined after final machining into tube plugs for heat exchangers.

#### **NB-2548 Elimination of Surface Defects**

Elimination of surface defects shall be made in accordance with NB-2538.

#### **NB-2549 Repair by Welding**

Repair by welding shall be in accordance with NB-2539, except that:

(a) the depth of repair that is permitted is not limited; and

(b) for ferritic steel forgings, the completed repair may be examined by the ultrasonic method in accordance with the requirements of NB-2542 in lieu of radiography.

#### **NB-2550 EXAMINATION AND REPAIR OF SEAMLESS AND WELDED (WITHOUT FILLER METAL) TUBULAR PRODUCTS AND FITTINGS**

##### **NB-2551 Required Examination**

In addition to the requirements of the material specification and of this Article, seamless and welded (without filler metal) tubular products (including pipe flanges and fittings machined from forgings and bars) shall comply with the following:

(a) Wrought seamless and welded (without filler metal) pipe and tubing shall be examined over the entire volume<sup>5</sup> of the material in accordance with (1), (2), (3), or (4), as follows. Tubular products may require both outside and inside surface conditioning prior to examination.

##### *(1) Pipe and Tubing*

(-a) Pipe and tubing smaller than 2½ in. (64 mm) O.D. shall be examined by the ultrasonic method in accordance with NB-2552(a)(1) in two opposite circumferential directions<sup>5</sup> and by the eddy current method in accordance with NB-2554, provided the product is limited to sizes, materials, and thicknesses for which meaningful results can be obtained by eddy current examination as evidenced by detection of required standards.

(-b) As an alternative to the eddy current examination or when the eddy current examination does not yield meaningful results, an axial scan ultrasonic examination in two opposite axial directions,<sup>6</sup> in accordance with NB-2552(a)(2), shall be made.

(2) Pipe and tubing 2½ in. (64 mm) O.D. and larger shall be examined by the ultrasonic method in accordance with NB-2552(a)(1) in two opposite circumferential directions, and in accordance with NB-2552(a)(2) in two opposite axial directions. Alternatively, for welded without filler metal pipe larger than 6¾ in. (170 mm) O.D., the plate shall be examined by the ultrasonic method in accordance with NB-2530 prior to forming and the weld shall be examined by the radiographic method in accordance with NB-2553. Radiographic examination of welds, including repair welds, shall be performed after final rolling and forming and may be performed prior to any required postweld heat treatment.

(3) Copper-nickel alloy and nickel alloy seamless pipe and tubing shall be examined as follows:

(-a) Except as provided in (d) below, each pipe and tube, all sizes shall be ultrasonically examined in accordance with NB-2552(a)(1) in two opposite circumferential directions.

(-b) Except as provided in (d) below, pipe and tubing smaller than 2½ in. (64 mm) O.D. shall be examined by the eddy current method in accordance with NB-2554 if meaningful indications can be obtained from the reference specimen notches. If meaningful indications cannot be obtained from the reference specimen, an axial scan ultrasonic examination in two opposite axial directions, in accordance with NB-2552(a)(2), shall be made.

(-c) Except as provided in (d) below, pipe and tubing 2½ in. (64 mm) O.D. and larger shall be examined by an axial scan ultrasonic examination in two opposite axial directions in accordance with NB-2552(a)(2).

(-d) For pipe and tubing which is specified to be coarse grain structure, radiographic examination in accordance with NB-2553 may be performed in lieu of ultrasonic examination.

(4) Tubing used in steam generator fabrication shall be examined as follows:

(-a) each tube shall be ultrasonically examined in accordance with NB-2552(a)(1) in two opposite circumferential directions, and

(-b) by eddy current in accordance with NB-2554 if meaningful indications can be obtained from the reference specimen notches. If meaningful results cannot be obtained from the reference specimen, an axial scan ultrasonic examination in two opposite axial directions, in accordance with NB-2552(a)(2), shall be made.

(b) Wrought seamless and welded without filler metal fittings (including pipe flanges and fittings machined from forgings and bars) shall be examined in accordance with the material specification, and in addition by the magnetic particle method in accordance with NB-2555, or the liquid penetrant method in accordance with NB-2556 on all



external surfaces and all accessible internal surfaces (excluding bolt holes and threads). Additionally, for fittings over NPS 6 (DN 150) nominal size, the entire volume shall be examined by the ultrasonic method, if feasible, in accordance with NB-2552, or the radiographic method in accordance with NB-2553. Alternatively, the plate shall be examined by the ultrasonic method in accordance with NB-2530 prior to forming and the weld shall be examined by the radiographic method in accordance with NB-2553. Radiographic examination of welds, including repair welds, shall be performed after final rolling and forming, and may be performed prior to any required postweld heat treatment.

(c) Tubular products used for vessel nozzles shall be examined over the entire volume of material by either the ultrasonic method in two opposite circumferential directions in accordance with NB-2552(b) or the radiographic method in accordance with NB-2553, and shall be examined on all external and all accessible internal surfaces by either the magnetic particle method in accordance with NB-2555 or the liquid penetrant method in accordance with NB-2556.

## NB-2552 Ultrasonic Examination<sup>5</sup>

(a) *Examination Procedure for Pipe and Tubing.* Independent channels or instruments shall be employed for circumferential and axial scans.

(1) *Circumferential Direction.* The procedure for ultrasonic examination of pipe and tubing in the circumferential direction shall be in accordance with SE-213. The procedure shall provide a sensitivity which will consistently detect defects that produce indications equal to, or greater than, the indications produced by the standard defects specified in (c).


(2) *Axial Direction.* When required by NB-2551, the ultrasonic examination of pipe and tubing shall include angle beam scanning in the axial direction. The procedure for the axial scans shall be in accordance with SE-213, except that the propagation of sound in the tube or pipe wall shall be in the axial direction instead of the circumferential direction. Figure NB-2552-1 illustrates the characteristic oblique entry of sound into the pipe or tube wall and the axial direction of ultrasonic energy propagation to detect transverse notches or similar surface discontinuities.

(3) *Acceptance Standards.* Products with defects that produce indications in excess of the indications produced by the standard defects in the reference specimen are unacceptable unless the defects are eliminated or repaired in accordance with NB-2558 or NB-2559.

(b) *Examination Procedure for Fittings*

(1) *Procedure.* The procedure for ultrasonic examination of fittings shall be in accordance with Article 5 of Section V for straight beam examination and, where feasible, angle-beam examination in two circumferential directions.

**Figure NB-2552-1**  
**Axial Propagation of Sound in Tube Wall**



(2) *Acceptance Standards.* Fittings shall be unacceptable if straight beam examination shows one or more reflectors which produce indications accompanied by complete loss of back reflection not associated with or attributable to the geometric configuration, or if angle beam examination results show one or more reflectors which produce indications exceeding in amplitude the indications from the calibrated notch. Complete loss of back reflection is assumed when the back reflection falls below 5% of full calibration screen height.

(c) *Reference Specimens*

(1) The reference specimen shall be of the same nominal diameter and thickness, and of the same nominal composition and heat-treated condition as the product which is being examined. For circumferential scanning, the standard defects shall be axial notches or grooves on the outside and inside surfaces of the reference specimen, and shall have a length of approximately 1 in. (25 mm) or less, a width not to exceed  $\frac{1}{16}$  in. (1.5 mm) for a square notch or U-notch, a width proportional to the depth for a V-notch, and a depth not greater than the larger of 0.004 in. (0.10 mm) or 5% of the nominal wall thickness. For axial scanning in accordance with SE-213, a transverse (circumferential) notch shall be introduced on the inner and outer surfaces of the standard. Dimensions of the transverse notch shall not exceed those of the longitudinal notch. The reference specimen may be the product being examined.

(2) The reference specimen shall be long enough to simulate the handling of the product being examined through the examination equipment. When more than one standard defect is placed in a reference specimen, the defects shall be located so that indications from each defect are separate and distinct without mutual interference or amplification. All upset metal and burrs adjacent to the reference notches shall be removed.

(d) *Checking and Calibration of Equipment.* The proper functioning of the examination equipment shall be checked and the equipment shall be calibrated by the use of the reference specimens, as a minimum:

(1) at the beginning of each production run of a given size and thickness of a given material.

(2) after each 4 hr or less during the production run.

(3) at the end of the production run.

(4) at any time that malfunctioning is suspected. If, during any check, it is determined that the examination equipment is not functioning properly, all of the products that have been examined since the last valid equipment calibration shall be reexamined.

### NB-2553 Radiographic Examination

(a) *General.* When radiographic examination is performed as an alternative for ultrasonic examination of the entire volume of the material, it shall apply to the entire volume of the pipe, tube, or fitting material. Acceptance standards specified for welds shall apply to the entire volume of material examined.

(b) *Examination Procedure.* The radiographic examination shall be performed in accordance with Article 2 of Section V, as modified by NB-5111.

(c) *Acceptance Standard.* Welds that are shown by radiography to have any of the following types of discontinuities are unacceptable:

(1) any type of crack or zone of incomplete fusion or penetration;

(2) any other elongated indication which has a length greater than:

(-a)  $\frac{1}{4}$  in. (6 mm) for  $t$  up to  $\frac{3}{4}$  in. (19 mm), inclusive

(-b)  $\frac{1}{3}t$  for  $t$  from  $\frac{3}{4}$  in. (19 mm) to  $2\frac{1}{4}$  in. (57 mm), inclusive

(-c)  $\frac{3}{4}$  in. (19 mm) for  $t$  over  $2\frac{1}{4}$  in. (57 mm)

where  $t$  is the thickness of the thinner portion of the weld;

(3) any group of aligned indications having an aggregate length greater than  $t$  in a length of  $12t$ , unless the minimum distance between successive indications exceeds  $6L$ , in which case the aggregate length is unlimited,  $L$  being the length of the largest indication;

(4) rounded indications in excess of that shown as acceptable in Appendix VI.

### NB-2554 Eddy Current Examination

(a) *General.* This examination method is restricted to materials with uniform magnetic properties and of sizes for which meaningful results can be obtained.

(b) *Examination Procedure.* The procedure for eddy current examination shall be in accordance with SE-426 or SE-571. The procedure shall provide a sensitivity that will consistently detect defects by comparison with the standard defects included in the reference specimen in (d).

(c) *Acceptance Standards.* Products with defects that produce indications in excess of the reference standards are unacceptable.

(d) *Reference Specimens.* The reference specimen shall be of the same nominal diameter and thickness, and of the same nominal composition and heat-treated condition as the product that is being examined. The standard shall contain transverse (circumferential) notches on the outside surface plus a  $\frac{1}{16}$  in. (1.5 mm) diameter hole drilled through the wall. For copper-nickel alloy and nickel alloy materials, the standard shall have one notch extending circumferentially on the outside surface and one notch extending circumferentially on the inside surface plus a  $\frac{1}{16}$  in. (1.5 mm) diameter hole drilled through the wall. These shall be used to establish the rejection level for the product to be tested. The reference notches shall have a depth not greater than the larger of 0.004 in. (0.10 mm) or 5% of the wall thickness. The width of the notch shall not exceed  $\frac{1}{16}$  in. (1.5 mm). The length shall be approximately 1 in. (25 mm) or less. The size of reference specimens shall be as specified in NB-2552(c). Additional examination using either transverse notches or axial notches shall be performed when required by the design specification.

(e) *Checking and Calibration of Equipment.* The checking and calibration of examination equipment shall be the same as in NB-2552(d).

### NB-2555 Magnetic Particle Examination

Magnetic particle examination shall be performed in accordance with the requirements of NB-2545.

### NB-2556 Liquid Penetrant Examination

Liquid penetrant examination shall be performed in accordance with the requirements of NB-2546.

### NB-2557 Time of Examination

(a) Products that are quenched and tempered shall be examined, as required, after the quenching and tempering heat treatment.

(b) Products that are not quenched and tempered shall receive the required examinations as follows:

(1) Ultrasonic or eddy current examination, when required, shall be performed after final heat treatment required by Section II material specification. Other heat treatment including postweld treatment, may be performed either prior to or after the examination.

(2) Radiographic examination, when required, may be performed prior to any required postweld heat treatment.

(3) Magnetic particle or liquid penetrant examination, including repair welds, shall be performed after final heat treatment, except that the examination may be performed prior to postweld heat treatment for P-No. 1 (Section IX of the Code) materials of 2 in. (50 mm) and less nominal thickness.

(4) Forgings and rolled bars which are to be bored and/or turned to form tubular parts or fittings shall be examined after boring and/or turning, except for threading. Fittings shall be examined after final forming.

#### **NB-2558 Elimination of Surface Defects**

Surface defects shall be removed by grinding or machining, provided the requirements of (a) through (c) below are met.

(a) The depression, after defect elimination, is blended uniformly into the surrounding surface.

(b) After defect elimination, the area is examined by the method which originally disclosed the defect to assure that the defect has been removed or reduced to an imperfection of acceptable size.

(c) If the elimination of the defect reduces the thickness of the section below the minimum required to satisfy the rules of [NB-3000](#), the product shall be repaired in accordance with [NB-2559](#).

#### **NB-2559 Repair by Welding**

Repair of defects shall be in accordance with [NB-2539](#), except repair by welding is not permitted on copper-nickel alloy and nickel alloy heat exchanger tubes.

#### **NB-2560 EXAMINATION AND REPAIR OF TUBULAR PRODUCTS AND FITTINGS WELDED WITH FILLER METAL**

##### **NB-2561 Required Examinations**

(a) Welded tubular products (with filler metal) such as pipe made in accordance with SA-358, SA-409, SA-671, SA-672, and SA-691, and fittings made in accordance with the WPW grades of SA-234, SA-403, and SA-420, which are made by welding with filler metal, shall be treated as material; however, inspection by an Inspector and stamping with a Certification Mark with NPT Designator shall be in accordance with Section III requirements. In addition to the Certification Mark with NPT Designator, a numeral 1 shall be stamped below and outside the official Certification Mark.

(b) In addition to the requirements of the material specification and of the Article, pipe and fittings shall comply with the following:

(1) The plate shall be examined in accordance with [NB-2530](#) prior to forming, or alternatively, the finished product shall be examined by the ultrasonic method in accordance with [NB-2562](#).

(2) All welds shall be examined 100% by radiography in accordance with the method and acceptance requirements of the base material specification, and by either the magnetic particle method in accordance with [NB-2564](#) or the liquid penetrant method in accordance with [NB-2565](#). If radiographic examination of welds is not specified in the basic material specification, the welds shall be examined by the radiographic method in accordance with [NB-2563](#). The radiographs and a radiographic report showing exposure locations shall be provided with the Certified Material Test Report.

dance with [NB-2563](#). The radiographs and a radiographic report showing exposure locations shall be provided with the Certified Material Test Report.

#### **NB-2562 Ultrasonic Examination**

The ultrasonic examination shall be performed in accordance with the requirements of [NB-2552](#).

#### **NB-2563 Radiographic Examination**

The radiographic examination shall be performed in accordance with the requirements of [NB-2553](#).

#### **NB-2565 Magnetic Particle Examination**

The magnetic particle examination shall be performed in accordance with the requirements of [NB-2545](#).

#### **NB-2566 Liquid Penetrant Examination**

The liquid penetrant examination shall be performed in accordance with the requirements of [NB-2546](#).

#### **NB-2567 Time of Examination**

The time of examination shall be in accordance with the requirements of [NB-2557](#), except that for magnetic particle or liquid penetrant examination of welds, including repair welds, for P-No. 1 (Section IX of the Code), examination may be performed prior to postweld heat treatment.

#### **NB-2568 Elimination of Surface Defects**

Unacceptable surface defects shall be removed in accordance with the requirements of [NB-2558](#).

#### **NB-2569 Repair by Welding**

When permitted by the basic material specification, base material defects shall be repair welded in accordance with the requirements of [NB-2559](#). Repair welding of weld seam defects shall be in accordance with [NB-4450](#).

#### **NB-2570 EXAMINATION AND REPAIR OF STATICALLY AND CENTRIFUGALLY CAST PRODUCTS**

In addition to the requirements of the material specification and of this Article, statically and centrifugally cast products shall comply with the following subparagraphs.

##### **NB-2571 Required Examination**

Cast products shall be examined by the radiographic method, except cast ferritic steels which shall be examined by either the radiographic or ultrasonic method, or a combination of both methods, as required for the product form by [Table NB-2571-1](#).

In addition, all cast products shall be examined on all external surfaces and all accessible internal surfaces by either the magnetic particle or liquid penetrant method.



**Table NB-2571-1  
Required Examinations**

Nominal Pipe Size	Item	Applicable Special Requirements for Class 1 Castings
Inlet piping connections of NPS 2 (DN 50) and less	Cast products other than pumps and valves	Cast products shall be examined by the radiographic method, except cast ferritic steels, which shall be examined by either the radiographic or ultrasonic method, or a combination of both methods. Castings or sections of castings that have coarse grains or configurations that do not yield meaningful examination results by the ultrasonic method shall be examined by the radiographic method. In addition, all cast products shall be examined on all external surfaces and all accessible internal surfaces by either the magnetic particle or the liquid penetrant method. Machined surfaces, except threaded surfaces, of a cast product shall be examined by either the liquid penetrant or the magnetic particle method after machining.
	Cast pumps and valves	None
	Repair welds in pumps and valves of P-No. 1 or P-No. 8 material	None
	Repair welds in cast products, excluding repair welds in pumps and valves of P-No. 1 or P-No. 8 material	Each repair weld shall be examined by the magnetic particle method or by the liquid penetrant method. In addition, repair welds in cavities the depth of which exceed the lesser of $\frac{3}{8}$ in. (10 mm) or 10% of the section thickness shall be radiographed in accordance with <a href="#">NB-2575</a> .
Inlet piping connections over NPS 2 (DN 50) up to and including NPS 4 (DN 100)	Cast products — See <i>Cast pumps and valves</i> below for exceptions	Cast products shall be examined by the radiographic method, except cast ferritic steels, which shall be examined by either the radiographic or the ultrasonic method, or a combination of both methods. Castings or sections of castings that have coarse grains or configurations that do not yield meaningful examination results by the ultrasonic method shall be examined by the radiographic method. In addition, all cast products shall be examined on all external surfaces and all accessible internal surfaces by either the magnetic particle or the liquid penetrant method. Machined surfaces, except threaded surfaces, of a cast product shall be examined by either the liquid penetrant or the magnetic particle method after machining.
	Cast pumps and valves	Magnetic particle or liquid penetrant examination may be performed, in lieu of volumetric examination, except the welding ends of cast pumps and valves shall be radiographed for a minimum distance of $t$ (when $t$ is the design section thickness of the weld) from the final weld end.
	Repair welds	Each repair weld shall be examined by the magnetic particle method or by the liquid penetrant method. In addition, repair welds in cavities the depth of which exceed the lesser of $\frac{3}{8}$ in. (10 mm) or 10% of the section thickness shall be radiographed in accordance with <a href="#">NB-2575</a> .
Inlet piping connections over NPS 4 (DN 100)	Cast products	Cast products shall be examined by the radiographic method, except cast ferritic steels, which shall be examined by either the radiographic or the ultrasonic method, or a combination of both methods. Castings or sections of castings that have coarse grains or configurations that do not yield meaningful examination results by the ultrasonic method shall be examined by the radiographic method. In addition, all cast products shall be examined on all external surfaces and all accessible internal surfaces by either the magnetic particle or the liquid penetrant method. Machined surfaces, except threaded surfaces, of a cast product shall be examined by either the liquid penetrant or the magnetic particle method after machining.
	Repair welds	Each repair weld shall be examined by the magnetic particle method or by the liquid penetrant method. In addition, repair welds in cavities the depth of which exceed the lesser of $\frac{3}{8}$ in. (10 mm) or 10% of the section thickness shall be radiographed in accordance with <a href="#">NB-2575</a> .

Machined surfaces, except threaded surfaces, of a cast product shall be examined by either the liquid penetrant or magnetic particle method after machining.

## **NB-2572 Time of Nondestructive Examination**

**NB-2572.1 Acceptance Examinations.** Acceptance examinations shall be performed at the time of manufacture as stipulated in the following and [Table NB-2571-1](#).

(a) *Ultrasonic Examination.* Ultrasonic examination, if required, shall be performed at the same stage of manufacture as required for radiography.

(b) *Radiographic Examination.* Radiography may be performed prior to heat treatment and may be performed prior to or after finish machining at the following limiting thicknesses.

(1) For finished thicknesses under  $2\frac{1}{2}$  in. (64 mm), castings shall be radiographed within  $\frac{1}{2}$  in. (13 mm) or 20% of the finished thickness, whichever is greater. The IQI and the acceptance reference radiographs shall be based on the finished thickness.

(2) For finished thickness from  $2\frac{1}{2}$  in. (64 mm) up to 6 in. (150 mm), castings shall be radiographed within 20% of the finished thickness. The IQI and the acceptance reference radiographs shall be based on the finished thickness.

(3) For finished thicknesses over 6 in. (150 mm), castings shall be radiographed within  $\frac{1}{2}$  in. (13 mm) or 15% of the finished thickness, whichever is greater. The IQI and the acceptance reference radiographs shall be based on the finished thickness.

(c) Radiography of castings for pumps and valves may be performed in as-cast or rough machined thickness exceeding the limits of (b)(1), (b)(2), or (b)(3) above, subject to the following conditions.

(1) When the thickness of the as-cast or rough machined section exceeds 2 in. (50 mm), acceptance shall be based on reference radiographs for the next lesser thickness; e.g., if the section being radiographed exceeds  $4\frac{1}{2}$  in. (114 mm), use reference radiographs of ASTM E186. The IQI shall be based on the thickness of the section being radiographed.

(2) When the thickness of the as-cast or rough machined section is 2 in. (50 mm) or less, the reference radiographs of ASTM E446 shall be used, and the IQI shall be based on the final section thickness.

(3) Weld ends for a minimum distance of  $t$  or  $\frac{1}{2}$  in. (13 mm), whichever is less (where  $t$  is the design section thickness of the weld), from the final welding end shall be radiographed at a thickness within the limits given in (b)(1), (b)(2), or (b)(3) above as applicable. As an alternative, the weld ends may be radiographed in the as-cast or rough machined thickness in accordance with (c)(1) and (c)(2) above, and the IQI shall be based on the final section thickness.

(d) *Magnetic Particle or Liquid Penetrant Examination.* Magnetic particle or liquid penetrant examination shall be performed after the final heat treatment required by the material specification. Repair weld areas shall be ex-

amined after postweld heat treatment when a postweld heat treatment is performed, except that repair welds in P-No. 1 (see Section IX of the Code) material 2 in. (50 mm) nominal thickness and less may be examined prior to postweld heat treatment. For cast products with machined surfaces, all finished machined surfaces, except threaded surfaces and small deep holes, shall also be examined by the magnetic particle or the liquid penetrant method.

## **NB-2573 Provisions for Repair of Base Material by Welding**

The Material Organization may repair, by welding, products from which defects have been removed, provided the requirements of this Article are met.

**NB-2573.1 Defect Removal.** The defects shall be removed or reduced to an imperfection of acceptable size by suitable mechanical or thermal cutting or gouging methods, and the cavity prepared for repair. When thermal cutting is performed, consideration shall be given to preheating the material.

**NB-2573.2 Repair by Welding.** The Material Organization may repair castings by welding after removing the material containing unacceptable defects. The depth of the repair is not limited. A cored hole or access hole may be closed by the Material Organization by welding in accordance with the requirements of this paragraph, provided the hole is closed by filler metal only. If the hole is closed by welding in a metal insert, the welding shall be performed by a holder of a Certificate of Authorization in accordance with the requirements of the Code.

**NB-2573.3 Qualification of Welding Procedures and Welders.** Each manufacturer is responsible for the welding done by his organization and shall establish the procedures and conduct the tests required by [NB-4000](#) and by Section IX of the Code in order to qualify both the welding procedures and the performance of welders and welding operators who apply these procedures. He is also responsible for the welding performed by his subcontractors and shall assure himself that the subcontractors conduct the tests required by [NB-4000](#) and by Section IX of the Code in order to qualify their welding procedures and the performance of their welders and welding operators.

**NB-2573.4 Blending of Repaired Areas.** After repair, the surface shall be blended uniformly into the surrounding surface.

### **NB-2573.5 Examination of Repair Welds.**

(a) Each repair weld shall be examined by the magnetic particle method in accordance with the requirements of [NB-2577](#) or by the liquid penetrant method in accordance with the requirements of [NB-2576](#). In addition, when radiography is specified in the order for the original casting, repair cavities, the depth of which exceeds the lesser of  $\frac{3}{8}$  in. (10 mm) or 10% of the nominal wall thickness, shall be radiographed after repair except that weld slag,

including elongated slag, shall be considered as inclusions under Category B of the applicable reference radiographs. The total area of all inclusions, including slag inclusions, shall not exceed the limits of the applicable severity level of Category B of the reference radiographs. The IQI and the acceptance standards for radiographic examination of repair welds shall be based on the actual section thickness at the repair area.

(b) Examination of repair welds in P-No. 1 and P-No. 8 material is not required for pumps and valves with inlet piping connections NPS 2 (DN 50) and less.

**NB-2573.6 Heat Treatment After Repairs.** The material shall be heat treated after repair in accordance with the heat treatment requirements of NB-4620, except that the heating and cooling rate limitations of NB-4623 do not apply.

**NB-2573.7 Elimination of Surface Defects.** Surface defects shall be removed by grinding or machining provided the requirements of (a) through (c) below are met.

(a) The depression, after defect elimination, is blended uniformly into the surrounding surface.

(b) After defect elimination, the area is reexamined by the magnetic particle method in accordance with NB-2577 or the liquid penetrant method in accordance with NB-2576 to assure that the defect has been removed or reduced to an imperfection of acceptable size.

(c) If the elimination of the defect reduces the section thickness below the minimum required by the specification or drawing, the casting shall be repaired in accordance with NB-2539.

**NB-2573.8 Material Report Describing Defects and Repairs.** Each defect repair exceeding in depth the lesser of  $\frac{3}{8}$  in. (10 mm) or 10% of the nominal wall thickness shall be described in the Certified Material Test Report. The Certified Material Test Report for each piece shall include a chart that shows the location and size of the prepared cavity, the welding material identification, the welding procedure, the heat treatment, and the examination results, including radiographs, when radiography is specified in the order for the original casting.

## **NB-2574 Ultrasonic Examination of Ferritic Steel Castings**

Ultrasonic examination shall be performed in accordance with T-571.4 of Article 5 of Section V. Each manufacturer shall certify that the procedure is in accordance with the requirements of NB-2574 and shall make the procedure available for approval upon request.

### **NB-2574.1 Acceptance Standards.**

(a) The Quality Levels of SA-609 as shown in Section V shall apply for the casting thicknesses indicated

(1) Quality Level 1 for thicknesses up to 2 in. (50 mm)

(2) Quality Level 3 for thicknesses 2 in. (50 mm) to 4 in. (100 mm)

(3) Quality Level 4 for thicknesses greater than 4 in. (100 mm)

(b) In addition to the Quality Level requirements stated in (a) above, the requirements in (1) through (5) below shall apply for both straight beam and angle beam examination.

(1) Areas giving indications exceeding the Amplitude Reference Line with any dimension longer than those specified in the following tabulation are unacceptable:

UT Quality Level	Longest Dimension of Area, in. (mm)
	[Note (1)], [Note (2)], [Note (3)]
1	1.5 (38)
2	2.0 (50)
3	2.5 (64)
4	3.0 (75)

#### NOTES:

(1) The areas for the Ultrasonic Quality Levels in SA-609 refer to the surface area on the casting over which continuous indication, exceeding the transfer corrected distance amplitude curve, is maintained.

(2) Areas are to be measured from dimensions of the movement of the search unit, using the center of the search unit as the reference point.

(3) In certain castings, because of very long metal path distances or curvature of the examination surfaces, the surface area over which a given discontinuity is detected may be considerably larger or smaller than the actual area of the discontinuity in the casting; in such cases, other criteria which incorporate a consideration of beam angles or beam spread must be used for realistic evaluation of the discontinuity.

(2) Quality Level 1 shall apply for the volume of castings within 1 in. (25 mm) of the surface regardless of the overall thickness.

(3) Discontinuities indicated to have a change in depth equal to or greater than one-half the wall thickness or 1 in. (25 mm) (whichever is less) are unacceptable.

(4) Two or more imperfections producing indications in the same plane with amplitudes exceeding the Amplitude Reference Line and separated by a distance less than the longest dimension of the larger of the adjacent indications are unacceptable if they cannot be encompassed within an area less than that of the Quality Level specified in (b)(1) above.

(5) Two or more imperfections producing indications greater than permitted for Quality Level 1 for castings less than 2 in. (50 mm) in thickness, greater than permitted for Quality Level 2 for thicknesses 2 in. (50 mm) through 4 in. (100 mm), and greater than permitted for Level 3 for thicknesses greater than 4 in. (100 mm), separated by a distance less than the longest dimension of the larger of the adjacent indications are unacceptable, if they cannot be encompassed in an area less than that of the Quality Level requirements stated in (a) above.

**NB-2575 Radiographic Examination**

**NB-2575.1 Examination.** Cast pressure-retaining materials shall be examined by the radiographic method when specified in the order for the original castings, except that cast ferritic steels may be examined by either the radiographic or ultrasonic method, or a combination of both methods. Castings or sections of castings that have coarse grains or configurations that do not yield meaningful examination results by ultrasonic methods shall be examined by the radiographic method.

**NB-2575.2 Extent.** Radiographic examination shall be performed on pressure-retaining castings such as vessel heads and flanges, valve bodies, bonnets and disks, pump casings and covers, and piping and fittings. The extent of radiographic coverage shall be of the maximum feasible volume and, when the shape of the casting precludes complete coverage, the coverage shall be at least as exemplified in the typical sketches as shown in [Figure NB-2575.2-1](#).

**NB-2575.3 Examination Requirements.** Radiographic examination shall be performed in accordance with Section V, Article 2, Mandatory Appendix VII, Radiographic Examination of Metallic Castings, with the following modifications:

(a) The geometric unsharpness limitations of T-274.2 need not be met.

(b) The examination procedure or report shall also address the following:

- (1) type and thickness of filters, if used
- (2) for multiple film techniques, whether viewing is to be single or superimposed, if used
- (3) blocking or masking technique, if used
- (4) orientation of location markers
- (5) description of how internal markers, when used, locate the area of interest

(c) The location of location markers (e.g., lead numbers or letters) shall be permanently stamped on the surface of the casting in a manner permitting the area of interest on a radiograph to be accurately located on the casting and providing evidence on the radiograph that the extent of coverage required by [NB-2575.2](#) has been obtained. For castings or sections of castings where stamping is not feasible, the radiographic procedure shall so state, and a radiographic exposure map shall be provided.

**NB-2575.6 Acceptance Criteria.** Castings shall meet the acceptance requirements of Severity Level 2 of ASTM E446, Reference Radiographs for Steel Castings up to 2 in. (50 mm) in Thickness; ASTM E186, Reference Radiographs for Heavy-Walled [2 in. to 4<sup>1</sup>/<sub>2</sub> in. (50 mm to 114 mm)] Steel Castings; or ASTM E280, Reference Radiographs for Heavy-Walled [4<sup>1</sup>/<sub>2</sub> in. to 12 in. (114 mm to 300 mm)] Steel Castings, as applicable for the thickness being radiographed except that Category D,

E, F, or G defects are not acceptable. The requirements of ASTM E280 shall apply for castings over 12 in. (300 mm) in thickness.

**NB-2576 Liquid Penetrant Examination**

(a) Castings shall be examined, if required, on all accessible surfaces by the liquid penetrant method in accordance with Section V of the Code.

(b) *Evaluation of Indications.* All indications shall be evaluated in terms of the acceptance standards. Mechanical discontinuities intersecting the surface are indicated by bleeding out of the penetrant; however, localized surface discontinuities as may occur from machining marks, scale, or dents, may produce indications which are not relevant. Any indication in excess of the acceptance standards believed to be nonrelevant shall be reexamined to verify whether actual defects are present. Surface conditioning may precede the reexamination. Nonrelevant indications and broad areas of pigmentation that would mask indications of defects are unacceptable. Relevant indications are those which result from imperfections and have a major dimension greater than  $\frac{1}{16}$  in. (1.5 mm). Linear indications are those whose length is more than three times the width. Rounded indications are those which are circular or elliptical with the length less than three times the width.

(c) *Acceptance Standards.* The following relevant indications are unacceptable:

(1) linear indications greater than  $\frac{1}{16}$  in. (1.5 mm) long for materials less than  $\frac{5}{8}$  in. (16 mm) thick, greater than  $\frac{1}{8}$  in. (3 mm) long for materials from  $\frac{5}{8}$  in. (16 mm) thick to under 2 in. (50 mm) thick, and  $\frac{3}{16}$  in. (5 mm) long for materials 2 in. (50 mm) thick and greater;

(2) rounded indications with dimensions greater than  $\frac{1}{8}$  in. (3 mm) for thicknesses less than  $\frac{5}{8}$  in. (16 mm) and greater than  $\frac{3}{16}$  in. (5 mm) for thicknesses  $\frac{5}{8}$  in. (16 mm) and greater;

(3) four or more indications in a line separated by  $\frac{1}{16}$  in. (1.5 mm) or less edge to edge;


(4) ten or more indications in any 6 in.<sup>2</sup> (4 000 mm<sup>2</sup>) of surface with the major dimension of this area not to exceed 6 in. (150 mm) taken in the most unfavorable orientation relative to the indications being evaluated.

**NB-2577 Magnetic Particle Examination (for Ferritic Steel Products Only)**

(a) Castings of magnetic material shall be examined, if required, on all accessible surfaces by a magnetic particle method in accordance with Section V of the Code.


(b) *Evaluation of Indications.* All indications shall be evaluated in terms of the acceptance standards. Mechanical discontinuities intersecting the surface are indicated by retention of the examination medium. All indications are not necessarily defects since certain metallurgical discontinuities and magnetic permeability variations may produce indications that are not relevant. Any indication in excess of the acceptance standards believed to be

**Figure NB-2575.2-1**  
**Typical Pressure-Retaining Parts of Pumps and Valves**




**(a) Typical Volute-Type Pump Case**

**(b) Typical Diffuser-Type Pump case**




**(c) Typical Diffuser-Type Pump Case Detail**



**(d) Typical Single Stage Pump Case**



**Figure NB-2575.2-1**  
**Typical Pressure-Retaining Parts of Pumps and Valves (Cont'd)**



**GENERAL NOTES:**

- (a) Radiographic examination areas shall be indicated by a circle at each change of direction. The examination symbol for radiography shall be indicated as RT.
- (b) For nondestructive examination areas or revolution, the area shall be indicated by the examine-all-around symbol: – RT – ⊙.
- (c) The sketches are typical and are to be used as a guide for minimum required coverage. Even though a sketch may be titled, "pump" or "valve," the coverage shown by the configurations may be applied interchangeably.

nonrelevant shall be reexamined to verify whether actual defects are present. Nonrelevant indications which would mask indications of defects are unacceptable. Surface conditioning may precede the reexamination. Relevant indications are those which result from imperfections and have a major dimension greater than  $\frac{1}{16}$  in. (1.5 mm). Linear indications are those whose length is more than three times the width. Rounded indications are those which are circular or elliptical with the length less than three times the width.

(c) *Acceptance Standards.* The following relevant indications are unacceptable:

(1) linear indications greater than  $\frac{1}{16}$  in. (1.5 mm) long for materials less than  $\frac{5}{8}$  in. (16 mm) thick, greater than  $\frac{1}{8}$  in. (3 mm) long for materials from  $\frac{5}{8}$  in. (16 mm) thick to under 2 in. (50 mm) thick, and  $\frac{3}{16}$  in. (5 mm) long for materials 2 in. (50 mm) thick and greater;

(2) rounded indications with dimensions greater than  $\frac{1}{8}$  in. (3 mm) for thicknesses less than  $\frac{5}{8}$  in. (16 mm) and greater than  $\frac{3}{16}$  in. (5 mm) for thicknesses  $\frac{5}{8}$  in. (16 mm) and greater;

(3) four or more relevant indications in a line separated by  $\frac{1}{16}$  in. (1.5 mm) or less edge to edge;

(4) ten or more relevant indications in any 6 in.<sup>2</sup> (4 000 mm<sup>2</sup>) of surface with the major dimension of this area not to exceed 6 in. (150 mm) taken in the most unfavorable orientation relative to the indications being evaluated.

**NB-2580 EXAMINATION OF BOLTS, STUDS, AND NUTS**

**NB-2581 Required Examination**

All bolting material shall be visually examined in accordance with NB-2582. Nominal sizes greater than 1 in. (25 mm) shall be examined by either the magnetic particle or the liquid penetrant method. In addition, nominal sizes greater than 2 in. (50 mm) but not over 4 in. (100 mm) shall be examined by the ultrasonic method in accordance with NB-2585 and nominal sizes greater than 4 in. (100 mm) shall be examined by the ultrasonic method in accordance with both NB-2585 and NB-2586.

**NB-2582 Visual Examination**

The areas of threads, shanks, and heads of final machined parts shall be visually examined. Harmful discontinuities such as laps, seams, or cracks that would be detrimental to the intended service are unacceptable.



**NB-2583 Magnetic Particle Examination (for Ferritic Steel Bolting Material Only)**

**NB-2583.1 Examination Procedure.** All bolts, studs, and nuts greater than 1 in. (25 mm) nominal bolt size shall be examined by the magnetic particle method in accordance with ASTM A275. If desired, the supplier may perform liquid penetrant examination in accordance with [NB-2584](#) instead of magnetic particle examination. Such examination shall be performed on the finished component after threading or on the materials stock at approximately the finished diameter before threading and after heading (if involved). This examination shall be performed on all accessible surfaces.

**NB-2583.2 Evaluation of Indications.**

(a) All indications shall be evaluated in terms of the acceptance standards. Linear indications are those indications in which the length is more than three times the width. Rounded indications are those which are circular or elliptical with the length equal to or less than three times the width.

(b) All indications are not necessarily relevant: leakage of magnetic fields and permeability variations may produce indications that are not relevant to the detection of unacceptable discontinuities. Indications with major dimensions of  $\frac{1}{16}$  in. (1.5 mm) or less are not relevant.

(c) Any indication that is believed to be nonrelevant, and that is larger than acceptable, shall be considered to be a defect and shall be reexamined after light surface conditioning.

(d) Any indication observed during such reexamination shall be considered relevant and shall be evaluated in terms of the acceptance standards.

(e) As an alternative to magnetic particle reexamination, other nondestructive examination means (such as liquid penetrant examination for surface discontinuities) may be used to determine relevancy.

**NB-2583.3 Acceptance Standard.** Linear nonaxial indications are unacceptable. Linear axial indications greater than 1 in. (25 mm) in length are unacceptable.

**NB-2584 Liquid Penetrant Examination**

**NB-2584.1 Examination Procedure.** All bolts, studs, and nuts greater than 1 in. (25 mm) nominal bolt size shall be examined by a liquid penetrant method in accordance with the methods of Article 6, Section V. Such examination shall be performed on the finished component after threading or on the materials stock at approximately the finished diameter before threading and after heading (if involved).

**NB-2584.2 Evaluation of Indications.** All indications shall be evaluated in terms of the acceptance standards. Linear indications are those indications in which the length is more than three times the width. Rounded indications are those which are circular to elliptical with the length equal to or less than three times the width. All

penetrant indications are not necessarily relevant. Surface imperfections such as machining marks and scratches may produce indications that are nonrelevant to the detection of unacceptable discontinuities. Broad areas of pigmentation, which could mask indications of defects, are unacceptable. Indications with major dimensions of  $\frac{1}{16}$  in. (1.5 mm) or less are not relevant. Any indication that is believed to be nonrelevant, and that is larger than acceptable, shall be considered to be a defect and shall be reexamined after light surface conditioning. Any area of pigmentation also shall be reexamined after recleaning or light surface conditioning, as appropriate. Any indication observed during such reexamination shall be considered relevant and shall be evaluated in terms of the acceptance standards.

**NB-2584.3 Acceptance Standard.** Linear nonaxial indications are unacceptable. Linear axial indications greater than 1 in. (25 mm) long are unacceptable.

**NB-2585 Ultrasonic Examination for Sizes Greater Than 2 in. (50 mm)**

All bolts, studs, and nuts greater than 2 in. (50 mm) nominal bolt size shall be ultrasonically examined over the entire cylindrical surface prior to threading in accordance with the following requirements.

**NB-2585.1 Ultrasonic Method.** Examination shall be carried out by the straight beam, radial-scan method in accordance with SA-388 of Article 23 of Section V.

**NB-2585.2 Examination Procedure.** Examination shall be performed at a nominal frequency of 2.25 MHz with a search unit not to exceed 1 in.<sup>2</sup> (650 mm<sup>2</sup>).

**NB-2585.3 Calibration of Equipment.** Calibration sensitivity shall be established by adjustment of the instrument so that the first back reflection is 75% to 90% of full-screen height.

**NB-2585.4 Acceptance Standard.** Any discontinuity that causes an indication in excess of 20% of the height of the first back reflection or any discontinuity that prevents the production of a first back reflection of 50% of the calibration amplitude is not acceptable.

**NB-2586 Ultrasonic Examination for Sizes Over 4 in. (100 mm)**

In addition to the requirements of [NB-2585](#), all bolts, studs, and nuts over 4 in. (100 mm) nominal bolt size shall be ultrasonically examined over the entire surface of each end before or after threading in accordance with the following requirements.

**NB-2586.1 Ultrasonic Method.** Examination shall be carried out by the straight beam, longitudinal-scan method.

**NB-2586.2 Examination Procedure.** Examination shall be performed at a nominal frequency of 2.25 MHz with a search unit having a circular cross section with a diameter not less than  $\frac{1}{2}$  in. (13 mm) nor more than  $1\frac{1}{8}$  in. (29 mm).

**NB-2586.3 Calibration of Equipment.** Calibration shall be established on a test bar of the same nominal composition and diameter as the production part and a minimum of one-half of the length. A  $\frac{3}{8}$  in. (10 mm) diameter by 3 in. (75 mm) deep flat-bottom hole shall be drilled in one end of the bar and plugged to full depth. A distance-amplitude curve shall be established by scanning from both ends of the test bar.

**NB-2586.4 Acceptance Standard.** Any discontinuity that causes an indication in excess of that produced by the calibration hole in the reference specimen as corrected by the distance-amplitude curve is not acceptable.

#### **NB-2587 Time of Examination**

Acceptance examinations shall be performed after the final heat treatment required by the basic material specification.

#### **NB-2588 Elimination of Surface Defects**

Unacceptable surface defects on finished bolts, studs, and nuts are not permitted, and are cause for rejection.

#### **NB-2589 Repair by Welding**

Weld repairs of bolts, studs, and nuts are not permitted.

### **NB-2600 MATERIAL ORGANIZATIONS' QUALITY SYSTEM PROGRAMS**

#### **NB-2610 DOCUMENTATION AND MAINTENANCE OF QUALITY SYSTEM PROGRAMS**

(a) Except as provided in (b) below, Material Organizations shall have a Quality System Program that meets the requirements of NCA-3800.

(b) The requirements of NCA-3862 and NCA-3856 shall be met as required by [NB-2130](#) and [NB-2150](#), respectively. The other requirements of NCA-3800 need not be used by Material Organizations for small products, as defined in (c) below, for brazing material, and for material which is allowed by this Subsection to be furnished with a Certificate of Compliance. For these products, the Certificate Holder's Quality Assurance Program (NCA-4000) shall include measures to provide assurance that the material is furnished in accordance with the material specification and with the applicable requirements of this Subsection.

(c) For the purpose of this paragraph, small products are defined as given in (1) through (5) below:

(1) pipe, tube (except heat exchanger tube), pipe fittings, and flanges NPS 2 (DN 50) and less;

(2) bolting material, including studs, nuts, and bolts of 1 in. (25 mm) nominal diameter and less;

(3) bars with a nominal cross-sectional area of 1 in.<sup>2</sup> (650 mm<sup>2</sup>) and less;

(4) material for pumps and valves with inlet pipe connections of NPS 2 (DN 50) and less;

(5) material exempted by [NB-2121\(c\)](#).

#### **NB-2700 DIMENSIONAL STANDARDS**

Dimensions of standard items shall comply with the standards and specifications listed in Table NCA-7100-1.

## ARTICLE NB-3000 DESIGN

### NB-3100 GENERAL DESIGN

#### NB-3110 LOADING CRITERIA

##### NB-3111 Loading Conditions

The loadings that shall be taken into account in designing a component include, but are not limited to, those in (a) through (g) below:

- (a) internal and external pressure;
- (b) impact loads, including rapidly fluctuating pressures;
- (c) weight of the component and normal contents under operating or test conditions, including additional pressure due to static and dynamic head of liquids;
- (d) superimposed loads such as other components, operating equipment, insulation, corrosion-resistant or erosion resistant linings, and piping;
- (e) wind loads, snow loads, vibrations, and earthquake loads where specified;
- (f) reactions of supporting lugs, rings, saddles, or other types of supports;
- (g) temperature effects.

##### NB-3112 Design Loadings

The Design Loadings shall be established in accordance with NCA-2142.1 and the following subparagraphs.

###### NB-3112.1 Design Pressure.

(a) The specified internal and external Design Pressures to be used in this Subsection shall be established in accordance with NCA-2142.1(a). They shall be used in the computations made to show compliance with the stress intensity limits of NB-3221, NB-3227.1, NB-3227.2, NB-3227.4, NB-3228.1, NB-3228.2, and NB-3231. The specified service pressure at the appropriate time shall be used in the computations made to show compliance with the stress intensity limits of NB-3222, NB-3228.3, and NB-3232. When the occurrence of different pressures during operation can be predicted for different zones of a component, the Design Pressure of the different zones may be based on their predicted pressures.

(b) All pressures referred to in this Article are to be taken as psi (MPa), above atmospheric pressure, unless otherwise stated.

###### NB-3112.2 Design Temperature.

(a) The specified Design Temperature shall be established in accordance with NCA-2142.1(b). It shall be used in computations involving the Design Pressure and coincidental Design Mechanical Loads. The actual metal tem-

perature at the point under consideration shall be used in all computations where the use of the specified service pressure is required.

(b) All temperatures referred to in this Subsection are the metal temperatures expressed in degrees Fahrenheit, °F (degrees Centigrade, °C) unless otherwise stated.

(c) Where a component is heated by tracing, induction coils, jacketing, or internal heat generation, the effect of such heating shall be incorporated in the establishment of the Design Temperature.

**NB-3112.3 Design Mechanical Loads.** The specified Design Mechanical Loads shall be established in accordance with NCA-2142.1(c). They shall be used in conjunction with the Design Pressure.

**NB-3112.4 Design Stress Intensity Values.** Design stress intensity values for materials are listed in Section II, Part D, Subpart 1, Tables 2A, 2B, and 4. The material shall not be used at metal and design temperatures that exceed the temperature limit in the applicability column for which stress intensity values are listed. The values in the Table may be interpolated for intermediate temperatures.

##### NB-3113 Service Conditions

Each service condition to which the components may be subjected shall be classified in accordance with NCA-2142 and Service Limits [NCA-2142.4(b)] designated in the Design Specifications in such detail as will provide a complete basis for design, construction, and inspection in accordance with this Article. The requirements of (a) and (b) below shall also apply.

(a) *Level B Conditions.* The estimated duration of service conditions for which Level B Limits are specified shall be included in the Design Specifications.

(b) *Level C Conditions.* The total number of postulated occurrences for all specified service conditions for which Level C Limits are specified shall not cause more than 25 stress cycles having an  $S_a$  value greater than that for  $10^6$  cycles from the applicable fatigue design curves of Section III Appendices, Mandatory Appendix I, Figures I-9.1 through I-9.8.

### NB-3120 SPECIAL CONSIDERATIONS

#### NB-3121 Corrosion

Material subject to thinning by corrosion, erosion, mechanical abrasion, or other environmental effects shall have provision made for these effects during the design

or specified life of the component by a suitable increase in or addition to the thickness of the base metal over that determined by the design equations. Material added or included for these purposes need not be of the same thickness for all areas of the component if different rates of attack are expected for the various areas. It should be noted that the tests on which the design fatigue curves (Section III Appendices, Mandatory Appendix I, Figures I-9.1 through I-9.8) are based did not include tests in the presence of corrosive environments which might accelerate fatigue failure.

### NB-3122 Cladding

The rules of the following subparagraphs apply to the analysis of clad components constructed of material permitted in Section II, Part D, Subpart 1, Tables 2A and 2B.

**NB-3122.1 Primary Stresses.** No structural strength shall be attributed to the cladding in satisfying [NB-3221](#).

**NB-3122.2 Design Dimensions.** The dimensions given in (a) and (b) below shall be used in the design of the component:

(a) For components subjected to internal pressure, the inside diameter shall be taken at the nominal inner face of the cladding.

(b) For components subjected to external pressure, the outside diameter shall be taken at the outer face of the base metal.

**NB-3122.3 Secondary and Peak Stresses.** In satisfying [NB-3222.2](#) and [NB-3222.4](#), the presence of the cladding shall be considered with respect to both the thermal analysis and the stress analysis. The stresses in both materials shall be limited to the values specified in [NB-3222.2](#) and [NB-3222.4](#). However, when the cladding is of the integrally bonded type and the nominal thickness of the cladding is 10% or less of the total thickness of the component, the presence of the cladding may be neglected.

**NB-3122.4 Bearing Stresses.** In satisfying [NB-3227.1](#), the presence of cladding shall be included.

### NB-3123 Welding

**NB-3123.1 Dissimilar Welds.** In satisfying the requirements of this Subarticle, caution should be exercised in design and construction involving dissimilar metals having different coefficients of thermal expansion in order to avoid difficulties in service.

**NB-3123.2 Fillet Welded Attachments.** Fillet welds conforming to [Figure NB-4427-1](#) may be used for attachments to components except as limited by [NB-4433](#). Evaluation for cyclic loading shall be made in accordance with the appropriate Subarticle of [NB-3000](#), and shall include consideration of temperature differences between the component and the attachment, and of expansion or contraction of the component produced by internal or external pressure.

### NB-3124 Environmental Effects

Changes in material properties may occur due to environmental effects. In particular, fast neutron irradiation (>1 MeV) above a certain level may result in significant increase in the brittle fracture transition temperature and deterioration in the resistance to fracture at temperatures above the transition range (upper shelf energy). Therefore, nozzles or other structural discontinuities in ferritic vessels should preferably not be placed in regions of high neutron flux.

### NB-3125 Configuration

Accessibility to permit the examinations required by the Edition and Addenda of Section XI as specified in the Design Specification for the component shall be provided in the design of the component.

## NB-3130 GENERAL DESIGN RULES

### NB-3131 Scope

Design rules generally applicable to all components are provided in the following paragraphs. The design Subarticle for the specific component provides rules applicable to that particular component. In case of conflict between [NB-3130](#) and the design rules for a particular component, the component design rules govern.

### NB-3132 Dimensional Standards for Standard Products

Dimensions of standard products shall comply with the standards and specifications listed in Table NCA-7100-1 when the standard or specification is referenced in the specific design Subarticle. However, compliance with these standards does not replace or eliminate the requirements for stress analysis when called for by the design Subarticle for a specific component.

### NB-3133 Components Under External Pressure

**NB-3133.1 General.** Rules are given in this paragraph for determining the stresses under external pressure loading in spherical and cylindrical shells with or without stiffening rings, and tubular products consisting of pipes, tubes, and fittings. Charts for determining the stresses in shells, hemispherical heads, and tubular products are given in Section II, Part D, Subpart 3.

**NB-3133.2 Nomenclature.** The symbols used in this paragraph are defined as follows:

$A$  = factor determined from Figure G in Section II, Part D, Subpart 3 and used to enter the applicable material chart in Section II, Part D, Subpart 3. For the case of cylinders having  $D_o/T$  values less than 10, see [NB-3133.3\(b\)](#). Also, factor determined from the applicable chart in Section II, Part D, Subpart 3 for the material used in a stiffening ring, corresponding to the factor  $B$  and the design metal temperature for the shell under consideration.

- $A_s$  = cross-sectional area of a stiffening ring
- $B$  = factor determined from the applicable chart in Section II, Part D, Subpart 3 for the material used in a shell or stiffening ring at the design metal temperature, psi (MPa).
- $D_o$  = outside diameter of the cylindrical shell course or tube under consideration.
- $E$  = modulus of elasticity of material at Design Temperature, psi (MPa). For external pressure and axial compression design in accordance with this Section, the modulus of elasticity to be used shall be taken from the applicable materials chart in Section II, Part D, Subpart 3. (Interpolation may be made between lines for intermediate temperatures.) The modulus of elasticity values shown in Section II, Part D, Subpart 3 for material groups may differ from those values listed in Section II, Part D, Subpart 2, Tables TM for specific materials. Section II, Part D, Subpart 3 values shall be applied only to external pressure and axial compression design.
- $I$  = available moment of inertia of the combined ring-shell section about its neutral axis, parallel to the axis of the shell. The width of the shell which is taken as contributing to the combined moment of inertia shall not be greater than  $1.10\sqrt{D_o T_n}$  and shall be taken as lying one-half on each side of the centroid of the ring. Portions of shell plates shall not be considered as contributing area to more than one stiffening ring.
- $I_s$  = required moment of inertia of the combined ring-shell section about its neutral axis parallel to the axis of the shell.
- $L$  = total length of a tube between tubesheets, or the design length of a vessel section, taken as the largest of the following:
- (a) the distance between head tangent lines plus one-third of the depth of each head if there are no stiffening rings;
  - (b) the greatest center-to-center distance between any two adjacent stiffening rings; or
  - (c) the distance from the center of the first stiffening ring to the head tangent line plus one-third of the depth of the head, all measured parallel to the axis of the vessel
- $L_s$  = one-half the distance from the center line of the stiffening ring to the next line of support on one side, plus one-half of the center line distance to the next line of support on the other side of the stiffening ring, both measured parallel to the axis of the component. A line of support is:
- (a) a stiffening ring that meets the requirements of this paragraph;
  - (b) a circumferential line on a head at one-third the depth of the head from the head tangent line; or
  - (c) circumferential connection to a jacket for a jacketed section of a cylindrical shell.

- $P$  = external design pressure, psi (MPa) (gage or absolute, as required)
- $P_a$  = allowable external pressure, psi (MPa) (gage or absolute, as required)
- $R$  = inside radius of spherical shell
- $S$  = the lesser of 1.5 times the stress intensity at design metal temperature from Section II, Part D, Subpart 1, Tables 2A and 2B, or 0.9 times the tabulated yield strength at design metal temperature from Section II, Part D, Subpart 1, Table Y-1, psi (MPa)
- $T$  = minimum required thickness of cylindrical shell or tube, or spherical shell
- $T_n$  = nominal thickness used, less corrosion allowance, of cylindrical shell or tube

### NB-3133.3 Cylindrical Shells and Tubular Products.

(a) The minimum thickness of cylindrical shells or tubular products under external pressure having  $D_o/T$  values equal to or greater than 10 shall be determined by the procedure given in [Steps 1](#) through [8](#) below.

*Step 1.* Assume a value for  $T$ . Determine the ratios  $L/D_o$  and  $D_o/T$ .

*Step 2.* Enter Figure G in Section II, Part D, Subpart 3 at the value of  $L/D_o$  determined in [Step 1](#). For values of  $L/D_o$  greater than 50, enter the chart at a value of  $L/D_o$  of 50. For values of  $L/D_o$  less than 0.05, enter the chart at a value of  $L/D_o$  of 0.05.

*Step 3.* Move horizontally to the line for the value of  $D_o/T$  determined in [Step 1](#). Interpolation may be made for intermediate values of  $D_o/T$ . From this intersection move vertically downward and read the value of factor  $A$ .

*Step 4.* Using the value of  $A$  calculated in [Step 3](#), enter the applicable material chart in Section II, Part D, Subpart 3 for the material/temperature under consideration. Move vertically to an intersection with the material/temperature line for the design temperature. Interpolation may be made between lines for intermediate temperatures. In cases where the value at  $A$  falls to the right of the end of the material/temperature line, assume an intersection with the horizontal projection of the upper end of the material/temperature line. For values of  $A$  falling to the left of the material line, see [Step 7](#).

*Step 5.* From the intersection obtained in [Step 4](#) move horizontally to the right and read the value of  $B$ .

*Step 6.* Using this value of  $B$ , calculate the maximum allowable external pressure  $P_a$  using the following equation:

$$P_a = \frac{4B}{3(D_o/T)}$$

*Step 7.* For values of  $A$  falling to the left of the applicable material/temperature line, the value of  $P_a$  can be calculated using the following equation:

$$P_a = \frac{2AE}{3(D_o/T)}$$



*Step 8.* Compare  $P_a$  with  $P$ . If  $P_a$  is smaller than  $P$ , select a larger value for  $T$  and repeat the design procedure until a value for  $P_a$  is obtained that is equal to or greater than  $P$ .

(b) The minimum thickness of cylindrical shells or tubular products under external pressure having  $D_o/T$  values less than 10 shall be determined by the procedure given in [Steps 1](#) through [4](#) below.

*Step 1.* Using the same procedure as given in (a) above, obtain the value of  $B$ . For values of  $D_o/T$  less than 4, the value of factor  $A$  can be calculated using the following equation:

$$A = \frac{1.1}{(D_o/T)^2}$$

For values of  $A$  greater than 0.10 use a value of 0.10.

*Step 2.* Using the value of  $B$  obtained in [Step 1](#), calculate a value  $P_{a1}$  using the following equation:

$$P_{a1} = \left[ \frac{2.167}{(D_o/T)} - 0.0833 \right] B$$

*Step 3.* Calculate a value  $P_{a2}$  using the following equation:

$$P_{a2} = \frac{2S}{(D_o/T)} \left[ 1 - \frac{1}{(D_o/T)} \right]$$

*Step 4.* The smaller of the values of  $P_{a1}$  calculated in [Step 2](#) or  $P_{a2}$  calculated in [Step 3](#) shall be used for the maximum allowable external pressure  $P_a$ . Compare  $P_a$  with  $P$ . If  $P_a$  is smaller than  $P$ , select a larger value for  $T$  and repeat the design procedure until a value for  $P_a$  is obtained that is equal to or greater than  $P$ .

**NB-3133.4 Spherical Shells.** The minimum required thickness of a spherical shell under external pressure, either seamless or of built-up construction with butt joints, shall be determined by the procedure given in [Steps 1](#) through [6](#) below.

*Step 1.* Assume a value for  $T$  and calculate the value of factor  $A$  using the following equation:

$$A = \frac{0.125}{(R/T)}$$

*Step 2.* Using the value of  $A$  calculated in [Step 1](#), enter the applicable material chart in Section II, Part D, Subpart 3 for the material under consideration. Move vertically to an intersection with the material/temperature line for the design temperature. Interpolation may be made between lines for intermediate temperatures. In cases where the value of  $A$  falls to the right of the end of the material/temperature line, assume an intersection with the horizontal projection of the upper end of the material/temperature line. For values at  $A$  falling to the left of the material/temperature line, see [Step 5](#).

*Step 3.* From the intersection obtained in [Step 2](#), move horizontally to the right and read the value of factor  $B$ .

*Step 4.* Using the value of  $B$  obtained in [Step 3](#), calculate the value of the maximum allowable external pressure  $P_a$  using the following equation:

$$P_a = \frac{B}{(R/T)}$$

*Step 5.* For values of  $A$  falling to the left of the applicable material/temperature line for the Design Temperature, the value of  $P_a$  can be calculated using the following equation:

$$P_a = \frac{0.0625E}{(R/T)^2}$$

*Step 6.* Compare  $P_a$  obtained in [Step 4](#) or [5](#) with  $P$ . If  $P_a$  is smaller than  $P$ , select a larger value for  $T$ , and repeat the design procedure until a value for  $P_a$  is obtained that is equal to or greater than  $P$ .

#### **NB-3133.5 Stiffening Rings for Cylindrical Shells.**

(a) The required moment of inertia of the combined ring-shell section is given by the equation:

$$I_s = \frac{D_o^2 L_s (T + A_s/L_s) A}{10.9}$$

The available moment of inertia  $I$  for a stiffening ring shall be determined by the procedure given in [Steps 1](#) through [6](#) below.

*Step 1.* Assuming that the shell has been designed and  $D_o$ ,  $L_s$ , and  $T_n$  are known, select a member to be used for the stiffening ring and determine its area  $A_s$  and the value of  $I$  defined in [NB-3133.2](#). Then calculate  $B$  by the equation:

$$B = \frac{3}{4} \left( \frac{P D_o}{T_n + A_s/L_s} \right)$$

*Step 2.* Enter the right-hand side of the applicable material chart in Section II, Part D, Subpart 3 for the material under consideration at the value of  $B$  determined in [Step 1](#). If different materials are used for the shell and stiffening ring, then use the material chart resulting in the larger value for factor  $A$  in [Step 4](#) or [Step 5](#) below.

*Step 3.* Move horizontally to the left to the material/temperature line for the design metal temperature. For values of  $B$  falling below the left end of the material/temperature line, see [Step 5](#).

*Step 4.* Move vertically to the bottom of the chart and read the value of  $A$ .

*Step 5.* For values of  $B$  falling below the left end of the material/temperature line for the design temperature, the value of  $A$  can be calculated using the following equation:

$$A = 2B/E$$



*Step 6.* If the required  $I_s$  is greater than the computed moment of inertia  $I$  for the combined-ring shell section selected in [Step 1](#), a new section with a larger moment of inertia must be selected and a new  $I_s$  determined. If the required  $I_s$  is smaller than the computed  $I$  for the section selected in [Step 1](#), that section should be satisfactory.

(b) Stiffening rings may be attached to either the outside or the inside of the component by continuous welding.

**NB-3133.6 Cylinders Under Axial Compression.** The maximum allowable compressive stress to be used in the design of cylindrical shells and tubular products subjected to loadings that produce longitudinal compressive stresses in the shell or wall shall be the lesser of the values given in (a) or (b) below:

(a) the  $S_m$  value for the applicable material at design temperature given in Section II, Part D, Subpart 1, Tables 2A and 2B;

(b) the value of the factor  $B$  determined from the applicable chart contained in Section II, Part D, Subpart 3, using the following definitions for the symbols on the charts:

$R$  = inside radius of the cylindrical shell or tubular product

$T$  = minimum required thickness of the shell or tubular product, exclusive of the corrosion allowance

The value of  $B$  shall be determined from the applicable chart contained in Section II, Part D, Subpart 3 as given in [Steps 1](#) through [5](#) below.

*Step 1.* Using the selected values of  $T$  and  $R$ , calculate the value of factor  $A$  using the following equation:

$$A = \frac{0.125}{(R/T)}$$

*Step 2.* Using the value of  $A$  calculated in [Step 1](#), enter the applicable material chart in Section II, Part D, Subpart 3 for the material under consideration. Move vertically to an intersection with the material/temperature line for the design temperature. Interpolation may be made between lines for intermediate temperatures. In cases where the value at  $A$  falls to the right of the end of the material/temperature line, assume an intersection with the horizontal projection of the upper end of the material/temperature line. For values of  $A$  falling to the left of the material/temperature line, see [Step 4](#).

*Step 3.* From the intersection obtained in [Step 2](#), move horizontally to the right and read the value of factor  $B$ . This is the maximum allowable compressive stress for the values of  $T$  and  $R$  used in [Step 1](#).

*Step 4.* For values of  $A$  falling to the left of the applicable material/temperature line, the value of  $B$  shall be calculated using the following equation:

$$B = \frac{AE}{2}$$

*Step 5.* Compare the value of  $B$  determined in [Step 3](#) or [4](#) with the computed longitudinal compressive stress in the cylindrical shell or tube, using the selected values of  $T$  and  $R$ . If the value of  $B$  is smaller than the computed compressive stress, a greater value of  $T$  must be selected and the design procedure repeated until a value of  $B$  is obtained which is greater than the compressive stress computed for the loading on the cylindrical shell or tube.

## NB-3134 Leak Tightness

Where a system leak tightness greater than that required or demonstrated by a hydrostatic test is required, the leak tightness requirements for each component shall be set forth in the Design Specifications.

## NB-3135 Attachments

(a) Except as permitted in (d), (e), or (f) below, attachments and connecting welds within the jurisdictional boundary of the component as defined in [NB-1130](#) shall meet the stress limits of the component or [NB-3200](#).

(b) The design of the component shall include consideration of the localized interaction effects and loads transmitted through the attachment to and from the pressure-retaining portion of the component. Localized interaction effects include thermal stresses, stress concentrations, and restraint of the pressure-retaining portion of the component.

(c) The first welded structural attachment within  $2t$  of the pressure-retaining portion of the component, where  $t$  is the nominal thickness of the pressure-retaining material, shall be evaluated for cyclic loading. Evaluation shall be in accordance with the appropriate Subarticle of [NB-3000](#) and shall be made at the juncture of the attachment to the component.

(d) Beyond  $2t$  the appropriate design rules of [NF-3000](#) may be used as a substitute for the design rules of [NB-3000](#) for cast and forged portions of attachments which are in the component support load path.

(e) Nonstructural attachments shall meet the requirements of [NB-4435](#).

(f) Beyond  $2t$  the appropriate design rules of [NG-3000](#) may be used as a substitute for the design rules of [NB-3000](#) for portions of cast or forged attachments which are core support structures.

## NB-3136 Appurtenances

(a) Except as permitted in (b) below, the portions of appurtenances having a pressure retaining function shall be designed in accordance with the rules for components.

(b) Small diameter appurtenance fabrication weld joints may be designed using weld joint details in accordance with [Figure NB-4440-1](#), provided the following requirements are met.

(1) The appurtenance weld joint shall have an outside diameter equal to NPS 2 (DN 50) or less (see [Figure NB-4440-1](#)).

(2) The design of the welded joints shall be such that the stresses will not exceed the limits described in NB-3220 and tabulated in Section II, Part D, Subpart 1, Tables 2A and 2B.

(3) A fatigue strength reduction factor of 4 shall be used in the fatigue analysis of the joints.

(4) The requirements of NB-4440 and NB-5260 shall be satisfied.

### NB-3137 Reinforcement for Openings

The requirements applicable to vessels and piping are contained in NB-3330 and NB-3643, respectively.

## NB-3200 DESIGN BY ANALYSIS

### NB-3210 DESIGN CRITERIA

#### NB-3211 Requirements for Acceptability

The requirements for the acceptability of a design by analysis are given in (a) through (d) below.

(a) The design shall be such that stress intensities will not exceed the limits described in this Subarticle and in NB-3100 and tabulated in Section II, Part D, Subpart 1, Tables 2A, 2B, and 4.

(b) The design details shall conform to the rules given in NB-3100 and those given in the Subarticle applicable to the specific component.

(c) For configurations where compressive stresses occur, in addition to the requirements in (a) and (b) above, the critical buckling stress shall be taken into account. For the special case of external pressure, NB-3133 applies.

(d) Protection against nonductile fracture shall be provided by satisfying one of the following provisions:

(1) performing an evaluation of service and test conditions by methods similar to those contained in Appendix G; or

(2) for piping, pump, and valve material thickness greater than  $2\frac{1}{2}$  in. (64 mm) establishing a lowest service temperature<sup>7</sup> that is not lower than  $RT_{NDT}$  (NB-2331) + 100°F (56°C);

(3) for piping, pump, and valve material thickness equal to or less than  $2\frac{1}{2}$  in. (64 mm), the requirements of NB-2332(a) shall be met at or below the lowest service temperature as established in the design specification.

#### NB-3212 Basis for Determining Stresses

The theory of failure, used in the rules of this Subsection for combining stresses, is the maximum shear stress theory. The maximum shear stress at a point is equal to one-half the difference between the algebraically largest and the algebraically smallest of the three principal stresses at the point.

#### NB-3213 Terms Relating to Stress Analysis

Terms used in this Subsection relating to stress analysis are defined in the following subparagraphs.

**NB-3213.1 Stress Intensity.**<sup>8</sup> Stress intensity is defined as twice the maximum shear stress, which is the difference between the algebraically largest principal stress and the algebraically smallest principal stress at a given point. Tensile stresses are considered positive and compressive stresses are considered negative.

**NB-3213.2 Gross Structural Discontinuity.** Gross structural discontinuity is a geometric or material discontinuity that affects the stress or strain distribution through the entire wall thickness. Gross discontinuity-type stresses are those portions of the actual stress distributions that produce net bending and membrane force resultants when integrated through the wall thickness. Examples of a gross structural discontinuity are head-to-shell junctions, flange-to-shell junctions, nozzles, and junctions between shells of different diameters or thicknesses.

**NB-3213.3 Local Structural Discontinuity.** Local structural discontinuity is a geometric or material discontinuity that affects the stress or strain distribution through a fractional part of the wall thickness. The stress distribution associated with a local discontinuity causes only very localized deformation or strain and has no significant effect on the shell-type discontinuity deformations. Examples are small fillet radii, small attachments, and partial penetration welds.

**NB-3213.4 Normal Stress.** Normal stress is the component of stress normal to the plane of reference. This is also referred to as direct stress. Usually the distribution of normal stress is not uniform through the thickness of a part, so this stress is considered to have two components, one uniformly distributed and equal to the average stress across the thickness under consideration, and the other varying from this average value across the thickness.

**NB-3213.5 Shear Stress.** Shear stress is the component of stress tangent to the plane of reference.

**NB-3213.6 Membrane Stress.** Membrane stress is the component of normal stress that is uniformly distributed and equal to the average stress across the thickness of the section under consideration.

**NB-3213.7 Bending Stress.** Bending stress is the component of normal stress that varies across the thickness. The variation may or may not be linear.

**NB-3213.8 Primary Stress.** Primary stress is any normal stress or shear stress developed by an imposed loading that is necessary to satisfy the laws of equilibrium of external and internal forces and moments. The basic characteristic of a primary stress is that it is not self-limiting. Primary stresses that considerably exceed the yield strength will result in failure or, at least, in gross distortion. Primary membrane stress is divided into general and local categories. A general primary membrane stress

is one that is so distributed in the structure that no redistribution of load occurs as a result of yielding. Examples of primary stress are:

(a) general membrane stress in a circular cylindrical shell or a spherical shell due to internal pressure or to distributed loads;

(b) bending stress in the central portion of a flat head due to pressure;

Refer to [Table NB-3217-1](#) for examples of primary stress.

**NB-3213.9 Secondary Stress.** Secondary stress is a normal stress or a shear stress developed by the constraint of adjacent material or by self-constraint of the structure. The basic characteristic of a secondary stress is that it is self-limiting. Local yielding and minor distortions can satisfy the conditions that cause the stress to occur and failure from one application of the stress is not to be expected. Examples of secondary stress are:

(a) general thermal stress [[NB-3213.13\(a\)](#)];

(b) bending stress at a gross structural discontinuity.

Refer to [Table NB-3217-1](#) for examples of secondary stress.

**NB-3213.10 Local Primary Membrane Stress.** Cases arise in which a membrane stress produced by pressure or other mechanical loading and associated with a discontinuity would, if not limited, produce excessive distortion in the transfer of load to other portions of the structure. Conservatism requires that such a stress be classified as a local primary membrane stress even though it has some characteristics of a secondary stress.

A stressed region may be considered local if the distance over which the membrane stress intensity exceeds  $1.1S_m$  does not extend in the meridional direction more than  $1.0\sqrt{Rt}$ , where  $R$  is the minimum midsurface radius of curvature and  $t$  is the minimum thickness in the region considered. Regions of local primary stress intensity involving axisymmetric membrane stress distributions that exceed  $1.1S_m$  shall not be closer in the meridional direction than  $2.5\sqrt{R_L t_L}$ , where  $R_L$  is defined as  $(R_1 + R_2)/2$  and  $t_L$  is defined as  $(t_1 + t_2)/2$  (where  $t_1$  and  $t_2$  are the minimum thicknesses at each of the regions considered, and  $R_1$  and  $R_2$  are the minimum midsurface radii of curvature at these regions where the membrane stress intensity exceeds  $1.1S_m$ ). Discrete regions of local primary membrane stress intensity, such as those resulting from concentrated loads acting on brackets, where the membrane stress intensity exceeds  $1.1S_m$ , shall be spaced so that there is no overlapping of the areas in which the membrane stress intensity exceeds  $1.1S_m$ .

**NB-3213.11 Peak Stress.** Peak stress is that increment of stress that is additive to the primary plus secondary stresses by reason of local discontinuities or local thermal stress [[NB-3213.13\(b\)](#)] including the effects, if any, of stress concentrations. The basic characteristic of a peak stress is that it does not cause any noticeable dis-

tortion and is objectionable only as a possible source of a fatigue crack or a brittle fracture. A stress that is not highly localized falls into this category if it is of a type that cannot cause noticeable distortion. Examples of peak stress are:

(a) the thermal stress in the austenitic steel cladding of a carbon steel part;

(b) certain thermal stresses that may cause fatigue but not distortion;

(c) the stress at a local structural discontinuity;

(d) surface stresses produced by thermal shock.

**NB-3213.12 Load Controlled Stress.** Load controlled stress is the stress resulting from application of a loading, such as internal pressure, inertial loads, or gravity, whose magnitude is not reduced as a result of displacement.

**NB-3213.13 Thermal Stress.** Thermal stress is a self-balancing stress produced by a nonuniform distribution of temperature or by differing thermal coefficients of expansion. Thermal stress is developed in a solid body whenever a volume of material is prevented from assuming the size and shape that it normally would under a change in temperature. For the purpose of establishing allowable stresses, two types of thermal stress are recognized, depending on the volume or area in which distortion takes place, as described in (a) and (b) below.

(a) General thermal stress is associated with distortion of the structure in which it occurs. If a stress of this type, neglecting stress concentrations, exceeds twice the yield strength of the material, the elastic analysis may be invalid and successive thermal cycles may produce incremental distortion. Therefore this type is classified as secondary stress in [Table NB-3217-1](#). Examples of general thermal stress are:

(1) stress produced by an axial temperature distribution in a cylindrical shell;

(2) stress produced by the temperature difference between a nozzle and the shell to which it is attached;

(3) the equivalent linear stress<sup>9</sup> produced by the radial temperature distribution in a cylindrical shell.

(b) Local thermal stress is associated with almost complete suppression of the differential expansion and thus produces no significant distortion. Such stresses shall be considered only from the fatigue standpoint and are therefore classified as peak stresses in [Table NB-3217-1](#). In evaluating local thermal stresses the procedures of [NB-3227.6\(b\)](#) shall be used. Examples of local thermal stress are:

(1) the stress in a small hot spot in a vessel wall;

(2) the difference between the actual stress and the equivalent linear stress resulting from a radial temperature distribution in a cylindrical shell;

(3) the thermal stress in a cladding material that has a coefficient of expansion different from that of the base metal.

**NB-3213.14 Total Stress.** Total stress is the sum of the primary, secondary, and peak stress contributions. Recognition of each of the individual contributions is essential to establishment of appropriate stress limitations.

**NB-3213.15 Service Cycle.** Service cycle is defined as the initiation and establishment of new conditions followed by a return to the conditions that prevailed at the beginning of the cycle. The types of service conditions that may occur are further defined in NB-3113.

**NB-3213.16 Stress Cycle.** Stress cycle is a condition in which the alternating stress difference [NB-3222.4(e)] goes from an initial value through an algebraic maximum value and an algebraic minimum value and then returns to the initial value. A single service cycle may result in one or more stress cycles. Dynamic effects shall also be considered as stress cycles.

**NB-3213.17 Fatigue Strength Reduction Factor.** Fatigue strength reduction factor is a stress intensification factor which accounts for the effect of a local structural discontinuity (stress concentration) on the fatigue strength. Values for some specific cases, based on experiment, are given in NB-3338 and NB-3339. In the absence of experimental data, the theoretical stress concentration factor may be used.

**NB-3213.18 Free End Displacement.** Free end displacement consists of the relative motions that would occur between a fixed attachment and connected piping if the two members were separated and permitted to move.

**NB-3213.19 Expansion Stresses.** Expansion stresses are those stresses resulting from restraint of free end displacement of the piping system.

**NB-3213.20 Deformation.** Deformation of a component part is an alteration of its shape or size.

**NB-3213.21 Inelasticity.** Inelasticity is a general characteristic of material behavior in which the material does not return to its original shape and size after removal of all applied loads. Plasticity and creep are special cases of inelasticity.

**NB-3213.22 Creep.** Creep is the special case of inelasticity that relates to the stress-induced, time-dependent deformation under load. Small time-dependent deformations may occur after the removal of all applied loads.

**NB-3213.23 Plasticity.** Plasticity is the special case of inelasticity in which the material undergoes time-independent nonrecoverable deformation.

**NB-3213.24 Plastic Analysis.** Plastic analysis is that method which computes the structural behavior under given loads considering the plasticity characteristics of the materials, including strain hardening and the stress redistribution occurring in the structure.

**NB-3213.25 Plastic Analysis — Collapse Load.** A plastic analysis may be used to determine the collapse load for a given combination of loads on a given structure.

The following criterion for determination of the collapse load shall be used. A load-deflection or load-strain curve is plotted with load as the ordinate and deflection or strain as the abscissa. The angle that the linear part of the load-deflection or load-strain curve makes with the ordinate is called  $\theta$ . A second straight line, hereafter called the collapse limit line, is drawn through the origin so that it makes an angle  $\phi = \tan^{-1} (2 \tan \theta)$  with the ordinate. The collapse load is the load at the intersection of the load-deflection or load-strain curve and the collapse limit line. If this method is used, particular care should be given to ensure that the strains or deflections that are used are indicative of the load carrying capacity of the structure.

**NB-3213.26 Plastic Instability Load.** The plastic instability load for members under predominantly tensile or compressive loading is defined as that load at which unbounded plastic deformation can occur without an increase in load. At the plastic tensile instability load, the true stress in the material increases faster than strain hardening can accommodate.

**NB-3213.27 Limit Analysis.** Limit analysis is a special case of plastic analysis in which the material is assumed to be ideally plastic (nonstrain-hardening). In limit analysis, the equilibrium and flow characteristics at the limit state are used to calculate the collapse load. The two bounding methods which are used in limit analysis are the lower bound approach, which is associated with a statically admissible stress field, and the upper bound approach, which is associated with a kinematically admissible velocity field. For beams and frames, the term *mechanism* is commonly used in lieu of *kinematically admissible velocity* field.

**NB-3213.28 Limit Analysis — Collapse Load.** The methods of limit analysis are used to compute the maximum load that a structure assumed to be made of ideally plastic material can carry. At this load, which is termed the collapse load, the deformations of the structure increase without bound.

**NB-3213.29 Collapse Load — Lower Bound.** If, for a given load, any system of stresses can be found which everywhere satisfies equilibrium, and nowhere exceeds the material yield strength, the load is at or below the collapse load. This is the lower bound theorem of limit analysis which permits calculations of a lower bound to the collapse load.

**NB-3213.30 Plastic Hinge.** A plastic hinge is an idealized concept used in Limit Analysis. In a beam or a frame, a plastic hinge is formed at the point where the moment, shear, and axial force lie on the yield interaction surface. In plates and shells, a plastic hinge is formed where the generalized stresses lie on the yield surface.

**NB-3213.31 Strain Limiting Load.** When a limit is placed upon a strain, the load associated with the strain limit is called the strain limiting load.



**NB-3213.32 Test Collapse Load.** Test collapse load is the collapse load determined by tests according to the criteria given in II-1430.

**NB-3213.33 Ratcheting.** Ratcheting is a progressive incremental inelastic deformation or strain which can occur in a component that is subjected to variations of mechanical stress, thermal stress, or both.

**NB-3213.34 Shakedown.** Shakedown of a structure occurs if, after a few cycles of load application, ratcheting ceases. The subsequent structural response is elastic, or elastic-plastic, and progressive incremental inelastic deformation is absent. Elastic shakedown is the case in which the subsequent response is elastic.

**NB-3213.35 Reversing Dynamic Loads.** Reversing dynamic loads (Figure NB-3213-1) are those loads which cycle about a mean value and include building filtered and earthquake loads.

**NB-3213.36 Nonreversing Dynamic Loads.** Nonreversing dynamic loads (Figure NB-3213-1) are those loads which do not cycle about a mean value and include the initial thrust force due to sudden opening or closure of valves and waterhammer resulting from entrapped water in two-phase flow systems. Reflected waves in a piping system due to flow transients are classified as nonreversing dynamic loads.

## NB-3214 Stress Analysis

A detailed stress analysis of all major structural components shall be prepared in sufficient detail to show that each of the stress limitations of NB-3220 and NB-3230 is satisfied when the component is subjected to the loadings of NB-3110. As an aid to the evaluation of these stresses, equations and methods for the solution of certain recurring problems have been placed in Appendix A.

## NB-3215 Derivation of Stress Intensities

One requirement for the acceptability of a design (NB-3210) is that the calculated stress intensities shall not exceed specified allowable limits. These limits differ depending on the stress category (primary, secondary, etc.) from which the stress intensity is derived. This paragraph describes the procedure for the calculation of the stress intensities which are subject to the specified limits. The steps in the procedure are stipulated in (a) through (e) below.

(a) At the point on the component which is being investigated, choose an orthogonal set of coordinates, such as tangential, longitudinal, and radial, and designate them by the subscripts  $t$ ,  $l$ , and  $r$ . The stress components in these directions are then designated  $\sigma_t$ ,  $\sigma_l$ , and  $\sigma_r$  for direct stresses and  $\tau_{lt}$ ,  $\tau_{lr}$ , and  $\tau_{rt}$  for shear stresses.

(b) Calculate the stress components for each type of loading to which the part will be subjected, and assign each set of stress values to one or a group of the following categories:<sup>10</sup>

(1) general primary membrane stress  $P_m$  (NB-3213.8);

(2) local primary membrane stress  $P_L$  (NB-3213.10);

(3) primary bending stress  $P_b$  (NB-3213.7 and NB-3213.8);

(4) expansion stress  $P_e$  (NB-3213.19);

(5) secondary stress  $Q$  (NB-3213.9);

(6) peak stress  $F$  (NB-3213.11).

NB-3217 provides guidance for this step.

(c) For each category, calculate the algebraic sum of the  $\sigma_t$  values which result from the different types of loadings and similarly for the other five stress components. Certain combinations of the categories must also be considered.

(d) Translate the stress components for the  $t$ ,  $l$ , and  $r$  directions into principal stresses  $\sigma_1$ ,  $\sigma_2$ , and  $\sigma_3$ . In many pressure component calculations, the  $t$ ,  $l$ , and  $r$  directions may be so chosen that the shear stress components are zero and  $\sigma_1$ ,  $\sigma_2$ , and  $\sigma_3$  are identical to  $\sigma_t$ ,  $\sigma_l$ , and  $\sigma_r$ .

(e) Calculate the stress differences  $S_{12}$ ,  $S_{23}$ , and  $S_{31}$  from the relations:

$$S_{12} = \sigma_1 - \sigma_2$$

$$S_{23} = \sigma_2 - \sigma_3$$

$$S_{31} = \sigma_3 - \sigma_1$$

The stress intensity  $S$  is the largest absolute value of  $S_{12}$ ,  $S_{23}$ , and  $S_{31}$ .

NOTE: Membrane stress intensity is derived from the stress components averaged across the thickness of the section. The averaging shall be performed at the component level in (b) or (c) above.


## NB-3216 Derivation of Stress Differences

If the specified operation of the component does not meet the conditions of NB-3222.4(d), the ability of the component to withstand the specified cyclic service without fatigue failure shall be determined as provided in NB-3222.4(e). The determination shall be made on the basis of the stresses at a point of the component, and the allowable stress cycles shall be adequate for the specified service at every point. Only the stress differences due to cyclic service loadings as specified in the Design Specification need be considered.


**NB-3216.1 Constant Principal Stress Direction.** For any case in which the directions of the principal stresses at the point being considered do not change during the cycle, the steps stipulated in (a) through (c) below shall be taken to determine the alternating stress intensity.

(a) *Principal Stresses.* Consider the values of the three principal stresses at the point versus time for the complete stress cycle taking into account both the gross and local


**Figure NB-3213-1**  
**Examples of Reversing and Nonreversing Dynamic Loads**



**(a) Nonreversing Dynamic Load**  
**(Relief/Safety Valve Open End Discharge)**



**(b) Reversing Dynamic Load**  
**(Earthquake Load Cycling About Normal Operating Condition)**



**(c) Nonreversing Dynamic Load**  
**(Initial Water Slug Followed By Reflected Waves)**



structural discontinuities and the thermal effects which vary during the cycle. These are designated as  $\sigma_1$ ,  $\sigma_2$ , and  $\sigma_3$  for later identification.

(b) *Stress Differences.* Determine the stress differences  $S_{12} = \sigma_1 - \sigma_2$ ,  $S_{23} = \sigma_2 - \sigma_3$ , and  $S_{31} = \sigma_3 - \sigma_1$  versus time for the complete cycle. In what follows, the symbol  $S_{ij}$  is used to represent any one of these three stress differences.

(c) *Alternating Stress Intensity.* Determine the extremes of the range through which each stress difference  $S_{ij}$  fluctuates and find the absolute magnitude of this range for each  $S_{ij}$ . Call this magnitude  $S_{rij}$  and let  $S_{alt\ ij} = 0.5S_{rij}$ . The alternating stress intensity  $S_{alt}$  is the largest  $S_{alt\ ij}$  value.

**NB-3216.2 Varying Principal Stress Direction.** For any case in which the directions of the principal stresses at the point being considered do change during the stress cycle, it is necessary to use the more general procedure of (a) through (e) below.

(a) Consider the values of the six stress components  $\sigma_t$ ,  $\sigma_l$ ,  $\sigma_r$ ,  $\tau_{lt}$ ,  $\tau_{lr}$ , and  $\tau_{rt}$  versus time for the complete stress cycle, taking into account both the gross and local structural discontinuities and the thermal effects which vary during the cycle.

(b) Choose a point in time when the conditions are one of the extremes for the cycle (either maximum or minimum, algebraically) and identify the stress components at this time by the subscript  $i$ . In most cases it will be possible to choose at least one time during the cycle when the conditions are known to be extreme. In some cases it may be necessary to try different points in time to find the one which results in the largest value of alternating stress intensity.

(c) Subtract each of the six stress components  $\sigma_{ti}$ ,  $\sigma_{li}$ , etc., from the corresponding stress components  $\sigma_t$ ,  $\sigma_l$ , etc., at each point in time during cycle and call the resulting components  $\sigma'_t$ ,  $\sigma'_l$ , etc.

(d) At each point in time during the cycle, calculate the principal stresses  $\sigma'_1$ ,  $\sigma'_2$ , and  $\sigma'_3$  derived from the six stress components  $\sigma'_t$ ,  $\sigma'_l$ , etc. Note that the directions of the principal stresses may change during the cycle but each principal stress retains its identity as it rotates.

(e) Determine the stress differences  $S'_{12} = \sigma'_1 - \sigma'_2$ ,  $S'_{23} = \sigma'_2 - \sigma'_3$ , and  $S'_{31} = \sigma'_3 - \sigma'_1$  versus time for the complete cycle and find the largest absolute magnitude of any stress difference at any time. The alternating stress intensity  $S_{alt}$  is one-half of this magnitude.

## NB-3217 Classification of Stresses

Tables NB-3217-1 and NB-3217-2 provide assistance in the determination of the category to which a stress should be assigned.

## NB-3220 STRESS LIMITS FOR OTHER THAN BOLTS

### NB-3221 Design Loadings

The stress intensity limits that must be satisfied for the Design Loadings (NB-3112) stated in the Design Specifications are the four limits of this paragraph and the Special Stress Limits of NB-3227. The provisions of NB-3228 may provide relief from certain of these stress limits if plastic analysis techniques are applied. The design stress intensity values  $S_m$  are given by NB-3229. The limits are summarized by Figure NB-3221-1.

**NB-3221.1 General Primary Membrane Stress Intensity.** (Derived from  $P_m$  in Figure NB-3221-1.) This stress intensity is derived from the average value across the thickness of a section of the general primary stresses (NB-3213.8) produced by design internal pressure and other specified Design Mechanical Loads, but excluding all secondary and peak stresses. Averaging is to be applied to the stress components prior to determination of the stress intensity values. The allowable value of this stress intensity is  $S_m$  at the Design Temperature.

**NB-3221.2 Local Membrane Stress Intensity.** (Derived from  $P_L$  in Figure NB-3221-1.) This stress intensity is derived from the average value across the thickness of a section of the local primary stresses (NB-3213.10) produced by Design Pressure and specified Design Mechanical Loads, but excluding all thermal and peak stresses. Averaging is to be applied to the stress components prior to the determination of the stress intensity values. The allowable value of this stress intensity is  $1.5S_m$ .

**NB-3221.3 Primary Membrane (General or Local) Plus Primary Bending Stress Intensity.** (Derived from  $P_L \pm P_b$  in Figure NB-3221-1.) This stress intensity is derived from the highest value across the thickness of a section of the general or local primary membrane stresses plus primary bending stresses produced by Design Pressure and other specified Design Mechanical Loads, but excluding all secondary and peak stresses. For solid rectangular sections, the allowable value of this stress intensity is  $1.5S_m$ . For other than solid rectangular sections, a value of  $\alpha$  times the limit established in NB-3221.1 may be used, where the factor  $\alpha$  is defined as the ratio of the load set producing a fully plastic section to the load set producing initial yielding in the extreme fibers of the section. In the evaluation of the initial yield and fully plastic section capacities, the ratios of each individual load in the respective load set to each other load in that load set shall be the same as the respective ratios of the individual loads in the specified design load set. The value of  $\alpha$  shall not exceed the value calculated for bending only ( $P_m = 0$ ). In no case shall the value of  $\alpha$  exceed 1.5. The propensity for buckling of the part of the section that is in compression shall be investigated. The  $\alpha$  factor is not permitted for Level D Service Limits when inelastic component analysis is used as permitted in Appendix F.

**Table NB-3217-1**  
**Classification of Stress Intensity in Vessels for Some Typical Cases**

Vessel Part	Location	Origin of Stress	Type of Stress	Classification
Cylindrical or spherical shell	Shell plate remote from discontinuities	Internal pressure	General membrane Gradient through plate thickness	$P_m$ $Q$
		Axial thermal gradient	Membrane Bending	$Q$ $Q$
	Junction with head or flange	Internal pressure	Membrane Bending	$P_L$ $Q$ [Note (1)]
Any shell or head	Any section across entire vessel	External load or moment, or internal pressure	General membrane averaged across full section	$P_m$
		External load or moment	Bending across full section	$P_m$
	Near nozzle or other opening	External load or moment, or internal pressure	Local membrane Bending Peak (fillet or corner)	$P_L$ $Q$ $F$
	Any location	Temperature difference between shell and head	Membrane Bending	$Q$ $Q$
Dished head or conical head	Crown	Internal pressure	Membrane Bending	$P_m$ $P_b$
	Knuckle or junction to shell	Internal pressure	Membrane Bending	$P_L$ [Note (2)] $Q$
Flat head	Center region	Internal pressure	Membrane Bending	$P_m$ $P_b$
	Junction to shell	Internal pressure	Membrane Bending	$P_L$ $Q$ [Note (1)]
Perforated head or shell	Typical ligament in a uniform pattern	Pressure	Membrane (averaged through cross section) Bending (averaged through width of ligament, but gradient through plate) Peak	$P_m$ $P_b$ $F$
	Isolated or atypical ligament	Pressure	Membrane Bending Peak	$Q$ $F$ $F$

**Table NB-3217-1**  
**Classification of Stress Intensity in Vessels for Some Typical Cases (Cont'd)**

Vessel Part	Location	Origin of Stress	Type of Stress	Classification
Nozzle (NB-3227.5)	Within the limits of reinforcement defined by NB-3334	Pressure and external loads and moments, including those attributable to restrained free end displacements of attached piping	General membrane Bending (other than gross structural discontinuity stresses) averaged through nozzle thickness	$P_m$ $P_m$
		Pressure and external axial, shear, and torsional loads other than those attributable to restrained free end displacements of attached piping	General membrane stresses	$P_m$
	Outside the limits of reinforcement defined by NB-3334	Pressure and external loads and moments other than those attributable to restrained free end displacements of attached piping	Membrane Bending	$P_L$ $P_b$
		Pressure and all external loads and moments	Membrane Bending Peak	$P_L$ $Q$ $F$
	Nozzle wall	Gross structural discontinuities	Local membrane Bending Peak	$P_L$ $Q$ $F$
		Differential expansion	Membrane Bending Peak	$Q$ $Q$ $F$
Cladding	Any	Differential expansion	Membrane Bending	$F$ $F$
Any	Any	Radial temperature distribution [Note (3)]	Equivalent linear stress [Note (4)]	$Q$
			Nonlinear portion of stress distribution	$F$
Any	Any	Any	Stress concentration (notch effect)	$F$

GENERAL NOTE:  $Q$  and  $F$  classification of stresses refers to other than design condition (Figure NB-3222-1).

NOTES:

- (1) If the bending moment at the edge is required to maintain the bending stress in the middle to acceptable limits, the edge bending is classified as  $P_b$ . Otherwise, it is classified as  $Q$ .
- (2) Consideration shall also be given to the possibility of wrinkling and excessive deformation in vessels with a large diameter-thickness ratio.
- (3) Consider possibility of thermal stress ratchet.
- (4) Equivalent linear stress is defined as the linear stress distribution, which has the same net bending moment as the actual stress distribution.

**Table NB-3217-2**  
**Classification of Stress Intensity in Piping, Typical Cases**

Piping Component	Locations	Origin of Stress	Classification	Discontinuities Considered	
				Gross	Local
Pipe or tube, elbows, and reducers. Intersections and branch connections, except in crotch regions	Any, except crotch regions of intersections	Internal pressure	$P_m$ $P_L$ and $Q$ $F$	No Yes Yes	No No Yes
		Sustained mechanical loads, including weight Nonreversing dynamic loads	$P_b$ $P_L$ and $Q$ $F$	No Yes Yes	No No Yes
		Expansion	$P_e$ $F$	Yes Yes	No Yes
		Axial thermal gradient	$Q$ $F$	Yes Yes	No Yes
		Reversing dynamic loads	[Note (1)]	...	...
Intersections, including tees and branch connections	In crotch region	Internal pressure, sustained mechanical loads, expansion, and nonreversing dynamic loads	$P_L$ and $Q$ [Note (2)] $F$	Yes Yes	No Yes
		Axial thermal gradient	$Q$ $F$	Yes Yes	No Yes
		Reversing dynamic loads	[Note (1)]	...	...
Bolts and flanges	Any	Internal pressure, gasket compression, and bolt load	$P_m$ $Q$ $F$	No Yes Yes	No No Yes
		Thermal gradient	$Q$ $F$	Yes Yes	No Yes
		Expansion	$P_e$ $F$	Yes Yes	No Yes
Any	Any	Nonlinear radial thermal gradient	$F$	Yes	Yes
		Linear radial thermal gradient	$F$	Yes	No
		Anchor point motions, including those resulting from earthquake	$Q$	Yes	No

NOTES:

(1) The stress intensity resulting from this loading has special requirements that must be satisfied. For Level B Service Limits, these are provided in NB-3223(b)(2) and for Level D Service Limits in NB-3225(b).

(2) Analysis is not required when reinforced in accordance with NB-3643.

**NB-3221.4 External Pressure.** The provisions of NB-3133 apply.

### **NB-3222 Level A Service Limits**


Level A Service Limits must be satisfied for the Service Conditions [NCA-2142.4(b)(1)] for which these limits are designated in the Design Specifications and are the four limits of this paragraph and the Special Stress Limits of NB-3227. The provisions of NB-3228 may provide relief from certain of these stress limits if plastic analysis techniques are applied. The design stress intensity values  $S_m$  are given by NB-3229. The limits are summarized by Figure NB-3222-1.

**NB-3222.1 Primary Membrane and Bending Stress Intensities.** There are no specific limits established on the primary stresses in the Level A Limits. However, the stresses due to primary loads presented during normal service must be computed and combined with the effects of other loadings in satisfying the remaining limits.

**NB-3222.2 Primary Plus Secondary Stress Intensity.<sup>11</sup>** This stress intensity is derived from the highest value at any point across the thickness of a section of the general or local primary membrane stresses, plus primary bending stresses plus secondary stresses, produced by the specified service pressure and other specified mechanical loads and by general thermal effects associated with normal Service Conditions. The allowable value of the maximum range of this stress intensity is  $3S_m$ .

(13)

**Figure NB-3221-1**  
**Stress Categories and Limits of Stress Intensity for Design Conditions**

**NOTES:**

- (1) Bending component of primary stress for piping shall be the stress proportional to the distance from centroid of pipe cross section.
- (2) The symbols  $P_m$ ,  $P_L$ , and  $P_b$  do not represent single quantities, but rather sets of six quantities representing the six stress components  $\sigma_{tx}$ ,  $\sigma_{ty}$ ,  $\sigma_{rz}$ ,  $\tau_{tx}$ ,  $\tau_{ty}$ , and  $\tau_{rz}$ .


**NB-3222.3 Expansion Stress Intensity.** (Not applicable to vessels;  $P_e$  in Figure NB-3222-1.) This stress intensity is the highest value of stress, neglecting local structural discontinuities, produced at any point across the thickness of a section by the loadings that result from restraint of free end displacement. The allowable value of the maximum range of this stress intensity is  $3S_m$ .

**NB-3222.4 Analysis for Cyclic Operation.**

(a) *Suitability for Cyclic Condition.* The suitability of a component for specified service loadings involving cyclic application of loads and thermal conditions shall be determined by the methods described herein, except that the suitability of high strength bolts shall be determined by

the methods of NB-3232.3(b) and the possibility of thermal stress ratchet shall be investigated in accordance with NB-3222.5. If the specified Service Loadings of the component meet all of the conditions of (d) below, no analysis for cyclic service is required, and it may be assumed that the limits on peak stress intensities as governed by fatigue have been satisfied by compliance with the applicable requirements for material, design, fabrication, examination, and testing of this Subsection. If the Service Loadings do not meet all the conditions of (d) below, a fatigue analysis shall be made in accordance with (e) below or a fatigue test shall be made in accordance with II-1500.

**Figure NB-3222-1**  
**Stress Categories and Limits of Stress Intensity for Level A and Level B Service Limits**



NOTES:

(1) Bending component of primary stress due to mechanical loads for piping shall be the stress proportional to the distance from centroid of pipe cross-section. For piping, the calculation of  $P_b$  stresses is not required for reversing dynamic loads (including inertia earthquake effects). See NB-3223(b)(2).

(2) The symbols  $P_m$ ,  $P_L$ ,  $P_b$ ,  $P_e$ ,  $Q$ , and  $F$  do not represent single quantities, but sets of six quantities representing the six stress components  $\sigma_t$ ,  $\sigma_r$ ,  $\tau_{tr}$ ,  $\tau_{rt}$ ,  $\tau_{rr}$ , and  $\tau_{tt}$ .

(3) For Level B Service Limits for primary stress intensities generated by Level B Service Loadings, see NB-3223(a)(1).



### Figure NB-3222-1 Stress Categories and Limits of Stress Intensity for Level A and Level B Service Limits (Cont'd)

#### NOTES (CONT'D):

- (4) When the secondary stress is due to a temperature transient at the point at which the stresses are being analyzed or to restraint of free end deflection, the value of  $S_m$  shall be taken as the average of the tabulated  $S_m$  values for the highest and lowest temperatures of the metal during the transient. When part or all of the secondary stress is due to mechanical load, the value of  $S_m$  shall not exceed the value for the highest temperature during the transient.
- (5) Special rules for exceeding  $3S_m$  are provided in NB-3228.5.
- (6)  $S_a$  is obtained from the fatigue curves, Figure I-9.0. The allowable stress intensity for the full range of fluctuation is  $2S_a$ .
- (7) The stresses in category Q are those parts of the total stress that are produced by thermal gradients, structural discontinuities, etc., and they do not include primary stresses that may also exist at the same point. However, it should be noted that a detailed stress analysis frequently gives the combination of primary and secondary stresses directly and, when appropriate, this calculated value represents the total of  $P_m + P_b + Q$ , and not  $Q$  alone. Similarly, if the stress in category F is produced by a stress concentration, the quantity  $F$  is the additional stress produced by the notch over and above the nominal stress. For example, if a point has a nominal stress intensity  $P_m$  and has a notch with a stress concentration factor  $K$ , then  $P_m \leq S_m$ ,  $P_b = Q$ ,  $Q = 0$ ,  $F = P_m (K - 1)$ , and the total stress intensity equals  $P_m + P_m (K - 1) = KP_m$ . However,  $P_L$  is the total membrane stress that results from mechanical loads, including discontinuity effects, rather than a stress increment. Therefore, the  $P_L$  value always includes the  $P_m$  contribution.

(b) *Peak Stress Intensity.* This stress intensity is derived from the highest value at any point across the thickness of a section of the combination of all primary, secondary, and peak stresses produced by specified service pressures and other mechanical loads, and by general and local thermal effects associated with normal service conditions, and including the effects of gross and local structural discontinuities.

(c) *Conditions and Procedures.* The conditions and procedures of NB-3222.4 are based on a comparison of peak stresses with strain cycling fatigue data. The strain cycling fatigue data are represented by design fatigue strength curves of Figs. I-9.0. These curves show the allowable amplitude  $S_a$  of the alternating stress intensity component (one-half of the alternating stress intensity range) plotted against the number of cycles. This stress intensity amplitude is calculated on the assumption of elastic behavior and, hence, has the dimensions of stress, but it does not represent a real stress when the elastic range is exceeded. The fatigue curves are obtained from uniaxial strain cycling data in which the imposed strains have been multiplied by the elastic modulus and a design margin has been provided so as to make the calculated stress intensity amplitude and the allowable stress intensity amplitude directly comparable. Where necessary, the curves have been adjusted to include the maximum effects of mean stress, which is the condition where the stress fluctuates about a mean value that is different from zero. As a consequence of this procedure, it is essential that the requirements of NB-3222.2 be satisfied at all times with transient stresses included, and that the calculated value of the alternating stress intensity be proportional to the actual strain amplitude. To evaluate the effect of alternating stresses of varying amplitudes, a linear damage relation is assumed in (e) (5).

(d) *Components Not Requiring Analysis for Cyclic Service.* An analysis for cyclic service is not required, and it may be assumed that the limits on peak stress intensities as governed by fatigue have been satisfied for a component by compliance with the applicable requirements for material, design, fabrication, examination, and testing of this Subsection, provided the specified Service Loading<sup>12</sup> of the component or portion thereof meets all the conditions stipulated in (1) through (6) below.

(1) *Atmospheric to Service Pressure Cycle.* The specified number of times (including startup and shutdown) that the pressure will be cycled from atmospheric pressure to service pressure and back to atmospheric pressure during normal service does not exceed the number of cycles on the applicable fatigue curve of Figs. I-9.0 corresponding to an  $S_a$  value of three times the  $S_m$  value for the material at service temperature.

(2) *Normal Service Pressure Fluctuation.* The specified full range of pressure fluctuations during normal service does not exceed the quantity  $\frac{1}{3} \times \text{Design Pressure} \times$

$(S_a/S_m)$ , where  $S_a$  is the value obtained from the applicable design fatigue curve for the total specified number of significant pressure fluctuations and  $S_m$  is the allowable stress intensity for the material at service temperature. If the total specified number of significant pressure fluctuations exceeds the maximum number of cycles defined on the applicable design fatigue curve, the  $S_a$  value corresponding to the maximum number of cycles defined on the curve may be used. Significant pressure fluctuations are those for which the total excursion exceeds the quantity:

$$\text{Design Pressure} \times \frac{1}{3} \times (S/S_m)$$

where  $S$  is defined as follows.

(-a) If the total specified number of service cycles is  $10^6$  cycles or less,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for  $10^6$  cycles.

(-b) If the total specified number of service cycles exceeds  $10^6$  cycles,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for the maximum number of cycles defined on the curve.

(3) *Temperature Difference — Startup and Shutdown.* The temperature difference, °F (°C), between any two adjacent points<sup>13</sup> of the component during normal service does not exceed  $S_a/2E\alpha$ , where  $S_a$  is the value obtained from the applicable design fatigue curves for the specified number of startup-shutdown cycles,  $\alpha$  is the value of the instantaneous coefficient of thermal expansion and  $E$  at the mean value of the temperatures at the two points as given by Section II, Part D, Subpart 2, Tables TE and TM.

(4) *Temperature Difference — Normal Service.*<sup>14</sup> The temperature difference, °F (°C), between any two adjacent points<sup>13</sup> does not change<sup>15</sup> during normal service by more than the quantity  $S_a/2E\alpha$ , where  $S_a$  is the value obtained from the applicable design fatigue curve of Figs. I-9.0 for the total specified number of significant temperature difference fluctuations. A temperature difference fluctuation shall be considered to be significant if its total algebraic range exceeds the quantity  $S/2E\alpha$ , where  $S$  is defined as follows:

(-a) If the total specified number of service cycles is  $10^6$  cycles or less,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for  $10^6$  cycles.

(-b) If the total specified number of service cycles exceeds  $10^6$  cycles,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for the maximum number of cycles defined on the curve.

(5) *Temperature Difference — Dissimilar Materials.* For components fabricated from materials of differing moduli of elasticity or coefficients of thermal expansion, the total algebraic range of temperature fluctuation, °F (°C), experienced by the component during normal service does not exceed the magnitude  $S_a/2(E_1\alpha_1 - E_2\alpha_2)$ , where  $S_a$  is the value obtained from the applicable design fatigue curve for the total specified number of significant

temperature fluctuations,  $E_1$  and  $E_2$  are the moduli of elasticity, and  $\alpha_1$  and  $\alpha_2$  are the values of the instantaneous coefficients of thermal expansion at the mean temperature value involved for the two materials of construction given in Section II, Part D, Subpart 2, Tables TE and TM. A temperature fluctuation shall be considered to be significant if its total excursion exceeds the quantity  $S/2(E_1\alpha_1 - E_2\alpha_2)$ , where  $S$  is defined as follows:

(-a) If the total specified number of service cycles is  $10^6$  cycles or less,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for  $10^6$  cycles.

(-b) If the total specified number of service cycles exceeds  $10^6$  cycles,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for the maximum number of cycles defined on the curve. If the two materials used have different applicable design fatigue curves, the lower value of  $S_a$  shall be used in applying the rules of this paragraph.

(6) *Mechanical Loads.* The specified full range of mechanical loads, excluding pressure but including pipe reactions, does not result in load stresses whose range exceeds the  $S_a$  value obtained from the applicable design fatigue curve of Figs. I-9.0 for the total specified number of significant load fluctuations. If the total specified number of significant load fluctuations exceeds the maximum number of cycles defined on the applicable design fatigue curve, the  $S_a$  value corresponding to the maximum number of cycles defined on the curve may be used. A load fluctuation shall be considered to be significant if the total excursion of load stress exceeds the quantity  $S$ , where  $S$  is defined as follows.

(-a) If the total specified number of service cycles is  $10^6$  cycles or less,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for  $10^6$  cycles.

(-b) If the total specified number of service cycles exceeds  $10^6$  cycles,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for the maximum number of cycles defined on the curve.

(e) *Procedure for Analysis for Cyclic Loading.* If the specified Service Loadings for the component do not meet the conditions of (d), the ability of the component to withstand the specified cyclic service without fatigue failure shall be determined as provided in this subparagraph. The determination shall be made on the basis of the stresses at a point, and the allowable stress cycles shall be adequate for the specified Service Loadings at every point. Only the stress differences due to service cycles as specified in the Design Specifications need be considered. Compliance with these requirements means only that the component is suitable from the standpoint of possible fatigue failure; complete suitability for the specified Service Loadings is also dependent on meeting the general stress limits of NB-3222 and any applicable special stress limits of NB-3227.

(1) *Stress Differences.* For each condition of normal service, determine the stress differences and the alternating stress intensity  $S_a$  in accordance with NB-3216.

(2) *Local Structural Discontinuities.* These effects shall be evaluated for all conditions using stress concentration factors determined from theoretical, experimental, or photoelastic studies, or numerical stress analysis techniques. Experimentally determined fatigue strength reduction factors may be used when determined in accordance with the procedures of II-1600, except for high strength alloy steel bolting for which the requirements of NB-3232.3(c) shall apply when using the design fatigue curve of Section III Appendices, Mandatory Appendix I, Figure I-9.4. Except for the case of crack-like defects and specified piping geometries for which specific values are given in NB-3680, no fatigue strength reduction factor greater than five need be used.

(3) *Design Fatigue Curves.* Section III Appendices, Mandatory Appendix I, Figures I-9.1 through I-9.8 contain the applicable fatigue design curves for the materials permitted by this Subsection. When more than one curve is presented for a given material, the applicability of each is identified. Where curves for various strength levels of a material are given, linear interpolation may be used for intermediate strength levels of these materials. The strength level is the specified minimum room temperature value.

(4) *Effect of Elastic Modulus.* Multiply  $S_{alt}$  (as determined in NB-3216.1 or NB-3216.2) by the ratio of the modulus of elasticity given on the design fatigue curve to the value of the modulus of elasticity used in the analysis. Enter the applicable design fatigue curve of Figs. I-9.0 at this value on the ordinate axis and find the corresponding number of cycles on the abscissa. If the service cycle being considered is the only one which produces significant fluctuating stresses, this is the allowable number of cycles.

(5) *Cumulative Damage.* If there are two or more types of stress cycle which produce significant stresses, their cumulative effect shall be evaluated as stipulated in Steps 1 through 6 below.

*Step 1.* Designate the specified number of times each type of stress cycle of types 1, 2, 3, ...,  $n$ , will be repeated during the life of the component as  $n_1, n_2, n_3, \dots, n_n$ , respectively.

NOTE: In determining  $n_1, n_2, n_3, \dots, n_n$ , consideration shall be given to the superposition of cycles of various origins which produce a total stress difference range greater than the stress difference ranges of the individual cycles. For example, if one type of stress cycle produces 1,000 cycles of a stress difference variation from zero to +60,000 psi and another type of stress cycle produces 10,000 cycles of a stress difference variation from zero to -50,000 psi, the two types of cycle to be considered are defined by the following parameters:

(a) for type 1 cycle,  $n_1 = 1,000$  and  $S_{alt1} = (60,000 + 50,000)/2 = 55,000$  psi;

(b) for type 2 cycle,  $n_2 = 9,000$  and  $S_{alt2} = (50,000 + 0)/2 = 25,000$  psi.

*Step 2.* For each type of stress cycle, determine the alternating stress intensity  $S_{alt}$  by the procedures of NB-3216.1 or NB-3216.2 above. Call these quantities  $S_{alt1}, S_{alt2}, S_{alt3}, \dots, S_{altn}$ .

*Step 3.* For each value  $S_{alt\ 1}, S_{alt\ 2}, S_{alt\ 3}, \dots, S_{alt\ n}$ , use the applicable design fatigue curve to determine the maximum number of repetitions which would be allowable if this type of cycle were the only one acting. Call these values  $N_1, N_2, N_3, \dots, N_n$ .

*Step 4.* For each type of stress cycle, calculate the usage factors  $U_1, U_2, U_3, \dots, U_n$ , from  $U_1 = n_1/N_1, U_2 = n_2/N_2, U_3 = n_3/N_3, \dots, U_n = n_n/N_n$ .

*Step 5.* Calculate the cumulative usage factor  $U$  from  $U = U_1 + U_2 + U_3 + \dots + U_n$ .

*Step 6.* The cumulative usage factor  $U$  shall not exceed 1.0.

**NB-3222.5 Thermal Stress Ratchet.** It should be noted that under certain combinations of steady state and cyclic loadings there is a possibility of large distortions developing as the result of ratchet action; that is, the deformation increases by a nearly equal amount for each cycle. Examples of this phenomenon are treated in this subparagraph and in [NB-3227.3](#).

(a) The limiting value of the maximum cyclic thermal stress permitted in a portion of an axisymmetric shell loaded by steady state internal pressure in order to prevent cyclic growth in diameter is as follows. Let

$x$  = maximum general membrane stress due to pressure divided by the yield strength<sup>16</sup>  $S_y$   
 $y'$  = maximum allowable range of thermal stress computed on an elastic basis divided by the yield strength<sup>16</sup>  $S_y$

(1) Case 1: Linear variation of temperature through the wall: for  $0 < x < 0.5, y' = 1/x$  and, for  $0.5 < x < 1.0, y' = 4(1-x)$ .

(2) Case 2: Parabolic constantly increasing or constantly decreasing variation of temperature through the wall: for  $0.615 < x < 1.0, y' = 5.2(1-x)$  and, approximately for  $x < 0.615, y' = 4.65, 3.55, \text{ and } 2.70$  for  $x = 0.3, 0.4, \text{ and } 0.5$ , respectively.

(b) Use of yield strength  $S_y$  in the above relations instead of the proportional limit allows a small amount of growth during each cycle until strain hardening raises the proportional limit to  $S_y$ . If the yield strength of the material is higher than two times the  $S_a$  value for the maximum number of cycles on the applicable fatigue curve of Figs. I-9.0 for the material, the latter value shall be used if there is to be a large number of cycles because strain softening may occur.

**NB-3222.6 Deformation Limits.** Any deformation limits prescribed by the Design Specifications shall be satisfied.

## NB-3223 Level B Service Limits

(a) For components other than piping operating within the temperature limits of this Subsection, the requirements of (1), (2), and (3) below shall apply.

(1) The values of Level A Service Limits shall apply for Level B Service Limits, except that for primary stress intensities generated by Level B Service Loadings, allowable stress intensity values of 110% of those given in [Figure NB-3221-1](#) shall apply.

(2) In evaluating possible exemption from fatigue analysis by the methods of [NB-3222.4\(d\)](#), Service Loadings for which Level B Limits are designated shall be considered as though Level A Limits were designated.

(3) Any deformation limits prescribed by the Design Specifications shall be satisfied.

(b) For piping components operating within the temperature limits of this Subsection, the requirements of (1) or (2) below shall apply.

(1) For Level B Service Limits which do not include reversing dynamic loads ([NB-3213.35](#)) or have reversing dynamic loads combined with nonreversing dynamic loads ([NB-3213.36](#)), the requirements of (a)(1), (a)(2), and (a)(3) above shall be satisfied.

(2) For Level B Service Limits which include reversing dynamic loads that are not required to be combined with nonreversing dynamic loads, the requirements of [NB-3222.2](#) and [NB-3222.4\(e\)](#) shall be satisfied in lieu of (b)(1) above. In addition, any deflection limits prescribed by the Design Specification must be satisfied.

## NB-3224 Level C Service Limits

If the Design Specifications specify any Service Loadings for which Level C Service Limits are designated [[NCA-2142.4\(b\)\(3\)](#) and [NB-3113\(b\)](#)] for components other than piping, the rules used in evaluating these loadings shall be those used for other loadings, except as modified by the following subparagraphs and as summarized in [Figure NB-3224-1](#). For piping, special requirements are provided in [NB-3224.7](#).

**NB-3224.1 Primary Stress Limits.** The primary stress limits of [NB-3221](#) shall be satisfied using an  $S_m$  value equal to the greater of 120% of the tabulated  $S_m$  value or 100% of the tabulated yield strength, with both values taken at the appropriate temperature. In addition, for ferritic material, the  $P_m$  elastic analysis limits for pressure loadings alone shall be equal to the greater of  $1.1S_m$  or  $0.9S_y$ .

**NB-3224.2 External Pressure.** The permissible external pressure shall be taken as 120% of that given by the rules of [NB-3133](#).

**NB-3224.3 Special Stress Limits.** The permissible values for special stress limit shall be taken as 120% of the values given in [NB-3227.4](#) and [NB-3228](#).

**NB-3224.4 Secondary and Peak Stresses.** The requirements of [NB-3222.2](#), [NB-3222.4](#), [NB-3222.5](#), and [NB-3227.3](#) need not be satisfied.

**Figure NB-3224-1**  
**Stress Categories and Limits of Stress Intensity for Level C Service Limits**

Stress Category	Primary [Notes (1) and (2)]			Secondary [Notes (1) and (2)] Membrane Plus Bending	Peak [Notes (1) and (2)]
	General Membrane	Local Membrane	Bending		
Description (for examples see Table NB-3217-1)	Average primary stress across solid section. Excludes discontinuities and concentrations. Produced only by mechanical loads.	Average stress across any solid section. Considers discontinuities but not concentrations. Produced only by mechanical loads.	Component of primary stress proportional to distance from centroid of solid section. Excludes discontinuities and concentrations. Produced only by mechanical loads.	Self-equilibrating stress necessary to satisfy continuity of structure. Occurs at structural discontinuities. Can be caused by mechanical load or by differential thermal expansion. Excludes local stress concentration.	(1) Increment added to primary or secondary stress by a concentration (notch). (2) Certain thermal stresses which may cause fatigue but not distortion of vessel shape.
Symbol [Note (1)]	$P_m$ NB-3213.6 and NB-3213.8 [Note (3)]	$P_L$ NB-3213.10	$P_b$ NB-3213.7 and NB-3213.8	$Q$ NB-3213.9	$F$ NB-3213.11
Combination of stress components and allowable limits of stress intensities					

**Legend**

- Allowable Value
- Calculated Value
- Service Condition Loads

GENERAL NOTE: For configurations where compressive stresses occur, the stress limits shall be revised to take into account critical buckling stresses [NB-3211(c)].

**NOTES:**

- (1) The symbols  $P_m$ ,  $P_L$ ,  $P_b$ ,  $Q$ , and  $F$  do not represent single quantities, but rather sets of six quantities representing the six stress components  $\sigma_t$ ,  $\sigma_l$ ,  $\sigma_r$ ,  $\tau_{lt}$ ,  $\tau_{lr}$ , and  $\tau_{rt}$ .
- (2) For piping, alternative requirements are provided in NB-3224.7.
- (3) The limits shown are for stresses resulting from pressure in combination with other mechanical loads. For ferritic materials, the  $P_m$  elastic analysis limits for pressure loadings alone shall be equal to the greater of  $1.1S_m$  or  $0.9S_y$ .
- (4) Use the greater of the values specified.
- (5)  $C_L$  the collapse load calculated on the basis of the lower bound theorem of limit analysis and yield strength values specified in Section II, Part D, Subpart 1, Table Y-1.
- (6) The triaxial stresses represent the algebraic sum of the three primary principal stresses ( $\sigma_1 + \sigma_2 + \sigma_3$ ) for the combination of stress components.



**NB-3224.5 Fatigue Requirements.** Service Loadings for which Level C Service Limits are designated need not be considered when applying the procedures of NB-3224.4(a) to determine whether or not a fatigue analysis is required.

**NB-3224.6 Deformation Limits.** Any deformation limits prescribed by the Design Specifications shall be considered.

**NB-3224.7 Piping Requirements.**

(a) For Level C Service Limits which do not include reversing dynamic loads or have reversing dynamic load combined with nonreversing dynamic loads, the requirements of NB-3224.1 through NB-3224.6 above shall be satisfied.

(b) As an alternative to (a) above, for Level C Service Limits which include reversing dynamic loads that are not required to be combined with nonreversing dynamic loads, the requirements of NB-3655.2(b) may be satisfied.

**NB-3225 Level D Service Limits**

(a) For components other than piping, if the Design Specifications specify any Service Loadings for which Level D Limits are designated [NCA-2142.4(b)(4)], the rules contained in Appendix F may be used in evaluating these loadings, independently of all other Design and Service Loadings.

(b) For piping fabricated from material designated P-No. 1 through P-No. 9 in Table 2A, Section II, Part D, if the Design Specifications specify any Service Loading for which Level D Limits are designated [NCA-2142.4(b)(4)], the rules contained in NB-3656(b) may be used as an alternative to those contained in Appendix F. For other piping materials, the rules of Appendix F may be used in evaluating these loadings, independently of all other Design and Service Loadings.

**NB-3226 Testing Limits**

The evaluation of pressure test loadings (NCA-2142.3) shall be in accordance with (a) through (e) below, except that these rules do not apply to the items in NB-3500.

(a) If the calculated pressure at any point in a vessel, including static head, exceeds the required test pressure defined in NB-6221 or NB-6321 by more than 6%, the resulting stresses shall be calculated using all the loadings that may exist during the test. The stress allowables for this situation are given in (b) and (c) below.

(b) For hydrostatically tested vessels, the general primary membrane stress intensity  $P_m$  shall not exceed 90% of the tabulated yield strength  $S_y$  at test temperature. For pneumatically tested vessels,  $P_m$  shall not exceed 80% of the tabulated yield strength  $S_y$  at test temperature.

(c) For either hydrostatically or pneumatically tested vessels, the primary membrane plus bending stress intensity  $P_m + P_b$  shall not exceed the applicable limits given in (1) or (2) below.

(1) For  $P_m \leq 0.67S_y$

$$P_m + P_b \leq 1.35S_y$$

(2) For  $0.67S_y < P_m \leq 0.90S_y$

$$P_m + P_b \leq (2.15S_y - 1.2P_m)$$

$S_y$  is the tabulated yield strength at test temperature. For other than rectangular sections,  $P_m + P_b$  shall not exceed a value of  $\alpha \times 0.9S_y$  for hydrostatic tests or  $\alpha \times 0.8S_y$  for pneumatic tests, where the factor  $\alpha$  is defined as the ratio of the load set producing a fully plastic section divided by the load set producing initial yielding in the extreme fibers of the section.

(d) The external pressure shall not exceed 135% of the value determined by the rules of NB-3133. Alternatively, an external hydrostatic test pressure may be applied up to a maximum of 80% of the lower of the collapse or elastic instability pressures determined by analysis or experimental procedures (NB-3228 and Appendix II) including consideration of allowable tolerances. If a collapse analysis is performed, it shall be a lower bound limit analysis assuming ideally elastic-plastic (nonstrain-hardening) material having a yield strength equal to its tabulated yield strength at test temperature.

(e) Tests, with the exception of either the first 10 hydrostatic tests in accordance with NB-6220, the first 10 pneumatic tests in accordance with NB-6320, or any combination of 10 such tests, shall be considered in the fatigue evaluation of the component. In this fatigue evaluation, the limits on the primary plus secondary stress intensity range (NB-3222.2) may be taken as the larger of  $3S_m$  or  $2S_y$  when at least one extreme of the stress intensity range is determined by the Test Loadings.

**NB-3227 Special Stress Limits**

The following deviations from the basic stress limits are provided to cover special Service Loadings or configurations. Some of these deviations are more restrictive, and some are less restrictive, than the basic stress limits. In cases of conflict between these requirements and the basic stress limits, the rules of NB-3227 take precedence for the particular situations to which they apply.

**NB-3227.1 Bearing Loads.**

(a) The average bearing stress for resistance to crushing under the maximum load, experienced as a result of Design Loadings, Test Loadings, or any Service Loadings, except those for which Level D Limits are designated, shall be limited to  $S_y$  at temperature, except that when the distance to a free edge is larger than the distance over which the bearing load is applied, a stress of  $1.5S_y$  at temperature is permitted. For clad surfaces, the yield strength of the base metal may be used if, when calculating the bearing stress, the bearing area is taken as the lesser of the actual contact area or the area of the base metal supporting the contact surface.



(b) When bearing loads are applied near free edges, such as at a protruding ledge, the possibility of a shear failure shall be considered. In the case of load stress only (NB-3213.12) the average shear stress shall be limited to  $0.6S_m$ . In the case of load stress plus secondary stress (NB-3213.9) the average shear stress shall not exceed (1) or (2) below:

(1) for materials to which Note G7 of Table 2A or Note G1 of Table 2B, Section II, Part D, Subpart 1 applies, the lower of  $0.5S_y$  at  $100^\circ\text{F}$  ( $38^\circ\text{C}$ ) and  $0.675S_y$  at temperature;

(2) for all other materials,  $0.5S_y$  at temperature.

For clad surfaces, if the configuration or thickness is such that a shear failure could occur entirely within the clad material, the allowable shear stress for the cladding shall be determined from the properties of the equivalent wrought material. If the configuration is such that a shear failure could occur across a path that is partially base metal and partially clad material, the allowable shear stresses for each material shall be used when evaluating the combined resistance to this type of failure.

(c) When considering bearing stresses in pins and similar members, the  $S_y$  at temperature value is applicable, except that a value of  $1.5S_y$  may be used if no credit is given to bearing area within one pin diameter from a plate edge.

#### NB-3227.2 Pure Shear.

(a) The average primary shear stress across a section loaded in pure shear, experienced as a result of Design Loadings, Test Loadings, or any Service Loadings, except those for which Level D Limits are designated (for example, keys, shear rings, screw threads), shall be limited to  $0.6S_m$ .

(b) The maximum primary shear that is experienced as a result of Design Loadings, Test Loadings, or any Service Loadings (except those for which Level D Limits are designated), exclusive of stress concentration, at the periphery of a solid circular section in torsion shall be limited to  $0.8S_m$ . Primary plus secondary and peak shear stresses shall be converted to stress intensities (equal to two times the pure shear stress) and as such shall not exceed the basic stress limits of NB-3222.2 and NB-3222.4.

**NB-3227.3 Progressive Distortion of Nonintegral Connections.** Screwed on caps, screwed in plugs, shear ring closures, and breech lock closures are examples of nonintegral connections which are subject to failure by bell mousing or other types of progressive deformation. If any combination of applied loads produces yielding, such joints are subject to ratcheting because the mating members may become loose at the end of each complete operating cycle and start the next cycle in a new relationship with each other, with or without manual manipulation. Additional distortion may occur in each cycle so that interlocking parts, such as threads, can eventually lose engagement. Therefore, primary plus secondary stress intensities (NB-3222.2), which result in slippage between the parts of a nonintegral connection in which dis-

engagement could occur as a result of progressive distortion, shall be limited to the value  $S_y$  (Section II, Part D, Subpart 1, Table Y-1).

**NB-3227.4 Triaxial Stresses.** The algebraic sum of the three primary principal stresses ( $\sigma_1 + \sigma_2 + \sigma_3$ ) shall not exceed four times the tabulated value of  $S_m$ , except for Service Level D.

**NB-3227.5 Nozzle Piping Transition.** Within the limits of reinforcement given by NB-3334, whether or not nozzle reinforcement is provided, the  $P_m$  classification is applicable to stress intensities resulting from pressure-induced general membrane stresses as well as stresses other than discontinuity stresses due to external loads and moments including those attributable to restrained free end displacements of the attached pipe. Also, within the limits of reinforcement, a  $P_L$  classification shall be applied to local primary membrane stress intensities derived from discontinuity effects plus primary bending stress intensities due to combined pressure and external loads and moments, including those attributable to restrained free end displacements of the attached pipe; and a  $P_L + P_b + Q$  classification shall apply to primary plus secondary stress intensities resulting from a combination of pressure, temperature, and external loads and moments, including those due to restrained free end displacements of the attached pipe. Beyond the limits of reinforcement, a  $P_m$  classification is applicable to stress intensities resulting from pressure-induced general membrane stresses as well as the average stress across the nozzle thickness due to externally applied nozzle axial, shear, and torsional loads other than those attributable to restrained free end displacement of the attached pipe. Also, outside the limits of reinforcement a  $P_L + P_b$  classification is applicable to the stress intensities that result from adding those stresses classified as  $P_m$  to those due to externally applied bending moments, except those attributable to restrained free end displacement of the pipe. Further, beyond the limits of reinforcement, a  $P_L + P_b + Q$  classification is applicable to stress intensities resulting from all pressure, temperature, and external loads and moments, including those attributable to restrained free end displacements of the attached pipe. Beyond the limits of reinforcement, the  $3S_m$  limit on the range of primary plus secondary stress intensity may be exceeded as provided in NB-3228.5, except that in the evaluation of NB-3228.5(a) stresses from restrained free end displacements of the attached pipe may also be excluded. The range of membrane plus bending stress intensity attributable solely to the restrained free end displacements of the attached pipe shall be  $\leq 3S_m$ . The nozzle, outside the reinforcement limit, shall not be thinner than the larger of the pipe thickness or the quantity  $t_p(S_{mp}/S_{mn})$ , where  $t_p$  is the nominal thickness of the mating pipe,  $S_{mp}$  is the allowable stress intensity value for the pipe material, and  $S_{mn}$  is the allowable stress intensity value for the nozzle material.

**NB-3227.6 Applications of Elastic Analysis for Stresses Beyond the Yield Strength.** Certain of the allowable stresses permitted in the design criteria are such that the maximum stress calculated on an elastic basis may exceed the yield strength of the material. The limit on primary plus secondary stress intensity of  $3S_m$  (NB-3222.2) has been placed at a level which ensures shakedown to elastic action after a few repetitions of the stress cycle except in regions containing significant local structural discontinuities or local thermal stresses. These last two factors are considered only in the performance of a fatigue evaluation. Therefore:

(a) In evaluating stresses for comparison with the stress limits on other than fatigue allowables, stresses shall be calculated on an elastic basis.

(b) In evaluating stresses for comparison with fatigue allowables, all stresses, except those which result from local thermal stresses [NB-3213.13(b)], shall be evaluated on an elastic basis. In evaluating local thermal stresses, the elastic equations shall be used, except that the numerical value substituted for Poisson's ratio shall be determined from the expression:

$$\nu = 0.5 - 0.2 \left( S_y / S_a \right), \text{ but not less than } 0.3$$

where

$S_a$  = alternating stress intensity determined in NB-3222.4(e) prior to the elastic modulus adjustment in NB-3222.4(e)(4)

$S_y$  = yield strength of the material at the mean value of the temperature of the cycle

**NB-3227.7 Requirements for Specially Designed Welded Seals.**

(a) Welded seals, such as omega and canopy seals (NB-4360), shall be designed to meet the pressure induced general primary membrane stress intensity limits specified in this Subsection. Note that the general primary membrane stress intensity varies around the toroidal cross section.

(b) All other membrane and bending stress intensities developed in the welded seals may be considered as secondary stress intensities. The range of these stress intensities combined with the general primary membrane stress intensity may exceed the primary plus secondary stress intensity limit of  $3S_m$  if they are analyzed in accordance with NB-3228.5 as modified in (1) and (2) below.

(1) In lieu of NB-3228.5(a), the range of the combined primary plus secondary membrane stress intensities shall be  $\leq 3S_m$ .

(2) NB-3228.5(d) need not apply.

**NB-3228 Applications of Plastic Analysis**

The following subparagraphs provide guidance in the application of plastic analysis and some relaxation of the basic stress limits which are allowed if plastic analysis is used.

**NB-3228.1 Limit Analysis.** The limits on General Membrane Stress Intensity (NB-3221.1), Local Membrane Stress Intensity (NB-3221.2), and Primary Membrane Plus Primary Bending Stress Intensity (NB-3221.3) need not be satisfied at a specific location if it can be shown by limit analysis that the specified loadings do not exceed two-thirds of the lower bound collapse load. The yield strength to be used in these calculations is  $1.5S_m$ . The use of  $1.5S_m$  for the yield strength of those materials of Section II, Part D, Subpart 1, Tables 2A and 2B to which Note (G7) in Table 2A and Note (G1) in Table 2B is applicable may result in small permanent strains during the first few cycles of loading. If these strains are not acceptable, the yield strength to be used shall be reduced according to the strain limiting factors of Section II, Part D, Subpart 1, Table Y-2. When two-thirds of the lower bound collapse load is used, the effects of plastic strain concentrations in localized areas of the structure such as the points where hinges form must be considered. The effects of these concentrations of strain on the fatigue behavior, ratcheting behavior, or buckling behavior of the structure must be considered in the design. The design shall satisfy the minimum wall thickness requirements.

**NB-3228.2 Experimental Analysis.** The limits of General Primary Membrane Stress Intensity (NB-3221.1), Local Membrane Stress Intensity (NB-3221.2), and Primary Membrane Plus Primary Bending Stress Intensity (NB-3221.3) need not be satisfied at a specific location if it can be shown that the specified loadings do not exceed two-thirds of the test collapse load determined by application of II-1430, in which case the effects of plastic strain concentrations in localized areas of the structure, such as the points where hinges form, must be considered. The effects of these concentrations of strain on the fatigue behavior, ratcheting behavior, or buckling behavior of the structure must be considered in the design. The design shall satisfy the minimum wall thickness requirements.

**NB-3228.3 Plastic Analysis.** Plastic analysis is a method of structural analysis by which the structural behavior under given loads is computed by considering the actual material stress-strain relationship and stress redistribution, and it may include either strain hardening or change in geometry, or both.

The limits of General Membrane Stress Intensity (NB-3221.1), Local Membrane Stress Intensity (NB-3221.2), and Primary Membrane Plus Primary Bending Stress Intensity (NB-3221.3) need not be satisfied at a specific location if it can be shown that the specified loadings do not exceed two-thirds of the plastic analysis collapse load determined by application of II-1430 to a

load-deflection or load-strain relationship obtained by plastic analysis. When this rule is used, the effects of plastic strain concentrations in localized areas of the structure, such as the points where hinges form, must be considered. The effects of the concentrations of strain on the fatigue behavior, ratcheting behavior, or buckling behavior of the structure must be considered in the design. The design shall satisfy the minimum wall thickness requirements.

**NB-3228.4 Shakedown Analysis.** The limits on Thermal Stress Ratchet in Shell (NB-3222.5) and Progressive Distortion of Nonintegral Connections (NB-3227.3) need not be satisfied at a specific location, if, at the location, the procedures of (a) through (c) below are used.

(a) In evaluating stresses for comparison with the remaining stress limits, the stresses shall be calculated on an elastic basis.

(b) In lieu of satisfying the specific requirements of NB-3221.2, NB-3222.2, NB-3222.5, and NB-3227.3 at a specific location, the structural action shall be calculated on a plastic basis, and the design shall be considered to be acceptable if shakedown occurs (as opposed to continuing deformation). However, this shakedown requirement need not be satisfied for materials having a minimum specified yield strength to specified minimum ultimate strength ratio of less than 0.70 provided the maximum accumulated local strain at any point, as a result of cyclic operation to which plastic analysis is applied, does not exceed 5.0%. In all cases, the deformations which occur shall not exceed specified limits.

(c) In evaluating stresses for comparison with fatigue allowables, the numerically maximum principal total strain range shall be multiplied by one-half the modulus of elasticity of the material (Section II, Part D, Subpart 2, Tables TM) at the mean value of the temperature of the cycle.

**NB-3228.5 Simplified Elastic-Plastic Analysis.** The  $3S_m$  limit on the range of primary plus secondary stress intensity (NB-3222.2) may be exceeded provided that the requirements of (a) through (f) below are met.

(a) The range of primary plus secondary membrane plus bending stress intensity, excluding thermal bending stresses, shall be  $\leq 3S_m$ .

(b) The value of  $S_a$  used for entering the design fatigue curve is multiplied by the factor  $K_e$ , where

$$K_e = 1.0, \text{ for } S_n \leq 3S_m$$

$$= 1.0 + \left[ \frac{(1 - n)}{n(m - 1)} \right] (S_n / 3S_m - 1),$$

$$\text{for } 3S_m < S_n < 3mS_m$$

$$= 1/n, \text{ for } S_n \geq 3mS_m$$

$S_n$  = range of primary plus secondary stress intensity, psi

The values of the material parameters  $m$  and  $n$  for the various classes of permitted materials are as given in Table NB-3228.5(b)-1.

**Table NB-3228.5(b)-1**  
**Values of  $m$ ,  $n$ , and  $T_{\max}$  for Various Classes of Permitted Materials**

Materials	$m$	$n$	$T_{\max}$ , °F (°C)
Carbon steel	3.0	0.2	700 (370)
Low alloy steel	2.0	0.2	700 (370)
Martensitic stainless steel	2.0	0.2	700 (370)
Austenitic stainless steel	1.7	0.3	800 (425)
Nickel-chromium-iron	1.7	0.3	800 (425)
Nickel-copper	1.7	0.3	800 (425)

(c) The rest of the fatigue evaluation stays the same as required in NB-3222.4, except that the procedure of NB-3227.6 need not be used.

(d) The component meets the thermal ratcheting requirement of NB-3222.5.

(e) The temperature does not exceed those listed in Table NB-3228.5(b)-1 for the various classes of materials.

(f) The material shall have a specified minimum yield strength to specified minimum tensile strength ratio of less than 0.80.

## **NB-3229 Design Stress Values**

The design stress intensity values  $S_m$  are given in Section II, Part D, Subpart 1, Tables 2A and 2B for component materials. Values for intermediate temperatures may be found by interpolation. These form the basis for the various stress limits. Values of yield strength are given in Section II, Part D, Subpart 1, Table Y-1. Values of the coefficient of thermal expansion and modulus of elasticity are in Section II, Part D, Subpart 2, Tables TE and TM. The basis for establishing stress values is given in Appendix III. The design fatigue curves used in conjunction with NB-3222.4 are those of Figs. I-9.0.

## **NB-3230 STRESS LIMITS FOR BOLTS**

### **NB-3231 Design Conditions**

(a) The number and cross-sectional area of bolts required to resist the Design Pressure shall be determined in accordance with the procedures of Appendix E, using the larger of the bolt loads, given by the equations of Appendix E, as a Design Mechanical Load. The allowable bolt design stresses shall be the values given in Section II, Part D, Subpart 1, Table 4 for bolting material.

(b) When sealing is affected by a seal weld instead of a gasket, the gasket factor  $m$  and the minimum design seating stress  $y$  may be taken as zero.

(c) When gaskets are used for preservice testing only, the design is satisfactory if the above requirements are satisfied for  $m = y = 0$ , and the requirements of NB-3232 are satisfied when the appropriate  $m$  and  $y$  factors are used for the test gasket.

**NB-3232 Level A Service Limits**

Actual service stresses in bolts, such as those produced by the combination of preload, pressure, and differential thermal expansion, may be higher than the values given in Section II, Part D, Subpart 1, Table 4.

**NB-3232.1 Average Stress.** The maximum value of service stress, averaged across the bolt cross section and neglecting stress concentrations, shall not exceed two times the stress values of Section II, Part D, Subpart 1, Table 4.

**NB-3232.2 Maximum Stress.** The maximum value of service stress, except as restricted by NB-3232.3(b), at the periphery of the bolt cross-section resulting from direct tension plus bending and neglecting stress concentrations shall not exceed three times the stress values of Section II, Part D, Subpart 1, Table 4. Stress intensity, rather than maximum stress, shall be limited to this value when the bolts are tightened by methods other than heaters, stretchers, or other means which minimize residual torsion.

- (13) **NB-3232.3 Fatigue Analysis of Bolts.** Unless the components on which they are installed meet all the conditions of NB-3222.4(d) and thus require no fatigue analysis, the suitability of bolts for cyclic service shall be determined in accordance with the procedures of (a) through (e) below.

(a) *Bolting Having Less Than 100.0 ksi (689 MPa) Tensile Strength.* Bolts made of material which has specified minimum tensile strength of less than 100.0 ksi (689 MPa) shall be evaluated for cyclic service by the methods of NB-3222.4(e), using the applicable design fatigue curve of Figs. I-9.0 and an appropriate fatigue strength reduction factor [(c)].

(b) *High Strength Alloy Steel Bolting.* High strength alloy steel bolts and studs may be evaluated for cyclic service by the methods of NB-3222.4(e) using the design fatigue curve of Figure I-9.4 provided:

(1) the maximum value of the service stress (NB-3232.2) at the periphery of the bolt cross-section, resulting from direct tension plus bending and neglecting stress concentration, shall not exceed  $2.7S_m$  if the higher of the two fatigue design curves given in Figure I-9.4 is used. The  $2S_m$  limit for direct tension is unchanged.

(2) threads shall be of a Vee-type having a minimum thread root radius no smaller than 0.003 in. (0.08 mm);

(3) fillet radii at the end of the shank shall be such that the ratio of fillet radius to shank diameter is not less than 0.060.

(c) *Fatigue Strength Reduction Factor (NB-3213.17).* Unless it can be shown by analysis or tests that a lower value is appropriate, the fatigue strength reduction factor used in the fatigue evaluation of threaded members shall not be less than 4.0. However, when applying the rules of (b) for high strength alloy steel bolts, the value used shall not be less than 4.0.

(d) *Effect of Elastic Modulus.* Multiply  $S_{alt}$  (as determined in NB-3216.1 or NB-3216.2) by the ratio of the modulus of elasticity given on the design fatigue curve to the value of the modulus of elasticity used in the analysis. Enter the applicable design fatigue curve at this value on the ordinate axis and find the corresponding number of cycles on the abscissa. If the service cycle being considered is the only one which produces significant fluctuating stresses, this is the allowable number of cycles.

(e) *Cumulative Damage.* The bolts shall be acceptable for the specified cyclic application of loads and thermal stresses provided the cumulative usage factor  $U$ , as determined in NB-3222.4(e)(5), does not exceed 1.0.

**NB-3233 Level B Service Limits**

Level A Service Limits (NB-3232) apply.

**NB-3234 Level C Service Limits**

The stress limits of NB-3232.1 and NB-3232.2 apply.

**NB-3235 Level D Service Limits**

If the Design Specifications specify any Service Loadings for which Level D Limits are designated [NCA-2142.4(b)(4)], the rules contained in Appendix F may be used in evaluating these loadings independently of all other Design and Service Loadings.

**NB-3236 Design Stress Intensity Values**

The design stress intensity values  $S_m$  are given in Section II, Part D, Subpart 1, Table 4 for bolting. Values for intermediate temperature may be found by interpolation. The basis for establishing stress intensity values is given in Appendix III.

**NB-3300 VESSEL DESIGN****NB-3310 GENERAL REQUIREMENTS****NB-3311 Acceptability**

The requirements for acceptability of a vessel design are as follows:

(a) The design shall be such that the requirements of NB-3100 and NB-3200 shall be satisfied.

(b) The rules of this Subarticle shall be met. In cases of conflict between NB-3200 and NB-3300 the requirements of NB-3300 shall govern.

**NB-3320 DESIGN CONSIDERATIONS****NB-3321 Design and Service Loadings**

The provisions of NB-3110 apply.

**NB-3322 Special Considerations**

The provisions of NB-3120 apply.



**NB-3323 General Design Rules**

The provisions of NB-3130 apply except when they conflict with rules of this Subarticle. In case of conflict, this Subarticle governs in the design of vessels.

**NB-3324 Tentative Pressure Thickness**

The following equations are given as an aid to the designer for determining a tentative thickness for use in the design. They are not to be construed as equations for acceptable thicknesses. However, except in local regions (NB-3221.2), the wall thickness of a vessel shall never be less than that obtained from the equations in NB-3324.1 and NB-3324.2, in which:

$P$  = Design Pressure

$R$  = inside radius of shell or head

$R_o$  = outside radius of shell or head

$S_m$  = design stress intensity values (Section II, Part D, Subpart 1, Tables 2A and 2B)

$t$  = thickness of shell or head

**NB-3324.1 Cylindrical Shells.**

$$t = \frac{PR}{S_m - 0.5P} \quad \text{or} \quad t = \frac{PR_o}{S_m + 0.5P}$$

**NB-3324.2 Spherical Shells.**

$$t = \frac{PR}{2S_m - P} \quad \text{or} \quad t = \frac{PR_o}{2S_m}$$

**NB-3330 OPENINGS AND REINFORCEMENT****NB-3331 General Requirements for Openings**

(a) For vessels or parts thereof which meet the requirements of NB-3222.4(d), analysis showing satisfaction of the requirements of NB-3221.1, NB-3221.2, NB-3221.3, and NB-3222.2 in the immediate vicinity of the openings is not required for pressure loading if the rules of NB-3330 are met.

(b) For vessels or parts thereof that do not meet the requirements of NB-3222.4(d) so that a fatigue analysis is required, the rules contained in NB-3330 ensure satisfaction of the requirements of NB-3221.1, NB-3221.2, and NB-3221.3 in the vicinity of openings, and no specific analysis showing satisfaction of those stress limits is required for pressure loading. The requirements of NB-3222.2 may also be considered to be satisfied if, in the vicinity of the nozzle, the stress intensity resulting from external nozzle loads and thermal effects, including gross but not local structural discontinuities, is shown by analysis to be less than  $1.5S_m$ . In this case, when evaluating the requirements of NB-3222.4(e), the peak stress intensity resulting from pressure loadings may be obtained by application of the stress index method of NB-3338 or NB-3339.

(c) The provisions of (a) and (b) above are not intended to restrict the design to any specified section thicknesses or other design details, provided the basic stress limits

are satisfied. If it is shown by analysis that all the stress requirements have been met, the rules of NB-3330 are waived.

(d) Openings shall be circular, elliptical, or of any other shape which results from the intersection of a circular or elliptical cylinder with a vessel of the shapes permitted by this Subsection. Additional restrictions given in NB-3338.2(d) are applicable if the Stress Index Method is used. If fatigue analysis is not required, the restrictions on hole spacing are applicable unless there will be essentially no pipe reactions.

(e) Openings are not limited as to size except to the extent provided in NB-3338.2(d).

(f) All references to dimensions apply to the finished dimensions excluding material added as corrosion allowance. Rules regarding metal available for reinforcement are given in NB-3335.

(g) Any type of opening permitted in these rules may be located in a welded joint.

**NB-3332 Reinforcement Requirements for Openings in Shells and Formed Heads****NB-3332.1 Openings Not Requiring Reinforcement.**

The rules for openings not requiring reinforcement are given in (a) through (c) below, where  $R$  is the mean radius and  $t$  is the nominal thickness of the vessel shell or head at the location of the opening; and *locally stressed area* means any area in the shell where the primary local membrane stress exceeds  $1.1S_m$ , but excluding those areas where such primary local membrane stress is due to an unreinforced opening.

(a) A single opening has a diameter not exceeding  $0.2\sqrt{Rt}$ , or if there are two or more openings within any circle of diameter  $2.5\sqrt{Rt}$ , but the sum of the diameters of such unreinforced openings shall not exceed  $0.25\sqrt{Rt}$ .

(b) No two unreinforced openings shall have their centers closer to each other, measured on the inside of the vessel wall, than 1.5 times the sum of their diameters.

(c) No unreinforced opening shall have its center closer than  $2.5\sqrt{Rt}$  to the edge of a locally stressed area in the shell.

**NB-3332.2 Required Area of Reinforcement.** The total cross-sectional area of reinforcement  $A$ , required in any given plane for a vessel under internal pressure, shall not be less than:

$$A = dt_r F$$

where

$d$  = finished diameter of a circular opening or finished dimension (chord length) of an opening on the plane being considered for elliptical and obround openings in corroded condition.

$F$  = a correction factor which compensates for the variation in pressure stresses on different planes with respect to the axis of a vessel. (A value of 1.00 shall be used for all configurations, except that Figure NB-3332.2-1 may be used for integrally reinforced openings in cylindrical shells and cones.)


$t_r$  = the thickness which meets the requirements of NB-3221.1 in the absence of the opening.

Not less than half the required material shall be on each side of the center line.

### NB-3333 Reinforcement Required for Openings in Flat Heads

Flat heads that have an opening with a diameter that does not exceed one-half the head diameter shall have a total cross-sectional area of reinforcement not less than that given by the equation:

$$A = 0.5dt_r$$



where  $d$  is as defined in NB-3332 and  $t_r$  is the thickness, which meets the requirements of NB-3221.1 and NB-3221.3 in the absence of the opening.

### NB-3334 Limits of Reinforcement

The boundaries of the cross-sectional area in any plane normal to the vessel wall and passing through the center of the opening and within which metal shall be located in order to have value as reinforcement are designated as the limits of reinforcement for that plane and are given in the following subparagraphs.

**NB-3334.1 Limit of Reinforcement Along the Vessel Wall.** The limits of reinforcement, measured along the midsurface of the nominal wall thickness, shall meet the following.

(a) One hundred percent of the required reinforcement shall be within a distance on each side of the axis of the opening equal to the greater of the following:

(1) the diameter of the finished opening in the corroded condition;

(2) the radius of the finished opening in the corroded condition plus the sum of the thicknesses of the vessel wall and the nozzle wall.

(b) Two-thirds of the required reinforcement shall be within a distance on each side of the axis of the opening equal to the greater of the following:

(1)  $r + 0.5\sqrt{Rt}$ , where  $R$  is the mean radius of shell or head,  $t$  is the nominal vessel wall thickness, and  $r$  is the radius of the finished opening in the corroded condition;

(2) the radius of the finished opening in the corroded condition plus two-thirds the sum of the thicknesses of the vessel wall and the nozzle wall.

**NB-3334.2 Limit of Reinforcement Normal to the Vessel Wall.** The limits of reinforcement, measured normal to the vessel wall, shall conform to the contour of the surface at a distance from each surface equal to the following limits as shown in Figure NB-3338.2(a)-2.

(a) For Figure NB-3338.2(a)-2, sketches (a), (b), (d), and (e):

$$\text{Limit} = 0.5\sqrt{r_m t_n} + 0.5r_2$$

where

$r_i$  = inside radius

$r_m$  = mean radius

$$= r_i + 0.5t_n$$

$r_2$  = transition radius, between nozzle and wall

$t_n$  = nominal nozzle thickness, as indicated.

For the case of a nozzle with a tapered inside diameter, the limit shall be obtained by using  $r_i$  and  $t_n$  values at the nominal outside diameters of the vessel wall [Figure NB-3338.2(a)-2 sketch (e)].



(b) For Figure NB-3338.2(a)-2 sketches (c) and (f):

$$\text{Limit} = 0.5 \sqrt{r_m t_n}$$

where

- $r_i$  = inside radius
- $r_m = r_i + 0.5t_n$
- $t_n = t_p + 0.667X$
- $t_p$  = nominal thickness of the attached pipe
- $X$  = slope offset distance
- $\theta$  = angle between vertical and slope, 45 deg or less

For the case of a nozzle with a tapered inside diameter, the limit shall be obtained by using  $r_i$  and  $t_n$  values at the center of gravity of nozzle reinforcement area. These values must be determined by a trial and error procedure [Figure NB-3338.2(a)-2, sketch (f)].

### NB-3335 Metal Available for Reinforcement

Metal may be counted as contributing to the area of reinforcing called for in NB-3332, provided it lies within the limits of reinforcement specified in NB-3334, and shall be limited to material which meets the following requirements:

- (a) metal forming a part of the vessel wall which is in excess of that required on the basis of membrane stress intensity (NB-3221.1) and is exclusive of corrosion allowance;
- (b) similar excess metal in the nozzle wall, provided the nozzle is integral with the vessel wall or is joined to it by a full penetration weld;
- (c) weld metal which is fully continuous with the vessel wall;
- (d) the mean coefficient of thermal expansion of metal to be included as reinforcement under (b) and (c) above shall be within 15% of the value of the vessel wall material;
- (e) metal not fully continuous with the shell, such as that in nozzles attached by partial penetration welds, shall not be counted as reinforcement;
- (f) metal available for reinforcement shall not be considered as applying to more than one opening.

### NB-3336 Strength of Reinforcing Material

Material used for reinforcement shall preferably be the same as that of the vessel wall. If the material of the nozzle wall or reinforcement has a lower design stress intensity value  $S_m$  than that for the vessel material, the amount of area provided by the nozzle wall or reinforcement in satisfying the requirements of NB-3332 shall be taken as the actual area provided multiplied by the ratio of the nozzle or reinforcement design stress intensity value to the vessel material design stress intensity value. No reduction in the reinforcing required may be taken for the increased strength of reinforcing material and weld metal having higher design stress intensity values than that of the ma-

terial of the vessel wall. The strength of the material at the point under consideration shall be used in fatigue analyses.

### NB-3337 Attachment of Nozzles and Other Connections

**NB-3337.1 General Requirements.** Nozzles and other Category D connections (NB-3351) shall be attached to the shell or head of the vessel by one of the methods provided in NB-3352.

**NB-3337.2 Full Penetration Welded Nozzles.** Full penetration welds, as shown in Figures NB-4244(a)-1, NB-4244(b)-1, NB-4244(c)-1, and NB-4244(e)-1 may be used (except as otherwise provided in NB-3337.3) for the purpose of achieving continuity of metal and facilitating the required radiographic examination. When all or part of the required reinforcement is attributable to the nozzle, the nozzle shall be attached by full penetration welds through either the vessel or the nozzle thickness, or both.

#### NB-3337.3 Partial Penetration Welded Nozzles.

(a) Partial penetration welds, as shown in Figures NB-4244(d)-1 and NB-4244(d)-2, are allowed only for nozzles on which there are substantially no piping reactions, such as control rod housings, pressurizer heater wells, and openings for instrumentation. Earthquake loadings need not be considered in determining whether piping reactions are substantial. For such nozzles, all reinforcement shall be integral with the portion of the vessel penetrated. Partial penetration welds shall be of sufficient size to develop the full strength of the nozzles. Nozzles attached by partial penetration welds shall have an interference fit or a maximum diametral clearance between the nozzle and the vessel penetration of:

- (1) 0.010 in. (0.25 mm) for  $d \leq 1$  in. (25 mm)
- (2) 0.020 in. (0.50 mm) for  $1$  in. (25 mm)  $< d \leq 4$  in. (100 mm)
- (3) 0.030 in. (0.75 mm) for  $d > 4$  in. (100 mm)

where  $d$  is the outside diameter of the nozzle, except that the above limits on maximum clearance need not be met for the full length of the opening, provided there is a region at the weld preparation and a region near the end of the opening opposite the weld that does meet the above limits on maximum clearance and the latter region is extensive enough (not necessarily continuous) to provide a positive stop for nozzle deflection.

(b) In satisfying the limit of NB-3222.2, the stress intensities resulting from pressure induced strains (dilation of hole) may be treated as secondary in the penetrating part of partial penetration welded construction, provided the requirements of NB-3352.4(d) and Figure NB-4244(d)-1 are fulfilled.

### NB-3338 Fatigue Evaluation of Stresses in Openings

**NB-3338.1 General.** For the purpose of determining peak stresses around the opening, three acceptable methods are listed below.

(a) *Analytical Method.* This method uses suitable analytical techniques such as finite element computer analyses, which provide detailed stress distributions around openings. In addition to peak stresses due to pressure, the effects of other loadings shall be included. The total peak stress at any given point shall be determined by combining stresses due to pressure, thermal, and external loadings in accordance with the rules of NB-3200.


(b) *Experimental Stress Analysis.* This is based on data from experiments (Appendix II).

(c) *Stress Index Method.* This uses various equations together with available data obtained from an extensive series of tests covering a range of variation of applicable dimensional ratios and configurations (NB-3338.2). This method covers only single, isolated openings. Stress indices may also be determined by theoretical or experimental stress analysis.

#### NB-3338.2 Stress Index Method.

(a) The term *stress index*, as used herein, is defined as the numerical ratio of the stress components  $\sigma_t$ ,  $\sigma_n$ , and  $\sigma_r$  [Figure NB-3338.2(a)-1] under consideration to the computed membrane hoop stress in the unpenetrated vessel material; however, the material which increases the thickness of a vessel wall locally at the nozzle shall not be included in the calculations of these stress components. When the thickness of the vessel wall is increased over that required to the extent provided hereinafter, the values of  $r_1$  and  $r_2$  in Figure NB-3338.2(a)-2 shall be referred to the thickened section.

(b) The nomenclature used in NB-3338 is defined as follows.



$R$  = inside radius, in corroded condition, of cylindrical vessel, spherical vessel, or spherical head

$S$  = stress intensity (combined stress) at the point under consideration

$t$  = nominal wall thickness, less corrosion allowance, of vessel or head

$\sigma_n$  = stress component normal to the plane of the section (ordinarily the circumferential stress around the hole in the shell)

$\sigma_r$  = stress component normal to the boundary of the section

$\sigma_t$  = stress component in the plane of the section under consideration and parallel to the boundary of the section

(c) When the conditions of (d) below are satisfied, the stress indices of Table NB-3338.2(c)-1 may be used for nozzles designed in accordance with the applicable rules of NB-3330. These stress indices deal only with the maximum stresses, at certain general locations, due to internal pressure. In the evaluation of stresses in or adjacent to vessel openings and connections, it is often necessary to consider the effect of stresses due to external loadings or thermal stresses. In such cases, the total stress at a given point may be determined by superposition. In the case of combined stresses due to internal pressure and nozzle loading, the maximum stresses for a given location shall be considered as acting at the same point and added algebraically unless positive evidence is available to the contrary.

(d) The indices of Table NB-3338.2(c)-1 apply when the conditions stipulated in (1) through (7) below exist.

(1) The opening is for a circular nozzle whose axis is normal to the vessel wall. If the axis of the nozzle makes an angle  $\phi$  with the normal to the vessel wall and if  $d/D \leq 0.15$ , an estimate of the  $\sigma_n$  index on the inside may be obtained from one of the following equations.

For hillside connections in spheres or cylinders:

$$K_2 = K_1 (1 + 2 \sin^2 \phi)$$

For lateral connections in cylinders:

$$K_2 = K_1 [1 + (\tan \phi)^{4/3}]$$


where

$K_1$  = the  $\sigma_n$  inside stress index of Table NB-3338.2(c)-1 for a radial connection

$K_2$  = the estimated  $\sigma_n$  inside stress index for the nonradial connection

(2) The arc distance measured between the center lines of adjacent nozzles along the inside surface of the shell is not less than three times the sum of their inside radii for openings in a head or along the longitudinal axis of a shell and is not less than two times the sum of their radii

**Figure NB-3338.2(a)-2  
Nozzle Dimensions**



**Table NB-3338.2(c)-1  
Stress Indices for Nozzles**

Nozzles in Spherical Shells and Formed Heads				
Stress	Inside Corner	Outside Corner		
$\sigma_n$	2.0	2.0		
$\sigma_t$	-0.2	2.0		
$\sigma_r$	$-2t/R$	0		
$S$	2.2	2.0		
Nozzles in Cylindrical Shells				
	Longitudinal Plane		Transverse Plane	
Stress	Inside	Outside	Inside	Outside
$\sigma_n$	3.1	1.2	1.0	2.1
$\sigma_t$	-0.2	1.0	-0.2	2.6
$\sigma_r$	$-t/R$	0	$-t/R$	0
$S$	3.3	1.2	1.2	2.6

for openings along the circumference of a cylindrical shell. When two nozzles in a cylindrical shell are neither in a longitudinal line nor in a circumferential arc, their center line distance along the inside surface of the shell shall be such that  $[(L_c/2)^2 + (L_l/3)^2]^{1/2}$  is not less than the sum of their inside radii, where  $L_c$  is the component of the center line distance in the circumferential direction and  $L_l$  is the component of the center line distance in the longitudinal direction.

(3) The following dimensional ratios are met:

Ratio	Cylinder	Sphere
$D/t$	10 to 100	10 to 100
$d/D$	0.5 max	0.5 max.
$d/\sqrt{Dt}$	...	0.8 max.
$d/\sqrt{Dt_n r_2/t}$	1.5 max	...

where  $D$  is the inside shell diameter,  $t$  is the shell thickness, and  $d$  is the inside nozzle diameter. In the case of cylindrical shells, the total nozzle reinforcement area on the transverse axis of the connections, including any outside of the reinforcement limits, shall not exceed 200% of that required for the longitudinal axis (compared to 50% permitted by Figure NB-3332.2-1) unless a tapered transition section is incorporated into the reinforcement and the shell, meeting the requirements of NB-3361.

(4) In the case of spherical shells and formed heads, at least 40% of the total nozzle reinforcement area shall be located beyond the outside surface of the minimum required vessel wall thickness.

(5) The inside corner radius  $r_1$  [Figure NB-3338.2(a)-2] is between 10% and 100% of the shell thickness  $t$ .

(6) The outer corner radius  $r_2$  [Figure NB-3338.2(a)-2] is large enough to provide a smooth transition between the nozzles and the shell. In addition, for opening diameters greater than  $1\frac{1}{2}$  times the shell thickness in cylindrical shells and 2:1 ellipsoidal

heads and greater than three shell thicknesses in spherical shells, the value of  $r_2$  shall be not less than one-half the thickness of the shell or nozzle wall, whichever is greater.

(7) The radius  $r_3$  [Figure NB-3338.2(a)-2] is not less than the greater of the following:

(-a)  $0.002\theta d_o$ , where  $d_o$  is the outside diameter of the nozzle and is as shown in Figure NB-3338.2(a)-2, and the angle  $\theta$  is expressed in degrees;

(-b)  $2(\sin \theta)^3$  times offset for the configuration shown in Figure NB-3338.2(a)-2 sketches (a) and (b).

### NB-3339 Alternative Rules for Nozzle Design

Subject to the limitations stipulated in NB-3339.1, the requirements of this paragraph constitute an acceptable alternative to the rules of NB-3332 through NB-3336 and NB-3338.

**NB-3339.1 Limitations.** These alternative rules are applicable only to nozzles in vessels within the limitations stipulated in (a) through (f) below.

(a) The nozzle is circular in cross-section and its axis is normal to the vessel or head surface.

(b) The nozzle and reinforcing (if required) are welded integrally into the vessel with full penetration welds. Details such as those shown in Figures NB-4244(a)-1, NB-4244(b)-1, and NB-4244(c)-1 are acceptable. However, fillet welds shall be finished to a radius in accordance with Figure NB-3339.1(b)-1.

(c) In the case of spherical shells and formed heads, at least 40% of the total nozzle reinforcement area shall be located beyond the outside surface of the minimum required vessel wall thickness.

(d) The spacing between the edge of the opening and the nearest edge of any other opening is not less than the smaller of  $1.25(d_1 + d_2)$  or  $2.5\sqrt{Rt}$ , but in any case not less than  $d_1 + d_2$ , where  $d_1$  and  $d_2$  are the inside diameters of the openings.

(e) The material used in the nozzle, reinforcing, and vessel adjacent to the nozzle shall have a ratio of  $UTS/YS$  of not less than 1.5, where

$UTS$  = specified minimum ultimate tensile strength

$YS$  = specified minimum yield strength


(f) The following dimensional limitations are met:

	Nozzles in Cylindrical Vessels	Nozzles in Spherical Vessels or Hemispherical Heads
$D/t$	10 to 100	10 to 100
$d/D$	0.5 max.	0.5 max.
$d/\sqrt{Dt}$	...	0.8 max.
$d/\sqrt{Dt_n r_2/t}$	1.5 max.	...

**NB-3339.2 Nomenclature.** The nomenclature used in NB-3339 is defined as follows:

$A_a$  = available reinforcing area

**Figure NB-3339.1(b)-1**  
**Examples of Acceptable Transition Details**



$$r_1 = 0.1t \text{ to } 0.5t$$

$$r_2 \geq \text{larger of } \sqrt{dt_m} \text{ or } t/2$$

$$r_3 \geq \text{larger of } [\sqrt{(\theta/90)(dt_m)}] \text{ or } [(\theta/90)t_n]$$

$$r_4 \geq \text{larger of } [(1 - \sqrt{\theta/90})\sqrt{dt_m}] \text{ or } [(1 - \theta_1/90)(t/2)]$$

$$r_5 = (\theta_1/90)t$$

$$\theta \text{ and } \theta_1 \text{ are in degrees}$$

$A_r$  = required minimum reinforcing area

$D$  = inside diameter, in corroded condition, of cylindrical vessel, spherical vessel, or spherical head

$d$  = inside diameter, in corroded condition, of the nozzle

$R$  = inside radius, in corroded condition, of cylindrical vessel, spherical vessel, or spherical head

$t$  = nominal wall thickness, less corrosion allowance, of vessel or head

$t_n$  = nominal wall thickness, less corrosion allowance, of nozzle

$t_r$  = wall thickness of vessel or head, computed by the equations given in NB-3324.1 for cylindrical vessels and in NB-3324.2 for spherical vessels or spherical heads

$t_{rn}$  = wall thickness of nozzle, computed by the equation given in NB-3324.1, in. (mm)

For the definitions of  $r_1$ ,  $r_2$ ,  $r_3$ ,  $r_4$ ,  $\theta$ , and  $\theta_1$  see Figure NB-3339.1(b)-1; for  $L_c$  and  $L_n$  see Figure NB-3339.4-1; for  $S$ ,  $\sigma_t$ ,  $\sigma_n$ , and  $\sigma_r$  see NB-3338.2 and Figure NB-3338.2(a)-1.

**NB-3339.3 Required Reinforcement Area.** The required minimum reinforcing area is related to the value of  $d/\sqrt{Rt_r}$  as tabulated in Table NB-3339.3-1. The required minimum reinforcing area shall be provided in all planes containing the nozzle axis.

**NB-3339.4 Limits of Reinforcing Zone.** Reinforcing metal included in meeting the minimum required reinforcing area specified in Table NB-3339.3-1 must be located within the reinforcing zone boundary shown in Figure NB-3339.4-1.

**NB-3339.5 Strength of Reinforcing Material Requirements.** Material in the nozzle wall used for reinforcing shall preferably be the same as that of the vessel

**Table NB-3339.3-1**  
**Required Minimum Reinforcing Area  $A_r$**


$d/\sqrt{Rt_r}$	$A_r$ in. <sup>2</sup> (mm <sup>2</sup> )	
	Nozzles in Cylinders	Nozzles in Spherical Vessels or Heads
< 0.20	None [Note (1)]	None [Note (1)]
> 0.20 and < 0.40	$[4.05(d/\sqrt{Rt_r})^{1/2} - 1.81]dt_r$	$[5.40(d/\sqrt{Rt_r})^{1/2} - 2.41]dt_r$
> 0.40	$0.75dt_r$	$dt_r \cos \phi$ $\phi = \sin^{-1}(d/D)$

NOTE:

(1) The transition radius  $r_2$ , shown in Figure NB-3339.1(b)-1, or the equivalent thereof is required.



**Figure NB-3339.4-1**  
**Limits of Reinforcing Zone**



**GENERAL NOTES:**

**(a) Reinforcing Zone Limit**

- (1) For nozzles in cylindrical shells:  $L_c = 0.75 (t/D)^{3/5} D$
- (2) For nozzles in heads:  $L_n = (t/D)^{3/5} (d/D + 0.5) D$
- (3) The center of  $L_c$  or  $L_n$  is at the juncture of the outside surfaces of the shell and nozzles of thickness  $t_r$  and  $t_n$ .
- (4) In constructions where the zone boundary passes through a uniform thickness wall segment, the zone boundary may be considered as  $L_c$  or  $L_n$  through the thickness.

**(b) Reinforcing Area**

- (1) Hatched areas represent available reinforcement area  $A_a$ .
- (2) Metal area within the zone boundary, in excess of the area formed by the intersection of the basic shells, shall be considered as contributing to the required area  $A_r$ . The basic shells are defined as having inside diameter  $D$ , thickness  $t_r$ , inside diameter of the nozzle  $d$ , and thickness  $t_n$ .
- (3) The available reinforcement area  $A_a$  shall be at least equal to  $A_r / 2$  on each side of the nozzle center line and in every plane containing the nozzle axis.

wall. If material with a lower design stress intensity value  $S_m$  is used, the area provided by such material shall be increased in proportion to the inverse ratio of the stress values of the nozzle and the vessel wall material. No reduction in the reinforcing area requirement shall be taken for the increased strength of nozzle material or weld metal which has a higher design stress intensity value than that of the material of the vessel wall. The strength of the material at the point under consideration shall be used in fatigue analyses. The mean coefficient of thermal expansion of metal to be included as reinforcement shall be within 15% of the value for the metal of the vessel wall.

**NB-3339.6 Transition Details.** Examples of acceptable transition tapers and radii are shown in Figure NB-3339.1(b)-1. Other configurations which meet the reinforcing area requirements of NB-3339.3 and with equivalent or less severe transitions are also acceptable; e.g., larger radius-thickness ratios.

**NB-3339.7 Stress Indices.**

(a) The term *stress index*, as used herein, is defined as the numerical ratio of the stress components  $\sigma_t$ ,  $\sigma_n$ , and  $\sigma_r$ , under consideration, to the computed stress  $\sigma$ .

(b) The nomenclature for the stress components is shown in Figure NB-3338.2(a)-1 and is defined as follows:

- $P$  = service pressure  
 $S$  = stress intensity (combined stress) at the point under consideration  
 $\sigma = P(D + t)/4t$  for nozzles in spherical vessels or heads  
 $= P(D + t)/2t$  for nozzles in cylindrical vessels  
 $\sigma_n$  = stress component normal to the plane of the section (ordinarily the circumferential stress around the hole in the shell)  
 $\sigma_r$  = stress component normal to the boundary of the section  
 $\sigma_t$  = stress component in the plane of the section under consideration and parallel to the boundary of the section

(c) When the conditions of NB-3339.1 through NB-3339.6 are satisfied, the stress indices given in Table NB-3339.7(c)-1 may be used. These stress indices deal only with the maximum stresses, at certain general locations, due to internal pressure. In the evaluation of stresses in or adjacent to vessel openings and connections, it is often necessary to consider the effect of stresses due to external loadings or thermal stresses. In such cases, the total stress at a given point may be determined by superposition. In the case of combined stresses due to internal pressure and nozzle loading, the maximum stresses shall be considered as acting at the same point and added algebraically. If the stresses are otherwise determined by more accurate analytical techniques or by the experimental stress analysis procedure of Appendix II, the stresses are also to be added algebraically.

**Table NB-3339.7(c)-1**  
**Stress Indices for Internal Pressure Loading**

Nozzles in Spherical Shells and Spherical Heads				
Stress	Inside		Outside	
$\sigma_n$	$2.0 -d/D$		$2.0 -d/D$	
$\sigma_t$	$-0.2$		$2.0 -d/D$	
$\sigma_r$	$-4t/(D+t)$		0	
$S$	larger of: $2.2 -d/D$ or $2.0 + [4t/(D+t)] -d/D$		$2.0 -d/D$	
Nozzles in Cylindrical Shells				
	Longitudinal Plane		Transverse Plane	
Stress	Inside	Outside	Inside	Outside
$\sigma_n$	3.1	1.2	1.0	2.1
$\sigma_t$	-0.2	1.0	-0.2	2.6
$\sigma_r$	$-2t/(D+t)$	0	$-2t/(D+t)$	0
$S$	3.3	1.2	1.2	2.6

## NB-3340 ANALYSIS OF VESSELS

The provisions of NB-3214 apply.

## NB-3350 DESIGN OF WELDED CONSTRUCTION

### NB-3351 Welded Joint Category

The term *Category* defines the location of a joint in a vessel, but not the type of joint. The categories established are for use in specifying special requirements regarding joint type and degree of examination for certain welded joints. Since these special requirements, which are based on service, material, and thickness, do not apply to every welded joint, only those joints to which special requirements apply are included in the categories. The special requirements apply to joints of a given category only when specifically stated. The joints included in each category are designated as joints of Categories A, B, C, and D. Figure NB-3351-1 illustrates typical joint locations included in each category.

**NB-3351.1 Category A.** Category A comprises longitudinal welded joints within the main shell, communicating chambers,<sup>17</sup> transitions in diameter, or nozzles; any welded joint within a sphere, within a formed or flat head, or within the side plates<sup>18</sup> of a flat sided vessel; and circumferential welded joints connecting hemispherical heads to main shells, to transitions in diameters, to nozzles, or to communicating chambers.

**NB-3351.2 Category B.** Category B comprises circumferential welded joints within the main shell, communicating chambers, nozzles, or transitions in diameter,

including joints between the transition and a cylinder at either the large or small end; and circumferential welded joints connecting formed heads other than hemispherical to main shells, to transitions in diameter, to nozzles, or to communicating chambers.

**NB-3351.3 Category C.** Category C comprises welded joints connecting flanges, Van Stone laps, tubesheets, or flat heads to main shell, to formed heads, to transitions in diameter, to nozzles, or to communicating chambers<sup>17</sup> any welded joint connecting one side plate<sup>18</sup> to another side plate of a flat sided vessel.

**NB-3351.4 Category D.** Category D comprises welded joints connecting communicating chambers or nozzles to main shells, to spheres, to transitions in diameter, to heads, or to flat sided vessels, and those joints connecting nozzles to communicating chambers. For nozzles at the small end of a transition in diameter, see Category B.

## NB-3352 Permissible Types of Welded Joints

The design of the vessel shall meet the requirements for each category of joint. Butt joints are full penetration joints between plates or other elements that lie approximately in the same plane. Category B angle joints between plates or other elements that have an offset angle  $\alpha$  not exceeding 30 deg are considered as meeting the requirements for butt joints. Figure NB-3352-1 shows typical butt welds for each category joint.

**NB-3352.1 Joints of Category A.** All welded joints of Category A as defined in NB-3351 shall meet the fabrication requirements of NB-4241 and shall be capable of being examined in accordance with NB-5210.


**NB-3352.2 Joints of Category B.** All welded joints of Category B as defined in NB-3351 shall meet the fabrication requirements of NB-4242 and shall be capable of being examined in accordance with NB-5220. When joints with opposing lips to form an integral backing strip or joints with backing strips not later removed are used, the suitability for cyclic service shall be analyzed by the method of NB-3222.4 using a fatigue strength reduction factor of not less than 2.

**NB-3352.3 Joints of Category C.** All welded joints of Category C as defined in NB-3351 shall meet the fabrication requirements of NB-4243 and shall be capable of being examined in accordance with NB-5230. Minimum dimensions of the welds and throat thickness shall be as shown in Figure NB-4243-1 where:

(a) for forged tubesheets, forged flat heads, and forged flanges with the weld preparation bevel angle not greater than 45 deg measured from the face:

$$\begin{aligned} t_n &= \text{nominal thicknesses of welded parts} \\ t_c &= 0.7t_n \text{ or } 1/4 \text{ in. (6 mm), whichever is less} \\ t_w &= t_n/2 \text{ or } t/4, \text{ whichever is less} \end{aligned}$$

**Figure NB-3351-1**  
**Welded Joint Locations Typical of Categories A, B, C, and D**



(b) for all other material forms and for forged tube-sheets, forged flat heads, and forged flanges with the weld preparation bevel angle greater than 45 deg measured from the face:

$t_n$  = nominal thicknesses of welded parts  
 $t_c = 0.7t_n$  or  $\frac{1}{4}$  in. (6 mm), whichever is less  
 $t_w = t_n$  or  $t/2$ , whichever is less

**NB-3352.4 Joints of Category D.** All welded joints of Category D as defined in NB-3351 shall be in accordance with the requirements of one of (a) through (e) below.

(a) *Butt Welded Nozzles.* Nozzles shall meet the fabrication requirements of NB-4244(a) and shall be capable of being examined in accordance with NB-5242. The minimum dimensions and geometrical requirements of Figure NB-4244(a)-1 shall be met, where

$r_1 = \frac{1}{4}t$  or  $\frac{3}{4}$  in. (19 mm), whichever is less  
 $r_2 = \frac{1}{4}$  in. (6 mm) minimum  
 $t$  = nominal thickness of part penetrated  
 $t_n$  = nominal thickness of penetrating part

(b) *Full Penetration Corner Welded Nozzles.* Nozzles shall meet the fabrication requirements of NB-4244(b) and shall be capable of being examined as required in NB-5243. The minimum dimensions of Figure NB-4244(b)-1 shall be met, where

$r_1 = \frac{1}{4}t$  or  $\frac{3}{4}$  in. (19 mm), whichever is less  
 $r_2 = \frac{1}{4}$  in. (6 mm) minimum  
 $t$  = nominal thickness of part penetrated  
 $t_c = 0.7t_n$  or  $\frac{1}{4}$  in. (6 mm), whichever is less  
 $t_n$  = nominal thickness of penetrating part

(c) *Use of Deposited Weld Metal for Openings and Nozzles*

(1) Nozzles shall meet the fabrication requirements of NB-4244(c) and shall be capable of being examined in accordance with NB-5244.

(2) When the deposited weld metal is used as reinforcement, the coefficients of thermal expansion of the base metal, the weld metal, and the nozzle shall not differ by more than 15% of the lowest coefficient involved.

(3) The minimum dimensions of Figure NB-4244(c)-1 shall be met, where

$r_1 = \frac{1}{4}t$  or  $\frac{3}{4}$  in. (19 mm), whichever is less  
 $t$  = nominal thickness of part penetrated  
 $t_c = 0.7t_n$  or  $\frac{1}{4}$  in. (6 mm), whichever is less  
 $t_n$  = nominal thickness of penetrating part

(4) The corners of the end of each nozzle neck extending less than  $\sqrt{dt_n}$  beyond the inner surface of the part penetrated shall be rounded to a radius of one-half the thickness  $t_n$  of the nozzle neck or  $\frac{3}{4}$  in. (19 mm), whichever is smaller.


(d) *Attachment of Nozzles Using Partial Penetration Welds*

(1) Partial penetration welds used to connect nozzles as permitted in NB-3337.3 shall meet the fabrication requirements of NB-4244(d) and shall be capable of being examined in accordance with the requirements of NB-5245.

(2) The minimum dimensions of Figures NB-4244(d)-1 and NB-4244(d)-2 shall be met, where

$d$  = outside diameter of nozzle or of the inner cylinder as shown in Figure NB-4244(d)-2  
 $r_1 = \frac{1}{4}t_n$  or  $\frac{3}{4}$  in. (19 mm), whichever is less  
 $r_2 = \frac{1}{16}$  in. (1.5 mm) minimum  
 $r_3 = r_2$  or equivalent chamfer minimum

**Figure NB-3352-1  
Typical Butt Joints**



$r_4 = \frac{1}{2}t_n$  or  $\frac{3}{4}$  in. (19 mm), whichever is less  
 $t$  = nominal thickness of part penetrated  
 $t_c = 0.7t_n$  or  $\frac{1}{4}$  in. (6 mm), whichever is less  
 $t_n$  = nominal thickness of penetrating part or the lesser of  $t_{n1}$  or  $t_{n2}$  in Figure NB-4244(d)-2  
 $\lambda = \frac{1}{16}$  in. (1.5 mm) minimum  
 $\lambda = t_n$  maximum

(3) The corners of the end of each nozzle neck, extending less than  $\sqrt{dt_n}$  beyond the inner surface of the part penetrated, shall be rounded to a radius of one-half of the thickness  $t_n$  of the penetrating part or  $\frac{3}{4}$  in. (19 mm), whichever is smaller.

(4) Weld groove design for partial penetration joints attaching nozzles may require special consideration to achieve the  $1.25t_n$  minimum depth of weld and adequate access for welding examination. The welds shown in the sketches of Figures NB-4244(d)-1 and NB-4244(d)-2

may be on either the inside or the outside of the vessel shell. Weld preparation may be J-groove as shown in the figures or straight bevel.

(5) A fatigue strength reduction factor of not less than four shall be used when fatigue analysis is required.

(e) *Oblique Full Penetration Nozzles.* Internal or external nozzles shall meet the fabrication requirements of NB-4244(e) and shall be capable of being examined in accordance with NB-5246.

### **NB-3354 Structural Attachment Welds**

Welds for structural attachments shall meet the requirements of NB-4430.

### **NB-3355 Welding Grooves**

The dimensions and shape of the edges to be joined shall be such as to permit complete fusion and complete joint penetration, except as otherwise permitted in NB-3352.4.

**NB-3357 Thermal Treatment**


All vessels and vessel parts shall be given the appropriate postweld heat treatment prescribed in [NB-4620](#).

**NB-3360 SPECIAL VESSEL REQUIREMENTS****NB-3361 Category A or B Joints Between Sections of Unequal Thickness**

In general, a tapered transition section as shown in [Figure NB-3361-1](#) which is a type of gross structural discontinuity ([NB-3213.2](#)) shall be provided at joints of Categories A and B between sections that differ in thickness by more than one-fourth the thickness of the thinner section. The transition section may be formed by any process that will provide a uniform taper. An ellipsoidal or hemispherical head which has a greater thickness than a cylinder of the same inside diameter may be machined to the outside diameter of the cylinder provided the remaining thickness is at least as great as that required for a shell of the same diameter. A uniform taper is not required for flanged hubs. The adequacy of the transition shall be evaluated by stress analysis. Stress intensity limitations are given in [NB-3220](#). The requirements of this paragraph do not apply to flange hubs.

**NB-3362 Bolted Flange Connections**

It is recommended that the dimensional requirements of bolted flange connections to external piping conform to ASME B16.5, Steel Pipe Flanges and Flanged Fittings.

**NB-3363 Access Openings**

Access openings, where provided, shall consist of hand-hole or manhole openings having removable covers. These may be located on either the inside or outside of the shell or head openings and may be attached by studs or bolts in combination with gaskets or welded membrane seals or strength welds. Plugs using pipe threads are not permitted.

**NB-3364 Attachments**

Attachments used to transmit support loads shall meet the requirements of [NB-3135](#).

**NB-3365 Supports**

All vessels shall be so supported and the supporting members shall be arranged and attached to the vessel wall in such a way as to provide for the maximum imposed loadings. The stresses produced in the vessel by such loadings and by steady state and transient thermal conditions shall be subjected to the stress limits of this Subsection. Additional requirements are given in NCA-3240 and Subsection NF.

**NB-3400 PUMP DESIGN****NB-3410 GENERAL REQUIREMENTS FOR CENTRIFUGAL PUMPS****NB-3411 Scope**

**NB-3411.1 Applicability.** The rules of [NB-3400](#) apply to (a) through (j) below.

- (a) pump casings
- (b) pump inlets and outlets
- (c) pump covers
- (d) clamping rings
- (e) seal housing and seal glands
- (f) related bolting
- (g) pump internal heat exchanger piping
- (h) pump auxiliary nozzle connections up to the face of the first flange or circumferential joint in welded connections, excluding the connecting weld
- (i) piping identified with the pump and external to and forming part of the pressure-retaining boundary and supplied with the pump
- (j) mounting feet or pedestal supports when integrally attached to the pump pressure-retaining boundary and supplied with the pump

**NB-3411.2 Exemptions.** The rules of [NB-3400](#) do not apply to (a) through (c) below.

- (a) pump shafts and impellers; shafts may be designed in accordance with Appendix S
- (b) nonstructural internals
- (c) seal packages



**NB-3412 Acceptability**

**NB-3412.1 Acceptability of Large Pumps.** The requirements for the design acceptability of pumps having an inlet connection greater than NPS 4 (DN 100) diameter are given in (a), (b), and (c) below.

(a) The design shall be such that the requirements of NB-3100 and of NB-3200 or Appendix II (provided the requirements of NB-3414 and the minimum wall thicknesses of NB-3430 are met) are satisfied.

(b) The rules of this Subarticle shall be met. In cases of conflict between NB-3100 and NB-3200 or Appendix II and NB-3400, the requirements of NB-3400 apply.

(c) The requirements for prevention of nonductile fracture as set forth in NB-3211(d) shall be met.

**NB-3412.2 Acceptability of Small Pumps.** The requirements for the design acceptability of pumps having an inlet connection 4 in. nominal pipe size (DN 100) diameter or smaller are given in (a) and (b) below.

(a) The design shall be such that the requirements of NB-3100 or Appendix II are satisfied.

(b) The rules of this Subarticle shall be met. In cases of conflict between NB-3100 or Appendix II and NB-3400, the requirements of this Subarticle shall apply.

**NB-3414 Design and Service Conditions**

The general design considerations, including definitions of NB-3100 plus the requirements of NB-3320, NB-3330, NB-3361, and NB-3362 are applicable to pumps.

**NB-3415 Loads From Connected Piping**

(a) Loads imposed on pump inlets and outlets by connected piping shall be considered in the pump casing design. The forces and moments produced by the connected piping on each pump inlet and outlet shall be provided by the Owner in the Design Specifications.

(b) Stresses generated in the pump casing by the connected piping shall be combined with the pressure stresses in accordance with the requirements of NB-3200.

**NB-3417 Earthquake Loadings**

(a) The effects of earthquake shall be considered in the design of pumps, pump supports, and restraints. The stresses resulting from these earthquake effects shall be included with the stresses resulting from pressure or other applied loads.

(b) Where pumps are provided with drivers on extended supporting structures and these structures are essential to maintaining pressure integrity, an analysis shall be performed when required by the Design Specifications.

**NB-3418 Corrosion**

The requirements of NB-3121 apply.

**NB-3419 Cladding**

Cladding dimensions used in the design of pumps shall be required as in NB-3122.

**NB-3420 DEFINITIONS****NB-3421 Radially Split Casing**

A radially split casing shall be interpreted as one in which the primary sealing joint is radially disposed around the shaft.

**NB-3422 Axially Split Casing**

An axially split casing shall be interpreted as one in which the primary sealing joint is axially disposed with respect to the shaft.

**NB-3423 Single and Double Volute Casings**

Figures NB-3423-1 and NB-3423-2 show typical single and double volute casings, respectively.

**NB-3424 Seal Housing**

Seal housing is defined as that portion of the pump cover or casing assembly which contains the seal and forms a part of the primary pressure boundary.


**NB-3425 Typical Examples of Pump Types**

Figures NB-3441.1-1 through NB-3441.6(a)-1 are typical examples to aid in the determination of pump type and are not to be considered as limiting.


**NB-3430 DESIGN REQUIREMENTS FOR CENTRIFUGAL PUMPS****NB-3431 Design of Welding**

(a) The design of welded construction shall be in accordance with NB-3350.

**Figure NB-3423-1  
Typical Single Volute Casing**



**Figure NB-3423-2**  
**Typical Double Volute Casing**



(b) Partial penetration welds are permitted for piping connections NPS 2 (DN 50) and less when the requirements of NB-3337.3 and NB-3352.4(d) are met.

#### NB-3432 Cutwater Tip Stresses

(a) It is recognized that localized high stresses may occur at the cutwater tips of volute casings (Figure NB-3441.3-2). Adequacy of the design in this area shall be demonstrated either by an investigation through experimental stress analysis in accordance with Appendix II or by detailing satisfactory service performance of other pumps under similar operating conditions.

(b) Where experimental stress analysis is used, stress intensity at this point shall meet the requirements of NB-3222.

#### NB-3433 Reinforcement of Pump Casing Inlets and Outlets

##### NB-3433.1 Axially Oriented Inlets and Outlets.

(a) An axially oriented pump casing inlet or outlet shall be considered similar to an opening in a vessel and shall be reinforced. It shall be treated as required in NB-3331 through NB-3336.

(b) To avoid stress concentrations, the outside radius  $r_2$  in Figure NB-3441.3-2 shall not be less than one-half the thickness of the inlets and outlets as reinforced.

**NB-3433.2 Radially Oriented Inlets and Outlets.** Reinforcement of radially oriented inlets and outlets in accordance with the rules of NB-3331 through NB-3336 is required.

**NB-3433.3 Tangential Inlets and Outlets.** Except as modified in NB-3433.4, any design which has been demonstrated to be satisfactory for the specified Design Loadings may be used.

**NB-3433.4 Minimum Inlet and Outlet Wall Thicknesses.** The wall thickness of the inlet or outlet shall not be less than the minimum wall thickness of the casing for a distance  $l$  as shown in Figure NB-3433.4-1. The wall thickness beyond the distance  $l$  may be reduced to the minimum wall thickness of the connected piping. The change in wall thickness shall be gradual and have a maximum slope as indicated in Figure NB-4250-1. The distance  $l$  in Figure NB-3433.4-1 is the limit of reinforcement. The value of  $l$ , in. (mm), shall be determined from the relationship:

$$l = 0.5 \sqrt{r_m t_m}$$

where

$r_i$  = inlet or outlet inside radius, in. (mm)  
=  $d_i/2$

$r_m$  =  $r_i + 0.5t_m$ , in. (mm)

$t_m$  = mean inlet or outlet wall thickness, in. (mm), taken between section x-x and a parallel section y-y


#### NB-3434 Bolting

Bolting in axisymmetric arrangements involving the pressure boundary shall be designed in accordance with NB-3230.

#### NB-3435 Piping

**NB-3435.1 Piping Under External Pressure.** Piping located within the pressure-retaining boundary of the pump shall be designed in accordance with NB-3133.

**Figure NB-3433.4-1**  
**Minimum Tangential Inlet and Outlet Wall Thickness**



**NB-3435.2 Piping Under Internal Pressure.** Piping identified with the pump and external to or forming a part of the pressure-retaining boundary, such as auxiliary water connections, shall be designed in accordance with NB-3600.

#### NB-3436 Attachments

(a) External and internal attachments to pumps shall be designed so as not to cause excessive localized bending stresses or harmful thermal gradients in the pump as determined by the rules of NB-3200. Such attachments shall be designed to minimize stress concentrations in applications where the number of stress cycles, due either to pressure or thermal effect, is relatively large for the expected life of the equipment.

(b) Attachments shall meet the requirements of NB-3135.

#### NB-3437 Pump Covers

Pump covers shall be designed in accordance with NB-3200.

#### NB-3438 Supports

Pump supports shall be designed in accordance with the requirements of Subsection NF unless included under the rules of NB-3411.1(j).


### NB-3440 DESIGN OF SPECIFIC PUMP TYPES

#### NB-3441 Standard Pump Types

**NB-3441.1 Design of Type A Pumps.** Type A pumps are those having single volutes and radially split casings with single suction, as illustrated in Figures NB-3441.1-1 and NB-3441.1-2. Their design shall be in accordance with the requirements of this Subarticle.

**NB-3441.2 Design of Type B Pumps.** Type B pumps are those having single volutes and radially split casings with double suction, as illustrated in Figure NB-3441.2-1. Their design shall be in accordance with the requirements of this Subarticle.

**Figure NB-3441.1-2  
Type A Pump**



**NB-3441.3 Design of Type C Pumps.** Type C pumps are those having double volutes and radially split casings with single suction, as illustrated in Figures NB-3441.3-1 and NB-3441.3-2. The splitter is considered a structural part of the casing. Casing design shall be in accordance with the requirements of this Subarticle and with those given in (a) through (d) below.

(a) *Casing Wall Thickness.* Except where specifically indicated in these rules, no portion of the casing wall shall be thinner than the value of  $t$  determined as follows:

$$t = (0.63 \times P \times A) / S_m$$

where


$A$  = scroll dimension inside casing as shown in Figure NB-3441.3-2, in. (mm)

$P$  = Design Pressure, psig (MPa gage)


$S_m$  = allowable stress intensity for casing material at Design Temperature, psi (MPa)

$t$  = minimum allowable wall thickness, in. (mm)


**Figure NB-3441.1-1  
Type A Pump**



**Figure NB-3441.2-1  
Type B Pump**



**Figure NB-3441.3-1  
Type C Pump**



**(b) Splitter Wall Thickness**

(1) The splitter shall have a minimum wall thickness of  $t$  as determined above for the casing wall and shall extend from point B in Figure NB-3441.3-2 through a minimum angle of 135 deg to point C. Beyond point C, the splitter wall may be reduced in thickness and tapered to blend with the cutwater tip radius.

(2) Cutwater tip and splitter tip radii shall not be less than  $0.05t$ .

(3) All cutwater and splitter fillets, including the tips, where they meet the casing wall, shall have a minimum radius of  $0.10t$  or 0.25 in. (6 mm), whichever is greater.

(c) Crotch Radius (Figure NB-3441.3-2). The crotch radius shall not be less than  $0.3t$ .

**(d) Bottom of Casing**

(1) That section of the pump casing within the diameter defined by dimension  $A$  in Figure NB-3441.3-2 on the inlet side of the casing, normally referred to as the bottom of the casing (Figure NB-3441.3-1), shall have a wall thickness no less than the value of  $t$  determined in (a) above.

(2) The casing surface shall be analyzed in accordance with an acceptable procedure, such as that shown for flat heads in A-5000, or by an experimental stress technique, such as described in Appendix II.

(3) The minimum permissible thickness of the bottom of the casing shall be the lesser of the value determined by the analysis in (2) above and the value obtained from the calculation shown in (a) above.


**NB-3441.4 Design of Type D Pumps.**

(a) Type D pumps are those having double volutes and radially split casings with double suction as illustrated in Figure NB-3441.4(a)-1. The design shall be in accordance with this Subarticle.


(b) The requirements of NB-3441.3(a), NB-3441.3(b), and NB-3441.3(c), governing casing wall thickness, splitter wall thickness, and crotch radius, apply.

(c) In the casing portion between the cover and the casing wall, a wall thickness in excess of  $t$  may be required.

**Figure NB-3441.3-2  
Type C Pump**



**Figure NB-3441.4(a)-1  
Type D Pump**




**NB-3441.5 Design of Type E Pumps.** Type E pumps are those having volute type radially split casings and multivane diffusers which form structural parts of the casing as illustrated in Figure NB-3441.5-1. The design shall be in accordance with this Subarticle.

**NB-3441.6 Design of Type F Pumps.**

(a) Type F pumps are those having radially split, axisymmetric casings with either tangential or radial outlets as illustrated in Figure NB-3441.6(a)-1. The basic configuration of a Type F pump casing is a shell with a dished head attached at one end and a bolting flange at the other. The inlet enters through the dished head, and the outlet may be either tangent to the side or normal to the center line of the casing. Variations of these inlet and outlet locations are permitted.

(b) The design of Type F pumps shall be in accordance with this Subarticle.

**Figure NB-3441.5-1  
Type E Pump**



**NB-3442 Special Pump Types — Type J Pumps**

(a) Type J pumps are those that cannot logically be classified with any of the preceding types.

(b) Any design method which has been demonstrated to be satisfactory for the specified Design Conditions may be used.

**NB-3500 VALVE DESIGN**


**NB-3510 ACCEPTABILITY<sup>19</sup>**

**NB-3511 General Requirements<sup>20</sup>**

The requirements for design acceptability for valves shall be those given in this Subarticle. In all cases, pressure-temperature rating shall be as given in NB-3530 and, except for NB-3512.2(d) and in local regions (NB-3221.2), the wall thickness of the valve body shall not be less than that given by NB-3541. The requirements for prevention of nonductile fracture as set forth in NB-3211(d) shall be met. The requirements of NCA-3254(a) for specifying the location of valve boundary jurisdiction may be considered to have been met by employing the minimum limits of NB-1131, unless the Design Specification extends the boundary of jurisdiction beyond these minimum limits. The requirements of NCA-3254(b) for specifying the boundary conditions are not applicable to valve end connections.

**CAUTION:** Certain types of double-seated valves have the capability of trapping liquid in the body or bonnet cavity in the closed position. If such a cavity accumulates liquid and is in the closed position at a time when adjacent system piping is increasing in temperature, a substantial and uncontrolled increase in pressure in the body or bonnet cavity may result. Where such a condition is possible, it is the responsibility of the Owner or the Owner's designee to provide, or require to be provided, protection against harmful overpressure in such valves.

**Figure NB-3441.6(a)-1  
Type F Pump**





## NB-3512 Acceptability of Large Valves

Valve designs having an inlet piping connection larger than NPS 4 (DN 100) are acceptable when they satisfy either the standard design rules or one of the alternative design rules.

**NB-3512.1 Standard Design Rules.** The design shall be such that requirements of this Subarticle are met. The requirements of NB-3530 through NB-3550 apply to valves of conventional shape having generally cylindrical or spherical bodies with a single neck of a diameter commensurate with that of the main body portion, such as having a neck inside diameter less than twice the main run inside diameter in the neck region.

**NB-3512.2 Alternative Design Rules.** A valve design may not satisfy all of the requirements of NB-3512.1. A design may be accepted provided it meets one of the alternatives listed in (a), (b), (c), or (d) below.

(a) When the valve design satisfies the rules of NB-3530 through NB-3546.2 with thermal stresses neglected, the rules of NB-3200 relative to accounting for thermal secondary stresses and fatigue analysis [NB-3222.2, NB-3222.3, and NB-3222.4] shall also be satisfied.

(b) When a valve is exempted from fatigue analysis by the rules of NB-3222.4(d), the design is acceptable, provided that the requirements of (1) or (2) below are met.

(1) The rules of NB-3530 through NB-3546 shall be met. The rules of NB-3200 may be substituted for those of NB-3545.2 for evaluating secondary stresses, and NB-3545.3 need not be considered.

(2) The rules of NB-3530 and NB-3541 shall be met. An experimental stress analysis is performed in accordance with Appendix II, and the rules of NB-3200 with respect to primary and secondary stresses resulting from pressure and mechanical loads shall be met. Unless otherwise specified in the Design Specifications, the pipe reactions shall be taken as those loads which produce a stress [NB-3545.2(b)] of 0.5 times the yield strength of the piping in tension for the direct or axial load and a stress of 1.0 times the yield strength of the piping in bending and torsion. Thermal secondary stresses shall be accounted for by either the rules of NB-3200 or NB-3545.

(c) When a valve design satisfies the rules of NB-3530 and NB-3541, and when an experimental stress analysis has been performed upon a similar valve in accordance with Appendix II, and an acceptable analytic method has been established, the results may be used in conjunction with the requirements of NB-3200 for pressure and mechanical loads to establish design acceptability. Accommodation of thermal secondary stresses and pipe reactions shall be as given in (b)(2). Requirements for fatigue analysis of either NB-3200 or NB-3550 shall be met.

(d) When permitted by the Design Specification, a weld end valve that does not meet all of the requirements of NB-3540 may be designed so that it meets the require-

ments of NB-3200 for all pressure-retaining parts and those parts defined by NB-3546.3(a), and shall also meet all of the following requirements.

(1) Pressure, thermal, and mechanical effects, such as those resulting from earthquake, maximum stem force, closure force, assembly forces, and others that may be defined in the Design Specification, shall be included in the design analysis. For Level A Service Limits, the pipe reaction effects are to be determined by considering that the maximum fiber stress in the connected pipe is at one-half of its yield strength in direct tension and at its yield strength in torsion and in bending in the plane of the neck and run, and also in the plane of the run perpendicular to the neck, each considered separately. The individual pipe reaction effects that result in the maximum stress intensity at all points, including all other effects, shall be used for the analysis to satisfy the rules of NB-3200. The valve Design Specification shall provide the loadings and operating requirements to be considered under Level B, C, and D Service Limits [NCA-3252(a)(6)] for which a design analysis is to be included in the Design Report.

(2) In place of using the values of  $S_m$  to satisfy the rules of NB-3200, the allowable stress intensity values for ferritic valve body and bonnet materials shall be those allowable stress values given in Section II, Part D, Subpart 1, Table 1A. For materials in Section II, Part D, Subpart 1, Tables 2A and 2B, a reduced allowable stress intensity based on applying a factor of 0.67 to the yield strengths listed in Section II, Part D, Subpart 1, Table Y-1 shall be used.

(3) The adequacy of the stress analysis of the body and bonnet shall be verified by experimental stress analysis conducted in accordance with the requirements of II-1100 through II-1400. Individual tests shall be made to verify the adequacy of the stress analysis of internal pressure effects and pipe reaction effects. Tests shall be made on at least one valve model of a given configuration, but a verified analytical procedure may then be applied to other valves of the same configuration, although they may be of different size or pressure rating. The geometrical differences shall be accounted for in the extrapolation stress analysis. The analytical procedure shall have verified capability of providing this extrapolation.

(4) A Design Report shall be prepared in sufficient detail to show that the valve satisfies all applicable requirements.

(5) Prior to installation, the valve shall be hydrostatically tested in accordance with NB-3531.2. For this purpose, the primary pressure rating shall be determined by interpolation in accordance with NB-3543(c).

## NB-3513 Acceptability of Small Valves

Valve designs having an inlet piping connection NPS 4 (DN 100) or less are acceptable when they satisfy either the standard design rules or the alternative design rules.

**NB-3513.1 Standard Design Rules.** The design shall be such that the requirements of [NB-3530](#) and [NB-3541](#) shall be met for wall thicknesses corresponding to the applicable pressure-temperature rating. When the Special Class Ratings of ASME B16.34 apply, the NDE exemptions of [NB-2510](#) shall not be used.

**NB-3513.2 Alternative Design Rules.** A valve design shall satisfy the requirements of [NB-3512.2](#).

## **NB-3515 Acceptability of Metal Bellows and Metal Diaphragm Stem Sealed Valves**

Valves using metal bellows or metal diaphragm stem seals shall be constructed in accordance with the rules of this Subarticle, based on the assumption that the bellows or diaphragms do not retain pressure, and Design Pressure is imposed on a required backup stem seal such as packing. The bellows or diaphragms need not be constructed in accordance with the requirements of this Section.

## **NB-3520 DESIGN CONSIDERATIONS**

### **NB-3521 Design and Service Loadings**

The general design considerations of [NB-3100](#) are applicable to valves. In case of conflict between [NB-3100](#) and [NB-3500](#), the requirements of [NB-3500](#) shall apply.

### **NB-3524 Earthquake**

The rules of this Subarticle consider that under earthquake loadings the piping system, not the valve, will be limiting and that the integrity of the valve pressure-retaining body is adequately considered under the piping requirements of [NB-3600](#). Where valves are provided with operators having extended structures and these structures are essential to maintaining pressure integrity, an analysis, when required by the Design Specifications, may be performed based on static forces resulting from equivalent earthquake accelerations acting at the centers of gravity of the extended masses.

### **NB-3525 Levels A and B Service Limits**

The design rules of [NB-3512](#) and [NB-3513](#) apply to loadings for which Level A or B Limits are designated except that when evaluating Level B Limits during operation of relief or safety valves (a) and (b) below shall be met.

(a) The service pressure may exceed the Design Pressures defined by the pressure-temperature ratings of ASME B16.34 by no more than 10%.

(b) The rules of [NB-3540](#) apply using allowable stress intensity values of 110% of those listed in Section II, Part D, Subpart 1, Tables 2A and 2B.

## **NB-3526 Level C Service Limits**

If the Design Specifications specify any loadings for which Level C Limits are designated, the rules used in evaluating these loadings shall be those of [NB-3512](#) and [NB-3513](#), except as modified by the following subparagraphs.

**NB-3526.1 Pressure-Temperature Ratings.** The pressure permissible for loadings for which Level C Limits are designated shall not exceed 120% of that permitted for Level A Limits.

**NB-3526.2 Pipe Reaction Stress.** Pipe reaction stresses shall be computed in accordance with the equations of [NB-3545.2\(b\)\(1\)](#), and the allowable value considered individually is  $1.8S_m$  for the valve body material at 500°F (260°C). In performing these calculations, the value of  $S$  shall be taken as 1.2 times the yield strength at 500°F (260°C) of the material of the connected pipe, or 36.0 ksi (248 MPa) when the pipe material is not defined in the Design Specifications.

**NB-3526.3 Primary Stress and Secondary Stress.** (13) The equation of [NB-3545.2](#) shall be satisfied using  $C_p$  equal to 1.5,  $P_{eb}$  computed in accordance with [NB-3526.2](#), and  $Q_{T3}$  equal to 0, and the calculated value shall be limited to  $2.25S_m$ .

**NB-3526.4 Secondary and Peak Stresses.** The requirements of [NB-3545](#) and [NB-3550](#) need not be met.

## **NB-3527 Level D Service Limits**

If the Design Specifications specify any loadings for which Level D Limits are designated, the guidelines of Appendix F may be used in evaluating those loadings independently of other loadings.

## **NB-3530 GENERAL RULES**

### **NB-3531 Pressure-Temperature Ratings and Hydrostatic Tests**

**NB-3531.1 Pressure-Temperature Ratings.** A valve designed in accordance with [NB-3541](#) may be used in accordance with the pressure-temperature ratings in ASME B16.34, Tables 2-1.1A to 2-2.7A (Standard Class) for flanged end or welding end (including socket welding end) valves, and ASME B16.34, Tables 2-1.1B to 2-2.7B (Special Class) for welding end (including socket welding end) valves, provided the Design Pressure and Design Temperature are used. When a single valve has a flanged and a welding end, the flanged end requirements shall be used. The materials<sup>21</sup> listed in ASME B16.34, Table 1, may be used if listed in Section II, Part D, Subpart 1, Tables 2A and 2B, subject to the temperature limitations therein, and as defined in NCA-1220.

#### **NB-3531.2 Hydrostatic Tests.**

(a) Valves designed in accordance with [NB-3541](#) shall be subjected to the shell hydrostatic test pressures required by ASME B16.34 and in accordance with other

appropriate rules of [NB-6000](#). Valves with a primary pressure rating less than Class 150 shall be subjected to the required test pressure for Class 150 rated valves.

(b) The shell hydrostatic test shall be made with the valve in the partially open position. Stem leakage during this test is permissible. End closure seals for retaining fluid at test pressure in welding end valves may be positioned in the welding end transitions, as defined in [NB-3544.8\(b\)](#), in reasonable proximity to the end plane of the valve so as to ensure safe application of the test pressure.

(c) After the shell hydrostatic test, a valve closure test shall also be performed with the valve in the fully closed position with a test pressure across the valve disk no less than 110% of the 100°F (38°C) pressure rating. For valves that are designed for Service Conditions that have the pressure differential across the closure member limited to values less than the 100°F (38°C) pressure rating, and have closure members or actuating devices (direct, mechanical, fluid, or electrical), or both, that would be subject to damage at high differential pressures, the test pressure may be reduced to 110% of the maximum specified differential pressure in the closed position. This exception shall be identified in the Design Specification, and this maximum specified differential pressure shall be noted on the valve nameplate and N Certificate Holder's Data Report Form. During this test, seat leakage is permitted unless a limiting leakage value is defined by the Design Specifications. The duration of this test shall be 1 min/in. (2.5 sec/mm) of minimum wall thickness  $t_m$  with a minimum duration of 1 min unless otherwise defined in the Design Specifications.

(d) For valves designed for nonisolation service, whose primary function is to modulate flow, and by their design are prevented from providing full closure, the valve closure test defined in (c) above is not required. This exception shall be identified in the Design Specification and noted on the valve nameplate and the N Certificate Holder's Data Report Form.

(e) Hydrostatic tests for metal bellows or metal diaphragm stem sealed valves shall include hydrostatic testing of the valve body, bonnet, body-to-bonnet joint, and either the bellows or diaphragm or the required backup stem seal.

(f) The inlet (primary pressure-containing) portion of pressure relief valves shall be hydrostatically tested at a pressure at least 1.5 times the set pressure marked on the valve. For closed system application, the outlet portion of the pressure relief valves shall be hydrostatically tested to 1.5 times the design secondary pressure ([NB-7111](#)).

**NB-3531.3 Allowance for Variation From Design Loadings.** Under the conditions of relief or safety valve operation for valves designed in accordance with [NB-3541](#), the service pressure may exceed the Design Pressure as defined by the pressure-temperature ratings of ASME B16.34 by no more than 10%.

## NB-3532 Design Stress Intensity Values

Design stress intensity values to be used in the design of valves are given in Section II, Part D, Subpart 1, Tables 2A and 2B.<sup>21</sup>

## NB-3533 Marking

Each valve shall be marked as required by ASME B16.34 and NCA-8220.

## NB-3534 Nomenclature

- $A_f$  = effective fluid pressure area based on fully corroded interior contour for calculating crotch primary membrane stress [[NB-3545.1\(a\)](#)]
- $A_m$  = metal area based on fully corroded interior contour effective in resisting fluid force acting on  $A_f$  [[NB-3545.1\(a\)](#)]
- $C_a$  = stress index for oblique bonnets [[NB-3545.2\(a\)](#)]
- $C_b$  = stress index for body bending secondary stress resulting from moment in connected pipe [[NB-3545.2\(b\)](#)]
- $C_p$  = stress index for body primary plus secondary stress, inside surface, resulting from internal pressure [[NB-3545.2\(a\)](#)]
- $C_1$  = discontinuity temperature gradient index, °F/in.<sup>2</sup> (°C/mm<sup>2</sup>) [[NB-3545.2](#)]
- $C_2$  = stress index for thermal secondary membrane stress resulting from structural discontinuity
- $C_3$  = stress index for maximum secondary membrane plus bending stress resulting from structural discontinuity
- $C_4$  = maximum magnitude of the difference in average wall temperatures for wall thicknesses  $T_{e1}$  and  $t_e$  (resulting from a step change in fluid temperature  $\Delta T_f$ ) divided by  $\Delta T_f$
- $C_5$  = stress index for thermal fatigue stress component resulting from through-wall temperature gradient caused by step change in fluid temperature [[NB-3550](#)]
- $C_6$  =  $E\alpha$  = product of Young's modulus and the coefficient of linear thermal expansion at 500°F (260°C), psi/°F (MPa/°C) ([NB-3550](#))
- $C_7$  = stress index for thermal stress resulting from through-wall temperature gradient associated with 100°F/hr (56°C/hr) fluid temperature change rate, psi/in. (MPa/mm)
- $d$  = inside diameter used as a basis for crotch reinforcement [[NB-3545.1\(a\)](#)]
- $d_e$  = inside diameter of the larger end of the valve body [[NB-3545.2\(b\)\(3\)](#)]
- $d_m$  = inside diameter used as basis for determining body minimum wall thickness ([NB-3541](#))
- $F_b$  = bending modulus of standard connected pipe
- $G_b$  = valve body section bending modulus at crotch region [[NB-3545.2\(b\)](#)], in.<sup>3</sup> (mm<sup>3</sup>)

- $I$  = moment of inertia, used in calculating  $G_b$  [NB-3545.2(b)(5)]
- $I_t$  = fatigue usage factor for step changes in fluid temperature
- $K_e$  = strain distribution factor used in elastic-plastic fatigue calculation (NB-3550)
- $L_A, L_N$  = effective distances used to determine  $A_f, A_m$  [NB-3545.1(a)(3)]
- $m, n$  = material parameters for determining  $K_e$  [NB-3554]
- $N_a$  = permissible number of complete startup/shutdown cycles at 100°F/hr (56°C/hr) fluid temperature change rate (NB-3545.3)
- $N_i$  = permissible number of step changes in fluid temperature from Figs. I-9.0
- $N_{ri}$  = required number of fluid step temperature changes  $\Delta T_{fi}$  (NB-3553)
- $P_{eb}$  = secondary stress due to pipe reaction [NB-3545.2(b)], psi (MPa)
- $P_m$  = general primary membrane stress intensity at crotch region, calculated according to NB-3545.1(a), psi (MPa)
- $p_d$  = Design Pressure, psi (MPa)
- $p_r$  = Pressure Rating Class Index, psi (MPa)
- $p_s$  = standard calculation pressure from NB-3545.1, psi (MPa)
- $p_1, p_2$  = rated pressures from tables of ASME B16.34 corresponding to Pressure Rating Class Indices  $p_{r1}$  and  $p_{r2}$ , psi (MPa)
- $Q_p$  = sum of primary plus secondary stresses at crotch resulting from internal pressure [NB-3545.2(a)], psi (MPa)
- $Q_{T1}$  = maximum thermal stress component caused by through-wall temperature gradient associated with 100°F/hr (56°C/hr) fluid temperature change rate [NB-3545.2(c)], psi (MPa)
- $Q_{T3}$  = maximum thermal secondary membrane plus bending stress resulting from structural discontinuity and 100°F/hr (56°C/hr) fluid temperature change rate, psi (MPa)
- $r$  = mean radius of body wall at crotch region [Figure NB-3545.2(c)-1], in. (mm)
- $r_i$  = inside radius of body at crotch region for calculating  $Q_p$  [NB-3545.2(a)], in. (mm)
- $r_2$  = fillet radius of external surface at crotch [NB-3545.1(a)], in. (mm)
- $S$  = assumed maximum stress in connected pipe for calculating the secondary stress due to pipe reaction [NB-3545.2(b)], psi (MPa)
- $S_i$  = fatigue stress intensity range at crotch region resulting from step change in fluid temperature  $\Delta T_{fi}$  and pressure  $\Delta P_{fi}$  (NB-3550), psi (MPa)
- $S_m$  = design stress intensity (NB-3532), psi (MPa)
- $S_n$  = sum of primary plus secondary stress intensities at crotch region resulting from 100°F/hr (56°C/hr) temperature change rate (NB-3545.2), psi (MPa)
- $S_{n(max)}$  = maximum range of sum of primary plus secondary stress, psi (MPa)
- $S_{p1}$  = fatigue stress intensity at inside surface in crotch region resulting from 100°F/hr (56°C/hr) fluid temperature change rate (NB-3545.3), psi (MPa)
- $S_{p2}$  = fatigue stress intensity at outside surface in crotch region resulting from 100°F/hr (56°C/hr) fluid temperature change rate (NB-3545.3), psi (MPa)
- $T_b$  = thickness of valve wall adjacent to crotch region for calculating  $L_A$  and  $L_N$  [Figure NB-3545.1(a)-1], in. (mm)
- $T_e$  = maximum effective metal thickness in crotch region for calculating thermal stresses [Figure NB-3545.2(c)-1], in. (mm)
- $T_r$  = thickness of body (run) wall adjacent to crotch for calculating  $L_A$  and  $L_N$  [Figure NB-3545.1(a)-1], in. (mm)
- $t_e$  = minimum body wall thickness adjacent to crotch for calculating thermal stresses [Figure NB-3545.2(c)-1], in. (mm)
- $t_m$  = minimum body wall thickness as determined by NB-3541, in. (mm)
- $t_1, t_2$  = minimum wall thicknesses from ASME B16.34 corresponding to Listed Pressure Rating Class Indices  $p_{r1}$  and  $p_{r2}$  and inside diameter  $d_m$ , in. (mm)
- $\Delta P_{fi}$  = full range of pressure fluctuation associated with  $\Delta T_{fi}$ , psi (MPa)
- $\Delta P_i$  = specified range of pressure fluctuation associated with  $\Delta T_i$ , psi (MPa)
- $\Delta T_{fi}$  = a specified step change in fluid temperature, °F (°C), where  $i = 1, 2, 3, \dots, n$ ; used to determine the fatigue acceptability of a valve body (NB-3554)
- $\Delta T_i$  = specified range of fluid temperature, °F (°C), where  $i = 1, 2, 3, \dots, n$ ; used to evaluate normal valve usage (NB-3553)
- $\Delta T'$  = maximum magnitude of the difference in average wall temperatures for walls of thicknesses  $t_e$  and  $T_e$ , resulting from 100°F/hr (56°C/hr) fluid temperature change rate, °F (°C)

## NB-3540 DESIGN OF PRESSURE-RETAINING PARTS

### NB-3541 General Requirements for Body Wall Thickness

The minimum wall thickness of a valve body is to be determined by the rules of NB-3542 or NB-3543.



**(13) NB-3542 Minimum Wall Thickness of Listed Pressure Rated Valves<sup>22</sup>**

The wall thickness requirements for listed pressure rated valves apply also to integral body venturi valves. For a valve designed to a listed pressure rating of ASME B16.34, the minimum thickness of its body wall, including the neck, is to be determined from ASME B16.34. Highly localized variations of inside diameter associated with weld preparation [NB-3544.8(a) and NB-3544.8(b)] need not be considered for establishing minimum wall thickness  $t_m$ . In all such cases, however, the requirements of NB-3545.2(b)(6) shall be satisfied.

**NB-3543 Minimum Wall Thickness of Valves of Nonlisted Pressure Rating<sup>22</sup>**

To design a valve for Design Pressure and Design Temperature corresponding to other than one of the pressure ratings listed in the tables of ASME B16.34, the procedure is the same as that of NB-3542 except that interpolation is required as follows.

(a) Based on the Design Temperature, linear interpolation between the tabulated temperature intervals shall be used to determine the listed pressure rating  $p_1$ , next below, and  $p_2$ , next above, the Design Pressure  $p_d$  corresponding to listed Pressure Rating Class Indices,<sup>23</sup>  $p_{r1}$  and  $p_{r2}$ , respectively.

(b) Determine the minimum wall thickness  $t_m$  corresponding to Design Loadings by:

$$t_m = t_1 + \left( \frac{p_d - p_1}{p_2 - p_1} \right) \times (t_2 - t_1)$$

(c) Determine the interpolated Pressure Rating Class Index  $p_r$ , corresponding to Design Loadings, by:

$$p_r = p_{r1} + \left( \frac{p_d - p_1}{p_2 - p_1} \right) \times (p_{r2} - p_{r1})$$

**NB-3544 Body Shape Rules**

The rules of this paragraph constitute minimum requirements intended to limit the fatigue strength reduction factor, associated with local structural discontinuities in critical regions, to 2.0 or less. When smaller values of the fatigue strength reduction factor can be justified, it is permissible to use them.

**NB-3544.1 Fillets for External and Internal Intersections and Surfaces.**

(a) Intersections of the surfaces of the pressure retaining boundary at the neck to body junction shall be provided with fillets of radius  $r_2 \geq 0.3 t_m$ . Figure NB-3544.1(a)-1 illustrates such fillets.

(b) Corner radii on internal surfaces with  $r_4 < r_2$  are permissible.

(c) Sharp fillets shall be avoided. When sharp discontinuities are convenient for ring grooves and similar configuration details, they shall be isolated from the major body primary and secondary stresses or modified as illustrated by Figure NB-3544.1(c)-1.

**NB-3544.2 Penetrations of Pressure-Retaining Boundary.** Penetrations of the pressure-retaining boundary, other than the neck intersection, such as holes required for check valve shafts and drain or sensing lines, shall be located to minimize the compounding of normal body stresses.

**NB-3544.3 Attachments.** Attachments, such as lugs and similar protuberances, on the pressure-retaining boundary shall be tapered to minimize discontinuity stresses (Figure NB-3544.3-1). Reentrant angles shall be avoided. Attachments shall meet the requirements of NB-3135.

**NB-3544.4 Body Internal Contours.** Body internal contours in sections normal to the run or neck center lines shall be generally smooth in curvature, or so proportioned that the removal of unavoidable discontinuities, such as the valve seat, will leave generally smooth curvature.

**NB-3544.5 Out-of-Roundness.** Out-of-roundness in excess of 5% for sections of essentially uniform thickness shall be such that:

$$\frac{b}{t_b} + \frac{3}{4} \left( \frac{3b^2 - 2ab - a^2}{t_b^2} \right) + 1 \leq 1.5 \left( \frac{S_m}{p_s} \right)$$

where

$2a$  = minor inside diameter, in. (mm)

$2b$  = major inside diameter, in. (mm)

$t_b$  = thickness, in. (mm)

The ovality criterion can be satisfied by increasing the thickness locally, provided that the thickness variation is smoothly distributed. Out-of-roundness in excess of this limitation must be compensated for by providing reinforcement.

**NB-3544.6 Doubly Curved Sections.** Sections curved longitudinally with radius  $r_{Long}$ , as well as laterally with radius  $r_{Lat}$ , must be such that:


$$\frac{1}{r_{Long}} + \frac{1}{r_{Lat}} \geq \frac{4}{3d_m}$$

where  $d_m$  is the diameter used to establish the local wall thickness by NB-3541.

**NB-3544.7 Flat Sections.** Flat sections shall be sufficiently limited in extent so that arcuate sections having the same radius-thickness ratio as required by NB-3542 may be inscribed (Figure NB-3544.7-1). The inscribed section may be less thick than the minimum thickness required by NB-3542, provided that its radius is proportionally smaller than the value used to determine the minimum




**Figure NB-3544.1(a)-1  
Filletlets and Corners**




**Figure NB-3544.1(c)-1  
Ring Grooves**

$$r_3 \geq \begin{cases} 0.05 t_m \\ 0.1 h \end{cases} \text{ whichever is greater}$$



**Figure NB-3544.3-1**  
**Lugs and Protuberances**



required thickness. The method of NB-3544.6 above may be used to show additive support, but the denominator of the right side term must be reduced in the ratio of the thickness of the inscribed arcuate section to the minimum required thickness (NB-3542). If adequacy cannot be shown by the above rules, it is necessary to determine the stresses in the flat region experimentally to demonstrate adequacy for pressure induced stresses only, with internal pressure equal to the standard calculation pressure  $p_s$ .

#### **NB-3544.8 Body End Dimensions.**

(a) Valve body contours at valve weld ends shall be in accordance with Figure NB-4250-1, and, unless otherwise stated in the Design Specifications, with ASME B16.34.

(b) Valve body transitions leading to valve weld ends shall be in accordance with ASME B16.34.

(c) Flanged ends shall be in accordance with ASME B16.34.

(d) Alignment tolerances given in Figure NB-4233(a)-1 shall apply to all auxiliary piping, such as drain lines, which begin or terminate at the valve.

(e) For socket welding ends, valves NPS 2 (DN 50) and smaller for which the body cavity consists of cylindrically bored sections shall meet all of the following:

- (1)  $d_m$  shall be the port drill diameter;
- (2) the requirements of NB-3542 shall be satisfied; and
- (3) socket welding end valves greater than NPS 2 (DN 50) shall not be used.

#### **NB-3544.9 Openings for Auxiliary Connections.**

Openings for auxiliary connections, such as for drains, bypasses, and vents, shall meet the requirements of ASME B16.34 and the applicable reinforcement requirements of NB-3330.

#### **NB-3545 Body Primary and Secondary Stress Limits**


The limits of primary and secondary stresses are established in the following subparagraphs.

**NB-3545.1 Primary Membrane Stress Due to Internal Pressure.** For valves meeting all requirements of this Subarticle, the most highly stressed portion of the body under internal pressure is at the neck to flow passage junction and is characterized by circumferential tension normal to the plane of center lines, with the maximum value at the inside surface. The rules of this paragraph are intended to control the general primary membrane stress in this crotch region. The Standard Calculation Pressure  $p_s$  to be used for satisfying the requirements of NB-3545 is found either directly or by interpolation from the tables in ASME B16.34 as the pressure at 500°F (260°C) for the given Pressure Rating Class Index  $p_r$ .

(a) In the crotch region, the maximum primary membrane stress is to be determined by the pressure area method in accordance with the rules of (1) through (6) below using Figure NB-3545.1(a)-1.

(1) From an accurately drawn layout of the valve body, depicting the finished section of the crotch region in the mutual plane of the bonnet and flow passage center

**Figure NB-3544.7-1  
Flat Wall Limitation**



lines, determine the fluid area  $A_f$  and metal area  $A_m$ .  $A_f$  and  $A_m$  are to be based on the internal surface after complete loss of metal assigned to corrosion allowance.

(2) Calculate the crotch general primary membrane stress intensity:

$$p_m = \left( \frac{A_f}{A_m} + 0.5 \right) p_s$$

The allowable value of this stress intensity is  $S_m$  for the valve body material at 500°F (260°C) as given in Section II, Part D, Subpart 1, Tables 2A and 2B.

(3) The distances  $L_A$  and  $L_N$  which provide bounds on the fluid and metal areas are determined as follows. Use the larger value of:

$$L_A = 0.5d - T_b$$

or

$$L_A = T_r$$

and use

$$L_N = 0.5r_2 + 0.354 \sqrt{T_b(d + T_b)}$$


where the dimensions are as shown in Figure NB-3545.1(a)-1.

In establishing appropriate values for the above parameters, some judgment may be required if the valve body is irregular as it is for globe valves and others with non-symmetric shapes. In such cases, the internal boundaries of  $A_f$  shall be the lines that trace the greatest width of internal wetted surfaces perpendicular to the plane of the stem and pipe ends [Figure NB-3545.1(a)-1 sketches (b), (d), and (e)].


(4) If the calculated boundaries for  $A_f$  and  $A_m$ , as defined by  $L_A$  and  $L_N$ , fall beyond the valve body [Figure NB-3545.1(a)-1 sketch (b)], the body surface becomes the proper boundary for establishing  $A_f$  and  $A_m$ . No credit is to be taken for any area of connected piping which may be included within the limits of  $L_A$  and  $L_N$ . If the flange is included with  $A_m$ , the area of one bolt hole is to be subtracted for determining the net value of  $A_m$ .

(5) Except as modified below, web or fin-like extensions of the valve body are to be credited to  $A_m$  only to an effective length from the wall equal to the average thickness of the credited portion. The remaining web area is to be added to  $A_f$  [Figure NB-3545.1(a)-1 sketch (b)]. However, to the extent that additional area will pass the following test, it may also be included in  $A_m$ . A line perpendicular to the plane of the stem and pipe ends from any points in  $A_m$  does not break out of the wetted surface but passes through a continuum of metal until it breaks through the outer surface of the body.


**Figure NB-3545.1(a)-1**  
**Pressure Area Method**



**Figure NB-3545.1(a)-1**  
**Pressure Area Method (Cont'd)**



(d)



(e)

Interior contour  
for fully corroded  
condition



(6) In most cases, it is expected that the portions defined by  $A_m$  in the several illustrations of Figure NB-3545.1(a)-1 will be most highly stressed. However, in the case of highly irregular valve bodies, it is recommended that all sections of the crotch be checked to ensure that the largest value of  $P_m$  has been established considering both open and fully closed conditions.

(b) In regions other than the crotch, while the value of  $P_m$  calculated by (a) will be the highest value of body general primary membrane stress for all normal valve types with typical wall proportioning, the designer is cautioned to review unusual body configurations for possible higher stress regions. Suspected regions are to be checked by the pressure area method applied to the particular local body contours. The allowable value of this stress intensity is  $S_m$  for the valve body material at 500°F (260°C) as given in Section II, Part D, Subpart 1, Tables 2A and 2B.

**NB-3545.2 Secondary Stresses.** In addition to satisfying the criteria of NB-3541 through NB-3545.1, a valve body shall also satisfy the criterion that the range of primary plus secondary stresses  $S_n$  due to internal pressure, pipe reaction, and thermal effects shall not exceed  $3S_m$  for the body material at 500°F (260°C), where  $Q_p$ ,  $P_{eb}$ , and  $Q_{T3}$  are determined by the rules of this paragraph. That is:

$$S_n = Q_p + P_{eb} + 2Q_{T3} \leq 3S_m$$

(a) See below.

(1) The body primary plus secondary stress  $Q_p$  due to internal pressure is to be determined by:

$$Q_p = C_p \left( \frac{r_i}{t_e} + 0.5 \right) p_s$$

where the primary plus secondary pressure stress index  $C_p$  is equal to 3 and

$p_s$  = Standard Calculation Pressure defined by NB-3545.1, psi (MPa)

$r_i$  = radius of a circle which circumscribes the inside wall contour in the crotch region, in. (mm)

$t_e$  = an effective wall thickness at that location, in. (mm) (typically  $t_e = T_r$ ) [Figure NB-3545.1(a)-1]

In choosing an appropriate value for  $t_e$ , credit may be taken for general reinforcement material at the critical section but not for local fillets. Protuberances or ribs are not to be considered in determining  $r_i$  and  $t_e$ . Guidance is provided by Figure NB-3545.2(a)-1 in which the illustrations correspond to the critical sections of the valve bodies of Figure NB-3545.1(a)-1. The parameters  $r_i$  and  $t_e$  are intended to be representative of a tee, reinforced or unreinforced, with the general configuration of the valve body for which minor shape details associated with the valve function are ignored.

(2) For valve bodies with bonnet center lines other than perpendicular to the flow passage, the body stress  $Q_p$  due to internal pressure defined above must be multiplied by the factor  $C_a$ :

$$C_a = 0.2 + \frac{0.8}{\sin \alpha}$$

where

$\alpha$  = acute angle between the bonnet and flow passage center lines, deg

(b) The secondary stress due to pipe reaction shall meet the criteria of (1) through (6) below to ensure the adequacy of the valve body for safely transmitting forces and moments imposed by the connected piping system.

(1) Based on the critical section A-A at the crotch, as illustrated by Figure NB-3545.2(a)-1, calculate the value of  $P_{eb}$  where

(Bending load effect)

$$P_{eb} = \frac{C_b F_b S}{G_b}$$

The allowable value of  $P_{eb}$  is  $1.5S_m$  for the valve body material at 500°F (260°C). Determination of  $S$ ,  $F_b$ ,  $C_b$ , and  $G_b$  required to calculate  $P_{eb}$  is to be in accordance with the requirements of (2) through (5) below.

(2) When the valve designer knows the material of the connected pipe,  $S$  may be calculated as the yield strength for the pipe material at 500°F (260°C). When the designer does not know the piping material or is designing a valve independently of a particular application, the value of  $S$  shall be taken as 30,000 psi (200 MPa).

(3) Calculate  $F_b$  as follows:

$$F_b = \frac{0.393 d_e^3 p_s}{f_o - p_s}$$

where

$d_e$  = the inside diameter of the larger end of the valve body

$f_o$  = 20,000 when  $p_s$  is in psi units

$f_o$  = 137.9 when  $p_s$  is in MPa units

The value  $F_b$  to be applied shall be the greater of the calculated value, or

(-a) for  $d_e \leq 10.02$  in. (254.5 mm), the section modulus of Schedule 40 pipe with the next larger inside diameter than  $d_e$ , or

(-b) for  $d_e > 10.02$  in. (254.5 mm), the quantity:


(-1)  $0.295 d_e^2$  when  $d_e$  is in inch units

(-2)  $7.493 d_e^2$  when  $d_e$  is in mm units

(4) Calculate the factor  $C_b$ :

$$C_b = 0.335 \left( \frac{r}{t_e} \right)^{\frac{2}{3}}$$

**Figure NB-3545.2(a)-1**  
**Critical Sections of Valve Bodies**



When the results are less than 1.0, use  $C_b = 1.0$ .

(5) The factor  $G_b$  is the section modulus  $I/(r_i + t_e)$ , in.<sup>3</sup> (mm<sup>3</sup>), for bending at the plane through A-A about the axis perpendicular to the mutual plane of bonnet and body center lines, such as that axis which produces maximum bending stress at the corner of the crotch. The fiber stress at the outside surface is to be considered as governing in calculating  $G_b$ .

(6) When valves are to be applied in a venturi arrangement such that the connected pipe may be larger than that corresponding to the nominal size of the valve, it is necessary to base  $P_{eb}$  on the actual larger connected pipe. Such cases must be treated individually to ensure compliance with the secondary and fatigue stress criteria of this Subarticle. When the venturi arrangement is not fabricated by the N Certificate Holder, the Design Specifications shall include sufficient information to permit the N Certificate Holder to make this check.

(c) Thermal secondary stresses in the valve crotch region, resulting from through-wall temperature gradient and thickness variation (average temperature difference), are to be calculated on the basis of a continuous ramp change in fluid temperature at 100°F/hr (56°C/hr) using the model of Figure NB-3545.2(c)-1 sketch (a). Figure NB-3545.2(c)-1 sketch (b) illustrates how  $r$ ,  $T_{e1}$ ,  $T_{e2}$ , and  $t_e$  are to be determined for the typically irregular crotch shape of valves. The thermal secondary stress components are to be determined in accordance with the following:

(1) Stress component  $Q_{T1}$  which is the result of a through-wall temperature gradient is defined as:

$$Q_{T1} = C_7 (T_{e1})^2$$

where

$C_7 = 110 \text{ psi/in.}^2$  (0.001 MPa/mm<sup>2</sup>) for ferritic steels, or  
 $C_7 = 380 \text{ psi/in.}^2$  (0.004 MPa/mm<sup>2</sup>) for austenitic steels

$T_{e1}$  is illustrated in Figure NB-3545.2(c)-1.

(2) Stress component  $Q_{T3}$  which is the membrane plus bending stress as a result of wall thickness variation is defined as:

$$Q_{T3} = C_6 C_3 \Delta T'$$

where  $C_3$  is found from Figure NB-3545.2(c)-4 and

$$\Delta T' = C_1 (T_{e1}^2 - t_e^2)$$

where

$C_1 = 0.53 \text{ °F/in.}^2$  ( $4.6 \times 10^{-4} \text{ °C/mm}^2$ ) for ferritic steels,  
 or  
 $C_1 = 1.4 \text{ °F/in.}^2$  ( $1.2 \times 10^{-3} \text{ °C/mm}^2$ ) for austenitic steels

$t_e$  is illustrated in Figure NB-3545.2(c)-1.

**NB-3545.3 Fatigue Requirements.** The fatigue analysis requirements are satisfied provided the rules of this subparagraph and the rules of NB-3550 are met.

The calculated allowable number of cycles is  $N_a \geq 2,000$  cycles, where  $N_a$  is determined from Figs. I-9.0 by entering the appropriate curve with  $S_a$ , with  $S_a$  defined as the larger value of  $S_{p1}$  and  $S_{p2}$  defined as follows:

$$S_{p1} = \frac{2}{3} Q_p + \frac{P_{eb}}{2} + Q_{T3} + 1.3 Q_{T1}$$

$$S_{p2} = 0.4 Q_p + \frac{K}{2} (P_{eb} + 2 Q_{T3})$$

The values of  $S_{p1}$  and  $S_{p2}$  are based on the values for  $Q_p$ ,  $P_{eb}$ ,  $Q_{T1}$ , and  $Q_{T3}$  found in accordance with the rules of NB-3545.2.  $K$  is the fatigue strength reduction factor associated with the external fillet at the crotch and is to be considered as 2.0 unless the designer can justify use of a smaller value.

## NB-3546 Design Requirements for Valve Parts Other Than Bodies

### NB-3546.1 Body-to-Bonnet Joints.

(a) Bolted body-to-bonnet joints shall be designed in accordance with the pressure design rules of XI-3000, including the use of the appropriate allowable stress given in Section II, Part D, Subpart 1, Tables 1A and 1B, or by the procedures of NB-3200, except fatigue analysis of bolts is not required.

(b) Body-to-bonnet joints other than bolted connections including joints of special or patented types for which specific standards do not exist may be used provided that the N Certificate Holder shall use methods of design and construction that will be as safe as otherwise required by the rules of this Subarticle for the following design conditions:

(1) Design Pressure equal to Standard Calculation Pressure  $p_s$  (NB-3545.1);

(2) calculation temperature of 500°F (260°C);

(3) thermal stresses based on most severe conditions resulting from continuous fluid temperature ramp increase or decrease at 100°F/hr (56°C/hr);

(4) fatigue life at least 2,000 cycles of startup/shutdown based on the above conditions with simultaneous increase or decrease of pressure and temperature.



**NB-3546.2 Valve Disk.** The valve disk shall be considered a part of the pressure-retaining boundary. The primary membrane stress intensity shall not exceed  $S_m$ , and the primary bending stress intensity shall not exceed  $1.5 S_m$ .

### NB-3546.3 Other Valve Parts.

(a) Valve stems, stem retaining structures, and other significantly stressed valve parts whose failure can lead to gross violation of the pressure-retaining boundary shall be designed so that their primary stresses, based on pressure equal to the 100°F (38°C) pressure rating and conservatively estimated or calculated additional loadings,

**Figure NB-3545.2(c)-1**  
**Model for Determining Secondary Stress in Valve Crotch Region**

Model based on  
 $R/r = 10$   
 $r_t/t_e = 0.5$




$T_{e1}$  = diameter of the largest circle that can be drawn in an area of the crotch on either side of a line bisecting the crotch

$T_{e2}$  = diameter of the largest circle that can be drawn entirely within the wall at the crotch region

For  $T_{e1} < t_e$  as  
determined above, use  $T_{e1} = t_e$

**Figure NB-3545.2(c)-3**  
**Thermal Stress Index Versus Thickness Continuity Run or Branch**



where applicable, do not exceed  $S_m$  as tabulated in Section II, Part D, Subpart 1, Tables 2A and 2B, or for materials not listed in these Tables, do not exceed two-thirds of the minimum specified yield strength or one-fourth of the minimum specified tensile strength, whichever is lower.

(b) Bypass piping shall be designed in accordance with the requirements of NB-3600. Unless otherwise stated in the valve Design Specifications, bypass piping design shall be the responsibility of the piping system designer.


(c) Valve designs, requiring solenoid plunger core tubes or electromagnetic position indicator core tubes, may substitute the rules of NB-3641.1 for the requirements of NB-3541, NB-3542, or NB-3543 for minimum wall thickness of the extension, provided that detailed calculations

are prepared in accordance with NB-3200 at the 100°F (38°C) valve pressure rating conditions, and covering all discontinuities in the core tube, including the cap end and attachment end, and all welds, including any dissimilar metal welds. These calculations shall be included in the Design Report (NB-3560). The calculations shall include the design loadings given in NB-3546.1(b)(1) through NB-3546.1(b)(4) along with any additional requirements given in the Design Specifications.


**NB-3546.4 Fatigue Evaluation.** When the Design Specifications include such service loadings that the valve is not exempted from fatigue analysis by the rules of




**Figure NB-3545.2(c)-4**  
**Secondary Stress Index Versus Thickness Discontinuity Run or Branch**



**Figure NB-3545.2(c)-5**  
 **$C_4$  Versus  $T_{e1}/t_e$**



**Figure NB-3545.2(c)-6**  
**Stress Index for Thermal Fatigue**



NB-3222.4(d), it is recommended that consideration be given to the cyclic stress duty of the portions considered by NB-3546.

## NB-3550 CYCLIC LOADING REQUIREMENTS

### NB-3551 Verification of Adequacy for Cyclic Conditions

The adequacy of a valve for cyclic loading shall be verified in accordance with this Subsubarticle. Nonintegral seat rings attached to the valve body by partial penetration or fillet welds (NB-4433) are exempt from the fatigue analysis requirements of NB-3123.2, provided the seat rings are shouldered against the valve body; see Figure NB-3544.1(c)-1.

### NB-3552 Excluded Cycles

In satisfying the cyclic loading requirements, the following variations need not be considered:

(a) pressure variations less than  $p_d/3$  for carbon and low alloy steels and less than  $p_d/2$  for austenitic stainless steels;

(b) temperature variations less than 30°F (17°C);

(c) accident or maloperation cycles expected to occur less than five times (total) during the expected valve life;

(d) startup, shutdown cycles with temperature change rates of 100°F/hr (56°C/hr) or less, not in excess of 2,000.

### NB-3553 Fatigue Usage

The application of a valve conforming to NB-3512.1 is acceptable for cyclic loading conditions provided its fatigue usage  $I_t$  is not greater than 1.0 as evaluated in (a), (b), and (c) below.

(a) Consider fluid temperature changes not excluded by NB-3552 to occur instantaneously. Provided that these changes occur in one direction and recovery is at temperature change rates not in excess of 100°F/hr (56°C/hr), the fatigue usage factor may be found by:

$$I_t = \sum \frac{N_{ri}}{N_i}$$

where  $N_{ri}$  is the required or estimated number of fluid temperature step changes  $\Delta T_{fi}$  and  $N_i$  is found from Figs. I-9.1 and I-9.2.

(b) If both heating and cooling effects are expected at change rates exceeding 100°F/hr (56°C/hr), the number of cycles are to be associated by temperature ranges  $\Delta T_i$ . For example, assuming the following variations are specified:

20 variations:  $\Delta T_1 = 250^\circ\text{F}$  (140°C) heating

10 variations:  $\Delta T_2 = 150^\circ\text{F}$  (80°C) cooling

100 variations:  $\Delta T_3 = 100^\circ\text{F}$  (56°C) cooling

lump the ranges of variation so as to produce the greatest effects as follows:

$$10 \text{ cycles } \Delta T_{f1} = 250 + 150 = 400^\circ\text{F} \\ (140 + 80 = 220^\circ\text{C})$$

$$10 \text{ cycles } \Delta T_{f2} = 250 + 100 = 350^\circ\text{F} \\ (140 + 56 = 196^\circ\text{C})$$

$$90 \text{ cycles } \Delta T_{f3} = 100^\circ\text{F} (56^\circ\text{C})$$

(c) Pressure fluctuations not excluded by NB-3552 are to be included in the cyclic load calculations. The full range of pressure fluctuation from the normal condition to the condition under consideration shall be represented by  $\Delta p_i$  in NB-3554.

### NB-3554 Cyclic Stress Calculations

A valve conforming to NB-3512.1 shall be qualified by the procedure of (a) through (d) below.

(a) The following criterion shall be met by the greatest temperature range:

$$Q_p \left[ \Delta p_{f(\max)} / p_s \right] + C_6 C_2 C_4 \Delta T_{f(\max)} < 3S_m$$

where  $\Delta T_{f(\max)}$  is the largest lumped temperature range obtained using the methods of NB-3553(b), and  $\Delta p_{f(\max)}$  is the largest range of pressure fluctuation associated with  $\Delta T_{f(\max)}$ .

(b) Calculate:

$$S_{n(\max)} = Q_p \left[ \Delta p_{f(\max)} / p_s \right] + C_6 C_3 C_4 \Delta T_{f(\max)}$$

Provided that  $S_{n(\max)} \leq 3S_m$ , calculate the fatigue stresses for each cyclic loading condition as follows:

$$S_i = \frac{4}{3} Q_p \left( \Delta p_{fi} / p_s \right) + C_6 (C_3 C_4 + C_5) \Delta T_{fi}$$

Determine the allowable number of cycles  $N_i$  for each loading condition by entering Figs. I-9.1 and I-9.2 with  $S_i/2$ , and determine the fatigue usage by NB-3553(a).

(c) If  $S_{n(\max)}$  is greater than  $3S_m$  but less than  $3mS_m$ , the value of  $S_i/2$  to be used for entering the design fatigue curve is to be found by multiplying  $S_i$  by  $K_e$ , where:

$$K_e = 1.0 + \frac{(1 - n)}{n(m - 1)} \left( \frac{S_n}{3S_m} - 1 \right)$$

and where the values of the material parameters  $m$  and  $n$  are as given in Table NB-3228.5(b)-1.

(d) If  $S_{n(\max)}$  is greater than  $3mS_m$ , use  $K_e = 1/n$ .

## NB-3560 DESIGN REPORTS

### NB-3561 General Requirements

The certified Design Reports listed in this paragraph meet the requirements of NCA-3550 for the Design Report.

**NB-3562 Design Report for Valves Larger Than NPS 4 (DN 100)**

A Design Report shall be prepared in sufficient detail to show that the valve satisfies the requirements of NB-3512. For a valve designed in accordance with NB-3512.1, the Design Report shall show that the applicable requirements of NB-3530, NB-3541 through NB-3546.2, and NB-3550 have been met. It is not necessary to write a special Design Report based on specified Design Pressure and Design Temperature when they are within the pressure-temperature rating and when supplementary information or calculations are also provided, as necessary, to complete the report for a specific application, such as the thermal cyclic duty evaluation of NB-3550. A report submitted demonstrating a design for loadings more severe than the specified loadings is also acceptable.

**NB-3563 Design Report Requirements for NPS 4 and Smaller ( $\leq$  DN 100) Valves**

For valves whose inlet piping connection is nominally NPS 4 (DN 100) or smaller, the Design Report shall include details to show that the requirements of NB-3513 have been met.

**NB-3590 PRESSURE RELIEF VALVE DESIGN****NB-3591 Acceptability**

**NB-3591.1 General.** The rules of this Subsubarticle constitute the requirements for the design acceptability of spring-loaded pressure relief valves. The design rules for pilot operated and power actuated pressure relief valves are covered by NB-3500. The rules of this Subsubarticle cover the pressure-retaining integrity of the valve inlet and outlet connections, nozzle, disk, body structure, bonnet (yoke), and body-to-bonnet (yoke) bolting. The rules of this Subsubarticle also cover other items such as the spring, spindle (stem), spring washers, and set pressure adjusting screw. The rules of this Subsubarticle do not apply to guides, control ring, bearings, set screws, and other nonpressure-retaining items. Figures NB-3591.1-1 and NB-3591.1-2 are illustrations of typical pressure relief valves.

**NB-3591.2 Definitions.** The definitions for pressure relief valve terms used in this Subsubarticle are given in ANSI B95.1, Terminology for Pressure Relief Devices, and also in NB-7000. Pressure relief valves characteristically have multipressure zones within the valve, that is, a primary pressure zone and a secondary pressure zone as illustrated by Figures NB-3591.1-1 and NB-3591.1-2.

**NB-3591.3 Acceptability of Small Liquid Relief Valves.** Liquid pressure relief valves meeting the requirements of NB-7000 and having an inlet piping connection NPS 2 (DN 50) and under shall comply with the minimum wall thickness requirements of NB-3542 or NB-3543 for the applicable pressure zone. Flange end ratings of NB-3531.1 shall be used regardless of end connection.

The applicable design requirements of this Subsubarticle covering the nozzle, disk, and bonnet shall apply. The analyses of NB-3544, NB-3545, and NB-3550 do not apply.

**NB-3591.4 Acceptability of Safety and Safety Relief Valves.** The design shall be such that the requirements of this Subsubarticle are met.

**NB-3592 Design Considerations**

**NB-3592.1 Design Conditions.** The general design requirements of NB-3100 are applicable, with consideration for the design conditions of the primary and secondary pressure zones. The design pressure of the Design Specification shall be used for the applicable zones.

In case of conflict between NB-3100 and NB-3590, the requirements of NB-3590 shall apply. Mechanical loads for both the closed and the open (full discharge) positions shall be considered in conjunction with the service conditions. In addition, the requirements of NB-7000 shall be met.

**NB-3592.2 Stress Limits for Specified Service Loadings.**

(a) Stress limits for Level A and B Service Loadings shall be as follows:

(1) the primary membrane stress intensity shall not exceed  $S_m$ ;

(2) the primary membrane stress intensity plus primary bending stress intensity shall not exceed  $1.5S_m$ ;

(3) substantiation by analysis of localized stresses associated with contact loading of bearing or seating surfaces is not required;

(4) the values of  $S_m$  shall be in accordance with Section II, Part D, Subpart 1, Tables 2A, 2B, and 4.

(b) Stress limits for Level C Service Loadings shall be as follows:

(1) the primary membrane stress intensity shall not exceed  $1.5S_m$ ;

(2) the primary membrane stress intensity plus primary bending stress intensity shall not exceed  $1.8S_m$  (NB-3526.2);

(3) the rules of NB-3526.3 must be satisfied.


(c) Stress limits for Level D Service Loadings shall be as follows:

(1) the guidelines of Appendix F may be used in evaluating these conditions.


(d) These requirements for the acceptability of valve design are not intended to ensure the functional adequacy of the valve. However, the Designer is cautioned that the requirements of NB-7000 relative to set pressure, lift, blow-down, and closure shall be met.

**NB-3592.3 Earthquake.** The rules of this Subsubarticle consider that under earthquake loadings the piping system or vessel nozzle, rather than the valve body, will be limiting. Pressure relief valves have extended structures and these structures are essential to maintaining pressure integrity. An analysis, when required by the Design Specification, shall be performed based on static

**Figure NB-3591.1-1**  
**Typical Pressure Relief Devices**



**Figure NB-3591.1-2**  
**Typical Pressure Relief and Safety Relief Devices**





forces resulting from equivalent earthquake acceleration acting at the centers of gravity of the extended masses. Classical bending and direct stress equations, where free body diagrams determine a simple stress distribution that is in equilibrium with the applied loads, may be used.

### NB-3593 Special Design Rules

**NB-3593.1 Hydrostatic Test.** Hydrostatic testing shall be performed in accordance with NB-3531.2(f).

**NB-3593.2 Marking.** In addition to the marking required by NCA-8220 and NB-7000, the secondary Design Pressure shall be marked on the valve or valve nameplate.

### NB-3594 Design of Pressure Relief Valve Parts

**NB-3594.1 Body.** The valve body shall be analyzed with consideration for the specific configuration of the body and the applicable pressure zone and loadings. The design shall take into consideration the adequacy of the inlet flange connection, the outer flange connection, and the body structural configuration. In valve designs where the outlet flange is an extension of the bonnet, the bonnet design shall conform to all rules of body design. The body shall be designed in accordance with the rules of NB-3540 through NB-3550. The design adequacy of the inlet and outlet flanges shall be determined using the rules of NB-3658. Flanges shall conform to the applicable pressure-temperature ratings of NB-3531.1 and shall meet the interface dimensions of ASME B16.5.

**NB-3594.2 Bonnet (Yoke).** The bonnet (yoke) may be analyzed using classic bending and direct stress equations, with appropriate free body diagrams. The general primary membrane stress intensity and the general primary membrane plus primary bending stress intensity shall be determined and shall not exceed the stress limits of NB-3592.2.

**NB-3594.3 Nozzle.** The nozzle shall be analyzed in accordance with the applicable rules of NB-3540 and NB-3550, with a basic analytical model configuration as shown in Figure NB-3594.3-1. The sections of the nozzle where dimensions are limited by the flow capacity and the operational control requirements may be considered as simple cylindrical sections. The minimum wall thickness of these sections shall be determined in accordance with NB-3324.1. These requirements are not applicable to the transition region to the seat contacting area of the nozzle, defined by  $L$  in Figure NB-3594.3-1, provided dimension  $L$  is less than the nominal wall thickness  $t_1$ .

**NB-3594.4 Body-to-Bonnet Joint.** The body-to-bonnet joint shall be analyzed in accordance with NB-3546.1.

**NB-3594.5 Disk.** The valve disk shall satisfy the requirements of NB-3546.2.

**NB-3594.6 Spring Washer.** The average shear stress shall not exceed  $0.6S_m$ . The primary bending stress intensity shall not exceed the stress limits of NB-3592.2.

**NB-3594.7 Spindle (Stem).** The general primary membrane stress intensity shall not exceed the stress limits of NB-3592.2.

**NB-3594.8 Adjusting Screw.** The adjusting screw shall be analyzed for thread shear stress in accordance with the method of ASME B1.1 and this stress shall not exceed  $0.6S_m$ . The general primary membrane stress intensity of the adjusting screw shall not exceed the stress limits of NB-3592.2, based on the root diameter of the thread.

**NB-3594.9 Spring.** The valve spring shall be designed so that the full lift spring compression shall be no greater than 80% of the nominal solid deflection. The permanent set of the spring (defined as the difference between the free height and height measured a minimum of 10 min after the spring has been compressed solid three additional times after presetting at room temperature) shall not exceed 0.5% of the free height.

### NB-3595 Design Report

**NB-3595.1 General Requirements.** A Design Report shall be prepared in sufficient detail to show that the valve satisfies the rules of this Subsubarticle and NCA-3550.

## NB-3600 PIPING DESIGN

### NB-3610 GENERAL REQUIREMENTS

#### NB-3611 Acceptability

The requirements for acceptability of a piping system are given in the following subparagraphs.

**NB-3611.1 Stress Limits.** The design shall be such that the stresses will not exceed the limits described in NB-3630 except as provided in NB-3611.2.


**NB-3611.2 Acceptability When Stresses Exceed Stress Limits.** When the stresses as determined by the methods given in NB-3630 exceed the limits thereof, the design can be accepted, provided it meets the requirements of NB-3200.

**NB-3611.3 Conformance to NB-3600.** In cases of conflict between NB-3100 and NB-3600, the requirements of NB-3600 shall apply.

**NB-3611.4 Dimensional Standards.** For the applicable year of issue of all dimensional standards referred to in NB-3600, see Table NCA-7100-1.

**NB-3611.5 Prevention of Nonductile Fracture.** The requirements for prevention of nonductile fracture as set forth in NB-3211(d) shall be met.

**Figure NB-3594.3-1**  
**Valve Nozzle**



- $t_1, t_2$  = nozzle wall thickness, in. (mm)  
 $t_e$  = minimum body wall thickness adjacent to crotch, in. (mm)  
 $T_{e1}$  = maximum effective thickness in crotch region, in. (mm)  
 $T_{e2}$  = effective crotch wall thickness, in. (mm)  
 $r_1$  = inside radius at crotch region, in. (mm)  
 $r_2$  = outside fillet radius at crotch, in. (mm)  
 $L$  = length of seat transition region, in. (mm)  
 $A_f$  = fluid area, in.<sup>2</sup> (mm<sup>2</sup>)  
 $A_m$  = metal area, in.<sup>2</sup> (mm<sup>2</sup>)

**NB-3612 Pressure-Temperature Ratings****NB-3612.1 Standard Piping Products.**

(a) When standard piping products are used, the pressure ratings given as functions of temperature in the appropriate standards listed in Table NCA-7100-1 shall not be exceeded. In addition, the requirements of NB-3625 shall be met. When established pressure ratings of standard products do not extend to the upper temperature limits for the material, the ratings between those established and the upper temperature limit may be determined in accordance with NB-3649.

(b) When the adequacy of the pressure design of a standard product is established by burst tests as permitted in NB-3649 (ASME B16.9, Section 8), the manufacturer of the product shall maintain a record of burst tests conducted to ensure adequacy of product and shall so certify. Such records shall be available to the purchaser.

**NB-3612.2 Piping Products Without Specific Ratings.** If piping products are used for which methods of construction are not covered by this Subsection, the manufacturer of the product shall use methods of construction that will be as safe as otherwise provided by the rules of this Subsection. When products are used for which pressure-temperature ratings have not been established by the standards listed in Table NCA-7100-1, the products shall be designed and tested in accordance with NB-3640. The manufacturer's recommended pressure-temperature ratings shall not be exceeded.

**NB-3612.4 Considerations for Local Conditions and Transients.**

(a) When piping systems operating at different pressures are connected by a valve or valves, the valve or valves shall be designed for the higher pressure system requirements of pressure and temperature. The lower pressure system shall be designed in accordance with (1), (2), or (3) below.

(1) The requirements of the pressure system shall be met.

(2) Pressure relief devices or safety valves shall be included to protect the lower pressure system in accordance with NB-7311.

(3) Ensure compliance with all the conditions of (-a) through (-e) below.

(-a) Redundant check or remote actuated valves shall be used in series at the interconnection, or a check in series with a remote actuated valve.

(-b) When mechanical or electrical controls are provided, redundant and diverse controls shall be installed which will prevent the interconnecting valves from opening when the pressure in the high pressure system exceeds the Design Pressure of the lower pressure system.

(-c) Means shall be provided such that operability of all components, controls, and interlocks can be verified by test.

(-d) Means shall be provided to ensure that the leakage rate of the interconnecting valves does not exceed the relieving capacity of the relief devices on the lower pressure system.

(-e) Adequate consideration shall be given to the control of fluid pressure caused by heating of the fluid trapped between two valves.

The low pressure system relieving capacity may be determined in accordance with NB-7311, on the basis of interconnecting valve being closed but leaking at a specified rate, when (-a) to (-e) above are met. The pressure relief devices or safety valves shall adjoin or be as close as possible to the interconnecting valve and shall relieve preferably to a system where the relieved effluent may be contained. The design of the overpressure protection system shall be based on pressure transients that are specified in the Design Specification, and all other applicable requirements of NB-7000 shall be met.

(b) When pressure-reducing valves are used and one or more pressure relief devices or safety valves are provided, bypass valves may be provided around the pressure-reducing valves. The combined relieving capacity of the pressure relief devices, safety valves, and relief piping shall be such that the lower pressure system service pressure will not exceed the lower pressure system Design Pressure by more than 10% if the pressure-reducing valve fails in the open position and the bypass valve is open at the same time. If the pressure-reducing valve and its bypass valve are mechanically or electrically interlocked so that only one may be open at any time the high pressure system is at a pressure higher than the Design Pressure of the low pressure system, then the relieving capacity of the pressure relief devices, safety valves, and relief piping shall be at least equal to the maximum capacity of the larger of the two valves. The interlocks shall be redundant and diverse.

(c) Exhaust and pump suction lines for any service and pressure shall have relief valves of a suitable size unless the lines and attached equipment are designed for the maximum pressure and temperature to which they may be accidentally or otherwise subjected.

(d) The effluent from relief devices may be discharged outside the containment only if provisions are made for the disposal of the effluent.

(e) Drip lines from steam headers, mains, separators, or other equipment operating at different pressures shall not discharge through the same trap. Where several traps discharge into a single header that is or may be under pressure, a stop valve and a check valve shall be provided in the discharge line from each trap. The Design Pressure of trap discharge piping shall not be less than the maximum discharge pressure to which it may be subjected. Trap discharge piping shall be designed for the same pressure as the trap inlet piping unless the discharge piping is vented to a system operated under lower pressure and has no intervening stop valves.

(f) Blowdown, dump, and drain piping from water spaces of a steam generation system shall be designed for saturated steam at the pressures and temperatures given below.

Vessel Pressure, psi (MPa)	Design Pressure, psi (MPa)	Design Temperature, °F (°C)
600 (4) and below	250 (1.7)	410 (210)
601 to 900 (4.01 to 6)	400 (2.8)	450 (230)
901 to 1,500 (6.01 to 10)	600 (4.1)	490 (255)
1,501 (10.01) and above	900 (6.2)	535 (280)

These requirements for blowdown, dump, and drain piping apply to the entire system beyond the blowdown valves to the blowdown tank or other points where the pressure is reduced to approximately atmospheric and cannot be increased by closing a valve. When pressures can be increased because of calculated pressure drop or otherwise, this shall be taken into account in the design. Such piping shall be designed for the maximum pressure to which it may be subjected.

(g) Pump discharge piping shall be designed for the maximum pressure exerted by the pump at any load and for the highest corresponding temperature actually existing.

(h) Where a fluid passes through heat exchangers in series, the design temperature of the piping in each section of the system shall conform to the most severe temperature condition expected to be produced by heat exchangers in that section.

### NB-3613 Allowances

**NB-3613.1 Corrosion or Erosion.** When corrosion or erosion is expected, the wall thickness of the piping shall be increased over that required by other design requirements. This allowance shall be consistent with the specified design life of the piping.

**NB-3613.2 Threading and Grooving.** The calculated minimum thickness of piping that is to be threaded or grooved shall be increased by an allowance equal to the depth of the cut.

**NB-3613.3 Mechanical Strength.** When necessary to prevent damage, collapse, or buckling of pipe due to superimposed loads from supports or other causes, the wall thickness of the pipe shall be increased, or, if this is impractical or would cause excessive local stresses, the superimposed loads or other causes shall be reduced or eliminated by other design methods.

### NB-3620 DESIGN CONSIDERATIONS

#### NB-3621 Design and Service Loadings

The provisions of NB-3110 apply.

### NB-3622 Dynamic Effects

**NB-3622.1 Impact.** Impact forces caused by either external or internal loads shall be considered in the piping design.

**NB-3622.2 Reversing Dynamic Loads.** Reversing dynamic loads (Figure NB-3622-1) are those loads which cycle about a mean value and include building filtered loads and earthquake loads. A reversing dynamic load shall be treated as a nonreversing dynamic load in applying the rules of NB-3600 when the number of reversing dynamic load cycles, exclusive of earthquake, exceeds 20.

**NB-3622.3 Vibration.** Piping shall be arranged and supported so that vibration will be minimized. The designer shall be responsible, by design and by observation under startup or initial service conditions, for ensuring that vibration of piping systems is within acceptable levels.

**NB-3622.4 Nonreversing Dynamic Loads.** Nonreversing dynamic loads (Figure NB-3622-1) are those loads which do not cycle about a mean value and include the initial thrust force due to sudden opening or closure of valves and waterhammer resulting from entrapped water in two-phase flow systems. Reflected waves in a piping system due to flow transients are classified as nonreversing dynamic loads.

### NB-3623 Weight Effects

Piping systems shall be supported to provide for the effects of live and dead weights, as defined in the following subparagraphs, and they shall be arranged or properly restrained to prevent undue strains on equipment.

**NB-3623.1 Live Weight.** The live weight shall consist of the weight of the fluid being handled or of the fluid used for testing or cleaning, whichever is greater.

**NB-3623.2 Dead Weight.** The dead weight shall consist of the weight of the piping, insulation, and other loads permanently imposed upon the piping.


### NB-3624 Thermal Expansion and Contraction Loads

**NB-3624.1 Loadings, Displacements, and Restraints.** The design of piping systems shall take into account the forces and moments resulting from thermal expansion and contraction, equipment displacements and rotations, and the restraining effects of hangers, supports, and other localized loadings.


**NB-3624.2 Analysis of Thermal Expansion and Contraction Effects.** The analysis of the effects of thermal expansion and contraction is covered in NB-3672.

**NB-3624.3 Provision for Rapid Temperature Fluctuation Effects.** The Designer shall provide for unusual thermal expansion and contraction loads caused by rapid temperature fluctuations.


**Figure NB-3622-1**  
**Examples of Reversing and Nonreversing Dynamic Loads**



**(a) Nonreversing Dynamic Load**  
**(Relief/Safety Valve Open End Discharge)**



**(b) Reversing Dynamic Load**  
**(Earthquake Load Cycling About Normal Operating Condition)**



**(c) Nonreversing Dynamic Load**  
**(Initial Water Slug Followed By Reflected Waves)**

### **NB-3625 Stress Analysis**

A stress analysis shall be prepared in sufficient detail to show that each of the stress limitations of [NB-3640](#) and [NB-3650](#) is satisfied when the piping is subjected to the loadings required to be considered by this Subarticle.

### **NB-3630 PIPING DESIGN AND ANALYSIS CRITERIA**

(a) The design and analysis of piping when subjected to the individual or combined effects of the loadings defined in [NB-3100](#) and [NB-3620](#) may be performed in accordance with this Subarticle. Design for pressure loading shall be performed in accordance with the rules of [NB-3640](#). Standard piping products that meet the requirements of ASME

B16.9 or [NB-3649](#) satisfy the requirements of [NB-3640](#), and only the analysis required by [NB-3650](#) need be performed.

(b) Within a given piping system, the stress and fatigue analysis shall be performed in accordance with one of the methods given in [NB-3650](#), [NB-3200](#), or Appendix II. Stress indices are given in [NB-3680](#) for standard piping products, for some fabricated joints, and for some fabricated piping products. Some piping products designed for pressure by applying the rules of [NB-3649](#) may not be listed in [NB-3680](#). For such products, the designer shall determine the stress indices as required in [NB-3650](#).



(c) When a design does not satisfy the requirements of NB-3640 and NB-3650, the more detailed alternative analysis given in NB-3200 or the experimental stress analysis of Appendix II may be used to obtain stress values for comparison with the criteria of NB-3200.

(d) The requirements of this Subarticle shall apply to all Class 1 piping except as exempted under (1) or (2) below.

(1) Piping of NPS 1 (DN 25) or less which has been classified as Class 1 in the Design Specification may be designed in accordance with the design requirements of Subsection NC.

(2) Class 1 piping may be analyzed in accordance with the Class 2 analysis of piping systems in Subsection NC, using the allowable Class 2 stresses and stress limits, provided the specified service loads for which Level A and B Service Limits are designated meet all of the requirements stipulated in (-a) through (-e) below.

(-a) *Atmospheric to Service Pressure Cycle.* The specified number of times (including startup and shutdown) that the pressure will be cycled from atmospheric pressure to service pressure and back to atmospheric pressure during normal service does not exceed the number of cycles on the applicable fatigue curve of Figs. I-9.0 corresponding to an  $S_a$  value of three times the  $S_m$  value for the material at service temperature.

(-b) *Normal Service Pressure Fluctuation.* The specified full range of pressure fluctuations during normal service does not exceed the quantity  $\frac{1}{3} \times \text{Design Pressure} \times (S_a/S_m)$ , where  $S_a$  is the value obtained from the applicable design fatigue curve for the total specified number of significant pressure fluctuations and  $S_m$  is the allowable stress intensity for the material at service temperature. If the total specified number of significant pressure fluctuations exceeds the maximum number of cycles defined on the applicable design fatigue curve, the  $S_a$  value corresponding to the maximum number of cycles defined on the curve may be used. Significant pressure fluctuations are those for which the total excursion exceeds the quantity:  $\text{Design Pressure} \times \frac{1}{3} \times (S/S_m)$ , where  $S$  is defined as follows:

(-1) If the total specified number of service cycles is  $10^6$  cycles or less,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for  $10^6$  cycles.

(-2) If the total specified number of service cycles exceeds  $10^6$  cycles,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for the maximum number of cycles defined on the curve.

(-c) *Temperature Difference — Startup and Shutdown.* The temperature difference, °F (°C), between any two adjacent points<sup>24</sup> of the component during normal service does not exceed  $S_a/2E\alpha$ , where  $S_a$  is the value obtained from the applicable design fatigue curves for the specified number of startup-shutdown cycles,  $\alpha$  is the value of the instantaneous coefficient of thermal expansion and  $E$  is the modulus of elasticity at the mean value of the temperatures at the two points as given by Section II, Part D, Subpart 2, Tables TE and TM.

(-d) *Temperature Difference — Normal Service.*<sup>14</sup>

The temperature difference, °F (°C), between any two adjacent points<sup>24</sup> does not change<sup>15</sup> during normal service by more than the quantity  $S_a/2E\alpha$ , where  $S_a$  is the value obtained from the applicable design fatigue curve of Figs. I-9.0 for the total specified number of significant temperature difference fluctuations. A temperature difference fluctuation shall be considered to be significant if its total algebraic range exceeds the quantity  $S/2E\alpha$ , where  $S$  is defined as follows:

(-1) If the total specified number of service cycles is  $10^6$  cycles or less,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for  $10^6$  cycles.

(-2) If the total specified number of service cycles exceeds  $10^6$  cycles,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for the maximum number of cycles defined on the curve.

(-e) *Temperature Difference — Dissimilar Materials.*

For components fabricated from materials of differing moduli of elasticity or coefficients of thermal expansion, the total algebraic range of temperature fluctuation, °F (°C), experienced by the component during normal service does not exceed the magnitude  $S_a/2 (E_1 \alpha_1 - E_2 \alpha_2)$ , where  $S_a$  is the value obtained from the applicable design fatigue curve for the total specified number of significant temperature fluctuations,  $E_1$  and  $E_2$  are the moduli of elasticity, and  $\alpha_1$  and  $\alpha_2$  are the values of the instantaneous coefficients of thermal expansion (Section II, Part D, Subpart 2, Tables TE and TM) at the mean temperature value involved for the two materials of construction. A temperature fluctuation shall be considered to be significant if its total excursion exceeds the quantity  $S/2(E_1 \alpha_1 - E_2 \alpha_2)$ , where  $S$  is defined as follows.

(-1) If the total specified number of service cycles is  $10^6$  cycles or less,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for  $10^6$  cycles.

(-2) If the total specified number of service cycles exceeds  $10^6$  cycles,  $S$  is the value of  $S_a$  obtained from the applicable design fatigue curve for the maximum number of cycles defined on the curve. If the two materials used have different applicable design fatigue curves, the lower value of  $S_a$  shall be used in applying the rules of this paragraph.

## NB-3640 PRESSURE DESIGN

### NB-3641 Straight Pipe

#### NB-3641.1 Straight Pipe Under Internal Pressure. (13)

The minimum thickness of a pipe wall required for Design Pressure shall be determined from one of the following equations:

$$t_m = \frac{PD_o}{2(S_m + P_y)} + A \quad (1)$$



$$t_m = \frac{Pd + 2A(S_m + Py)}{2(S_m + Py - P)} \quad (2)$$

where

$A$  = additional thickness, in. (mm):

(a) to compensate for material removed or wall thinning due to threading or grooving, required to make a mechanical joint. The values of  $A$  listed in [Table NB-3641.1\(a\)-1](#) are minimum values for material removed in threading.

(b) to provide for mechanical strength of the pipe. Small diameter, thin wall pipe or tubing is susceptible to mechanical damage due to erection, operation, and maintenance procedures. Accordingly, appropriate means must be employed to protect such piping against these types of loads if they are not considered as Design Loads. Increased wall thickness is one way of contributing to resistance against mechanical damage.

(c) to provide for corrosion or erosion. Since corrosion and erosion vary widely from installation to installation, it is the responsibility of designers to determine the proper amounts which must be added for either or both of these conditions.

$D_o$  = outside diameter of the pipe, in. (mm.) (For design calculations, the specified outside diameter of pipe disregarding outside tolerances shall be used to obtain the value of  $t_m$ .)

$d$  = inside diameter, in. (mm)

$P$  = internal Design Pressure, psi (MPa)

$S_m$  = maximum allowable stress intensity for the material at the Design Temperature taken from Section II, Part D, Subpart 1, Tables 2A and 2B, psi (MPa)

$t_m$  = the minimum required wall thickness, in. (mm) [eq. (2) is valid only if  $d = D_o - 2t_m$ . If pipe is ordered by its nominal wall thickness, the manufacturer's tolerance on wall thickness must be taken into account.]

$y = 0.4$

**Table NB-3641.1(a)-1  
Values of  $A$**

Type of Pipe	$A$ , in. (mm)
Threaded steel and nonferrous pipe:	
$\frac{3}{4}$ in. (19 mm) nominal and smaller	0.065 (1.65 mm)
1 in. (25 mm) nominal and larger	Depth of thread
Grooved steel and nonferrous pipe	Depth of groove plus $\frac{1}{64}$ in. (0.40 mm)

The allowable working pressure of pipe may be determined from the following equation:

$$P_a = \frac{2S_m t}{D_o - 2yt} \quad (3)$$

where

$P_a$  = the calculated maximum allowable internal pressure for a straight pipe which shall at least equal the Design Pressure, psi (MPa).

(a)  $P_a$  may be used for piping products with pressure ratings equal to that of straight pipe (see ASME B16.9).

(b) For standard flanged joints, the rated pressure shall be used instead of  $P_a$ .

(c) For reinforced branch connections ([NB-3643](#)) where part of the required reinforcement is in the run pipe, the Design Pressure shall be used instead of  $P_a$ .

(d) For other piping products where the pressure rating may be less than that of the pipe (for example, flanged joints designed to Section III Appendices, Mandatory Appendix XI), the Design Pressure shall be used instead of  $P_a$ .

(e)  $P_a$  may be rounded out to the next higher unit of 10 psi (0.1 MPa).

$t$  = the specified or actual wall thickness minus, as appropriate, material removed in threading, corrosion or erosion allowance, material manufacturing tolerances, bending allowance ([NB-3642.1](#)), or material to be removed by counterboring, in. (mm).

#### **NB-3641.2 Straight Pipe Under External Pressure.**

The rules of [NB-3133](#) shall be used.

#### **NB-3642 Curved Segments of Pipe**

**NB-3642.1 Pipe Bends.** The wall thickness for pipe bends shall be determined in the same manner as determined for straight pipe in accordance with [NB-3641](#), subject to the limitations given in (a), (b), and (c) below.

(a) The wall thickness after bending shall not be less than the minimum wall thickness required for straight pipe.

(b) The information in [Table NB-3642.1\(b\)-1](#) is given to guide the designer when ordering pipe.

(c) For the effects of ovality on stress levels, see [NB-3680](#).

**NB-3642.2 Elbows.** Elbows, manufactured in accordance with the standards listed in [Table NCA-7100-1](#) as limited by [NB-3612.1](#), shall be considered as meeting the requirements of [NB-3640](#), except that the minimum thickness in the crotch region of short radius welding elbows in accordance with ASME B16.28 shall be 20% greater than the minimum thickness required for the straight pipe by [eq. NB-3641.1\(1\)](#). The crotch region is defined as that portion of the elbow between  $\phi = 210$  deg and 330 deg, where  $\phi$  is defined in [Figure NB-3685.2-1](#).

**Table NB-3642.1(b)-1  
Bend Radius Versus Thickness**

Radius of Bends	Minimum Thickness Recommended Prior to Bending [Note (1)]
6 pipe diameters or greater	$1.06t_m$
5 pipe diameters	$1.08t_m$
4 pipe diameters	$1.16t_m$
3 pipe diameters	$1.25t_m$

NOTE:  
(1)  $t_m$  is determined by eq. NB-3641.1(1) or NB-3641.1(2).

## NB-3643 Intersections

### NB-3643.1 General Requirements.

(a) The rules contained in this paragraph meet the requirements of NB-3640 in the vicinity of branch connections.

(b) Openings shall be circular, elliptical, or of any other shape that results from the intersection of a circular or elliptical cylinder with a cylindrical shape. Additional restrictions affecting stress indices are given in NB-3680.

(c) Openings are not limited in size except to the extent provided for in connection with the stress indices listed in NB-3680.

(d) Any type of opening permitted in these rules may be located in a welded joint.

(e) Where intersecting pipes are joined by welding a branch to a run pipe as shown in Figure NB-3643.3(a)-2, the angle  $\alpha$  between axes of the intersecting pipes shall not be less than 60 deg or more than 120 deg. For angles outside this range, use fittings as specified in NB-3643.2(a) or NB-3643.2(b).

**NB-3643.2 Branch Connections.** Branch connections in piping may be made by using one of the products or methods set forth in (a) through (d) below.

(a) Flanged, butt welding, or socket welding fittings meeting the applicable standards listed in Table NCA-7100-1, subject to the limitations or requirements of this Subsection, are acceptable. Fittings that comply with the test requirements of ASME B16.9 or of NB-3649 are not required to meet requirements for reinforcement given in NB-3643.3.

(b) Welded outlet fittings, cast or forged branches, pipe adapters, couplings, or similar products with butt welding, socket welding, or flanged ends are acceptable for attachment to the run pipe when limited to types that have integral reinforcement and are attached to the main run by welding per NB-4246. Welded connections per NB-4244 are permitted; however, the stress indices of NB-3683.8 are not applicable to all configurations.

(c) An extruded outlet at right angles to the run pipe is acceptable.

(d) Branch pipe attached to the run pipe with fillet or partial penetration welds per NB-3661.3 is acceptable.

### NB-3643.3 Reinforcement for Openings.

#### (a) Nomenclature

(1) The following terms are as shown in Figure NB-3643.3(a)-1.

$d_o$  = outside diameter of the branch pipe

$L_1$  = height of nozzle reinforcement for branch connections

$R_m$  = mean radius of the run pipe

$r_i$  = inside radius of branch pipe

$r_m$  = mean radius of the branch pipe

$$= r_i + 0.5T_b$$

$r'_m$  = mean radius of the branch pipe

$$= r_i + 0.5T'_b$$

$r_n$  = nominal radius [sketch (c) only]

$$= r_i + 0.5T'_b + 0.5y \cos \theta$$

$r_p$  = outside radius of reinforced branch connection

$r_1, r_2, r_3$  = designated radii for reinforced branch connections

$T_b$  = nominal thickness of the reinforced branch, not including corrosion allowance or mill tolerance

$T'_b$  = nominal thickness of the branch pipe, not including corrosion allowance or mill tolerance

$T_o$  = corroded finished thickness or extruded outlet measured at a height of  $r_2$  above the outside surface of the run pipe

$T_r$  = nominal thickness of the run pipe, not including corrosion allowance or mill tolerance

$y$  = slope offset distance

$\theta$  = angle between vertical and slope, deg

(2) The following terms are as shown on Figure NB-3643.3(a)-2.

$A_1$  = metal area available for reinforcement

$A_2$  = metal area available for reinforcement

$A_3$  = metal area available for reinforcement

$d$  = diameter in the given plane of the finished opening in its corroded condition

$L_A$  = half-width of reinforcement zone measured along the midsurface of the run pipe


$L'_A$  = half-width of zone in which two-thirds of compensation must be placed

$L_N$  = limit of reinforcement measured normal to run pipe wall

$r$  = radius of the finished opening in the corroded condition

$T_r$  = nominal thickness of the run pipe, not including corrosion allowance or mill tolerance

**Figure NB-3643.3(a)-1**  
**Branch Connection Nomenclature**



$t_b$  = minimum required thickness of the branch pipe, not including corrosion allowance, according to NB-3641.1

$$= t_m - A$$

$t_r$  = minimum required thickness of the run pipe, not including corrosion allowance, according to NB-3641.1

$$= t_m - A$$

$\alpha$  = angle between axes of branch and run ( $90 \text{ deg} \geq \alpha \geq 60 \text{ deg}$ ), deg

(3) The following terms are as shown in Figure NB-3643.3(a)-3.

$D_o$  = outside diameter of the run pipe

$h$  = height of the extruded lip, equal to or greater than  $r_2$


$T_o$  = finished thickness of the extruded outlet in the corroded condition measured at a height equal to  $r_2$  above the outside surface of the main run

$T'_r$  = minimum thickness of the run pipe after extrusion of the opening, not including corrosion allowance or mill tolerance, in. (mm). Allowance shall be made for thinning of the run pipe wall by the extrusion of the opening, if it occurs.


#### (b) Requirements

(1) Reinforcement shall be provided in amount and distribution so that the requirements for the area of reinforcement are satisfied for all planes through the center of the opening and normal to the surface of the run pipe, except that openings need not be provided with reinforcement if all of the requirements of (-a), (-b), and (-c) below are met.

Figure NB-3643.3(a)-2  
Typical Reinforcement of Openings



**Figure NB-3643.3(a)-3  
Typical Reinforced Extruded Outlet**



(-a) A single opening has a diameter not exceeding  $0.2\sqrt{R_m T_r}$ , or, if there are two or more openings within any circle of diameter,  $2.5\sqrt{R_m T_r}$ , but the sum of the diameters of such unreinforced openings shall not exceed  $0.25\sqrt{R_m T_r}$ .

(-b) No two unreinforced openings shall have their centers closer to each other, measured on the inside wall of the run pipe, than the sum of their diameters.

(-c) No unreinforced opening shall have its center closer than  $2.5\sqrt{R_m T_r}$  to the edge of any other locally stressed area.

(2) The total cross-sectional area of reinforcement  $A$  required in any given plane for a pipe under internal pressure shall not be less than:

$$A = dt_r(2 - \sin \alpha)$$

(3) The required reinforcing material shall be uniformly distributed around the periphery of the branch except that, in the case of branches not at right angles, the designer may elect to provide additional reinforcement in the area of the crotch.

(c) *Limits of Reinforcement.* The boundaries of the cross-sectional area in any plane passing through the axis of the opening within which metal may be located to have value as reinforcement are designated as the limits of reinforcement for that plane, and they are given in (1) and (2) below.

(1) The limits of reinforcement, measured along the midsurface of the nominal wall thickness of the run pipe,  $L_A$ , shall be at a distance on each side of the axis of the opening that is equal to the greater of (-a) or (-b) below:

(-a) the diameter of the finished opening in the corroded condition; or

(-b) the radius of the finished opening in the corroded condition  $r$ , plus the nominal thickness of the run pipe  $T_r$ , plus the nominal thickness of the branch wall  $T_b$ .

(-c) In addition, two-thirds of the required reinforcement shall be provided within the greater of the limit given in (-b) above and the limit  $L'_A$  which is the greater of either

$$r + 0.5\sqrt{R_m T_r}$$

or

$$r + T_b / \sin \alpha + T_r$$

(2) The limits of reinforcement measured normal to the wall of the run pipe  $L_N$  shall conform to the contour of the surface of the branch at a distance from each surface equal to the limits given in (-a) and (-b) below and as shown in Figure NB-3643.3(a)-1.

(-a) For nozzle types of Figure NB-3643.3(a)-1, sketches (a), (b), and (d):

$$L_N = 0.5\sqrt{r_m T_b} + 0.5r_2$$

(-b) For Figure NB-3643.3(a)-1, sketch (c):

$$L_N = 0.5\sqrt{r_n T_b}$$

(d) *Metal Available for Reinforcement*

(1) Metal may be counted as contributing to the area of reinforcement called for in (b) if it lies within the area of reinforcement specified in (c), and it shall be limited to material that meets the requirements of (-a), (-b), and (-c) below:

(-a) metal forming a part of the run wall that is in excess of that required on the basis of NB-3641.1 and is exclusive of corrosion allowance shown in Figure NB-3643.3(a)-2;

(-b) similar excess metal in the branch wall, if the branch is integral with the run wall or is joined to it by a full penetration weld, as denoted by  $A_1$  in Figure NB-3643.3(a)-2;

(-c) weld metal that is fully continuous with the wall of the run pipe, as denoted by area  $A_2$  in Figure NB-3643.3(a)-2.

(2) The mean coefficient of thermal expansion of the metal to be included as reinforcement under (1)(-b) and (1)(-c) above shall be within 15% of the value for the metal in the wall of the run pipe.

(3) Metal available for reinforcement shall not be considered as applying to more than one opening.

(4) Metal not fully continuous with the run pipe, as that in branches attached by partial penetration welds, shall not be counted as reinforcement.

(e) *Strength of Metal.* Material used for reinforcement shall preferably be the same as that of the wall of the run pipe. If material with a lower design stress intensity  $S_m$  is used, the area provided by such material shall not be counted at full value but shall be multiplied by the ratio (less than unity) of the design stress intensity values  $S_m$  of the reinforcement material and of the run pipe material before being counted as reinforcement. No reduction in the reinforcement requirement may be taken for the increased strength of either the branch material or weld metal having a higher design stress intensity value than that of the material of the run pipe wall. The strength of the material at the point under consideration shall be used in the fatigue analysis.

(f) *Requirements for Extruded Outlets.* Extruded outlets shall meet all of the requirements of (a) and (b), and these rules apply only where the axis of the outlet intersects and is perpendicular to the axis of the run pipe.

(1) *Geometric Requirements*

(-a) An extruded outlet is one in which the extruded lip at the outlet has a height  $h$  above the surface of the run pipe that is equal to or greater than the transition radius between the extruded lip and the run pipe  $r_2$ .



(-b) The minimum value of the transition radius  $r_2$  shall not be less than  $0.05d_o$ , except that on branch pipe sizes larger than 30 in. (750 mm) the transition radius need not exceed 1.5 in. (38 mm). The maximum value of the transition radius  $r_2$  shall be limited as follows: for branch pipes nominally NPS 8 (DN 200) and larger, the dimension of the transition radius shall not exceed  $0.10d_o + 0.50$  in. (13 mm); for branch pipe sizes nominally less than NPS 8 (DN 200),  $r_2$  shall not be greater than 1.25 in. (32 mm).

(-c) When the external contour contains more than one radius, the radius of any arc sector of approximately 45 deg shall meet the requirements given in (-b) above.

(-d) Machining shall not be employed to meet the requirements of (-b) and (-c) above.

#### (2) Limits of Reinforcement

(-a) The height of the reinforcement zone shall be limited as shown in Figure NB-3643.3(a)-3:

$$L_N = 0.5 \sqrt{d_o T_o}$$

(-b) The half width of the reinforcement zone shall be limited as shown in Figure NB-3643.3(a)-3:

$$L_A = d$$

(3) *Metal Available for Reinforcement.* The reinforcement area shall be the sum of areas  $A_1 + A_2 + A_3$  defined in (-a), (-b), and (-c) below and shown in Figure NB-3643.3(a)-3. Metal counted as reinforcement shall not be applied to more than one opening.

(-a) Area  $A_1$  is the area lying within the reinforcement zone that results from any excess thickness available in the wall of the branch pipe:

$$A_1 = 2L_N(T'_b - t_b)$$

(-b) Area  $A_2$  is the area lying within the reinforcement zone that results from excess thickness available in the lip of the extruded outlet:

$$A_2 = 2r_2(T_o - T'_b)$$

(-c) Area  $A_3$  is the area lying within the reinforcement zone that results from any excess thickness in the run pipe wall:

$$A_3 = d(T'_r - t_r)$$

### NB-3644 Miters

Mitered joints may be used in piping systems under the conditions stipulated in (a) through (d) below.

(a) The minimum thickness of a segment of a miter shall be determined in accordance with NB-3641. The minimum thickness thus determined does not allow for the discontinuity stresses that exist at the junction between segments. The discontinuity stresses are reduced for a given miter as the number of segments is increased.

(b) The angle  $\theta$  in Figure NB-3644(b)-1 shall not be more than  $22\frac{1}{2}$  deg.

(c) The center line distance  $S$  between adjacent miters shall be in accordance with Figure NB-3644(b)-1.

(d) Stress indices and flexibility factors shall be determined in accordance with the requirements of NB-3681(d).

### NB-3646 Closures

(a) Closures in piping systems may be made by use of closure fittings, such as blind flanges or threaded or welded plugs or caps, either manufactured in accordance with standards listed in Table NCA-7100-1 and used within the specified pressure-temperature ratings, or made in accordance with (b) below.

(b) Closures not manufactured in accordance with the standards listed in Table NCA-7100-1 may be made in accordance with the rules for Class 2 vessels using the equation:

$$t_m = t + A$$

where

$t$  = pressure design thickness, in. (mm), calculated for the given closure shape and direction of loading using appropriate equations and procedures for Class 2 Vessels, except that the symbols used to determine  $t$  shall be defined

where


$A$  = sum of mechanical allowances (NB-3613), in. (mm)

$P$  = Design Pressure, psi (MPa)

$S$  = applicable design stress intensity value  $S_m$  from Section II, Part D, Subpart 1, Tables 2A and 2B, psi (MPa)

$t_m$  = minimum required thickness, in. (mm)

**Figure NB-3644(b)-1  
Miter Joint Geometry**



(c) Connections to closures may be made by welding or extruding. Connections to the closure shall be in accordance with the limitations provided for such connections in NB-3643 and Figures NB-4243-1, NB-4244(a)-1, NB-4244(b)-1, and NB-4244(c)-1 for branch connections. If the size of the opening is greater than one-half the inside diameter of the closure, the opening should be considered as a reducer in accordance with NB-3648.

(d) Openings in closures may be reinforced in accordance with the requirements of NB-3643.

(e) Flat heads that have an opening with a diameter that does not exceed one-half of the head diameter shall have a total cross-sectional area of reinforcement not less than  $dt/2$ , where

$d$  = the diameter of the finished opening, in. (mm)

$t$  = the design thickness for the closure, in. (mm)

### NB-3647 Pressure Design of Flanged Joints and Blanks

#### NB-3647.1 Flanged Joints.

(a) Flanged joints manufactured in accordance with the standards listed in Table NCA-7100-1, as limited by NB-3612.1, shall be considered as meeting the requirements of NB-3640.

(b) Flanged joints not included in Table NCA-7100-1 shall be designed in accordance with XI-3000, including the use of the appropriate allowable stress given in Section II, Part D, Subpart 1, Tables 1A, 1B, and 3.

**NB-3647.2 Permanent Blanks.** The minimum required thickness of permanent blanks (Figure NB-3647.2-1) shall be calculated from the following equations:

$$t_m = t + A \quad (7)$$

where

$A$  = sum of the mechanical allowances, in. (mm) (NB-3613)

$t$  = pressure design thickness, in. (mm), calculated from eq. (8)

$t_m$  = minimum required thickness, in. (mm)

$$t = d_6 \left( \frac{3P}{16S_m} \right)^{\frac{1}{2}} \quad (8)$$

where

$d_6$  = inside diameter of the gasket for raised or flat face flanges or the pitch diameter of the gasket for retained gasketed flanges, in. (mm)

$P$  = Design Pressure, psi (MPa)

$S_m$  = the design stress intensity value in accordance with Section II, Part D, Subpart 1, Tables 2A and 2B, psi (MPa)

**NB-3647.3 Temporary Blanks.** Blanks to be used for test purposes only shall have a minimum thickness not less than the Design Pressure thickness  $t$ , calculated from eq. NB-3647.2(8), except that  $P$  shall not be less than the test pressure and the design stress intensity value  $S_m$  may be taken as 95% of the specified minimum yield strength of the blank material (Section II, Part D, Subpart 1, Table Y-1).

### NB-3648 Reducers

Reducer fittings manufactured in accordance with the standards listed in Table NCA-7100-1 shall be considered suitable for use. Where butt welding reducers are made to a nominal pipe thickness, the reducers shall be considered suitable for use with pipe of the same nominal thickness.

### NB-3649 Pressure Design of Other Piping Products

Other piping products manufactured in accordance with the standards listed in Table NCA-7100-1 shall be considered suitable for use provided the design is consistent with the design philosophy of this Subsection. Piping products not included in Table NCA-7100-1 may be used if they satisfy the requirements of NB-3200. The pressure design shall be based on an analysis consistent with this Subsection, or experimental stress analysis as described in Appendix II, or an ASME B16.9 type burst test. The bursting pressure in a B16.9 type burst test shall be equal to or greater than that of the weakest pipe to be attached to the piping product, where the burst pressure [psi (MPa)] of the weakest pipe is calculated by the equation:

$$P = 2St/D_o$$

where

$D_o$  = outside diameter of pipe, in. (mm)

$S$  = specified minimum tensile strength of pipe material, psi (MPa)

$t$  = minimum specified wall thickness of pipe, in. (mm)


**NB-3649.1 Expansion Joints.** Rules are currently under development for the application of expansion joints in piping systems. Until these rules are available, expansion joints shall not be used in piping.

## NB-3650 ANALYSIS OF PIPING PRODUCTS

### NB-3651 General Requirements

**NB-3651.1 Piping Products for Which Stress Indices Are Given.** Piping products, for which values of stress indices  $B$ ,  $C$ , and  $K$  are given in NB-3683.2 and which meet the requirements of NB-3640, satisfy the design criteria of NB-3611 provided they comply with these rules. To validate a design in accordance with these rules, it is necessary to perform several flexibility analyses in accordance

**Figure NB-3647.2-1**  
**Types of Permanent Blanks**



with the requirements of [NB-3672](#) and to use the moments and forces obtained from these analyses as required in [NB-3650](#).

**NB-3651.2 Piping Products for Which Stress Indices Are Not Available.** For analysis of flanged joints, see [NB-3658](#). For other piping products for which stress indices are not available, see [NB-3680](#).

**NB-3651.3 Attachments.**

(a) Lugs, brackets, stiffeners, and other attachments may be welded, bolted, and studded to, or bear upon the outside or inside of piping. The interaction effects of attachments on the pressure boundary, producing thermal gradients, localized bending stresses, stress concentrations, or restraint of the pressure boundary shall be considered by the piping designer. Standard clamps generally have a negligible effect on the pressure boundary. However, the effects of clamps on thin-wall piping may need to be evaluated.

(b) Attachments shall meet the requirements of [NB-3135](#).

(c) [Figure NB-4433-1](#) shows some typical types of attachment welds ([NB-4430](#)).

(d) The effect of rectangular and circular cross-section welded attachments on straight pipes may be evaluated using the procedures in Appendix Y.

**NB-3652 Consideration of Design Conditions**

The primary stress intensity limit is satisfied if the requirement of [eq. \(9\)](#) is met:<sup>25</sup>

$$B_1 \frac{PD_o}{2t} + B_2 \frac{D_o}{2I} M_i \leq 1.5S_m \quad (9)$$

where

$B_1, B_2$  = primary stress indices for the specific product under investigation ([NB-3680](#))

$D_o$  = outside diameter of pipe, in. (mm) ([NB-3683](#))

$I$  = moment of inertia, in.<sup>4</sup> (mm<sup>4</sup>) ([NB-3683](#))

$M_i$  = resultant moment due to a combination of Design Mechanical Loads, in.-lb (N·mm). All Design Mechanical Loads, and combinations thereof shall be provided in the Design Specification. In

the combination of loads, all directional moment components in the same direction shall be combined before determining the resultant moment (i.e., resultant moments from different load sets shall not be used in calculating the moment  $M_i$ ). If the method of analysis for earthquake or other dynamic loads is such that only magnitudes without relative algebraic signs are obtained, the most conservative combination shall be assumed.

$P$  = Design Pressure, psi (MPa)

$S_m$  = allowable design stress intensity value, psi (MPa) (Section II, Part D, Subpart 1, Tables 2A and 2B)

$t$  = nominal wall thickness of product, in. (mm) (NB-3683)

### NB-3653 Consideration of Level A Service Limits

All load sets, for which Level A Service Limits are to be evaluated, shall satisfy the fatigue requirements of NB-3653.1 through NB-3653.6 and the thermal stress ratchet requirement of NB-3653.7.

#### NB-3653.1 Satisfaction of Primary Plus Secondary Stress Intensity Range.

(a) This calculation is based upon the effect of changes which occur in mechanical or thermal loadings which take place as the system goes from one load set, such as pressure, temperature, moment, and force loading, to any other load set which follows it in time. It is the range of pressure, temperature, and moment between two load sets which is to be used in the calculations. For example, one of the load sets to be included is that corresponding to zero pressure, zero moment, and room temperature. Equation (10) shall be satisfied for all pairs of load sets<sup>25</sup>:

$$S_n = C_1 \frac{P_o D_o}{2t} + C_2 \frac{D_o}{2I} M_i + C_3 E_{ab} \times |\alpha_a T_a - \alpha_b T_b| \leq 3S_m \quad (10)$$

(b) If for one or more pairs of load sets eq. (a)(10) is not met, the piping product may still be satisfactory, provided that the conditions of NB-3653.6 are met or provided that the requirements of NB-3200 are satisfied.

(c) The nomenclature used in eq. (a)(10) is defined as follows:

$C_1, C_2, C_3$  = secondary stress indices for the specific component under investigation (NB-3680)

$D_o, t, I$  = as defined for eq. NB-3652(9)

$d_a(d_b)$  = inside diameter on side  $a(b)$  of a gross structural discontinuity or material discontinuity, in. (mm)

$E_{ab}$  = average modulus of elasticity of the two sides of a gross structural discontinuity or material discontinuity at room temperature, psi (MPa) (Section II, Part D, Subpart 2, Tables TM)

$M_i$  = resultant range of moment which occurs when the system goes from one service load set to another, in.-lb (N·mm). Service loads and combinations thereof shall be provided in the Design Specification. In the combination of moments from load sets, all directional moment components in the same direction shall be combined before determining the resultant moment (i.e., resultant moments from different load sets shall not be used in calculating the moment range  $M_i$ ). Weight effects need not be considered in determining the loading range since they are noncyclic in character. If the method of analysis is such that only magnitudes without relative algebraic signs are obtained, the most conservative combination shall be assumed. If a combination includes reversing dynamic loads,  $M_i$  shall be either:

(a) the resultant range of moment due to the combination of all loads considering one-half the range of the reversing dynamic loads; or

(b) the resultant range of moment due to the full range of the reversing dynamic loads alone, whichever is greater.

$P_o$  = range of service pressure, psi (MPa)

$S_m$  = average of the allowable stress intensity value for the highest and the lowest temperatures of the metal during the transient, when secondary stress is due to a temperature transient at the point at which the stresses are being analyzed, or due to restraint of free-end deflection. When part or all of the secondary stress is due to mechanical load,  $S_m$  shall not exceed the allowable stress intensity value at the highest temperature during the transient.

$T_a(T_b)$  = range of average temperature on side  $a(b)$  of gross structural discontinuity or material discontinuity, °F (°C). For generally cylindrical shapes, the averaging of  $T$  (NB-3653.2) shall be over a distance of  $\sqrt{d_a t_a}$  for  $T_a$  and over a distance of  $\sqrt{d_b t_b}$  for  $T_b$ .

$t_a(t_b)$  = average wall thickness through the length  $\sqrt{d_a t_a}(\sqrt{d_b t_b})$ , in. (mm). A trial and error solution for  $t_a$  and  $t_b$  may be necessary.

$\alpha_a(\alpha_b)$  = coefficient of thermal expansion on side  $a(b)$  of a gross structural discontinuity or material discontinuity, at room temperature, 1/°F (1/°C) (Section II, Part D, Subpart 2, Tables TE)

### NB-3653.2 Satisfaction of Peak Stress Intensity Range.

(a) For every pair of load sets (NB-3653), calculate  $S_p$  values using eq. (11)<sup>25</sup>:

$$S_p = K_1 C_1 \frac{P_o D_o}{2t} + K_2 C_2 \frac{D_o}{2I} M_i + \frac{1}{2(1-\nu)} K_3 E \alpha |\Delta T_1| + K_3 C_3 E_{ab} \times |\alpha_a T_a - \alpha_b T_b| + \frac{1}{1-\nu} E \alpha |\Delta T_2| \quad (11)$$

NOTE: This simplified analysis is intended to provide a value of  $S_p$  that conservatively estimates the sum of  $P_L + P_b + P_e + Q + F$  as required in Figure NB-3222-1.

The nomenclature used in eq. (11) is defined as follows:

$E\alpha$  = modulus of elasticity ( $E$ ) times the mean coefficient of thermal expansion ( $\alpha$ ) both at room temperature, psi/°F (MPa/°C)

$K_1, K_2, K_3$  = local stress indices for the specific component under investigation (NB-3680)

$|\Delta T_1|$  = absolute value of the range of the temperature difference between the temperature of the outside surface  $T_o$  and the temperature of the inside surface  $T_i$  of the piping product assuming moment generating equivalent linear temperature distribution, °F (°C)

$|\Delta T_2|$  = absolute value of the range for that portion of the nonlinear thermal gradient through the wall thickness not included in  $\Delta T_1$  as shown below, °F (°C)

For a quantitative definition of  $|\Delta T_1|$  and  $|\Delta T_2|$ , see (b) below. All other terms are as defined for eq. NB-3653.1(a)(10).

(b) Quantitative Definitions of  $|\Delta T_1|$  and  $|\Delta T_2|$ .

The following nomenclature is used:

$T_i$  = value of  $T(y)$  at inside surface, °F (°C)  
 $= T(-t/2)$

$T_j(y), T_k(y)$  = temperature, as a function of radial position, for load set  $j$  and load set  $k$ , respectively, °F (°C)

$T_o$  = value of  $T(y)$  at outside surface, °F (°C)  
 $= T(t/2)$

$T(y)$  = temperature distribution range from condition  $j$  to condition  $k$ , °F (°C)  
 $= T_k(y) - T_j(y)$

$t$  = thickness of the wall of the pipe or element, in. (mm)

$y$  = radial position in the wall, measured positive outward from the midthickness position  $(-t/2 \leq y \leq t/2)$ , in. (mm)

Then the temperature distribution range  $T(y)$  may be thought of as being composed of three parts:

(1) a constant value:

$$T = (1/t) \int_{-t/2}^{t/2} T(y) dy$$

which is the average value through the thickness.  $T$  may be used in determining free thermal expansions. Also, the values of  $T$  determined (for the same pair of load sets) or two locations  $a$  and  $b$  on either side of a gross discontinuity may be used for  $T_a$  and  $T_b$  in eqs. NB-3653.1(a)(10) and NB-3653.1(a)(11).

(2) a linear portion, with zero average value, having variation given by:

$$V = (12/t^2) \int_{-t/2}^{t/2} yT(y) dy$$

(3) a nonlinear portion with a zero average value and a zero first moment with respect to the mid-thickness. This decomposition of  $T(y)$  into three parts is illustrated in Figure NB-3653.2(b)-1. The value of  $\Delta T_1$  to be used in eq. (a)(11) is the variation  $V$  of the linear portion:

$$\Delta T_1 = V$$

The value of  $\Delta T_2$  to be used in eq. (a)(11) is as follows:

$$\Delta T_2 = \max\left(|T_o - T| - \frac{1}{2}|\Delta T_1|, |T_i - T| - \frac{1}{2}|\Delta T_1|, 0\right)$$

**NB-3653.3 Alternating Stress Intensity.** The alternating stress intensity  $S_{alt}$  is equal to one-half the value of  $S_p$  ( $S_{alt} = S_p / 2$ ) calculated in eq. NB-3653.2(a)(11).

**NB-3653.4 Use of Design Fatigue Curve.** Enter the applicable design fatigue curve, Figure I-9.0, on the ordinate using  $S_a = S_{alt}$ , and find the corresponding number of cycles on the abscissa. If the service cycle being considered is the only one that produces significant fluctuating stresses, this is the allowable number of cycles.

**NB-3653.5 Cumulative Damage.** The cumulative damage shall be evaluated in accordance with NB-3222.4(e)(5). If  $N_i$  is greater than the maximum number of cycles defined on the applicable design fatigue curve, the value of  $n_i/N_i$  may be taken as zero.


**NB-3653.6 Simplified Elastic-Plastic Discontinuity Analysis.** If eq. NB-3653.1(a)(10) cannot be satisfied for all pairs of load sets, the alternative analysis described below may still permit qualifying the component under NB-3650. Only those pairs of load sets which do not satisfy eq. NB-3653.1(a)(10) need be considered.

(a) Equation (12) shall be met:

$$S_e = C_2 \frac{D_o}{2I} M_i^* \leq 3S_m \quad (12)$$



**Figure NB-3653.2(b)-1  
Decomposition of Temperature Distribution Range**



where

$M_i^*$  = same as  $M_i$  in eq. NB-3653.1(a)(10), except that it includes only moments due to thermal expansion and thermal anchor movements, in.-lb (N·mm)

$S_e$  = nominal value of expansion stress, psi (MPa)

$S_m$  = the average of the tabulated  $S_m$  values for the highest and the lowest temperatures of the metal during the transient

(b) The primary plus secondary membrane plus bending stress intensity, excluding thermal bending and thermal expansion stresses, shall be  $< 3S_m$ . This requirement is satisfied by meeting eq. (13) below:

$$C_1 \frac{P_o D_o}{2t} + C_2 \frac{D_o M_i}{2I} + C'_3 E_{ab} \times |\alpha_a T_a - \alpha_b T_b| \leq 3S_m \quad (13)$$

where

$C'_3$  = values in Table NB-3681(a)-1

$M_i$  = as defined in NB-3652 and all other variables are as defined in NB-3653

$S_m$  = as defined in NB-3653.1

(c) If these conditions are met, the value of  $S_{alt}$  shall be calculated by eq. (14):

$$S_{alt} = K_e \frac{S_p}{2} \quad (14)$$

where

$$K_e = 1.0 \text{ for } S_n \leq 3S_m \\ = 1.0 + [(1-n)/n(m-1)](S_n/3S_m - 1), \text{ for } 3S_m < S_n < 3mS_m \\ = 1/n, \text{ for } S_n \geq 3mS_m$$

$m, n$  = material parameters given in Table NB-3228.5(b)-1

$S_{alt}$  = alternating stress intensity, psi (MPa)

$S_n$  = primary plus secondary stress intensity value calculated in eq. NB-3653.1(a)(10), psi (MPa)

$S_p$  = peak stress intensity value calculated by eq. NB-3653.2(a)(11), psi (MPa)

$S_{alt}$  for all load sets shall be calculated in accordance with NB-3653.3 or eq. (14). Using the alternating stress intensity values calculated by the above procedures, determine the cumulative usage factor in accordance with NB-3653.4 and NB-3653.5. The cumulative usage factor shall not exceed 1.0.

**NB-3653.7 Thermal Stress Ratchet.** For all pairs of load sets, the value of the range of  $\Delta T_1$  cannot exceed that calculated as follows:

$$\Delta T_1 \text{ range} \leq \frac{y' S_y}{0.7 E \alpha} C_4$$

where

$C_4$  = 1.1 for ferritic material  
= 1.3 for austenitic material

$E\alpha$  = as defined for eq. NB-3653.2(a)(11), psi/°F (MPa/°C)

$P$  = maximum pressure for the set of conditions under consideration, psi (MPa)

$S_y$  = yield strength value, psi (MPa), taken at average fluid temperature of the transient under consideration

$x = (PD_o/2t) (1/S_y)$

$y'$  = 3.33, 2.00, 1.20, and 0.80 for  $x$  = 0.3, 0.5, 0.7, and 0.8, respectively

### NB-3654 Consideration of Level B Service Limits

The procedures for analyzing Service Loadings for which Level B Service Limits are designated, are the same as those given in NB-3653 for Level A Service Limits. All load sets, including Level A and Level B Service Loadings, shall satisfy the fatigue requirements of NB-3653.1 through NB-3653.6 and the thermal stress ratchet requirement of NB-3653.7.

**NB-3654.1 Permissible Pressure.** For Level B Service Limits [NCA-2142.4(b)(2)], the permissible pressure shall not exceed the pressure  $P_a$ , calculated in accordance with



eq. NB-3641.1(3) by more than 10%. The calculation of  $P_a$  shall be based on the allowable stress intensity for the material at the coincident temperature.

**NB-3654.2 Analysis of Piping Components.** For Service Loadings for which Level B Service Limits are designated, the requirements of (a) or (b) below shall apply.

(a) For Service Loadings for which Level B Service Limits are designated which do not include reversing dynamic loads (NB-3622.2) or have reversing dynamic loads combined with nonreversing dynamic loads (NB-3622.4), the conditions of eq. NB-3652(9) shall be met using Service Level B coincident pressure  $P$  and moments  $M_i$  which result in the maximum calculated stress. The allowable stress to be used for this condition is  $1.8S_m$ , but not greater than  $1.5S_y$ .

$S_y$  = yield strength value, psi (MPa), taken at average fluid temperature of the transient under consideration

(b) For Service Loadings for which Level B Service Limits are designated which include reversing dynamic loads that are not required to be combined with nonreversing dynamic loads, the requirements of NB-3653 for Level A Service Limits shall be met. In addition, any deflection limits prescribed by the Design Specification must be satisfied.

### NB-3655 Consideration of Level C Service Limits

(13) **NB-3655.1 Permissible Pressure.** When Level C Service Limits [NCA-2142.4(b)(3) and NB-3113(b)] are specified, the permissible pressure shall not exceed the pressure  $P_a$ , calculated in accordance with eq. NB-3641.1(3) by more than 50%. The calculation of  $P_a$  shall be based on the allowable stress intensity for the material at the coincident temperature.

**NB-3655.2 Analysis of Piping Components.** For Service Loadings for which Level C Service Limits [NCA-2142.4(b)(3) and NB-3113(b)] are designated, the following requirements shall apply.

(a) For Service Loadings for which Level C Service Limits are designated except as permitted by (b) below, the conditions of eq. NB-3652(9) shall be met using Service Level C coincident pressure  $P$  and moments  $M_i$  which result in the maximum calculated stress. The allowable stress to be used for this condition is  $2.25S_m$  but not greater than  $1.8S_y$ . In addition, if the effects of anchor motion,  $M_{AM}$ , from reversing dynamic loads are not considered in NB-3654, then the requirements of NB-3656(b)(4) shall be satisfied using 70% of the allowable stress given in NB-3656(b)(4).

(b) As an alternative to (a), for Service Loadings for which Level C Service Limits are designated, which include reversing dynamic loads (NB-3622.2) that are not required to be combined with nonreversing dynamic loads (NB-3622.2), the requirements of NB-3656(b) shall be satisfied

using the allowable stress in NB-3656(b)(2), 70% of the allowable stress in NB-3656(b)(3), and 70% of the allowable loads in NB-3656(b)(4).

**NB-3655.3 Deformation Limits.** Any deformation or deflection limits prescribed by the Design Specifications shall be considered with respect to Level C Service Limits.

### NB-3656 Consideration of Level D Service Limits (13)

If the Design Specifications specify any Service Loading for which Level D Limits are designated [NCA-2142.2(b)(4)], the following requirements shall apply.

(a) For Service Loadings for which Level D Service Limits are designated except as permitted by (b) below, the requirements of (1), (2), and (3) below shall apply.

(1) The permissible pressure shall not exceed 2.0 times the pressure  $P_a$  calculated in accordance with eq. NB-3641.1(3). The calculation of  $P_a$  shall be based on the allowable stress intensity for the material at the coincident temperature.

(2) The conditions of eq. NB-3652(9) of NB-3652 shall be met using Service Level D coincident pressure  $P$  and moment  $M_i$ , which results in the maximum calculated stress. The allowable stress to be used for this condition is  $3.0S_m$ , but not greater than  $2.0S_y$ .

(3) If the effects of anchor motion,  $M_{AM}$ , from reversing dynamic loads are not considered in NB-3654, then the requirements of (b)(4) shall be satisfied.

(b) As an alternative to (a), for piping fabricated from material designated P-No. 1 through P-No. 9 in Table 2A, Section II, Part D and limited to  $D_o/t_n \leq 40$  if Level D Service Limits are designated which include reversing dynamic loads (NB-3622.2) that are not required to be combined with nonreversing dynamic loads (NB-3622.4), the requirements of (1) through (5) below shall apply.

(1) The pressure occurring coincident with the earthquake or other reversing type loading,  $P_E$ , shall not exceed the Design Pressure.

(2) The sustained stress due to weight loading shall not exceed the following:

$$B_2 \frac{D_o}{2I} M_W \leq 0.5 S_m$$

where

$M_W$  = resultant moment due to weight effects, in.-lb (N·mm) (NB-3623)

(3) The stress due to weight and inertial loading due to reversing dynamic loads in combination with the Level D coincident pressure shall not exceed the following:

$$B_1 \frac{P_E D_o}{2t} + B_2 \frac{D_o}{2I} M_E \leq 3S_m$$

where

$B_2' = B_2$  from Table NB-3681(a)-1, except as follows:

where

$B_2' = 1.33$  for girth butt welds between items which do *not* have nominally identical wall thicknesses [NB-3683.4(b)]

$B_2' = 0.87/h^{2/3}$  for curved pipe or butt-welding elbows ( $h$  as defined in NB-3683.7), but not less than 1.0

$B_{2b}' = 0.27(R_m/T_r)^{2/3}$  and

$B_{2r}' = 0.33(R_m/T_r)^{2/3}$  for ASME B16.9 or MSS SP-87 butt-welding tees (terms as defined in NB-3683), but neither less than 1.0

$M_E$  = the amplitude of the resultant moment, in.-lb (N-mm). In the combination of loads, all directional moment components in the same direction shall be combined before determining the resultant moment. If the method of analysis is such that only magnitude without algebraic signs is obtained, the most conservative combination shall be assumed.

$P_E$  = the pressure occurring coincident with the reversing dynamic load, psi (MPa)

(4) The range of the resultant moment  $M_{AM}$  and the amplitude of the longitudinal force  $F_{AM}$  resulting from the anchor motions due to earthquake and other reversing type dynamic loading shall not exceed the following:

$$C_2 \frac{M_{AM} D_o}{2I} < 6.0 S_m$$

$$\frac{F_{AM}}{A_M} < S_m$$

where

$A_M$  = cross-sectional area of metal in the piping component wall, in.<sup>2</sup> (mm<sup>2</sup>)

(5) The use of the  $6S_m$  limit in (4) assumes essentially linear behavior of the entire piping system. This assumption is sufficiently accurate for systems where plastic straining occurs at many points or over relatively wide regions, but fails to reflect the actual strain distribution in unbalanced systems where only a small portion of the piping undergoes plastic strain. In these cases, the weaker or higher stressed portions will be subjected to strain concentrations due to elastic follow-up of the stiffer or lower stressed portions. Unbalance can be produced

(-a) by the use of small pipe runs in series with larger or stiffer pipe, with the small lines relatively highly stressed.

(-b) by local reduction in size or cross section, or local use of a weaker material.

In the case of unbalanced systems, the design shall be modified to eliminate the unbalance or the piping shall be qualified to the equations given in (4) with allowable  $6S_m$  replaced by  $3S_m$ .

(6) Piping displacements shall satisfy Design Specification limitations.

(c) As an alternative to (a) and (b), the rules contained in Appendix F may be used in evaluating these service loadings independently of all other Design and Service Loadings.

## NB-3657 Test Loadings

The evaluation of Test Loadings shall be carried out in accordance with NB-3226.

## NB-3658 Analysis of Flanged Joints

The pressure design of flanged joints is covered by NB-3647.1. Flanged joints subjected to combinations of moment and pressure shall meet the requirements of this paragraph. In addition, the pipe-to-flange welds shall meet the requirements of NB-3652 through NB-3656 using appropriate stress indices from Table NB-3681(a)-1. Flanged joints using flanges, bolting, and gaskets as specified in ASME B16.5 and using a bolt material having an  $S_m$  value at 100°F (38°C) not less than 20.0 ksi (138 MPa) may be analyzed in accordance with the following rules or in accordance with NB-3200. Other flanged joints shall be analyzed in accordance with NB-3200.

### NB-3658.1 Design Limits, Levels A and B Service Limits.

(a) The pressure shall not exceed the rated pressure for Level A Service Limits or 1.1 times the rated pressure for Level B Service Limits.

(b) The bolting shall meet the requirements of NB-3232. In addition, the limitations given by eqs. (15) and (16) shall be met:

(U.S. Customary Units)

$$M_{fs} \leq 3,125 (S_y / 36,000) C A_b \quad (15)$$

(SI Units)

$$M_{fs} \leq 21.7 (S_y / 250) C A_b$$

where

$A_b$  = total cross-sectional area of bolts at root of thread or section of least diameter under stress, in.<sup>2</sup> (mm<sup>2</sup>)

$C$  = diameter of bolt circle, in. (mm)

$M_{fs}$  = bending or torsional moment (considered separately) applied to the joint due to weight, thermal expansion of the piping, sustained anchor movements, relief valve steady-state thrust, and other sustained mechanical loads applied to the flanged

joint during the design or service conditions, in.-lb. (N·mm). If cold springing is used, the moment may be reduced to the extent permitted by [NB-3672.8](#).

$S_y$  = yield strength of flange material at Design Temperature (Section II, Part D, Subpart 1, Table Y-1), psi (MPa). The value of  $S_y/36,000$  ( $S_y/250$ ) shall not be taken as greater than unity.

(U.S. Customary Units)

$$M_{fd} \leq 6,250 \left( S_y / 36,000 \right) C A_b \quad (16)$$

(SI Units)

$$M_{fd} \leq 43.4 \left( S_y / 250 \right) C A_b$$

where

$M_{fd}$  = bending or torsional moment (considered separately) as defined for  $M_{fs}$ , but including dynamic loadings, in.-lb (N·mm)

#### **NB-3658.2 Level C Service Limits.**

(a) The pressure shall not exceed 1.5 times the rated pressure.

(b) The limitation given by [eq. \(17\)](#) shall be met:

(U.S. Customary Units)

$$M_{fd} \leq \left[ 11,250 A_b - (\pi / 16) D_f^2 P_{fd} \right] C \left( S_y / 36,000 \right) \quad (17)$$

(SI Units)

$$M_{fd} \leq \left[ 78.1 A_b - (\pi / 16) D_f^2 P_{fd} \right] C \left( S_y / 250 \right)$$

where

$D_f$  = outside diameter of raised face, in. (mm)

$P_{fd}$  = pressure concurrent with  $M_{fd}$ , psi (MPa)

$M_{fd}$ ,  $C$ ,  $S_y$ , the limitation on  $S_y/36,000$  ( $S_y/250$ ), and  $A_b$  are defined in [NB-3658.1\(b\)](#).

#### **NB-3658.3 Level D Service Limits.**

(a) The pressure shall not exceed 2.0 times the rated pressure.

(b) The limitation given by [eq. NB-3658.2\(b\)\(17\)](#) shall be met, where  $P_{fd}$  and  $M_{fd}$  are pressures, psi (MPa), and moments, in.-lb (N·mm), occurring concurrently.

**NB-3658.4 Test Loadings.** Analysis for Test Loadings is not required.

### **NB-3660 DESIGN OF WELDS**

#### **NB-3661 Welded Joints**

**NB-3661.1 General Requirements.** Welded joints shall be made in accordance with [NB-4200](#).

#### **NB-3661.2 Socket Welds.**<sup>26</sup>

(a) Socket welded piping joints shall be limited to pipe sizes of NPS 2 (DN 50) and less.

(b) Socket welds shall comply with the requirements of [NB-4427](#).

**NB-3661.3 Fillet Welds and Partial Penetration Welds for Branch Connections.** Fillet welds and partial penetration welds are allowed for branch connections provided the following requirements of (a) and (b) are met:

(a) The ratio of the run pipe NPS to the branch NPS shall not be less than 10; the branch shall not be larger than NPS 2; and, all reinforcement for the opening required by [NB-3643.3](#) shall be provided in the wall of the run pipe.

(b) The welds are fillet or groove welds as shown in [Figure NB-4246\(b\)-1](#). These welds shall allow for examination in accordance with [NB-5245](#).

### **NB-3670 SPECIAL PIPING REQUIREMENTS**

#### **NB-3671 Selection and Limitation of Nonwelded Piping Joints**

The type of piping joint used shall be suitable for the Design Loadings and shall be selected with consideration of joint tightness, mechanical strength, and the nature of the fluid handled. Piping joints shall conform to the requirements of this Subsection with leak tightness being a consideration in selection and design of joints for piping systems to satisfy the requirements of the Design Specifications.

**NB-3671.1 Flanged Joints.** Flanged joints are permitted.

**NB-3671.2 Expanded Joints.** Expanded joints shall not be used.

**NB-3671.3 Threaded Joints.** Threaded joints in which the threads provide the only seal shall not be used. If a seal weld is employed as the sealing medium, the stress analysis of the joint must include the stresses in the weld resulting from the relative deflections of the mated parts.

**NB-3671.4 Flared, Flareless, and Compression Joints.** Flared, flareless, and compression type tubing fittings may be used for tubing sizes not exceeding 1 in. O.D. (25 mm) within the limitations of applicable standards and specifications listed in Table NCA-7100-1 and requirements (b) and (c) below. In the absence of such standards or specifications, the Designer shall determine that the type of fitting selected is adequate and safe for the Design Loadings in accordance with the requirements of (a), (b), and (c) below.

(a) The pressure design shall meet the requirements of [NB-3649](#).

(b) Fittings and their joints shall be suitable for the tubing with which they are to be used in accordance with the minimum wall thickness of the tubing and method of assembly recommended by the manufacturer.

(c) Fittings shall not be used in services that exceed the manufacturer's maximum pressure-temperature recommendations.

**NB-3671.5 Caulked Joints.** Caulked or leaded joints shall not be used.

**NB-3671.6 Brazed and Soldered Joints.**

*(a) Brazed Joints*

(1) Brazed joints of a maximum nominal pipe size of 1 in. (DN 25) may be used only at dead end instrument connections and in special applications where space and geometry conditions prevent the use of joints permitted under NB-3661.2, NB-3661.3, and NB-3671.4. The depth of socket shall be at least equal to that required for socket welding fittings and shall be of sufficient depth to develop a rupture strength equal to that of the pipe at Design Temperature (NB-4500).

(2) Brazed joints that depend upon a fillet rather than a capillary type filler addition are not acceptable.

(3) Brazed joints shall not be used in systems containing flammable fluids or in areas where fire hazards are involved.

*(b) Soldered Joints.* Soldered joints shall not be used.

**NB-3671.7 Sleeve Coupled and Other Patented Joints.** Mechanical joints, for which no standards exist, and other patented joints may be used provided the requirements of (a), (b), and (c) below are met.

(a) Provision is made to prevent separation of the joints under all Service Loadings.

(b) They are accessible for maintenance, removal, and replacement after service.

(c) Either of the following two criteria are met.

(1) A prototype joint has been subjected to performance tests to determine the safety of the joint under simulated service conditions. When vibration, fatigue, cyclic conditions, low temperature, thermal expansion, or hydraulic shock is anticipated, the applicable conditions shall be incorporated in the tests. The mechanical joints shall be sufficiently leak tight to satisfy the requirements of the Design Specifications.

(2) Joints are designed in accordance with the rules of NB-3200.

**NB-3672 Expansion and Flexibility**

(a) In addition to meeting the design requirements for pressure, weight, and other loadings, piping systems shall be designed to absorb or resist thermal expansion or contraction or similar movements imposed by other sources and shall meet the criteria for allowable stress intensity as specified in NB-3611. Piping systems shall be designed to have sufficient flexibility to prevent the movements from causing:

(1) failure of piping or anchors from overstress or overstrain;

(2) leakage at joints;

(3) detrimental distortion of connected equipment resulting from excessive thrusts and moments.

(b) The effects of stresses, caused by pressure, thermal expansion, and other loads and their stress intensification factors, shall be considered cumulatively.

**NB-3672.1 Properties.** Thermal expansion data and moduli of elasticity shall be determined from Section II, Part D, Subpart 2, Tables TE and TM, which cover more commonly used piping materials. For materials not included in these tables, reference shall be to authoritative source data, such as publications of the National Institute of Standards and Technology.

**NB-3672.2 Unit Thermal Expansion Range.** The unit thermal expansion range in in./100 ft (mm/m), used in calculating the expansion range, shall be determined from Section II, Part D, Subpart 2, Tables TE as the algebraic difference between the unit expansion shown for the highest metal temperature and that for the lowest metal temperature resulting from service or shutdown conditions.

**NB-3672.3 Moduli of Elasticity.** The moduli of elasticity for ferrous and nonferrous materials shall be as given in Section II, Part D, Subpart 2, Tables TM.

**NB-3672.4 Poisson's Ratio.** When required for flexibility calculations, Poisson's ratio shall be taken as 0.3 for all metals at all temperatures.

**NB-3672.5 Stresses.** Flexibility calculations of the moments and forces in the piping system due to thermal expansion and end motions shall be based on the hot modulus  $E_h$ . Calculations for the expansion stresses shall be based on the least cross-sectional area of the pipe or fitting, using nominal dimensions. The expansion stress computed from the forces and moments shall be multiplied by the ratio  $E_c/E_h$ , where  $E_c$  is the modulus of elasticity at room temperature. The effect of expansion stresses in combination with stresses from other causes shall be evaluated in accordance with NB-3611 or NB-3630.

**NB-3672.6 Method of Analysis.** All systems shall be analyzed for adequate flexibility by a rigorous structural analysis unless they can be judged technically adequate by an engineering comparison with previously analyzed systems.

**NB-3672.7 Basic Assumptions and Requirements.**

(a) When calculating the flexibility of a piping system between anchor points, the system between the anchor points shall be treated as a whole. The significance of all parts of the line and of all restraints, such as supports or guides, including intermediate restraints introduced for the purpose of reducing moments and forces on equipment or small branch lines, shall be considered.

(b) Comprehensive calculations shall take into account the flexibility factors and stress indices found to exist in piping products other than straight pipe. Credit may be taken where extra flexibility exists in the piping system. Flexibility factors and stress indices are given in NB-3680.



(c) The total expansion range shall be used in all calculations whether or not the piping is cold sprung. Not only the expansion of the line itself, but also linear and angular movements of the equipment and supports to which it is attached, shall be considered.

(d) Where assumptions are used in calculations or model tests, the likelihood of underestimates of forces, moments, and stresses, including the effects of stress intensification, shall be evaluated.

**NB-3672.8 Cold Springing.** Cold springing provides a beneficial effect in assisting a system to attain its most favorable position sooner. The effect of cold springing shall be analyzed as any other movement in the system is analyzed. The maximum stress allowed due to cold springing is  $2.0S_m$  at the cold spring temperature. Since the usual erection procedures may not permit accurate determination of cold spring in a piping system, the allowable reduction of forces and moments at anchors or equipment caused by cold springing shall be limited to no more than two-thirds of the calculated reduction.

### NB-3674 Design of Pipe Supports

Pipe supports shall be designed in accordance with the requirements of Subsection NF.

### NB-3677 Pressure Relief Piping

**NB-3677.1 General Requirements.** Pressure relief piping within the scope of this Subsection shall be supported to sustain reaction forces and shall conform to the requirements of the following subparagraphs.

#### NB-3677.2 Piping to Pressure Relieving Safety Devices.

(a) Piping that connects a pressure relieving safety device to a piping system shall comply with all the requirements of the class of piping of the system which it is designated to relieve.

(b) There shall be no intervening stop valves between systems being protected and their protective device or devices except as provided for in NB-7142.

#### NB-3677.3 Discharge Piping From Pressure Relieving Safety Devices.

(a) Discharge piping from pressure relieving safety devices shall comply with the requirements applicable to the conditions under which it operates.

(b) There shall be no intervening stop valve between the protective device or devices and the point of discharge except as provided for in NB-7142.

(c) The effluent from relief devices may be discharged outside the containment only if adequate provisions are made for the safe disposal of the effluent. It shall not impinge on other piping or structure or equipment and shall be directed away from platforms and other areas which might be used by personnel.

(d) It is recommended that individual discharge lines be used. For requirements on discharge piping, see NB-7141(f).

(e) When the umbrella or drip pan type of connection between the pressure relieving safety device and the discharge piping is used, the discharge piping shall be so designed as to prevent binding due to expansion movements and shall be so dimensioned as to prevent the possibility of blow back of the effluent. Individual discharge lines shall be used in this application. Drainage shall be provided to remove water collected above the safety valve seat.

(f) Discharge lines from pressure relieving safety devices within the scope of this Subsection shall be designed to facilitate drainage if there is any possibility that the effluent can contain liquid.

### NB-3680 STRESS INDICES AND FLEXIBILITY FACTORS

#### NB-3681 Scope

(a) There are two types of analyses allowed by the rules of this Subarticle. The applicable *B*, *C*, and *K* indices to be used with eqs. NB-3652(9), NB-3653.1(a)(10), and NB-3653.2(a)(11) are given in Table NB-3681(a)-1. The applicable indices to be used with the detailed analysis of NB-3200 are given in NB-3685 and NB-3338.

(b) Methods of determining flexibility factors for some commonly used piping products are given in NB-3686.

(c) Values of stress indices are tabulated for commonly used piping products and joints. Unless specific data, which shall be referenced in the Design Report, exist that would warrant lower stress indices than those tabulated or higher flexibility factors than those calculated by the methods of NB-3686, the stress indices given shall be used as minimums and the flexibility factors shall be used as maximums.

(d) For piping products not covered by NB-3680, stress indices and flexibility factors shall be established by experimental analysis (Appendix II) or theoretical analysis. Such test data or theoretical analysis shall be included in the Design Report.

(e) When determining stress indices by experimental methods, the nominal stress at the point under consideration (crack site, point of maximum stress intensity, etc.) shall be used.

### NB-3682 Definitions of Stress Indices and Flexibility Factors

(13)

(a) The general definition of a stress index for mechanical loads is:

$$B, C, K, \text{ or } i = \frac{\sigma}{S}$$

where

$S$  = nominal stress, psi (MPa), due to load  $L$

$\sigma$  = elastic stress, psi (MPa), due to load  $L$

**Table NB-3681(a)-1**  
**Stress Indices for Use With Equations in NB-3650**

Piping Products and Joints [Note (3)]	Applicable for $D_o/t \leq 100$ for $C$ or $K$ Indices and $D_o/t \leq 50$ for $B$ Indices [Note (1)]									Notes
	Internal Pressure			Moment Loading			Thermal Loading			
	$B_1$	$C_1$	$K_1$	$B_2$	$C_2$	$K_2$	$C_3$	$C'_3$	$K_3$	
		[Note (4)]	[Note (4)]		[Note (4)]	[Note (4)]			[Note (4)]	
Straight pipe, remote from welds or other discontinuities	0.5	1.0	1.0	1.0	1.0	1.0	1.0	...	1.0	(5)
Longitudinal butt welds in straight pipe										
(a) flush	0.5	1.0	1.1	1.0	1.0	1.1	1.0	...	1.1	(6)
(b) as-welded $t > \frac{3}{16}$ in. (5 mm)	0.5	1.1	1.2	1.0	1.2	1.3	1.0	...	1.2	(6)
(c) as-welded $t \leq \frac{3}{16}$ in. (5 mm)	0.5	1.4	2.5	1.0	1.2	1.3	1.0	...	1.2	(6)
Girth butt welds between nominally identical wall thickness items	...	...	...	...	...	...	...	...		
(a) flush	0.5	1.0	1.1	1.0	1.0	1.1	0.60	0.50	1.1	(7)
(b) as-welded	0.5	1.0	1.2	1.0	...	1.8	0.60	0.50	1.7	(7)
Girth fillet weld to socket weld, fittings, socket weld valves, slip-on or socket welding flanges	...	...	3.0	...	...	2.0	2.0	1.0	3.0	(8)
NB-4250 transitions										
(a) flush	0.5	...	1.1	1.0	...	1.1	...	1.0	1.1	(9)
(b) as-welded	0.5	...	1.2	1.0	...	1.8	...	1.0	1.7	(9)
Transitions within a 1:3 slope envelope										
(a) flush	0.5	...	1.2	1.0	...	1.1	...	0.60	1.1	(10)
(b) as-welded	0.5	...	1.2	1.0	...	1.8	...	0.60	1.7	(10)
Butt welding reducers per ASME B16.9 or MSS SP-87	...	...	...	1.0	...	...	1.0	0.5	1.0	(11)
Curved pipe or butt welding elbows	...	...	1.0	...	...	1.0	1.0	0.5	1.0	(12)
Branch connections per NB-3643	0.5	...	2.0	...	...	...	1.8	1.0	1.7	(13)
Butt welding tees	0.5	1.5	4.0	...	...	...	1.0	0.5	1.0	(14)

GENERAL NOTE: For indices not listed, see the note referenced at the end of the applicable line.

NOTES:

- (1) For products and joints with  $50 < D_o/t \leq 100$ , see NB-3683.2(c).
- (2) For the calculation of pressure and moment loads and special instructions regarding eqs. NB-3652(9) through NB-3653.6(b)(13), see NB-3683.1(d).
- (3) For definitions, applicability, and specific restrictions, see NB-3683.
- (4) For special instructions regarding the use of these indices for welded products, intersecting welds, abutting products, or out-of-round products, see NB-3683.2.
- (5) See NB-3683.3, Straight Pipe Remote From Welds.
- (6) See NB-3683.4(a), Longitudinal Butt Welds.
- (7) See NB-3683.4(b), Girth Butt Welds.
- (8) See NB-3683.4(c), Girth Fillet Welds.
- (9) See NB-3683.5(a), NB-4250 Transitions.
- (10) See NB-3683.5(b), Transitions Within a 1:3 Slope.
- (11) See NB-3683.6, Concentric and Eccentric Reducers.
- (12) See NB-3683.7, Curved Pipe or Butt Welding Elbows. See also NB-3683.2(a) and NB-3683.2(b).
- (13) See NB-3683.8, Branch Connections per NB-3643. See also NB-3683.1(d).
- (14) See NB-3683.9, Butt Welding Tees. See also NB-3683.1(d).



For  $B$  indices,  $\sigma$  represents the stress magnitude corresponding to a limit load. For  $C$  or  $K$  indices,  $\sigma$  represents the maximum stress intensity due to load  $L$ . For  $i$  factors,  $\sigma$  represents the principal stress at a particular point, surface, and direction due to load  $L$ .

(b) The general definition of a stress index for thermal loads is:

$$C \text{ or } K = \frac{\sigma}{E\alpha\Delta T}$$

where

$E$  = modulus of elasticity, psi (MPa)

$\alpha$  = coefficient of thermal expansion,  $1/^\circ\text{F}$  ( $1/^\circ\text{C}$ )

$\Delta T$  = thermal difference,  $^\circ\text{F}$  ( $^\circ\text{C}$ )

$\sigma$  = maximum stress intensity, psi (MPa), due to thermal difference  $\Delta T$

The values of  $E$ ,  $\alpha$ , and  $\Delta T$  are defined in detail in NB-3650.

(c) Flexibility factors are identified herein by  $k$  with appropriate subscripts. The general definition of a flexibility factor is:

$$k = \theta_{ab} / \theta_{nom}$$

where

$\theta_{ab}$  = rotation of end  $a$ , with respect to end  $b$ , due to a moment load  $M$  and in the direction of the moment  $M$

$\theta_{nom}$  = nominal rotation due to moment load  $M$

The flexibility factor  $k$  and nominal rotation  $\theta_{nom}$  are defined in detail for specific components in NB-3686.

### NB-3683 Stress Indices for Use With NB-3650

The stress indices given herein and in Table NB-3681(a)-1 and subject to the additional restrictions specified herein are to be used with the analysis methods of NB-3650. For piping products outside the applicable range, stress indices shall be established in accordance with NB-3681.

#### (13) NB-3683.1 Nomenclature.

(a) *Dimensions.* Nominal dimensions as specified in the dimensional standards of Table NCA-7100-1 shall be used for calculating the numerical values of the stress indices given herein and in Table NB-3681(a)-1, and for evaluating eqs. NB-3652(9) through NB-3653.6(c)(14). For ASME B16.9 or MSS SP-87 piping products, the nominal dimensions of the equivalent pipe (for example, Schedule 40) as certified by the manufacturer shall be used. Not more than one equivalent pipe size shall be certified for given product items of the same size, shape, and weight.

For piping products such as reducers and tapered-wall transitions which have different dimensions at either end, the nominal dimensions of the large or small end, whichever gives the larger value of  $D_o/t$ , shall be used. Dimensional terms are defined as follows:

$D_o$  = nominal outside diameter of pipe, in. (mm)

$D_i$  = nominal inside diameter of pipe, in. (mm)

$D_m$  = mean diameter of designated run pipe, in. (mm) [see NB-3683.8(c) and Figure NB-3643.3(a)-1]  
 $= 2R_m = (D_o - T_r)$

$D_{max}$  = maximum outside diameter of cross section, in. (mm)

$D_{min}$  = minimum outside diameter of cross section, in. (mm)

$D_1$  = nominal outside diameter at large end of concentric and eccentric reducers, in. (mm) [see NB-3683.6]

$D_2$  = nominal outside diameter at small end of concentric and eccentric reducers, in. (mm) [see NB-3683.6]

$d_o$  = nominal outside diameter of attached branch pipe, in. (mm)

$d_i$  = nominal inside diameter of branch, in. (mm)

$d_m$  = nominal mean diameter of reinforced or unreinforced branch, in. (mm) [see NB-3683.8(c)]  
 $= (d_i + t_n)$

$h$  = characteristic bend parameter of a curved pipe or butt welding elbow

$$= tR/r_m^2$$

$I$  = moment of inertia of pipe, in.<sup>4</sup> (mm<sup>4</sup>)  
 $= 0.0491 (D_o^4 - D_i^4)$

$L_1$  = height of nozzle reinforcement for branch connections, in. (mm) [see Figure NB-3643.3(a)-1]

$L_1, L_2$  = length of cylindrical portion at the large end and small end of a reducer, respectively, in. (mm) [see NB-3683.6]

$R$  = nominal bend radius of curved pipe or elbow, in. (mm)

$R_m$  = mean radius of designated run pipe, in. (mm) [see NB-3683.8 and Figure NB-3643.3(a)-1]  
 $= (D_o - T_r)/2$

$r_i$  = inside radius of branch, in. (mm) [see Figure NB-3643.3(a)-1]  
 $= d_i/2$

$r_m$  = mean pipe radius, in. (mm)  
 $= (D_o - t)/2$

$r'_m$  = mean radius of attached branch pipe, in. (mm) [see Figure NB-3643.3(a)-1]  
 $= (d_o - T'_b)/2$

$r_p$  = outside radius of reinforced nozzle or branch connection, in. (mm) [see Figure NB-3643.3(a)-1]

- $r_1, r_2, r_3$  = designated radii for reinforced branch connections, concentric and eccentric reducers, in. (mm) [see NB-3683.6, NB-3683.8, and Figure NB-3643.3(a)-1]
- $T_b$  = wall thickness of branch connection reinforcement, in. (mm) [see Figure NB-3643.3(a)-1]
- $T'_b$  = nominal wall thickness of attached branch pipe, in. (mm) [see Figure NB-3643.3(a)-1]
- $T_r$  = nominal wall thickness of designated run pipe, in. (mm) [see Figure NB-3643.3(a)-1]
- $t$  = nominal wall thickness of pipe, in. (mm). For piping products purchased to a minimum wall specification, the nominal wall thickness shall be taken as 1.14 times the minimum wall.
- $t_{max}$  = maximum wall thickness of a welding transition within a distance of  $\sqrt{D_o t}$  from the welding end, in. (mm) [see NB-3683.5(b)], in. (mm)
- $t_n$  = wall thickness of nozzle or branch connection reinforcement, in. (mm) (see NB-3683.8; also used for concentric and eccentric reducers, see NB-3683.6)
- $t_1$  = nominal wall thickness at large end of concentric and eccentric reducers, in. (mm) (see NB-3683.6)
- $t_2$  = nominal wall thickness at small end of concentric and eccentric reducers, in. (mm) (see NB-3683.6)
- $t_{1m}, t_{2m}$  = minimum wall thickness at the large end and small end of a reducer, respectively, that is required to resist the Design Pressure  $P$  in accordance with eq. NB-3641.1(1), in. (mm)
- $Z$  = section modulus of pipe, in.<sup>3</sup> (mm<sup>3</sup>)  
 $= 2I/D_o$
- $Z_b$  = approximate section modulus of attached branch pipe, in.<sup>3</sup> (mm<sup>3</sup>)  
 $= \pi(r'_m)^2 T'_b$
- $Z_r$  = approximate section modulus of designated run pipe, in.<sup>3</sup> (mm<sup>3</sup>)  
 $= \pi(R_m)^2 T_r$
- $\alpha$  = cone angle of concentric and eccentric reducers, deg (see NB-3683.6)
- $\Delta$  = radial weld shrinkage measured from the nominal outside surface, in. (mm)
- $\theta_n$  = slope of nozzle-to-pipe transition for branch connections, deg [see Figure NB-3643.3(a)-1]

(b) *Material Properties.* Unless otherwise specified, material properties at the appropriate temperature, as given in Section II, Part D, Subparts 1 and 2, shall be used. Terms are defined as follows:

- $E$  = modulus of elasticity for the material at room temperature, psi (MPa), taken from Section II, Part D, Subpart 2, Tables TM
- $M$  = materials constant  
 $= 2$ , for ferritic steels and nonferrous materials except nickel-chrome-iron alloys and nickel-iron-chrome alloys  
 $= 2.7$ , for austenitic steel, nickel-chrome-iron alloys and nickel-iron-chrome alloys [see NB-3683.2(b)]
- $S_y$  = yield strength of the material at the Design Temperature, psi (MPa), taken from Section II, Part D, Subpart 1, Table Y-1
- $\nu$  = Poisson's ratio  
 $= 0.3$


(c) *Connecting Welds.* Connecting welds in accordance with the requirements of this Subsection are defined as either *flush* or *as-welded* welds.

(1) *Flush welds* are those welds with contours as defined in Figure NB-3683.1(c)-1. The total thickness (both inside and outside) of the weld reinforcement shall not exceed  $0.1t$ . There shall be no concavity on either the interior or exterior surfaces and the finished contour shall not have any slope greater than 7 deg where the angle is measured from a tangent to the surface of the pipe or on the tapered transition side of the weld to the nominal transition surface.

(2) *As-welded welds* are those welds not meeting the special requirements of flush welds.

(d) *Loadings.* Loadings for which stress indices are given include internal pressure, bending and torsional moments, and temperature differences. The indices are intended to be sufficiently conservative to account also for the effects of transverse shear forces normally encountered in flexible piping systems. If, however, thrust or shear forces account for a significant portion of the loading on a given piping product, the effect of these forces shall be included in the design analysis. The values of the

Figure NB-3683.1(c)-1



moments and forces shall be obtained from an analysis of the piping system in accordance with NB-3672. Loading terms are defined as follows:

$M_1, M_2, M_3$  = orthogonal moment loading components at a given position in a piping system, in.-lb (N·mm)

$M_{ij}$  = orthogonal moment components of a tee or branch connection as shown in Figure NB-3683.1(d)-1 where  $i = x, y, z$  and  $j = 1, 2, 3$ , in.-lb (N·mm)

$M_t$  = resultant moment loading applied during the specified operating cycle for straight-through products such as straight pipe, curved pipe or elbows, and concentric reducers, in.-lb (N·mm)

$$= \sqrt{M_1^2 + M_2^2 + M_3^2}$$

$P$  = Design Pressure, psi (MPa)

$P_o$  = range of service pressure, psi (MPa)

$P^*$  = maximum value of pressure in the load cycle under consideration, psi (MPa)

The moment components  $M_{x1}, M_{x2}, M_{y1}, M_{y2}, M_{z1}$ , and  $M_{z2}$  for the run are calculated at the intersection of the run and branch center lines. The moment components  $M_{x3}, M_{y3}$ , and  $M_{z3}$  for a branch connection where  $d_o/D_o \leq 0.5$  may be calculated for a point on the branch center line at a distance  $D_o/2$  from the intersection of the run and branch center lines. Otherwise,  $M_{x3}, M_{y3}$ , and  $M_{z3}$  are calculated at the intersection of the run and branch center lines.

$M_b$  = resultant moment on the branch for branch connections or tees, in.-lb (N·mm)

$$= \sqrt{M_{x3}^2 + M_{y3}^2 + M_{z3}^2}$$

$M_b^*$  = same as  $M_b$ , except it includes only moments due to thermal expansion and thermal anchor movements, in.-lb (N·mm)

$M_r$  = resultant moment on the run for branch connections or tees, in.-lb (N·mm)

$$= M_{xr}^2 + M_{yr}^2 + M_{zr}^2$$

$M_r^*$  = same as  $M_r$  except it includes only moments due to thermal expansion and thermal anchor movements, in.-lb (N·mm)

$M_{xr}, M_{yr}, M_{zr}$  = run moment components for use with the stress indices of NB-3683.8 and NB-3683.9, in.-lb (N·mm). Their numerical values are calculated as follows. If  $M_{i1}$  and  $M_{i2}$  (where  $i = x, y, z$ ) have the same algebraic sign (+/-), then  $M_{ir}$  equals zero. If  $M_{i1}$  and  $M_{i2}$  have opposite algebraic signs, then  $M_{ir}$  equals the smaller of  $M_{i1}$  or  $M_{i2}$ . If  $M_{i1}$  and  $M_{i2}$  are unsigned, then  $M_{ir}$  may be taken as the smaller of  $M_{i1}$  or  $M_{i2}$ . Combination of signed and unsigned moments from different load sources shall be done after determination of  $M_{ir}$ .

For branch connections or tees, the pressure term of eqs. NB-3652(9), NB-3653.1(a)(10), NB-3653.2(a)(11), and NB-3653.6(b)(13) shall be replaced by the following terms:

For eq. NB-3652(9):  $B_1 (PD_o / 2T_r)$

For eqs. NB-3653.1(a)(10) and NB-3653.6(b)(13):  $C_1 (P_o D_o / 2T_r)$

For eq. NB-3653.2(a)(11):  $K_1 C_1 (P_o D_o / 2T_r)$

For branch connections or tees, the moment term of eqs. NB-3652(9) through NB-3653.6(b)(13) shall be replaced by the following pairs of terms:

For eq. NB-3652(9):  $B_{2b} (M_b / Z_b) + B_{2r} (M_r / Z_r)$

For eqs. NB-3653.1(a)(10) and NB-3653.6(b)(13):  $C_{2b} (M_b / Z_b) + C_{2r} (M_r / Z_r)$

For eq. NB-3653.2(a)(11):  $C_{2b} K_{2b} (M_b / Z_b) + C_{2r} K_{2r} (M_r / Z_r)$


For eq. NB-3653.6(a)(12):  $C_{2b} (M_b^* / Z_b) + C_{2r} (M_r^* / Z_r)$

where the approximate section moduli are:

$$Z_b = \pi (r'_m)^2 T'_b$$

$$Z_r = \pi (R_m)^2 T_r$$

Figure NB-3683.1(d)-1



**NB-3683.2 Applicability of Indices—General.** The  $B$ ,  $C$ , and  $K$  stress indices given herein and in Table NB-3681(a)-1 predict stresses at a weld joint or within the body of a particular product. The stress indices given for ASME B16.9 and MSS SP-87 piping products apply only to seamless products with no connections, attachments, or other extraneous stress raisers on the body thereof. The stress indices for welds are not applicable if the radial weld shrinkage  $\Delta$  is greater than  $0.25t$ .

For products with longitudinal butt welds, the  $K_1$ ,  $K_2$ , and  $K_3$  indices shown shall be multiplied by 1.1 for flush welds or by 1.3 for as-welded welds. At the intersection

of a longitudinal butt weld in straight pipe with a girth butt weld or girth fillet weld, the  $C_1$ ,  $K_1$ ,  $C_2$ ,  $K_2$ , and  $K_3$  indices shall be taken as the product of the respective indices.

(a) *Abutting Products*. In general and unless otherwise specified, it is not required to take the product of stress indices for two piping products, such as a tee and a reducer when welded together, or a tee and a girth butt weld. The piping product and the weld shall be qualified separately.

For curved pipe or butt welding elbows welded together or joined by a piece of straight pipe less than one pipe diameter long, the stress indices shall be taken as the product of the indices for the elbow or curved pipe and the indices for the girth butt weld, except for  $B_1$  and  $C'_3$  which are exempted.

(b) *Out-of-Round Products*. The stress indices given in Table NB-3681(a)-1 are applicable for products and welds with out-of-roundness not greater than  $0.08t$  where out-of-roundness is defined as  $D_{\max} - D_{\min}$ . For straight pipe, curved pipe, longitudinal butt welds in straight pipe, girth butt welds, NB-4250 transitions, and 1:3 transitions not meeting this requirement, the stress indices shall be modified as specified below.

(1) If the cross section is out-of-round but with no discontinuity in radius, e.g., an elliptical cross section, an acceptable value of  $K_1$  may be obtained by multiplying the tabulated values of  $K_1$  by the factor  $F_{1a}$ :

$$F_{1a} = 1 + \frac{D_{\max} - D_{\min}}{t} \left[ \frac{1.5}{1 + 0.455(D_o/t)^3(p/E)} \right]$$

where

$D_o$  = nominal outside diameter, in. (mm)

$E$  = modulus of elasticity of material at room temperature, psi (MPa)

$p$  = internal pressure (use maximum value of pressure in the load cycle under consideration), psi (MPa)

Other symbols are defined in (b) above.

(2) If there are discontinuities in radius, e.g., a flat spot, and if  $D_{\max} - D_{\min}$  is not greater than  $0.08D_o$ , an acceptable value of  $K_1$  may be obtained by multiplying the tabulated values of  $K_1$  by the factor  $F_{1b}$ :

$$F_{1b} = 1 + MS_y / (PD_o / 2t)$$

where

$M$  = 2, for ferritic steels and nonferrous materials except nickel-chromium-iron alloys and nickel-iron-chromium alloys

= 2.7, for austenitic steel, nickel-chromium-iron alloys, and nickel-iron-chromium alloys

$P$  = Design Pressure, psi (MPa)

$S_y$  = yield strength at Design Temperature (Section II, Part D, Subpart 1, Table Y-1), psi (MPa)

$D_o$  and  $t$  are defined in (a) and (b) above.

(c) *Products and Joints With  $50 < D_o/t \leq 100$* . The  $B_1$  index in Table NB-3681(a)-1 is valid. The  $B_2$  index shall be multiplied by the factor  $1/(XY)$

where

$X = 1.3 - 0.006(D_o/t)$ , not to exceed 1.0

$Y = 1.033 - 0.00033T$  for Ferritic Material, not to exceed 1.0

$T$  = Design Temperature, °F

$Y = 1.0224 - 0.000594T$  for Ferritic Material, not to exceed 1.0

$T$  = Design Temperature, °C

$Y = 1.0$  for other materials

**NB-3683.3 Straight Pipe Remote From Welds.** The stress indices given in Table NB-3681(a)-1 apply for straight pipe remote from welds or other discontinuities, except as modified by NB-3683.2.

#### NB-3683.4 Welds.

(13)

(a) *Longitudinal Butt Welds*. The stress indices given in Table NB-3681(a)-1 are applicable for longitudinal butt welds in straight pipe, except as modified in NB-3683.2.

(b) *Girth Butt Welds*. The stress indices given in Table NB-3681(a)-1, except as modified herein and in NB-3683.2, are applicable to girth butt welds connecting abutting products for which the wall thickness is between  $0.875t$  and  $1.1t$  for an axial distance of  $\sqrt{D_o t}$  from the welding ends. Girth welds may also exhibit a reduction in diameter due to shrinkage of the weld material during cooling. The indices are not applicable if  $\Delta/t$  is greater than 0.25 where  $\Delta$  is the radial shrinkage measured from the nominal outside surface.

For as-welded girth butt welds joining items with nominal wall thicknesses  $t < 0.237$  in. ( $t < 6.0$  mm), the  $C_2$  index shall be taken as:

(U.S. Customary Units)

$$C_2 = 1.0 + 0.094/t \quad \text{but not} \quad > 2.1$$

(SI Units)

$$C_2 = 1.0 + 2.4/t \quad \text{but not} \quad > 2.1$$

for  $t \geq 0.237$  in. (6.0 mm),  $C_2 = 1.0$

(c) *Girth Fillet Welds*. The stress indices given in Table NB-3681(a)-1 are applicable to girth fillet welds used to attach socket welding fittings, socket welding valves, slip-on flanges, or socket welding flanges, except as added to or modified in NB-3683.1, and in (1) and (2) below.

(1) *Primary Stress Indices.* The  $B_1$  and  $B_2$  indices shall be taken as:

$$B_1 = 0.75(t_n / C_x) \geq 0.5$$

$$B_2 = 1.5(t_n / C_x) \geq 1.0$$

where  $C_x$  and  $t_n$  are defined in Figure NB-4427-1, sketches (c) and (d). In Figure NB-4427-1 sketch (c),  $C_x$  shall be taken as  $X_{\min}$  and  $C_x \geq 1.25t_n$ . In Figure NB-4427-1 sketch (d),  $C_x \geq 0.75t_n$ . For unequal leg lengths use the smaller leg length for  $C_x$ .

(2) *Primary Plus Secondary Stress Indices.* The  $C_1$  and  $C_2$  indices shall be taken as:

$$C_1 = 1.8(t_n / C_x) \geq 1.4$$

$$C_2 = 2.1(t_n / C_x) \geq 1.3$$

If  $C_x$  on the pipe side of the weld is greater than  $C_x$  on the fitting side, and if  $C_x$  on the fitting side is greater than or equal to either  $x_{\min}$  in Figure NB-4427-1 sketch (c) or  $C_x_{\min}$  in Figure NB-4427-1 sketch (d),  $C_x$  on the pipe side may be used in the equation for  $C_2$ .

**NB-3683.5 Welded Transitions.** The stress indices given in Table NB-3681(a)-1, except as modified herein and in NB-3683.2, are applicable for NB-4250 welded transitions as defined under (a) and for 1:3 welded transitions as defined under (b). Girth butt welds may also exhibit a reduction in diameter due to shrinkage of the weld material during cooling. The indices are not applicable if  $\Delta/t$  is greater than 0.25.

(a) *NB-4250 Transitions.* The stress indices given in Table NB-3681(a)-1, except as modified herein and in NB-3683.2, are applicable to girth butt welds between a product for which the wall thickness is between  $0.875t$  and  $1.1t$  for an axial distance of  $\sqrt{D_o t}$  from the welding end and an abutting product for which the welding end is within the envelope of Figure NB-4250-1, but with inside and outside surfaces that do not slope in the same direction. For transitions meeting these requirements, the  $C_1$ ,  $C_2$ , and  $C_3$  indices shall be taken as:

(U.S. Customary Units)

$$C_1 = 0.5 + 0.33(D_o / t)^{0.3} + 0.047 / t \quad \text{but not} \quad > 1.8$$

$$C_2 = 1.7 + 0.094 / t \quad \text{but not} \quad > 2.1$$

$$C_3 = 1.0 + 0.03(D_o / t) \quad \text{but not} \quad > 2.0$$

(SI Units)

$$C_1 = 0.5 + 0.33(D_o / t)^{0.3} + 1.2 / t \quad \text{but not} \quad > 1.8$$

$$C_2 = 1.7 + 2.4 / t \quad \text{but not} \quad > 2.1$$

$$C_3 = 1.0 + 0.03(D_o / t) \quad \text{but not} \quad > 2.0$$

For flush welds and for as-welded joints between items with  $t > 0.237$  in. ( $t > 6.0$  mm),  $C_1$  and  $C_2$  shall be taken as:

$$C_1 = 0.5 + 0.33(D_o / t)^{0.3} \quad \text{but not} \quad > 1.8$$

$$C_2 = 1.7$$

(b) *Transitions Within a 1:3 Slope.* The stress indices given in Table NB-3681(a)-1, except as modified herein and in NB-3683.2, are applicable for girth butt welds between a product for which the wall thickness is between  $0.875t$  and  $1.1t$  for an axial distance of  $\sqrt{D_o t}$  from the welding end and an abutting product for which the welding end is within an envelope defined by a 1:3 slope on the inside, outside, or both surfaces for an axial distance of  $\sqrt{D_o t}$  but with inside and outside surfaces that do not slope in the same direction. For transitions meeting these requirements, the  $C_1$ ,  $C_2$ , and  $C_3$  indices shall be taken as:

(U.S. Customary Units)

$$C_1 = 1.0 + 0.047 / t \quad \text{but not} \quad > 1.8$$

$$C_2 = t_{\max} / t + 0.094 / t \quad \text{but not} \quad > \text{the smaller of} \\ (1.33 + 0.04 \sqrt{D_o / t} + 0.094 / t) \text{ or } 2.1$$

$$C_3 = 0.35(t_{\max} / t) + 0.25 \quad \text{but not} \quad > 2.0$$

(SI Units)

$$C_1 = 1.0 + 1.2 / t \quad \text{but not} \quad > 1.8$$

$$C_2 = t_{\max} / t + 2.4 / t \quad \text{but not} \quad > \text{the smaller of} \\ (1.33 + 0.04 \sqrt{D_o / t} + 2.4 / t) \text{ or } 2.1$$

$$C_3 = 0.35(t_{\max} / t) + 0.25 \quad \text{but not} \quad > 2.0$$



where  $t_{\max}$  is the maximum wall thickness within the transition zone. If  $(t_{\max}/t) \leq 1.10$ , the stress indices given in NB-3683.4(b) for girth butt welds may be used. For flush welds and for as-welded joints between items with  $t > 0.237$  in. ( $t > 6.0$  mm),  $C_1$  and  $C_2$  shall be taken as:

$$C_1 = 1.0$$

$$C_2 = t_{\max}/t \quad \text{but not} > \text{the smaller of} \\ (1.33 + 0.04 \sqrt{D_o/t}) \text{ or } 2.1$$

- (13) **NB-3683.6 Concentric and Eccentric Reducers.** The stress indices given in Table NB-3681(a)-1, except as modified herein and in NB-3683.2, are applicable to butt welding reducers manufactured to the requirements of ASME B16.9 or MSS SP-87 if the cone angle  $\alpha$  defined in Figure NB-3683.6-1 is less than 60 deg and if the wall thickness is not less than  $t_{1m}$  throughout the body of the reducer, except in and immediately adjacent to the cylindrical portion on the small end where the thickness shall not be less than  $t_{2m}$ . The wall thicknesses  $t_{1m}$  and  $t_{2m}$  are the minimum thicknesses required to resist the Design Pressure  $P$  at the large end and small end, respectively, in accordance with eq. NB-3641.1(1). For eccentric reducers, the dimensions shown in Figure NB-3683.6-1 are to be taken at the location on the circumference where  $\alpha$  is the maximum.

(a) *Primary Stress Indices.* The  $B_1$  stress indices given in (1) or (2) below shall be used depending on the cone angle  $\alpha$ .

(1)  $B_1 = 0.5$  for  $\alpha \leq 30$  deg

(2)  $B_1 = 1.0$  for  $30 \text{ deg} < \alpha \leq 60$  deg

(b) *Primary Plus Secondary Stress Indices.* The  $C_1$  and  $C_2$  stress indices given in (1) or (2) below shall be used depending on the dimensions of the transition radii  $r_1$  and  $r_2$ .

(1) For reducers with  $r_1$  and  $r_2 \geq 0.1 D_1$ :

$$C_1 = 1.0 + 0.0058 \alpha \sqrt{D_n/t_n}$$

$$C_2 = 1.0 + 0.36 \alpha^{0.4} (D_n/t_n)^{0.4} (D_2/D_1 - 0.5)$$

where  $D_n/t_n$  is the larger of  $D_1/t_1$  and  $D_2/t_2$ .

(2) For reducers with  $r_1$  and/or  $r_2 < 0.1 D_1$ :

$$C_1 = 1.0 + 0.00465 \alpha^{1.285} (D_n/t_n)^{0.39}$$

$$C_2 = 1.0 + 0.0185 \alpha \sqrt{D_n/t_n}$$

where  $D_n/t_n$  is the larger of  $D_1/t_1$  and  $D_2/t_2$ .

(c) *Peak Stress Indices.* The  $K_1$  and  $K_2$  indices given in (1), (2), or (3) below shall be used depending on the type of connecting weld and thickness dimensions.

(1) For reducers connected to pipe with flush girth butt welds:

$$K_1 = 1.1 - 0.1 L_m / \sqrt{D_m t_m} \quad \text{but not} < 1.0$$

$$K_2 = 1.1 - 0.1 L_m / \sqrt{D_m t_m} \quad \text{but not} < 1.0$$

where  $L_m / \sqrt{D_m t_m}$  is the smaller of  $L_1 / \sqrt{D_1 t_1}$  and  $L_2 / \sqrt{D_2 t_2}$ .

(2) For reducers connected to pipe with as-welded girth butt welds where  $t_1$  and  $t_2 \geq 3/16$  in. (5 mm):

$$K_1 = 1.2 - 0.2 L_m / \sqrt{D_m t_m} \quad \text{but not} < 1.0$$

$$K_2 = 1.8 - 0.8 L_m / \sqrt{D_m t_m} \quad \text{but not} < 1.0$$

where  $L_m / \sqrt{D_m t_m}$  is the smaller of  $L_1 / \sqrt{D_1 t_1}$  and  $L_2 / \sqrt{D_2 t_2}$ .

(3) For reducers connected to pipe with as-welded girth butt welds where  $t_1$  or  $t_2 \leq 3/16$  in. (5 mm):

$$K_1 = 1.2 - 0.2 L_m / \sqrt{D_m t_m} \quad \text{but not} < 1.0$$

$$K_2 = 2.5 - 1.5 L_m / \sqrt{D_m t_m} \quad \text{but not} < 1.0$$

where  $L_m / \sqrt{D_m t_m}$  is the smaller of  $L_1 / \sqrt{D_1 t_1}$  and  $L_2 / \sqrt{D_2 t_2}$ .


(d) Alternative  $C_2$  and  $K_2$  stress indices may be used for reducers meeting the following requirements:

$$5 < (D_2/t_2) < 80$$

$$5 < \alpha < 60 \text{ deg}$$

$$0.08 < r_2/D_2 < 0.7$$

$$1 < t_1/t_2 < 2.12$$





(1) See below.

$$C_2 = 1 + 0.0056 (D_2/t_2)^{0.25} \alpha^{0.8} (r_2/D_2)^{-1} (t_1/t_2)^{-0.8}$$

(2) For reducers connected to pipe with flush girth butt welds

$$K_2 = 1.1 - 0.15L_2/(D_2t_2)^{0.5} \geq 1.0$$

(3) For reducers connected to pipe with as-welded girth butt welds where  $t_1$  and  $t_2 > 3/16$  in. (5 mm)

$$K_2 = 1.8 - 1.25L_2/(D_2t_2)^{0.5} \geq 1.0$$

(4) For reducers connected to pipe with as-welded girth butt welds where  $t_1$  or  $t_2 \leq 3/16$  in. (5 mm)

$$K_2 = 2.5 - 2.35L_2/(D_2t_2)^{0.5} \geq 1.0$$

- (13) **NB-3683.7 Curved Pipe or Butt Welding Elbows.** The stress indices given in [Table NB-3681\(a\)-1](#), except as modified herein and in [NB-3683.2](#), are applicable to curved pipe or butt welding elbows manufactured to the requirements of ASME B16.9 or MSS SP-87.

(a) *Primary Stress Index.* The  $B_1$  and  $B_2$  indices shall be taken as:

$$B_1 = -0.1 + 0.4h \quad \text{but not} \quad < 0 \quad \text{nor} \quad > 0.5$$

$$B_2 = 1.30/h^{2/3} \quad \text{but not} \quad < 1.0$$

where

$$h = tR/r_m^2$$

(b) *Primary Plus Secondary Stress Indices.* The  $C_1$  and  $C_2$  indices shall be taken as:

$$C_1 = (2R - r_m)/2(R - r_m)$$

$$C_2 = 1.95/h^{2/3} \quad \text{but not} \quad < 1.5$$

where

$$h = tR/r_m^2$$

**NB-3683.8 Branch Connections per NB-3643.** The stress indices given in [Table NB-3681\(a\)-1](#), except as modified herein and in [NB-3683.2](#), are applicable to reinforced or unreinforced branch connections meeting the general requirements of [NB-3643](#) and the additional requirements of (a). Symbols are defined in [NB-3683.1](#) and in [NB-3643.3](#).

(a) *Applicability.* The stress indices are applicable, provided the following limitations are met.

(1) The branch connection is in straight pipe.

(2) For branch connections in a pipe, the arc distance measured between the centers of adjacent branches along the outside surface of the run pipe is not less than three times the sum of the two adjacent branch inside radii in the longitudinal direction, or is not less than two times the sum of the two adjacent branch radii along the circumference of the run pipe.

(3) The axis of the branch connection is normal to the run pipe surface.

(4) The run pipe radius-to-thickness ratio  $R_m/T_r$  is less than 50, and the branch-to-run radius ratio  $r'_m/R_m$  is less than 0.50.

(5) If the branch-to-run fillet radius  $r_2$  is not less than the larger of  $T_b/2$ ,  $T_r/2$ , or  $(T'_b + y)/2$  [[Figure NB-3643.3\(a\)-1](#) sketch (c)], the  $K_{2b}$  index is reduced from 2.0 to 1.0.

(b) *Primary Stress Indices.* The primary stress indices  $B_{2b}$  and  $B_{2r}$  shall be taken as:

$$B_{2b} = 0.5C_{2b} \quad \text{but not} \quad < 1.0$$

$$B_{2r} = 0.86 \left( \frac{r'_m}{t_n} \right)^{1/4} \quad \text{but not} \quad < 1.0$$

(c) *Primary Plus Secondary Stress Indices.* The  $C_1$ ,  $C_{2b}$ , and  $C_{2r}$  indices [for moment loadings, see [NB-3683.1\(d\)](#)] shall be taken as:

$$C_1 = 1.4 \left( \frac{D_m}{T_r} \right)^{0.182} \left( \frac{d_m}{D_m} \right)^{0.367} \left( \frac{T_r}{t_n} \right)^{0.382} \left( \frac{t_n}{r_2} \right)^{0.148} \quad \text{but not} \quad < 1.2$$

If  $r_2/t_n > 12$ , use  $r_2/t_n = 12$  for computing  $C_1$ .

$$C_{2b} = 1.5 \left( \frac{R_m}{T_r} \right)^{2/3} \left( \frac{r'_m}{R_m} \right)^{1/2} \left( \frac{T'_b}{T_r} \right) \left( \frac{r'_m}{r_p} \right) \quad \text{but not} \quad < 1.5$$

$$C_{2r} = 1.15 \left( \frac{r'_m}{t_n} \right)^{1/4} \quad \text{but not} \quad < 1.5$$

where

For [Figures NB-3643.3\(a\)-1](#), sketches (a) and (b):

$$t_n = T_b \text{ if } L_1 \geq 0.5 (d_m T_b)^{1/2}$$

$$= T'_b \text{ if } L_1 < 0.5 (d_m T_b)^{1/2}$$

For Figure NB-3643.3(a)-1, sketch (c):

$$t_n = T'_b + (2/3)y \quad \text{if } \theta \leq 30 \text{ deg}$$

$$= T'_b + 0.385 L_1 \quad \text{if } \theta > 30 \text{ deg}$$

For Figure NB-3643.3(a)-1, sketch (d):

$$t_n = T'_b = T_b$$

(d) *Peak Stress Indices.* The peak stress indices  $K_{2b}$  and  $K_{2r}$  for moment loadings [see NB-3683.1(d)] shall be taken as:

$$K_{2b} = 2.0$$

$$K_{2r} = 1.75$$

and  $K_{2r}C_{2r}$  shall be a minimum of 2.65.

(e) For branch connections made with fillet or partial penetration welds per NB-3661.3, the stress indices given in Table NB-3681(a)-1 and in NB-3683.8 shall be increased as follows:

(1) The  $B_1$  and  $B_2$  indices shall be increased by a factor of 1.5.

(2)  $C_1$ ,  $C_{2b}$ , and  $C_{2r}$  shall be multiplied by 2.

(3)  $K_1$ ,  $K_{2b}$ , and  $K_3$  shall be multiplied by 3.

(4)  $K_{2r}$  shall be multiplied by 2.

(5)  $C_{2b} K_{2b}$  shall be a minimum of 6.0.

(6)  $C_{2r} K_{2r}$  shall be a minimum of 4.2.

In calculating the indices for fillet and partial penetration welded branch connections,  $r_2$  may be taken to be  $t_n$ , with the other dimensions consistent with Figure NB-3643.3(a)-1.

**NB-3683.9 Butt Welding Tees.** The stress indices given in Table NB-3681(a)-1, except as modified herein and in NB-3683.2, are applicable to butt welding tees manufactured to the requirements of ASME B16.9 or MSS SP-87.

(a) *Primary Stress Indices.* The primary stress indices  $B_{2b}$  and  $B_{2r}$  shall be taken as:

$$B_{2b} = 0.4 (R_m / T_r)^{2/3} \quad \text{but not} \quad < 1.0$$

$$B_{2r} = 0.50 (R_m / T_r)^{2/3} \quad \text{but not} \quad < 1.0$$

(b) *Primary Plus Secondary Stress Indices.* The  $C_{2b}$  and  $C_{2r}$  stress indices for moment loadings [see NB-3683.1(d)] shall be taken as:

$$C_{2b} = 0.67 (R_m / T_r)^{2/3} \quad \text{but not} \quad < 2.0$$

$$C_{2r} = 0.67 (R_m / T_r)^{2/3} \quad \text{but not} \quad < 2.0$$

(c) *Peak Stress Indices.* The peak stress indices  $K_{2b}$  and  $K_{2r}$  for moment loadings [see NB-3683.1(d)] shall be taken as:

$$K_{2b} = 1.0$$

$$K_{2r} = 1.0$$

## NB-3684 Stress Indices for Detailed Analysis

The symbols for the stress components and their definitions are given in Figure NB-3684-1. These definitions are applicable to all piping products, and the stress indices given in the tables in NB-3685 and NB-3338 are so defined.

## NB-3685 Curved Pipe or Welding Elbows

**NB-3685.1 Applicability of Indices.** The indices given in Tables NB-3685.1-1 and NB-3685.1-2 give stresses in curved pipe or elbows at points remote from girth or longitudinal welds or other local discontinuities. Stresses in curved pipe or welding elbows with local discontinuities, such as longitudinal welds, support lugs, and branch connections in the elbow, shall be obtained by appropriate theoretical analysis or by experimental analysis in accordance with Appendix II.


## NB-3685.2 Nomenclature (Figure NB-3685.2-1).

$A$  = an additional thickness, in. (mm) (NB-3641.1)

$D_i = D_o - 2(t_m - A)$ , in. (mm)

$D_o$  = nominal outside diameter of cross section, in. (mm)

**Figure NB-3684-1**  
**Direction of Stress Components**



$\sigma_t$  = stress component in the plane of the section under consideration and parallel to the boundary of the section  
 $\sigma_n$  = stress component normal to the plane of the section  
 $\sigma_r$  = stress component normal to the boundary of the section  
 $\sigma$  = stress intensity (combined stress) at the point under consideration

**Table NB-3685.1-1**  
**Curved Pipe or Welding End Elbows, Internal Pressure**

Location	Surface	Stress Direction	Stress Index <a href="#">[Note (1)]</a>
Round Cross Section			
$\phi$	Inside	$\sigma_n$	$\left[ \frac{D_o - 0.8(t_m - A)}{2(t_m - A)} \right] \left[ \frac{0.5(2R + r \sin \phi)}{R + r \sin \phi} \right] = i_1$
$\phi$	Mid	$\sigma_n$	
$\phi$	Outside	$\sigma_n$	
$\phi$	Inside	$\sigma_t$	$\frac{D_i}{4(t_m - A)} = i_2$
$\phi$	Mid	$\sigma_t$	
$\phi$	Outside	$\sigma_t$	
Out-of-Round Cross Section <a href="#">[Note (2)]</a>			
$\alpha$	Inside	$\sigma_n$	$i_1 + i_3$
$\alpha$	Mid	$\sigma_n$	$i_1$
$\alpha$	Outside	$\sigma_n$	$i_1 - i_3$
$\alpha$	Inside	$\sigma_t$	$i_2 + 0.3i_3$
$\alpha$	Mid	$\sigma_t$	$i_2$
$\alpha$	Outside	$\sigma_t$	$i_2 - 0.3i_3$

## NOTES:

(1) The radial stress  $\sigma_r$  is equal to  $-P$  on the inside surface, to  $-P/2$  on the midsurface, and to 0 on the outside surface.

(2) For out-of-round cross section:

$$i_3 = \left[ \frac{D_o(D_1 - D_2)}{2t_m^2} \right] \left[ \frac{1.5}{1 + 0.455(D_o/t_m)^3 (P/E)} \right] \cos 2\alpha$$

$D_1(D_2)$  = maximum (minimum) outside diameter of elbow with out-of-round cross section essentially describable as an ellipse or oval shape (Figure NB-3685.2-1), in. (mm)

$E$  = modulus of elasticity, psi (MPa) (Section II, Part D, Subpart 2, Tables TM)

$P$  = internal pressure, psi (MPa)

$R$  = bend radius

$r$  = mean cross section radius

$t_m$  = minimum specified wall thickness

$Z$  = section modulus of cross section

$$= 0.0982 (D_o^4 - D_i^4) / D_o$$

$\lambda = t_m R / \left( r^2 \sqrt{1 - v^2} \right)$  (Table NB-3685.1-2 limited to  $\lambda \geq 0.2$ )

**NB-3685.3 Stress From Stress Indices.** To obtain stresses from stress index:

Load	Multiply Stress Index by
Internal Pressure	$P$
$M_x$	$M_x / 2Z$
$M_y$	$M_y / Z$
$M_z$	$M_z / Z$

**NB-3685.4 Classification of Stresses.** For analysis of a curved pipe or welding elbow to NB-3210, the following rules shall apply to the classification of stresses developed under a load controlled in-plane or out-of-plane moment as distinguished from a displacement controlled loading.

(a) The entire membrane portion of the axial, circumferential, and torsional stresses shall be considered as primary ( $P_L$ ).

(b) Seventy-five percent of the through-wall bending stresses in both the axial and the circumferential directions shall be classified as primary ( $P_b$ ). The remaining 25% shall be classified as secondary ( $Q$ ). The stresses induced by displacement controlled in-plane or out-of-plane moments shall be classified as secondary ( $Q$ ).

**NB-3686 Flexibility Factors [see NB-3682(c) for Definition]**

**NB-3686.1 Straight Pipe.** For  $M = M_1$  or  $M_2$  (see Figure NB-3686.1-1):

$$k = 1.0$$

$$\theta_{\text{nom}} = \frac{Ml}{EI}$$

**Table NB-3685.1-2**  
**Curved Pipe or Welding End Elbows, Moment Loading ( $\lambda \geq 0.2$ )**

Location	Surface	Stress Direction	Stress Index [Note (1)]
<b>Torsional Moment <math>M_x</math></b>			
All	All	$\tau_{nt}$ [Note (2)]	1.0
<b>In-Plane or Out-of-Plane Moments <math>M_y</math> or <math>M_z</math> [Note (3)]</b>			
All	All	$\tau_{nt}$ [Note (2)]	1.0
$\phi$	Outside	$\sigma_n$	$v \sigma_{tm} + \sigma_{nb}$
$\phi$	Mid	$\sigma_n$	$v \sigma_{tm}$
$\phi$	Inside	$\sigma_n$	$v \sigma_{tm} - \sigma_{nb}$
$\phi$	Outside	$\sigma_t$	$\sigma_{tm} + v \sigma_{nb}$
$\phi$	Mid	$\sigma_t$	$\sigma_{tm}$
$\phi$	Inside	$\sigma_t$	$\sigma_{tm} - v \sigma_{nb}$

## NOTES:

(1) The radial stress  $\sigma_r$  is zero for all surfaces.(2)  $\tau_{nt}$  is a shear stress in the  $n-t$  plane and must be appropriately combined with the principal stresses  $\sigma_n$  and  $\sigma_t$  to obtain principal stresses due to combinations of  $M_x$  with  $M_y$  or  $M_z$ .

(3) Nomenclature for stress indices:

 $v$  = Poisson's ratio $\sigma_{tm} = \sin \phi + [(1.5X_2 - 18.75) \sin 3\phi + 11.25 \sin 5\phi]/X_4$  — In-plane  $M_z$  $\sigma_{nb} = \lambda (9X_2 \cos 2\phi + 225 \cos 4\phi)/X_4$  — In-plane  $M_z$  $\sigma_{tm} = \cos \phi + [(1.5X_2 - 18.75) \cos 3\phi + 11.25 \cos 5\phi]/X_4$  — Out-of-plane  $M_y$  $\sigma_{nb} = -\lambda (9X_2 \sin 2\phi + 225 \sin 4\phi)/X_4$  — Out-of-plane  $M_y$  $X_1 = 5 + 6\lambda^2 + 24\psi$  $X_2 = 17 + 600\lambda^2 + 480\psi$  $X_3 = X_1 X_2 - 6.25$  $X_4 = (1 - v^2)(X_3 - 4.5X_2)$  $\lambda = t_m R / \left( r^2 \sqrt{1 - v^2} \right)$  (Equations are valid for  $\lambda \geq 0.2$  only.) $\psi = PR^2 / Ert_m$ For  $M = M_3$  (see Figure NB-3686.1-1):

$$k = 1.0$$

$$\theta_{\text{nom}} = \frac{Ml}{GJ}$$

For  $M_1$  or  $M_2$  (see Figure NB-3686.2-1):

$$k = \frac{1.65}{h} \left[ \frac{1}{1 + (Pr/tE)X_k} \right]$$

but not less than 1.0, and

where

 $E$  = modulus of elasticity, psi (MPa) $G$  = shear modulus, psi (MPa) $I$  = plane moment of inertia, in.<sup>4</sup> (mm<sup>4</sup>) $J$  = polar moment of inertia, in.<sup>4</sup> (mm<sup>4</sup>) $l$  = one pipe diameter, in. (mm)

$$\theta_{\text{nom}} = \frac{R}{EI} \int_0^A M(d\alpha)$$

For  $M_3$  (see Figure NB-3686.2-1):


$$k = 1.0$$

$$\theta_{\text{nom}} = \frac{R}{GJ} \int_0^A M(d\alpha)$$


**NB-3686.2 Curved Pipe and Welding Elbows.** The flexibility factors may be calculated by the equations given below for  $k$ , provided<sup>27</sup> that:

(a)  $R/r$  is not less than 1.7;(b) center line length  $R\alpha$  is greater than  $2r$ ;(c) there are no flanges or other similar stiffeners within a distance  $r$  from either end of the curved section of pipe or from the ends of welding elbows.

**Figure NB-3685.2-1  
Elbow Nomenclature**



**Figure NB-3686.1-1**



In both cases

$A$  = total angle of curved pipe or welding elbow, rad  
 $E$  = modulus of elasticity, psi (MPa)  
 $G$  = shear modulus of elasticity, psi (MPa)  
 $h = tR/r^2$   
 $I$  = plane moment of inertia of cross section, in.<sup>4</sup> (mm<sup>4</sup>)  
 $J$  = polar moment of inertia of cross section, in.<sup>4</sup> (mm<sup>4</sup>)  
 $P$  = internal pressure, psi (MPa)  
 $R$  = bend radius, in. (mm)  
 $r$  = pipe or elbow mean radius, in. (mm)  
 $t$  = pipe or elbow nominal wall thickness, in. (mm)  
 $X_k = 6(r/t)^{4/3} (R/r)^{1/3}$   
 $\alpha$  = arc angle, rad

**NB-3686.3 Miter Bends.** The requirements of NB-3681(d) apply.


**NB-3686.4 Welding Tee or Branch Connections.** For welding tees (ASME B16.9) or branch connections (NB-3643) not included in NB-3686.5, the load displacement relationships shall be obtained by assuming that the run pipe and branch pipe extend to the intersection of the run pipe center line with the branch pipe center line. The imaginary juncture is to be assumed rigid, and the imaginary length of branch pipe from the juncture to the run pipe surface is also to be assumed rigid.

**NB-3686.5 Branch Connections in Straight Pipe.** (For branch connections in straight pipe meeting the dimensional limitations of NB-3683.8.) The load displacement relationships may be obtained by modeling the branch connections in the piping system analysis (NB-3672) as shown in (a) through (d) below. (see Figure NB-3686.5-1.)


(a) The values of  $k$  are given below.

For  $M_{x3}$ :

$$k = 0.1 (D/T_r)^{1.5} [(T_r/t_n)(d/D)]^{1/2} (T'_b/T_r)$$



**Figure NB-3686.5-1  
Branch Connections in Straight Pipe**



For  $M_{z3}$ :

$$k = 0.2 (D/T_r) [(T_r/t_n)(d/D)]^{1/2} (T'_b/T_r)$$

where

$D$  = run pipe outside diameter, in. (mm)  
 $d$  = branch pipe outside diameter, in. (mm)  
 $E$  = modulus of elasticity, psi (MPa)  
 $I_b$  = moment of inertia of branch pipe, in.<sup>4</sup> (mm<sup>4</sup>) (to be calculated using  $d$  and  $T'_b$ )  
 $M = M_{x3}$  or  $M_{z3}$ , as defined in NB-3683.1(d)  
 $T_r$  = run pipe wall thickness, in. (mm)  
 $\phi$  = rotation in direction of moment, rad

(b) For branch connections per Figure NB-3643.3(a)-1, sketches (a) and (b):

$$\begin{aligned}
 t_n &= T_b \quad \text{if } L_1 \geq 0.5 [(2r_i + T_b)T_b]^{1/2} \\
 &= T'_b \quad \text{if } L_1 < 0.5 [(2r_i + T_b)T_b]^{1/2}
 \end{aligned}$$

(c) For branch connections per Figure NB-3643.3(a)-1, sketch (c):

$$\begin{aligned}
 t_n &= T'_b + \left(\frac{2}{3}\right)y \quad \text{if } \theta_n \leq 30 \text{ deg} \\
 &= T'_b + 0.385L_1 \quad \text{if } \theta_n > 30 \text{ deg}
 \end{aligned}$$

(d) For branch connections per Figure NB-3643.3(a)-1, sketch (d):

$$t_n = T'_b = T_b$$



**(13) NB-3686.6 Reducers.**

(a) The reducer flexibility can be accurately represented by modeling a section of large-end diameter pipe rigidly connected to a section of small-end diameter pipe at the midpoint of the reducer as per [Figure NB-3686.6-1](#).

(b) Where the ratio  $D_2/t_2 > 55$ , additional flexibility should be considered. If the geometry requirements of [NB-3683.6\(d\)](#) are met, the reducer flexibility may be adjusted by applying the flexibility factor,  $k$ , below:

$$k = 0.2(D_2/t_2)^{0.24} \alpha^{0.4} (t_1/t_2)^{-0.66}$$

**NB-3690 DIMENSIONAL REQUIREMENTS FOR PIPING PRODUCTS****NB-3691 Standard Piping Products**

Dimensions of standard piping products shall comply with the standards and specifications listed in Table NCA-7100-1. However, compliance with these standards does not replace or eliminate the requirements of [NB-3625](#).


**NB-3692 Nonstandard Piping Products**

The dimensions of nonstandard piping products shall be such as to provide strength and performance as required by this Subsection. Nonstandard piping products shall be designed in accordance with [NB-3640](#).

www.iran-mavad.com

**(13)**

**Figure NB-3686.6-1  
Reducers**



## ARTICLE NB-4000 FABRICATION AND INSTALLATION

### NB-4100 GENERAL REQUIREMENTS

#### NB-4110 INTRODUCTION

Components, parts, and appurtenances shall be fabricated and installed in accordance with the requirements of this Article and shall be manufactured from materials which meet the requirements of [NB-2000](#).

#### NB-4120 CERTIFICATION OF MATERIALS AND FABRICATION BY CERTIFICATE HOLDER

##### NB-4121 Means of Certification

The Certificate Holder for an item shall certify, by application of the appropriate Certification Mark and completion of the appropriate Data Report in accordance with NCA-8000, that the materials used comply with the requirements of [NB-2000](#) and that the fabrication or installation complies with the requirements of this Article.

**NB-4121.1 Certification of Treatments, Tests, and Examinations.** If the Certificate Holder or Subcontractor performs treatments, tests, repairs, or examinations required by other Articles of this Subsection, the Certificate Holder shall certify that this requirement has been fulfilled (NCA-3862). Reports of all required treatments and of the results of all required tests, repairs, and examinations performed shall be available to the Inspector.

**NB-4121.2 Repetition of Tensile or Impact Tests.** If during the fabrication or installation of the item the material is subjected to heat treatment that has not been covered by treatment of the test coupons ([NB-2200](#)) and that may reduce either tensile or impact properties below the required values, the tensile and impact tests shall be repeated by the Certificate Holder on test specimens taken from test coupons which have been taken and treated in accordance with the requirements of [NB-2000](#).

**NB-4121.3 Repetition of Surface Examination After Machining.** If, during the fabrication or installation of an item, materials for pressure-containing parts are machined, then the Certificate Holder shall reexamine the surface of the material in accordance with [NB-2500](#) when:

(a) the surface was required to be examined by the magnetic particle or liquid penetrant method in accordance with [NB-2500](#); and

(b) the amount of material removed from the surface exceeds the lesser of  $\frac{1}{8}$  in. (3 mm) or 10% of the minimum required thickness of the part.

#### NB-4122 Material Identification

(a) Material for pressure-retaining parts shall carry identification markings which will remain distinguishable until the component is assembled or installed. If the original identification markings are cut off or the material is divided, the marks shall either be transferred to the parts cut or a coded marking shall be used to ensure identification of each piece of material during subsequent fabrication or installation. In either case, an as-built sketch or a tabulation of materials shall be made identifying each piece of material with the Certified Material Test Report, where applicable, and the coded marking. For studs, bolts, nuts, and heat exchanger tubes it is permissible to identify the Certified Material Test Reports for material in each component in lieu of identifying each piece of material with the Certified Material Test Report and the coded marking. Material supplied with a Certificate of Compliance, and welding and brazing material, shall be identified and controlled so that they can be traced to each component or installation of a piping system, or else a control procedure shall be employed which ensures that the specified materials are used.

(b) Material from which the identification marking is lost shall be treated as non-conforming material until appropriate tests or other verifications are made and documented to assure material identification. Testing is required unless positive identification can be made by other documented evidence. The material may then be re-marked upon establishing positive identification.

**NB-4122.1 Marking Material.** Material shall be marked in accordance with [NB-2150](#).

#### NB-4123 Examinations

Visual examination activities that are not referenced for examination by other specific Code paragraphs, and are performed solely to verify compliance with requirements of [NB-4000](#), may be performed by the persons who perform or supervise the work. These visual examinations are not required to be performed by personnel and procedures qualified to [NB-5500](#) and [NB-5100](#), respectively, unless so specified.

#### NB-4125 Testing of Welding and Brazing Material

All welding and brazing material shall meet the requirements of [NB-2400](#).

**NB-4130 REPAIR OF MATERIAL****NB-4131 Elimination and Repair of Defects**

Material originally accepted on delivery in which defects exceeding the limits of **NB-2500** are known or discovered during the process of fabrication or installation is unacceptable. The material may be used provided the condition is corrected in accordance with the requirements of **NB-2500** for the applicable product form, except:

(a) the limitation on the depth of the weld repair does not apply;

(b) the time of examination of the weld repairs to weld edge preparations shall be in accordance with **NB-5130**;

(c) radiographic examination is not required for weld repairs to seal membrane material when the material thickness is  $\frac{1}{4}$  in. (6 mm) or less.

**NB-4132 Documentation of Repair Welds of Base Material**

The Certificate Holder who makes a repair weld exceeding in depth the lesser of  $\frac{3}{8}$  in. (10 mm) or 10% of the section thickness, shall prepare a report which shall include a chart which shows the location and size of the prepared cavity, the welding material identification, the welding procedure, the heat treatment, and the examination results of repair welds.

**NB-4200 FORMING, FITTING, AND ALIGNING****NB-4210 CUTTING, FORMING, AND BENDING****NB-4211 Cutting**

Materials may be cut to shape and size by mechanical means, such as machining, shearing, chipping, or grinding, or by thermal cutting.

**NB-4211.1 Preheating Before Thermal Cutting.** When thermal cutting is performed to prepare weld joints or edges, to remove attachments or defective material, or for any other purpose, consideration shall be given to preheating the material, using preheat schedules such as suggested in Appendix D.

**NB-4212 Forming and Bending Processes**

Any process may be used to hot or cold form or bend pressure-retaining material (**NB-4223**), including weld metal, provided the required dimensions are attained (see **NB-4214** and **NB-4220**), and provided the impact properties of the material, when required, are not reduced below the minimum specified values, or they are effectively restored by heat treatment following the forming operation. *Hot forming* is defined as forming with the material temperature higher than 100°F (56°C) below the lower transformation temperature of the material. When required, the process shall be qualified for impact properties as outlined in **NB-4213**. When required, the process shall be qualified to meet thickness requirements as outlined in **NB-4223.1**.

**NB-4213 Qualification of Forming Processes for Impact Property Requirements**

A procedure qualification test shall be conducted using specimens taken from material of the same specification, grade or class, heat treatment, and with similar impact properties, as required for the material in the component. These specimens shall be subjected to the equivalent forming or bending process and heat treatment as the material in the component. Applicable tests shall be conducted to determine that the required impact properties of **NB-2300** are met after straining.

**NB-4213.1 Exemptions.** Procedure qualification tests are not required for materials listed in (a) through (f) below:

(a) hot formed material, such as forgings, in which the hot forming is completed by the Material Organization prior to removal of the impact test specimens;

(b) hot formed material represented by test coupons which have been subjected to heat treatment representing the hot forming procedure and the heat treatments to be applied to the parts;

(c) material which does not require impact tests in accordance with **NB-2300**;

(d) material which has a final strain less than 0.5%;

(e) material where the final strain is less than that of a previously qualified procedure for that material;

(f) material from which the impact testing is required by **NB-2300** is performed on each heat and lot, as applicable, after forming.

**NB-4213.2 Procedure Qualification Test.** The procedure qualification test shall be performed in the manner stipulated in (a) through (f) below.

(a) The tests shall be performed on three different heats of material both before straining and after straining and heat treatment to establish the effects of the forming and subsequent heat treatment operations.

(b) Specimens shall be taken in accordance with the requirements of **NB-2000** and shall be taken from the tension side of the strained material.

(c) The percent strain shall be established by the following equations.

For cylinders:

$$\% \text{ strain} = \frac{50t}{R_f} \left( 1 - \frac{R_f}{R_o} \right)$$

For spherical or dished surfaces:

$$\% \text{ strain} = \frac{75t}{R_f} \left( 1 - \frac{R_f}{R_o} \right)$$

For pipe:

$$\% \text{ strain} = \frac{100r}{R}$$

where

$R$  = nominal bending radius to the center line of the pipe  
 $R_f$  = final radius to center line of shell  
 $R_o$  = original radius (equal to infinity for a flat part)  
 $r$  = nominal radius of the pipe  
 $t$  = nominal thickness

(d) The procedure qualification shall simulate the maximum percent surface strain, employing a bending process similar to that used in the fabrication of the material or by direct tension on the specimen.

(e) Sufficient  $C_v$  test specimens shall be taken from each of the three heats of material to establish a transition curve showing both the upper and lower shelves. On each of the three heats, tests consisting of three impact specimens shall be conducted at a minimum of five different temperatures distributed throughout the transition region. The upper and lower shelves may be established by the use of one test specimen for each shelf. Depending on the product form, it may be necessary to plot the transition curves using both lateral expansion and energy level data (NB-2300). In addition, drop weight tests shall be made when required by NB-2300.

(f) Using the results of the impact test data from each of three heats, taken both before and after straining, determine either:

(1) the maximum change in  $NDT$  temperature along with:

(-a) the maximum change of lateral expansion and energy at the temperature under consideration; or

(-b) the maximum change of temperature at the lateral expansion and energy levels under consideration; or

(2) when lateral expansion is the acceptance criterion (NB-2300), either the maximum change in temperature or the maximum change in lateral expansion.

#### NB-4213.3 Acceptance Criteria for Formed Material.

To be acceptable, the formed material used in the component shall have impact properties before forming sufficient to compensate for the maximum loss of impact properties due to the qualified forming processes used.

**NB-4213.4 Requalification.** A new procedure qualification test is required when any of the changes in (a), (b), or (c) below are made.

(a) The actual postweld heat treatment time at temperature is greater than previously qualified considering NB-2211. If the material is not postweld heat treated, the procedure must be qualified without postweld heat treatment.

(b) The maximum calculated strain of the material exceeds the previously qualified strain by more than 0.5%.

(c) Preheat over 250°F (120°C) is used in the forming or bending operation but not followed by a subsequent postweld heat treatment.

#### NB-4214 Minimum Thickness of Fabricated Material

If any fabrication operation reduces the thickness below the minimum required to satisfy the rules of NB-3000, the material may be repaired in accordance with NB-4130.

#### NB-4220 FORMING TOLERANCES

##### NB-4221 Tolerance for Vessel Shells


Cylindrical, conical, or spherical shells of a completed vessel, except formed heads covered by NB-4222, shall meet the requirements of the following subparagraphs at all cross sections.

**NB-4221.1 Maximum Difference in Cross-Sectional Diameters.** The difference in in. (mm) between the maximum and minimum diameters at any cross section shall not exceed the smaller of  $(D + 50)/200$  [ $(D + 1\ 250)/200$ ] and  $D/100$ , where  $D$  is the nominal inside diameter, in. (mm), at the cross section under consideration. The diameters may be measured on the inside or outside of the vessel. If measured on the outside, the diameters shall be corrected for the plate thickness at the cross section under consideration (Figure NB-4221.1-1). When the cross section passes through an opening, the permissible difference in inside diameters given herein may be increased by 2% of the inside diameter of the opening.

**NB-4221.2 Maximum Deviation From True Theoretical Form for External Pressure.** Vessels designed for external pressure shall meet the tolerances given in (a) through (c) below.

(a) The maximum plus or minus deviation from the true circular form of cylinders or the theoretical form of other shapes, measured radially on the outside or inside of the component, shall not exceed the maximum permissible deviation obtained from Figure NB-4221.2(a)-1. Measurements shall be made from a segmental circular template having the design inside or outside radius depending on where the measurements are taken and a chord length equal to twice the arc length obtained from Figure NB-4221.2(a)-2. For Figure NB-4221.2(a)-1, the maximum permissible deviation  $e$  need not be less than

**Figure NB-4221.1-1**  
**Maximum Difference in Cross-Sectional**  
**Diameters**



0.3t. For Figure NB-4221.2(a)-2, the arc length need not be greater than  $0.30D_o$ . Measurements shall not be taken on welds or other raised parts.

(b) The value of  $t$ , in. (mm), at any cross section is the nominal plate thickness less corrosion allowance for sections of constant thickness and the nominal thickness of the thinnest plate less corrosion allowance for sections having plates of more than one thickness.

(c) The value of  $L$  in Figures NB-4221.2(a)-1 and NB-4221.2(a)-2 is determined by (1) through (3) below.

(1) For cylinders,  $L$  is as given in NB-3133.2.

(2) For cones,  $L$  is the axial length of the conical section if no stiffener rings are used or, if stiffener rings are used, the axial length from the head bend line at the large end of the cone to the first stiffener ring, with  $D_o$  taken as the outside diameter in inches of the cylinder at the large end of the cone.

(3) For spheres,  $L$  is one-half of the outside diameter  $D_o$ , in.

**NB-4221.3 Deviations From Tolerances.** Deviations from the tolerance requirements stipulated in NB-4221.1 and NB-4221.2 are permitted, provided the drawings are modified and reconciled with the Design Report

(NCA-3551) and provided the modifications are certified by a registered Professional Engineer in an addendum to the Design Report.


**NB-4221.4 Tolerance Deviations for Vessel Parts Fabricated From Pipe.** Vessel parts subjected to either internal or external pressure and fabricated from pipe, meeting all other requirements of this Subsection, may have variations of diameter and deviations from circularity permitted by the specification for such pipe.

## NB-4222 Tolerances for Formed Vessel Heads


The tolerance for formed vessel heads shall be as set forth in the following subparagraphs.

**NB-4222.1 Maximum Difference in Cross-Sectional Diameters.** The skirt or cylindrical end of a formed head shall be circular to the extent that the difference in inches between the maximum and minimum diameters does not exceed the lesser of  $(D + 50)/200$  [ $(D + 1\ 250)/200$ ] and  $(D + 12)/100$  [ $(D + 300)/100$ ], where  $D$  is the nominal inside diameter, in. (mm), and shall match the cylindrical edge of the adjoining part within the alignment tolerance specified in NB-4232.

**Figure NB-4221.2(a)-1**  
**Maximum Permissible Deviation From a True Circular Form**



**Figure NB-4221.2(a)-2**  
**Maximum Arc Length for Determining Plus or Minus Deviation**



#### **NB-4222.2 Deviation From Specified Shape.**

(a) The inner surface of a torispherical or ellipsoidal head shall not deviate outside the specified shape by more than  $1\frac{1}{4}\%$  of  $D$ , inside the specified shape by more than  $\frac{5}{8}\%$  of  $D$ , where  $D$  is the nominal inside diameter of the vessel. Such deviations shall be measured perpendicular to the specified shape and shall not be abrupt. The knuckle radius shall not be less than specified. For 2:1 ellipsoidal heads, the knuckle radius may be considered to be 17% of the diameter of the vessel.

(b) Hemispherical heads and any spherical portion of a formed head shall meet the local tolerances for spheres as given in NB-4221.2, using  $L$  as the outside spherical radius, in., and  $D_o$  as two times  $L$ .

(c) Deviation measurements shall be taken on the surface of the base material and not on welds.

#### **NB-4223 Tolerances for Formed or Bent Piping**

The tolerances for formed or bent piping shall be as set forth in the following subparagraphs.

#### **NB-4223.1 Minimum Wall Thickness.**

(a) In order to assure that the wall thickness requirements of the design calculations are met, the actual thickness shall be measured, or the process shall be qualified by demonstrating that it will maintain the required wall thickness.

(b) As an alternative to (a) above, the requirements of Table NB-3642.1(b)-1 shall be followed.

**NB-4223.2 Ovality Tolerance.** Unless otherwise justified by the Design Report, the ovality of piping after bending shall not exceed 8% as determined by:

$$100 \times (D_{\max} - D_{\min}) / D_o$$

where

$D_o$  = nominal pipe outside diameter

$D_{\min}$  = minimum outside diameter after bending or forming

$D_{\max}$  = maximum outside diameter after bending or forming



**NB-4230 FITTING AND ALIGNING****NB-4231 Fitting and Aligning Methods**

Parts that are to be joined by welding may be fitted, aligned, and retained in position during the welding operation by the use of bars, jacks, clamps, tack welds, or temporary attachments.

**NB-4231.1 Tack Welds.** Tack welds used to secure alignment shall either be removed completely, when they have served their purpose, or their stopping and starting ends shall be properly prepared by grinding or other suitable means so that they may be satisfactorily incorporated into the final weld. Tack welds shall be made by qualified welders using qualified welding procedures. When tack welds are to become part of the finished weld, they shall be visually examined and defective tack welds shall be removed.

**NB-4232 Alignment Requirements When Components Are Welded From Two Sides**

(a) Alignment of sections which are welded from two sides shall be such that the maximum offset of the finished weld will not be greater than the applicable amount listed in Table NB-4232-1, where  $t$  is the nominal thickness of the thinner section at the joint.

(b) Joints in spherical vessels, joints within heads, and joints between cylindrical shells and hemispherical heads shall meet the requirements in Table NB-4232-1 for longitudinal joints.

(c) In addition, offsets greater than those stated in Table NB-4232-1 are acceptable provided the requirements of NB-3200 are met.

**NB-4232.1 Fairing of Offsets.** Any offset within the allowable tolerance provided above shall be faired to at least a 3:1 taper over the width of the finished weld or, if necessary, by adding additional weld metal beyond what

would otherwise be the edge of the weld. In addition, single or multiple tapers or slopes more severe than 3:1 are acceptable provided the requirements of NB-3200 are met.

**NB-4233 Alignment Requirements When Inside Surfaces Are Inaccessible**

(a) When the inside surfaces of items are inaccessible for welding or fairing in accordance with NB-4232, alignment of sections shall meet the requirements of (1) and (2) below:

(1) See (-a) and (-b) below.

(-a) For circumferential joints the inside diameters shall match each other within  $\frac{1}{16}$  in. (1.5 mm). When the items are aligned concentrically, a uniform mismatch of  $\frac{1}{32}$  in. (0.8 mm) all around the joint can result as shown in Figure NB-4233(a)-1 sketch (a). However, other variables not associated with the diameter of the item often result in alignments that are offset rather than concentric. In these cases, the maximum misalignment at any one point around the joint shall not exceed  $\frac{3}{32}$  in. (2.5 mm) as shown in Figure NB-4233(a)-1 sketch (b). Should tolerances on diameter, wall thickness, out-of-roundness, etc., result in inside diameter variations which do not meet these limits, the inside diameters shall be counterbored, sized, or ground to produce a bore within these limits, provided the requirements of NB-4250 are met.

(-b) Offset of outside surfaces shall be faired to at least a 3:1 taper over the width of the finished weld or, if necessary, by adding additional weld metal.

(2) For longitudinal joints the misalignment of inside surfaces shall not exceed  $\frac{3}{32}$  in. (2.5 mm) and the offset of outside surfaces shall be faired to at least a 3:1 taper over the width of the finished weld or, if necessary, by adding additional weld metal.

(b) Single welded joints may meet the alignment requirements of (a)(1) and (a)(2) above in lieu of the requirements of NB-4232.

(c) In addition, misalignments and offsets greater than those stated in Figure NB-4233(a)-1 and single or multiple tapers or slopes more severe than 3:1 are acceptable provided the requirements of NB-3200 are met.



**NB-4240 REQUIREMENTS FOR WELD JOINTS IN COMPONENTS****NB-4241 Category A Weld Joints in Vessels and Longitudinal Weld Joints in Other Components**

Category A weld joints in vessels and longitudinal weld joints in other components shall be full penetration butt joints. Joints that have been welded from one side with backing that has been removed and those welded from one side without backing are acceptable as full penetration welds provided the weld root side of the joints meets the requirements of NB-4424.

**Table NB-4232-1**  
**Maximum Allowable Offset in Final Welded Joints**

Section Thickness, in. (mm)	Direction of Joints	
	Longitudinal	Circumferential
Up to $\frac{1}{2}$ (13), incl.	$\frac{1}{4}t$	$\frac{1}{4}t$
Over $\frac{1}{2}$ to $\frac{3}{4}$ (13 to 19), incl.	$\frac{1}{8}$ in. (3 mm)	$\frac{1}{4}t$
Over $\frac{3}{4}$ to $1\frac{1}{2}$ (19 to 38), incl.	$\frac{1}{8}$ in. (3 mm)	$\frac{3}{16}$ in. (5 mm)
Over $1\frac{1}{2}$ to 2 (38 to 50), incl.	$\frac{1}{8}$ in. (3 mm)	$\frac{1}{8}t$
Over 2 (50)	Lesser of $\frac{1}{16}t$ or $\frac{3}{8}$ in. (10 mm)	Lesser of $\frac{1}{8}t$ or $\frac{3}{4}$ in. (19 mm)

**Figure NB-4233(a)-1**  
**Butt Weld Alignment and Mismatch Tolerances for Unequal I.D. and O.D. When Components Are Welded From One Side and Fairing Is Not Performed**



GENERAL NOTE: The weld and transitions are typical and are not intended as requirements. Refer to NB-4250 for weld end transition requirements.

**NB-4242 Category B Weld Joints in Vessels and Circumferential Weld Joints in Other Components**

Category B weld joints in vessels and circumferential weld joints in other components shall be full penetration butt joints, except that piping NPS 2 (DN 50) and smaller may be socket welded. When used, backing strips shall be continuous in cross section. Joints prepared with opposing lips to form an integral backing strip and joints with backing strips which are not later removed are acceptable provided the requirements of [NB-3352.2](#) are met.

**NB-4243 Category C Weld Joints in Vessels and Similar Weld Joints in Other Components**

Category C weld joints in vessels and similar weld joints in other components shall be full penetration joints, except that NPS 2 (DN 50) and smaller socket welded joints may be used on component nozzles and in piping. Joints that have been welded from one side with backing that has been removed and those welded from one side without backing are acceptable as full penetration welds provided the weld root side of the joints meets the requirements of [NB-4424](#). Either a butt welded joint or a full penetration corner joint as shown in [Figure NB-4243-1](#) shall be used.

**NB-4244 Category D Weld Joints in Vessels and Similar Weld Joints in Other Components**

Category D weld joints in vessels and similar weld joints in other components shall be full or partial penetration weld joints using one of the details of (a) through (e) below.

(a) *Butt Welded Nozzles*. Nozzles shall be attached by full penetration butt welds through the wall of the component, nozzle, or branch as shown in [Figure NB-4244\(a\)-1](#). Backing strips, if used, shall be removed.

(b) *Corner Welded Nozzles*. Nozzles shall be joined to the component by full penetration welds through the wall of the component, nozzle, or branch similar to those shown in [Figure NB-4244\(b\)-1](#). Backing strips, if used, shall be removed.

(c) *Deposited Weld Metal of Openings for Nozzles*. Nozzles shall be joined to the component by full penetration welds to built-up weld deposits applied to the component or nozzle as shown in [Figure NB-4244\(c\)-1](#). Backing strips, if used, shall be removed. Fillet welds shall be used only to provide a transition between the parts joined or to provide a seal. The fillet welds, when used, shall be finished by grinding to provide a smooth surface having a transition radius at its intersection with either part being joined.

(d) *Partial Penetration Welded Nozzles*. Partial penetration welds in components shall meet the weld design requirements of [NB-3352.4\(d\)](#). Nozzles shall be attached as shown in [Figures NB-4244\(d\)-1](#) and [NB-4244\(d\)-2](#).

(e) *Oblique Nozzles*. Oblique nozzles shall be joined to the component by full penetration welds through the nozzle as shown in [Figure NB-4244\(e\)-1](#). Backing rings, if used, shall be removed.

**NB-4245 Complete Joint Penetration Welds**

Complete joint penetration is considered to be achieved when the acceptance criteria for the examinations specified by this Subsection have been met. No other examination is required to assess that complete penetration has been achieved.

**NB-4246 Piping Branch Connections**

Piping branch connections shall be welded joints using the details of (a), (b), or (c).

(a) *Full Penetration Welded Branch Connections*. Branch connections shall be joined by full penetration welds as shown in [Figure NB-4246\(a\)-1](#) meeting the following requirements:

(1) Backing strips if used shall be removed.

(2) The requirements of [NB-3683.8\(a\)](#) shall be met.

(b) *Fillet and Partial Penetration Welded Branch Connections*. Fillet and partial penetration welded branch connections shall meet the requirements of [NB-3661.3](#). Branch connections shall be attached as shown in [Figure NB-4246\(b\)-1](#).

(c) *Welded Branch Connections per NB-4244*. Welded connections per [NB-4244](#) are permitted; however, the stress indices of [NB-3683.8](#) are not applicable to all configurations.

**NB-4250 WELDING END TRANSITIONS — MAXIMUM ENVELOPE**

The welding ends of items shall provide a gradual change in thickness from the item to the adjoining item. Any welding end transition which lies entirely within the envelope shown in [Figure NB-4250-1](#) is acceptable provided:


(a) the wall thickness in the transition region is not less than the minimum wall thickness of the adjoining pipe;

(b) sharp reentrant angles and abrupt changes in slope in the transition region are avoided. When the included angle between any two adjoining surfaces of a taper transition is less than 150 deg, the intersection or corner (except for the weld reinforcement) shall be provided with a radius of at least  $0.05t_{\min}$ ; and


(c) if the weld is subject to preservice inspection, the length of the counterbore shall be  $2t_{\min}$  for pipe and  $t_{\min}$  for components and fittings, as shown in [Figure NB-4250-2](#) or [Figure NB-4250-3](#).

(d) Transitions more severe than those stated herein are acceptable provided the requirements of [NB-3200](#) are met.

**Figure NB-4243-1**  
**Acceptable Full Penetration Weld Details for Category C Joints (NB-3352.3)**




**Figure NB-4244(a)-1**  
**Nozzles Joined by Full Penetration Butt Welds**



**GENERAL NOTES:**

- (a) For definitions of symbols, see [NB-3352.4\(a\)](#).  
 (b) Reinforcement may be distributed within the limits prescribed by the Code.

**Figure NB-4244(b)-1**  
**Nozzles Joined by Full Penetration Corner Welds**




GENERAL NOTE: For definitions of symbols, see [NB-3352.4\(b\)](#).



(13)


**Figure NB-4244(c)-1**  
**Deposited Weld Metal Used as Reinforcement of Openings for Nozzles**



## GENERAL NOTES:

(a) For definitions of symbols, see [NB-3352.4\(c\)](#).(b) At Step 1 examination (see [NB-5244](#)) required before assembly.

**Figure NB-4244(d)-1**  
**Partial Penetration Nozzles**




GENERAL NOTE: For definitions of symbols and other related requirements, see NB-3352.4(d).

NOTES:

- (1) The  $\frac{3}{4}t_n$  min. dimension applies to the fillet leg and the J-groove depth.
- (2) Weld buildup, if used, shall be examined as required in NB-5244.
- (3) Weld buildups are not attached to the nozzle.

**Figure NB-4244(d)-2**  
**Partial Penetration Nozzle for Coaxial Cylinders**



## NB-4300 WELDING QUALIFICATIONS


### NB-4310 GENERAL REQUIREMENTS

#### NB-4311 Types of Processes Permitted

Only those welding processes which are capable of producing welds in accordance with the welding procedure qualification requirements of Section IX and this Subsection may be used for welding pressure-retaining material or attachments thereto. Any process used shall be such that the records required by NB-4320 can be prepared, except that records for stud welds shall be traceable to the welders and welding operators and not necessarily to each specific weld.

**NB-4311.1 Stud Welding Restrictions.** Stud welding is acceptable only for nonstructural and temporary attachments (NB-4435). Studs shall be limited to 1 in. (25 mm) maximum diameter for round studs and an equivalent cross-sectional area for studs of other shapes when welding in the flat position and  $\frac{3}{4}$  in. (19 mm) diameter for all other welding positions. Postweld heat treatment shall comply with NB-4600, except that time at temperature need not exceed  $\frac{1}{2}$  hr regardless of base material thickness. Welding procedure and performance qualification shall comply with the requirements of Section IX.

**Figure NB-4244(e)-1  
Oblique Connections**



**GENERAL NOTES:**

- (a) Step 1 examination required before assembly.  
(b) For definitions of symbols, see [NB-3352.4\(e\)](#).

**NB-4311.2 Capacitor Discharge Welding.** Capacitor discharge welding may be used for welding temporary attachments and permanent nonstructural attachments provided:

- (a) temporary attachments are removed in accordance with the provisions of [NB-4435\(b\)](#); and  
(b) the energy output for permanent nonstructural attachments such as strain gages and thermocouples is limited to 125 W-sec, and the minimum thickness of the material to which the attachment is made is greater than 0.09 in. (2.3 mm); and  
(c) a Welding Procedure Specification is prepared describing the capacitor discharge equipment, the combination of materials to be joined, and the technique of application; qualification of the welding procedure is not required.

**NB-4311.4 Inertia and Continuous Drive Friction Welding.**

- (a) Inertia and continuous drive friction welding shall not be used for the fabrication of vessels and piping.  
(b) The weld between the two members shall be a full penetration weld.

**NB-4320 WELDING QUALIFICATIONS, RECORDS, AND IDENTIFYING STAMPS**


**NB-4321 Required Qualifications**

(a) Each Certificate Holder is responsible for the welding done by his organization, and each Certificate Holder shall establish the procedure and conduct the tests required by this Article and by Section IX in order to qualify both the welding procedures and the performance of welders and welding operators who apply these procedures.

(b) Procedures, welders, and welding operators used to join permanent or temporary attachments to pressure parts and to make permanent or temporary tack welds used in such welding shall also meet the qualification requirements of this Article.

(c) When making procedure test plates for butt welds, consideration shall be given to the effect of angular, lateral, and end restraint on the weldment. This applies particularly to material and weld metal of 80.0 ksi (550 MPa) tensile strength or higher and heavy sections of both low

**Figure NB-4246(a)-1**  
**Typical Piping Branch Connections Joined by Full Penetration Welds**



GENERAL NOTE: Welds may be made from one or both sides in any of the locations shown.

and high tensile strength material. The addition of restraint during welding may result in cracking difficulties that otherwise might not occur.

(d) NCA-3131 provides specific additional requirements when welding services are subcontracted to or through organizations not holding an appropriate Certificate of Authorization.

#### **NB-4322 Maintenance and Certification of Records**


The Certificate Holder shall maintain a record of the qualified welding procedures and of the welders and welding operators qualified by him, showing the date

and results of tests and the identification mark assigned to each welder. These records shall be reviewed, verified, and certified by the Certificate Holder by signature or some other method of control in accordance with the Certificate Holder's Quality Assurance program and shall be available to the Authorized Nuclear Inspector.

#### **NB-4322.1 Identification of Joints by Welder or Welding Operator.**


(a) Each welder or welding operator shall apply the identification mark assigned by the Certificate Holder on or adjacent to all permanent welded joints or series of joints on which he welds. The marking shall be at intervals of 3 ft (1 m) or less and shall be done with either blunt

**Figure NB-4246(b)-1**  
**Typical Piping Branch Connections Joined by a Fillet Weld or a Partial Penetration Weld**




$T_b$  = Nominal branch pipe wall thickness  
 $X_{min.} = 1\frac{1}{4} T_b$   
 $\theta$  = Partial penetration weld groove angle  $\geq 45$  deg

**ASME B16.11 Coupling**




**Welded Outlet Fitting**



$T_b$  = Fitting wall thickness in the reinforcement zone  
 (when the fitting is tapered in the reinforcement zone, use average wall thickness)  
 $X_{min.} = 1\frac{1}{4} T_b$   
 $\theta$  = Partial penetration weld groove angle  $\geq 45$  deg;  
 $\theta = 90$  deg (fillet weld) is permitted



**Figure NB-4250-1**  
**Welding end Transitions — Maximum Envelope**




**GENERAL NOTES:**

- (a) Weld bevel is shown for illustration only.
- (b) The weld reinforcement permitted by [NB-4426](#) may lie outside the maximum envelope.

**NOTES:**

- (1) The maximum thickness at the end of the component is:
  - (a) the greater of  $t_{min} + 0.15$  in. (3.8 mm) or  $1.15t_{min}$  when ordered on a minimum wall basis;
  - (b) the greater of  $t_{min} + 0.15$  in. (3.8 mm) or  $1.0t_{nom}$  when ordered on a nominal wall basis.
- (2) The value of  $t_{min}$  is whichever of the following is applicable:
  - (a) the minimum ordered wall thickness of the pipe;
  - (b) 0.875 times the nominal wall thickness of pipe ordered to a pipe schedule wall thickness which has an under tolerance of 12.5%;
  - (c) the minimum ordered wall thickness of the cylindrical welding end of a component or fitting (or the thinner of the two) when the joint is between two components.

**Figure NB-4250-2  
Component to Pipe Weld**



nose continuous or blunt nose interrupted dot die stamps. As an alternative, the Certificate Holder shall keep a record of permanent welded joints in each item and of the welders and welding operators used in making each of the joints.


(b) When a multiple number of permanent structural attachment welds, nonstructural welds, fillet welds, socket welds, welds of specially designed seals, weld metal cladding, hard surfacing, and tube-to-tubesheet welds are made on an item, the Certificate Holder need not identify the welder or welding operator who welded each individual joint, provided:

(1) the Certificate Holder maintains a system that will identify the welders or welding operators who made such welds on each item so that the Inspector can verify that the welders or welding operators were all properly qualified;

(2) the welds in each category are all of the same type and configuration and are welded with the same Welding Procedure Specification.

(c) The identification of welder or welding operator is not required for tack welds.

**Figure NB-4250-3  
Pipe to Pipe Weld**



**NB-4323 Welding Prior to Qualifications**

No welding shall be undertaken until after the welding procedures which are to be used have been qualified. Only welders and welding operators who are qualified in accordance with [NB-4320](#) and Section IX shall be used.

**NB-4324 Transferring Qualifications**

The welding procedure qualifications and the performance qualification tests for welders and welding operators conducted by one Certificate Holder shall not qualify welding procedures and shall not qualify welders or welding operators to weld for any other Certificate Holder, except as provided in Section IX, QW-201 and QW-300.2.

**NB-4330 GENERAL REQUIREMENTS FOR WELDING PROCEDURE QUALIFICATION TESTS****NB-4331 Conformance to Section IX Requirements**

All welding procedure qualification tests shall be in accordance with the requirements of Section IX as supplemented or modified by the requirements of this Article.

**NB-4333 Heat Treatment of Qualification Welds for Ferritic Materials**

Postweld heat treatment of procedure qualification welds shall conform to the applicable requirements of [NB-4620](#) and Section IX. The postweld heat treatment time at temperature shall be at least 80% of the maximum time to be applied to the component weld material. The postweld heat treatment total time may be applied in one heating cycle.

**NB-4334 Preparation of Test Coupons and Specimens**

(a) Removal of test coupons from the test weld and the dimensions of specimens made from them shall conform to the requirements of Section IX, except that the removal of impact test coupons and the dimensions of impact test specimens shall be in accordance with (b) below.

(b) Weld deposit of each process in a multiple process weld shall, where possible, be included in the impact test specimens. When each process cannot be included in the full-size impact test specimen at the  $\frac{1}{4}t$  location required by this Section, additional full-size specimens shall be obtained from locations in the test weld that will ensure that at least a portion of each process has been included in full-size test specimens. As an alternative, additional test welds can be made with each process so that full-size specimens can be tested for each process.

**NB-4334.1 Coupons Representing the Weld Deposit.** Impact test specimens and testing methods shall conform to [NB-2321](#). The impact specimen shall be located so that the longitudinal axis of the specimen is at least  $0.25t$  and,

where the thickness of the test assembly permits, not less than  $\frac{3}{8}$  in. (10 mm) from the weld surface of the test assembly. In addition, when the postweld heat treatment temperature exceeds the maximum temperature specified in [NB-4620](#) and the test assembly is cooled at an accelerated rate, the longitudinal axis of the specimen shall be a minimum of  $t$  from the edge of the test assembly. The specimen shall be transverse to the longitudinal axis of the weld with the area of the notch located in the weld. The length of the notch of the Charpy V-notch specimen shall be normal to the surface of the weld. Where drop weight specimens are required, the tension surface of the specimen shall be oriented parallel to the surface of the test weld assembly.

**NB-4334.2 Coupons Representing the Heat Affected Zone.** Where impact tests of the heat affected zone are required by [NB-4335.2](#), specimens shall be taken from the welding procedure qualification test assemblies in accordance with (a) through (c) below.

(a) If the qualification test material is in the form of a plate or a forging, the axis of the weld shall be oriented in the direction parallel to the principal direction of rolling or forging.

(b) The heat affected zone impact test specimens and testing methods shall conform to the requirements of [NB-2321.2](#). The specimens shall be removed from a location as near as practical to a depth midway between the surface and center thickness. The coupons for heat affected zone impact specimens shall be taken transverse to the axis of the weld and etched to define the heat affected zone. The notch of the Charpy V-notch specimen shall be cut approximately normal to the material surface in such a manner as to include as much heat affected zone as possible in the resulting fracture. Where the material thickness permits, the axis of a specimen may be inclined to allow the root of the notch to align parallel to the fusion line. When a grain refining heat treatment is not performed on welds made by the electroslog or electrogas welding process, the notch for the impact specimens shall be located in the grain coarsened region.

(c) For the comparison of heat affected zone values with base material values [[NB-4335.2\(b\)](#)], Charpy V-notch specimens shall be removed from the unaffected base material at approximately the same distance from the base material surface as the heat affected zone specimens. The axis of the unaffected base material specimens shall be parallel to the axis of the heat affected zone specimens, and the axis of the notch shall be normal to the surface of the base material. When required by [NB-4335.2\(b\)\(1\)](#), drop-weight specimens shall be removed from a depth as near as practical to midway between the surface and center thickness of the unaffected base material and shall be tested in accordance with the requirements of [NB-2321.1](#).

**NB-4335 Impact Test Requirements**

When materials are required to be impact tested per NB-2300, impact tests of the weld metal and heat affected zone shall be performed in accordance with the following subparagraphs. The weld procedure qualification impact test specimens shall be prepared and tested in accordance with the applicable requirements of NB-2330 and NB-4334. Retests in accordance with the provisions of NB-2350 are permitted.

**NB-4335.1 Impact Tests of Weld Metal.**

(a) Impact tests of the weld metal shall be required for welding procedure qualification tests for production weld joints exceeding  $\frac{5}{8}$  in. (16 mm) in thickness when the weld will be made on the surface or penetrate base material that requires impact testing in accordance with NB-2310. In addition, such testing of the weld metal is required for the welding procedure qualification tests for any weld repair to base material that requires impact testing in accordance with NB-2310, regardless of the depth of the repair.

(b) The impact test requirements and acceptance standards for welding procedure qualification weld metal shall be the same as specified in NB-2330 for the base material to be welded or repaired. Where two materials are to be joined by welding and have different fracture toughness requirements, the test requirements and acceptance standards of either material may be used for the weld metal except where this is otherwise specified by NCA-1280 or other parts of this Subsection.

**NB-4335.2 Impact Tests of Heat Affected Zone.**

(a) Charpy V-notch tests of the heat affected zone of the welding procedure qualification test assembly are required whenever the thickness of the weld exceeds  $\frac{5}{8}$  in. (16 mm) and either of the base materials require impact testing in accordance with the rules of NB-2310. The only exceptions to the requirements are the following:

(1) the qualification for welds in P-Nos. 1 and 3 and SA-336 F12 materials that are postweld heat treated and are made by any process other than electroslag or electro-gas.

(2) the qualification for weld deposit cladding or hard-facing on any base material.

(3) that portion of the heat affected zone associated with GTAW root deposits with a maximum of two layers or  $\frac{3}{16}$  in. (5 mm) thickness, whichever is less.

(b) The required testing shall be in accordance with (c) for base material tested under NB-2331 or NB-2332(b) and in accordance with (d) for base material tested under NB-2332(a).

(c) For heat affected zones associated with base material tested under NB-2331 or NB-2332(b), the required testing shall be in accordance with (1) through (7).

(1) Determine the  $T_{NDT}$  of the unaffected base material to be used in the welding procedure qualification test assembly.

(2) Charpy V-notch test specimens representing both the heat affected zone and the unaffected base material shall be tested. The unaffected base material specimens shall be tested at the  $(T_{NDT} + 60^{\circ}\text{F})$  [ $T_{NDT} + 33^{\circ}\text{C}$ ] temperature.

(3) The Charpy V-notch tests of the unaffected base material shall meet the applicable requirements of NB-2331(a) or additional testing shall be performed at higher temperatures until the requirements of NB-2331(a) are met.

(4) The heat affected zone specimens shall be tested at the test temperature determined in (3). The average lateral expansion value of the specimens shall equal or exceed the average lateral expansion value of the unaffected base material. For this case the qualification test is acceptable for the essential and supplemental essential variables recorded on the welding procedure qualification record (PQR). If the heat affected zone average lateral expansion value is less than the unaffected base material lateral expansion value, the adjustment given in (5) through (7) shall be determined and applied as provided in (e).

(5) Additional Charpy V-notch tests shall be performed on either the heat affected zone or the unaffected base material, or both, at temperatures where the lateral expansion value of all three specimens tested is not less than 35 mils (0.89 mm). The average lateral expansion value for each test meeting this requirement shall be plotted on a lateral expansion versus temperature graph. The difference in temperature  $T_{HAZ}$  and  $T_{UBM}$  where the heat affected zone and the unaffected base material average lateral expansion values are the same and not less than 35 mils (0.89 mm) shall be used to determine the adjustment temperature  $T_{Adj}$  where:

$$T_{Adj} = T_{HAZ} - T_{UBM}$$

If  $T_{Adj} \leq 0$ , then  $T_{Adj} = 0$ .

(6) As an alternative to (5), if the average lateral expansion value of the heat affected zone specimens is no less than 35 mils (0.89 mm) and the average of the heat affected zone specimens is not less than 5 mils (0.13 mm) below the average lateral expansion value of the unaffected base material specimens,  $T_{Adj}$  may be taken as  $15^{\circ}\text{F}$  ( $8^{\circ}\text{C}$ ).

(7) As a second alternative to (5), if the average lateral expansion value of the heat affected zone specimens is no less than 35 mils (0.89 mm), the difference between the average lateral expansion of the heat affected zone and the unaffected base material specimens shall be calculated and used as described in (e)(3).

(d) For heat affected zones associated with base materials tested under NB-2332(a), the required testing shall be in accordance with (1) through (5).

(1) Three Charpy V-notch specimens shall be removed from both the unaffected base material and the heat affected zone. The unaffected base material

specimens shall be tested at a test temperature established in the design specification or additional testing shall be performed at higher temperatures until the applicable requirements of [Table NB-2332\(a\)-1](#) are met for the thickness of material to be welded in production.

(2) The heat affected zone specimens shall be tested at the test temperature determined in (1). The average lateral expansion value of the specimens shall equal or exceed the average lateral expansion value of the unaffected base material. For this case the qualification test is acceptable for the essential and supplemental essential variables recorded on the weld procedure qualification record. If the heat affected zone average lateral expansion value is less than the unaffected base material lateral expansion value, the adjustment given in (c)(3) through (c)(5) shall be determined and applied as provided in (e). Alternatively, another test coupon may be welded and tested.

(3) Additional Charpy V-notch tests shall be performed on either the heat affected zone or the unaffected base material, or both, at temperatures where the lateral expansion value of all three specimens tested is not less than the values shown in [Table NB-2332\(a\)-1](#) for the thickness of base material to be welded in production. The average lateral expansion value for each test meeting this requirement shall be plotted on a lateral expansion versus temperature graph. The difference in temperature  $T_{HAZ}$  and  $T_{UBM}$  where the heat affected zone and the unaffected base material average lateral expansion values are the same shall be used to determine the adjustment temperature where:

$$T_{ADJ} = T_{HAZ} - T_{UBM}$$

If  $T_{ADJ} \leq 0$ , then  $T_{ADJ} = 0$ .

(4) As an alternative to (3), if the average lateral expansion value of the heat affected zone is no less than 35 mils (0.89 mm) and the average of the heat affected zone specimens is not less than 5 mils (0.13 mm) below the average lateral expansion value of the unaffected base material,  $T_{ADJ}$  may be taken as 15°F (8°C).

(5) As a second alternative to (3), if the average lateral expansion value of the heat affected zone specimens is no less than 35 mils (0.89 mm), the difference between the average lateral expansion of the heat affected zone and unaffected base material specimens shall be calculated and used as described in (e)(3).

(e) At least one of the following methods shall be used to compensate for the heat affected zone toughness decrease due to the welding procedure.

(1) The  $RT_{NDT}$  temperature established in [NB-2331](#) or [NB-2332\(b\)](#) or the lowest service temperature specified in the Design Specification [[NB-2332\(a\)](#)] for all of the material to be welded in production welding procedure specifications (WPSs) supported by this PQR shall be increased by the adjustment temperature  $T_{ADJ}$ .

(2) The specified testing temperature for the production material may be reduced by  $T_{ADJ}$ .

(3) The materials to be welded may be welded using the WPS provided they exhibit Charpy V-notch values that are no less than the minimum required lateral expansion value required by [NB-2300](#) plus the difference in average lateral expansion values established in (c)(7) or (d)(5).

(f) The Charpy V-notch testing results shall be recorded on the welding PQR and any offsetting  $T_{ADJ}$  or increased toughness requirements shall be noted on the welding PQR and on the WPS. More than one compensation method may be used on a par basis.

### NB-4336 Qualification Requirements for Built-Up Weld Deposits

Built-up weld deposits for base metal reinforcement shall be qualified in accordance with the requirements of [NB-4331](#) through [NB-4335](#).

### NB-4337 Welding of Instrument Tubing

Welding of P-No. 8 material instrument tubing may be performed without the prescribed radiographic examination of [NB-5000](#) provided all of the additional rules of (a) through (j) are met.

(a) Nominal tube size shall not exceed  $\frac{1}{2}$  in. (13 mm), and wall thickness shall not exceed 0.065 in. (1.6 mm).

(b) Automatic welding equipment shall be used.

(c) Welding shall be limited to the gas tungsten-arc welding process.

(d) The welding procedures and welding operators shall be qualified in accordance with Sections III and IX. In addition, one sample weld shall be prepared for each nominal tube size, nominal wall thickness, welding position and welding machine model in accordance with the welding procedure specification, and the sample shall be tested in accordance with (f).

(e) Each production welding machine shall have the line voltage input corrected within  $\pm 10\%$ .

(f) Prior to the start of production welding, two consecutive acceptable sample welds shall be prepared after equipment setup and prior to the start of production welding for each type of weld to be performed, i.e., welding procedure specification with welding machine, welding position, nominal tube size, and nominal wall thickness. Each sample shall be sectioned approximately  $\frac{1}{4}$  in. (6 mm) from the weld so that the root of the weld is accessible for visual examination. Acceptance shall be based on complete root penetration.

(g) During production welding, voltage, current, and travel speed shall not vary more than  $\pm 10\%$  from that used in (d).

(h) The production welding voltage, current, and travel speed shall be recorded on a chart recorder. The chart shall be verified to ensure each weld is acceptable. The chart shall be retained as part of the Lifetime Quality Assurance Records.



(i) Concavity on the outside surface of the weld shall not exceed 10% of the nominal wall thickness.

(j) Unacceptable concavity or indications in the weld resulting from the examination per NB-5222(c) shall be cause for the weld to be cut out and remade. No repairs are permitted.

#### **NB-4350 SPECIAL QUALIFICATION REQUIREMENTS FOR TUBE-TO-TUBESHEET WELDS**

The welding procedure for tube-to-tubesheet welds shall be qualified in accordance with ASME Section IX, QW-202.6 using a demonstration mockup in accordance with QW-193. The weld throat (minimum leakage path) shall not be less than two-thirds of the specified tube wall thickness. Welders and welding operators shall be qualified by demonstration mockup in accordance with QW-303.5.

#### **NB-4360 QUALIFICATION REQUIREMENTS FOR WELDING SPECIALLY DESIGNED WELDED SEALS**

##### **NB-4361 General Requirements**

(a) Specially designed welded seals are defined as the walls or membranes, such as an omega shaped seal membrane, which confine the fluid and where strength is provided by a separate device.

(b) The welding procedure shall be qualified as a new procedure specification and shall be completely requalified when any of the essential variables specified or listed in the following paragraphs are made in the procedure. Changes other than those so given may be made in the procedure without the necessity for requalification provided the procedure is amended to show these changes. In addition, the essential variables specified in Section IX shall apply for both procedure and performance qualification.

##### **NB-4362 Essential Variables for Automatic, Machine, and Semiautomatic Welding**

The welding procedure shall be qualified as a new procedure specification and shall be completely requalified when any of the changes listed in this paragraph or the applicable portions of Section IX are made:

(a) when preplaced filler metal is melted to form all or part of a weld, a change from one alloy type or classification to any other alloy type or classification of base material or filler metal, even though previously qualified base materials and filler metals are of the same P-Number or A-Number;

(b) a change of any dimension of the weld joint for automatic or machine welding or a change of any dimension of the weld joint by more than 10% for semiautomatic welding beyond that qualified;

(c) a change in the nominal size or shape of any filler metal added to the arc;

(d) for automatic welding, an increase or decrease in the length of the seal weld by more than 30%;

(e) for automatic welding, a change in the welding current greater than 50% of the difference between the maximum and minimum amperages used during qualification; only two test assemblies need to be welded for requalification;

(f) any change in the angular relationship or distance between the welding electrode and the work and the filler metal beyond the range qualified;

(g) the addition or deletion of the use of tack welds or locating fixtures to facilitate alignment or to maintain the root opening of the weld joint;

(h) the addition or deletion of consumable inserts.

#### **NB-4363 Essential Variables for Manual Welding**

The welding procedure must be qualified as a new procedure specification and shall be completely requalified when any of the changes listed in (a) and (b) below are made in the procedure:

(a) a change of more than  $\pm 10\%$  of any dimension of the weld joint cross section other than the included angle of the groove, except that base material thickness may vary from minus 10% to 2.5 times the thickness qualified when welding parts of the same material thickness, or the thin member may vary from minus 10% to 2 times the thickness qualified when welding a thin seal membrane to a thick member;

(b) when preplaced filler metal is melted to form all or part of a weld, a change from one alloy type or classification to any other alloy type or classification of base material or filler metal, even though previously qualified base materials and filler metals are of the same P-Number or A-Number.

#### **NB-4366 Test Assembly**

The test assembly shall consist of a duplicate of the production weld except that tolerances as stated in NB-4362(b) or NB-4363(a) are permitted. Except for automatic welding, the Certificate Holder may use a 12 in. (300 mm) length to qualify, if the length of the production weld is considered to be greater than necessary to qualify.

**NB-4366.1 Automatic Welding.** For automatic welding, at least six consecutive test assemblies representing the range of dimensions to be qualified shall be required to establish the reproducibility of the welding procedure. In addition, the Certificate Holder making the production welds shall verify this capability of making two consecutive test assemblies prior to production welding using the previously qualified procedure.

**NB-4366.2 Manual, Machine, and Semiautomatic Welding.** For manual, machine, and semiautomatic welding, two test assemblies shall be required.



**NB-4367 Examination of Test Assembly**

(a) Where 100% weld penetration is required, the test assembly shall be sectioned, if necessary, to permit examination of the entire underside weld surface.

(b) A minimum of four cross sections shall be taken from each test assembly. One cross section shall be made in a weld start and stop area and the others shall be taken at random. Each cross-section shall be magnified to 10× to 15× in accordance with ASTM Standard E 883 for examination. All surfaces shall be free of cracks, incomplete penetration, incomplete melting of insert on consumable type welds, and porosity or inclusions in excess of one rounded void with the maximum dimension not greater than 10% of the thickness of the weld. When doubt exists as to the acceptability of the weld, after examination of four cross sections, the Inspector may require that additional metallographic cross sections be prepared for examination of the weld and adjacent base material.

**NB-4368 Performance Qualification Test**

The performance qualification test assembly shall meet the same requirements specified for the procedure qualification test assembly in NB-4366 and shall be examined in accordance with NB-4367. Furthermore, welding operators shall qualify using the same type and model of equipment, including the welding head, as the machine or machines that will be used to make production welds and shall be required to set up the machine with regard to adjustments and settings which affect the welding characteristics. One test assembly is required.

**NB-4400 RULES GOVERNING MAKING, EXAMINING, AND REPAIRING WELDS****NB-4410 PRECAUTIONS TO BE TAKEN BEFORE WELDING****NB-4411 Identification, Storage, and Handling of Welding Material**

Each Certificate Holder is responsible for control of the welding electrodes and other material which is used in the fabrication and installation of components (NB-4120). Suitable identification, storage, and handling of electrodes, flux, and other welding material shall be maintained. Precautions shall be taken to minimize absorption of moisture by electrodes and flux.

**NB-4412 Cleanliness and Protection of Welding Surfaces**

The method used to prepare the base metal shall leave the weld preparation with reasonably smooth surfaces. The surfaces for welding shall be free of scale, rust, oil, grease, and other deleterious material. The work shall be

protected from deleterious contamination and from rain, snow, and wind during welding. Welding shall not be performed on wet surfaces.

**NB-4420 RULES FOR MAKING WELDED JOINTS****NB-4421 Backing Rings**

When used in components other than piping, backing rings shall conform to the requirements of NB-4240. Backing rings shall not be used in piping unless removed after welding and the inside surfaces of the roots are examined by a magnetic particle or liquid penetrant method, in accordance with NB-5110, and meeting the acceptance standards of NB-5340 or NB-5350. The material for backing rings, when used, shall be compatible with the base metal. Permanent backing rings, when permitted by NB-3352, shall be continuous, and any splices shall be made by full penetration welds. Spacer pins shall not be incorporated into the welds.

**NB-4422 Peening**

Controlled peening may be performed to minimize distortion. Peening shall not be used on the initial layer, root of the weld metal, or on the final layer unless the weld is postweld heat treated.

**NB-4423 Miscellaneous Welding Requirements**

(a) Before applying weld metal on the second side to be welded, the root of full penetration double welded joints shall be prepared by suitable methods, such as chipping, grinding, or thermal gouging, except for those processes of welding by which proper fusion and penetration are otherwise obtained and demonstrated to be satisfactory by welding procedure qualification.

(b) If the welding is stopped for any reason, extra care shall be taken in restarting to get the required penetration and fusion. For submerged arc welding, chipping out a groove in the crater is recommended.

(c) Where single welded joints are used, particular care shall be taken in aligning and separating the components to be joined so that there will be complete penetration and fusion at the bottom of the joint for its full length.

**NB-4424 Surfaces of Welds**

**NB-4424.1 General.** As-welded surfaces are permitted, except for inertia and continuous drive friction welding where the flash shall be removed to sound metal. For piping, the appropriate stress indices given in Table NB-3681(a)-1 shall be applied. However, the surface of welds shall be sufficiently free from coarse ripples, grooves, overlaps, and abrupt ridges and valleys to meet (a) through (f) below.

(a) The surface condition of the finished weld shall be suitable for the proper interpretation of radiographic and other required nondestructive examinations of the weld. In those cases where there is a question regarding the surface condition of the weld on the interpretation

of a radiographic film, the film shall be compared to the actual weld surface for interpretation and determination of acceptability.

(b) Reinforcements are permitted in accordance with NB-4426.1 for vessels, pumps, and valves, and NB-4426.2 for piping only for those welds that do not require preservice examination.

(c) Undercuts shall not exceed  $\frac{1}{32}$  in. (0.8 mm) and shall not encroach on the required section thickness.

(d) Concavity on the root side of a single-welded circumferential butt weld is permitted when the resulting thickness of the weld meets the requirements of NB-3000.

(e) If the surface of the weld requires grinding to meet the above criteria, care shall be taken to avoid reducing the weld or base material below the required thickness.

(f) Diametrical weld shrinkage is permissible provided an acceptable ultrasonic examination can be performed.

#### NB-4424.2 Preservice Examination.

(a) The surface finish shall be 6.3 Ra or better for a distance of at least  $2t^{28}$  plus 4 in. (100 mm) or 6 in. (150 mm), whichever is greater (Figure NB-4250-2 or Figure NB-4250-3), from the edge of the weld crown on at least one side of the weld where an ultrasonic examination is required.

(b) Provide welds a circumferential clearance distance of 15 in. (375 mm) (minimum) for long seam welds. This measurement shall be from the toe of the weld.

(c) A reference system shall be established for all piping and vessel welds subject to surface or volumetric examination.

(1) For piping, each side of each weld joint shall be permanently marked at a minimum of two points in suitable increments from the edge prep. These marks shall be repeated at 90-deg intervals around the pipe. For welds joining pipes to components, other than vessels where punching is not feasible, punching on the pipe side only is permitted.

(2) For vessels, each side of each weld joint shall be permanently marked at a minimum of two points in suitable increments from the edge prep. These marks shall be repeated along the weld length at 1 ft (0.3 m) intervals for vessel to nozzle welds, and at 3 ft (1 m) intervals for all other vessel welds that are subject to preservice examination.

#### NB-4425 Welding Items of Different Diameters

When items of different diameters are welded together, there shall be a gradual transition between the two surfaces in accordance with NB-4250, unless greater slopes are shown to be acceptable by analysis in accordance with NB-3200. The length of the transition may include the weld.

#### NB-4426 Reinforcement of Welds

**NB-4426.1 Thickness of Weld Reinforcement for Vessels, Pumps, and Valves.** The surface of the reinforcement of all butt welded joints in vessels, pumps, and valves may be flush with the base material or may have uniform crowns. The height of reinforcement on each face of the weld shall not exceed the thickness in the following tabulation.

Nominal Thickness, in. (mm)	Maximum Reinforcement, in. (mm)
Up to 1 (25), incl.	$\frac{3}{32}$ (2.5)
Over 1 to 2 (25 to 50), incl.	$\frac{1}{8}$ (3)
Over 2 to 3 (50 to 75), incl.	$\frac{5}{32}$ (4.0)
Over 3 to 4 (75 to 100), incl.	$\frac{7}{32}$ (5.5)
Over 4 to 5 (100 to 125), incl.	$\frac{1}{4}$ (6)
Over 5 (125)	$\frac{5}{16}$ (8)


**NB-4426.2 Thickness of Weld Reinforcement for Piping.** For double-welded butt joints, the limitation on the reinforcement given in Column 1 of the following tabulation shall apply separately to both inside and outside surfaces of the joint. For single-welded butt joints, the reinforcement given in Column 2 shall apply to the inside surface and the reinforcement given in Column 1 shall apply to the outside surface. The reinforcement shall be determined from the higher of the abutting surfaces involved.

Material Nominal Thickness, in. (mm)	Maximum Reinforcement Thickness, in. (mm)	
	Column 1	Column 2
Up to $\frac{1}{8}$ (3), incl.	$\frac{3}{32}$ (2.5)	$\frac{3}{32}$ (2.5)
Over $\frac{1}{8}$ to $\frac{3}{16}$ (3 to 5), incl.	$\frac{1}{8}$ (3)	$\frac{3}{32}$ (2.5)
Over $\frac{3}{16}$ to $\frac{1}{2}$ (5 to 13), incl.	$\frac{5}{32}$ (4.0)	$\frac{1}{8}$ (3)
Over $\frac{1}{2}$ to 1 (13 to 25), incl.	$\frac{3}{16}$ (5)	$\frac{5}{32}$ (4.0)
Over 1 to 2 (25 to 50), incl.	$\frac{1}{4}$ (6)	$\frac{5}{32}$ (4.0)
Over 2 (50)	Greater of $\frac{1}{4}$ in. (6 mm) or $\frac{1}{8}$ times the width of the weld, in inches (millimeters)	$\frac{5}{32}$ (4.0)


#### NB-4427 Shape and Size of Fillet Welds

(a) Fillet welds may vary from convex to concave. The shape and size of the weld shall be in accordance with the requirements of Figure NB-4427-1. A fillet weld in any single continuous weld may be less than the specified fillet weld dimension by not more than  $\frac{1}{16}$  in. (1.5 mm), provided that the total undersize portion of the weld does not exceed 10% of the length of the weld. Individual undersize weld portions shall not exceed 2 in. (50 mm) in length. In making socket welds, a gap as shown in Figure NB-4427-1 shall be provided prior to welding. The gap need not be present nor be verified after welding. For sleeve type joints without internal shoulder, the gap shall be between the butting ends of the pipe or tube.


**Figure NB-4427-1**  
**Fillet and Socket Weld Details and Dimensions**




**(a) Equal Leg Fillet Weld [Note (1)]**



**(b) Unequal Leg Fillet Weld [Note (2)]**



**(c) Socket Welding Flange [Note (3)]**



**(d) Socket Welding Fittings [Note (4)]**

GENERAL NOTE: See NB-3661.2 for limitation on socket weld pipe size.

**NOTES:**

- (1) The size of an equal leg fillet is the leg length of the largest inscribed right isosceles triangle. Theoretical throat =  $0.7 \times$  size of weld.
- (2) The size of an unequal leg fillet weld is the shorter leg length of the largest right triangle that can be inscribed within the fillet weld cross section.
- (3)  $x$  min. =  $1.4 t_n$  or the thickness of the hub, whichever is smaller, but not less than  $\frac{1}{8}$  in. (3 mm), where  $t_n$  = nominal pipe wall thickness
- (4)  $C_x$  min. =  $1.09 t_n$  where  $t_n$  = nominal pipe wall thickness

(b) Socket welds smaller than those specified in Figure NB-4427-1 may be used provided the requirements of NB-3000 are met.

**NB-4428 Seal Welds of Threaded Joints**

Where seal welding of threaded pipe joints is performed, the exposed threads shall be either removed entirely or covered with weld metal.

**NB-4429 Welding of Clad Parts<sup>29</sup>**

The joint types and welding procedures used for cladding shall be such as to prevent the formation of brittle weld composition.

**NB-4430 WELDING OF ATTACHMENTS**

**NB-4431 Materials for Attachments**

Nonpressure-retaining attachments (NB-1132.1) welded to pressure-retaining components shall be of materials which meet the requirements of NB-2190. Materials for pressure-retaining attachments shall meet the requirements of NB-2120.

**NB-4432 Welding of Structural Attachments**

The rules of NB-4321 governing welding qualifications shall apply to the welding of structural attachments to pressure-retaining material.

**NB-4433 Structural Attachments**

Structural attachments shall conform reasonably to the curvature of the surface to which they are to be attached and shall be attached by full penetration, fillet, or partial penetration continuous welds. When fillet and partial penetration welds are used on components, the requirements of NB-3123.2 shall be met. Attachments to the internal surfaces of reactor vessels shall be made only with full penetration welds. Figure NB-4433-1 illustrates some of the typical details for attaching structural attachments to a component using full penetration welds. Valve seats may be attached to the pressure boundary part by fillet or partial penetration welds provided the valve seat is shouldered against the pressure boundary part.

**NB-4434 Welding of Internal Structural Supports to Clad Components**

Internal structural supports on clad components shall be welded to the base metal and not to the cladding, except for weld overlay cladding.

**NB-4435 Welding of Nonstructural Attachments and Their Removal**

(a) Nonstructural attachments (NB-1132.1) welded to the pressure-retaining portion of the component need not comply with NB-2000 and may be welded with continuous or intermittent fillet or partial penetration welds, provided the requirements of (1) through (4) below are met.

(1) The welding procedure and the welders have been qualified in accordance with NB-4321.

(2) The material is identified and is compatible with the material to which it is attached.

(3) The welding material is identified and compatible with the materials joined.

(4) The welds are postweld heat treated when required by NB-4620.

(b) Removal of nonstructural temporary attachments shall be accomplished as follows.

(1) The immediate area around the temporary attachment is marked in a suitable manner so that after removal the area can be identified until after it has been examined in accordance with (3) below.

(2) The temporary attachment is completely removed in accordance with the procedures of NB-4211.

(3) After the temporary attachment has been removed, the marked area is examined by the liquid penetrant or magnetic particle method in accordance with the requirements of NB-5110, and meets the acceptance standards of NB-5340 or NB-5350, whichever is applicable.

(4) As an alternative to (a)(4), postweld heat treatment may be deferred until after removal of the attachment.

**NB-4436 Installation of Attachments to Piping Systems After Testing**

Attachments may be welded to the piping system after performance of the pressure test provided that:

(a) the welds do not require PWHT under NB-4622.7;

(b) welds shall be restricted to fillet welds not exceeding  $\frac{3}{8}$  in. (10 mm) throat thickness and to full penetration welds attaching materials not exceeding  $\frac{1}{2}$  in. (13 mm) in thickness;

(c) welds shall not exceed a total length of 24 in. (600 mm) for fillet welds or 12 in. (300 mm) for full penetration welds;

(d) welds shall be examined as required by NB-5000.

**NB-4440 WELDING OF APPURTENANCES**

(a) When welded appurtenances are constructed in accordance with NB-3136(b), the welds shall meet the requirements shown in Figure NB-4440-1.

(b) Attachment of an appurtenance to the pressure boundary of a component shall, in all cases, be in accordance with the requirements of the component.

**NB-4450 REPAIR OF WELD METAL DEFECTS****NB-4451 General Requirements**

Defects in weld metal detected by the examinations required by NB-5000, or by the tests of NB-6000, shall be eliminated and repaired when necessary.

**NB-4452 Elimination of Surface Defects**

Weld metal surface defects may be removed by grinding or machining, and need not be repaired by welding, provided that the requirements of (a) through (c) below are met.

(a) The remaining thickness of the section is not reduced below that required by NB-3000.

(b) The depression, after defect elimination, is blended uniformly into the surrounding surface.


(c) The area is examined by a magnetic particle or liquid penetrant method in accordance with NB-5110 after blending and meets the acceptance standards of NB-5300 to ensure that the defect has been removed or reduced to an imperfection of acceptable limit. Defects detected by visual or volumetric method and located on an interior surface need only be reexamined by the method which initially detected the defect when the interior surface is inaccessible for surface examination.

**NB-4453 Requirements for Making Repairs of Welds**


Excavations in weld metal, when repaired by welding, shall meet the following requirements.

**NB-4453.1 Defect Removal.** Defects may be removed by mechanical means or by thermal gouging processes. The area prepared for repair shall be examined by a liquid penetrant or magnetic particle method in accordance with


**Figure NB-4433-1**  
**Types of Attachment Welds**



**(a) Attachment of Lugs, Shoes, Pipe Saddles, and Brackets**




**(b) Attachment of Trunnions**



**(c) Attachment of Rings**

GENERAL NOTE: The welds may be partial penetration or fillet welds.

**Figure NB-4440-1**  
**Appurtenance Weld Joint Details Size NPS 2 (DN 50) and Smaller**



$d$  = Inside diameter of the weld shall be  $2\frac{3}{8}$  in. (60 mm) maximum. Diameter restriction is on the diameter of the welded joint component (not the diameter of the appurtenance shell)

$$t_{c, \min} = 0.7 t_n$$

$$y_{\min} = \frac{1}{32} \text{ in. (1 mm)}$$

$z$  = Depth of engagement shall be  $\frac{3}{8}$  in. (10 mm) minimum for NPS  $\frac{1}{2}$  (DN 15) to NPS 2 (DN 50) and shall be  $\frac{1}{4}$  in. (6 mm) for under NPS  $\frac{1}{2}$  (DN 15)

**GENERAL NOTES:**

- (a) Not applicable to joints between the appurtenance and the component.
- (b) Maximum diametral clearance between connecting parts is 0.045 in. (1.1 mm).



NB-5110, and meet the acceptance standards of NB-5340 or NB-5350. This examination is not required where defect elimination removes the full thickness of the weld and where the backside of the weld joint is not accessible for removal of examination materials.

**NB-4453.2 Requirements for Welding Material, Procedures, and Welders.** The weld repair shall be made using welding material, welders, and welding procedures qualified in accordance with NB-4125 and NB-4300.

**NB-4453.3 Blending of Repaired Areas.** After repair, the surface shall be blended uniformly into the surrounding surface.

**NB-4453.4 Examination of Repair Welds.**

(a) The examination of a weld repair shall be repeated as required for the original weld, except that when the defect was originally detected by the liquid penetrant or magnetic particle method, and when the repair cavity does not exceed the lesser of  $\frac{3}{8}$  in. (10 mm) or 10% of the thickness, it need only be reexamined by the liquid penetrant or magnetic particle method.

(b) When repairs to welds joining P-No. 1 and P-No. 3 materials require examination by radiography as required in (a) above, but construction assembly prevents meaningful radiographic examination, ultrasonic examination may be substituted provided:

(1) the weld had been previously radiographed and met the applicable acceptance standards;

(2) the ultrasonic examination is performed using a procedure in accordance with Section V, Article 4, to the acceptance standards of NB-5330;

(3) the substitution is limited to Category A and B welds in vessels, and similar type welds in other items.

The absence of suitable radiographic equipment is not justification for the substitution.

**NB-4453.5 Heat Treatment of Repaired Areas.** The area shall be heat treated in accordance with NB-4620.

## **NB-4500 BRAZING**

### **NB-4510 RULES FOR BRAZING**

#### **NB-4511 Where Brazing May Be Used**

(a) Brazing is permitted for the attachment of cladding to base material, of tubes to tubesheets, and as specified in NB-3671.6(a). Appurtenances and piping with outside diameter equal to that of NPS 1 (DN 25) and less may be fabricated using brazed joints in accordance with Figure NB-4511-1.

(b) Valves with inlet piping connections of NPS 4 (DN 100) and less may have seats brazed to the valve body or bonnet provided the seat is shouldered against the pressure boundary part [Figure NB-3544.1(c)-1].

### **NB-4512 Brazing Material**

Where brazing is permitted, the brazing filler material and fluxes shall conform to the rules covering identification in NB-2150 and to the requirements of (a), (b), and (c) below.

(a) The filler material used in brazing shall be a nonferrous metal or alloy with a solidus temperature above 800°F (425°C) and at least 500°F (260°C) above the highest temperature of the joint in service.

(b) The filler material shall melt and flow freely by capillary action within the desired temperature range, and, in conjunction with a suitable flux or controlled atmosphere, the filler material shall wet and adhere to the surfaces to be joined.

(c) Fluxes that are fluid and chemically active at the brazing temperature shall be used, when necessary, to prevent oxidation of the filler metal and the surfaces to be joined, and to promote free flowing of the filler material.

### **NB-4520 BRAZING QUALIFICATION REQUIREMENTS**

#### **NB-4521 Brazing Procedure and Performance Qualification**

Qualification of the brazing procedure to be used and of the performance of brazers and brazing operators is required and shall comply with the requirements of Section IX, except as noted below.

#### **NB-4522 Valve Seat Rings**

Validation of the procedure qualification per QB-451.5 Note (1) is not required for the furnace brazing of seat rings to bodies or bonnets of valves having inlet piping connections of NPS 4 (DN 100) and less.


#### **NB-4523 Reheated Joints**

In addition to the requirements of Section IX, the brazing procedure shall be set up as a new procedure specification and shall be completely requalified when the construction of the brazed components includes reheating of any portion of the completed brazed joint to a temperature that is within 300°F (165°C) of the solidus temperature of the filler metal.

#### **NB-4524 Maximum Temperature Limits**

The design temperature shall not exceed the upper temperature shown in the third column of Table NB-4524-1. For design temperatures below the temperature shown in the second column of Table NB-4524-1, no further testing beyond that required by Section IX is required. For design temperatures in the range shown in the third column of Table NB-4524-1, tests in addition to those required by Section IX are required. These tests shall be considered a part of the procedure qualification. For such design temperatures, two tension tests on production type joints are required, one at the design temperature and one at

**Figure NB-4511-1**  
**Brazed Connections for Appurtenances and Piping, NPS 1 (DN 25) and Less**



$t$  = thickness of part penetrated  
 $t_n$  = nominal thickness of connecting part  
 $d$  = outside diameter of part B  
 $c$  = clearance or interference between mating parts and shall be in accordance with the brazing procedure specification  
 $z$  = depth of engagement and shall be the lesser of  $3t_n$  or  $d$ , but in no case less than  $1/4$  in. (6 mm)

**GENERAL NOTES:**

- (a) Part A shall be attached to a component in accordance with the requirements for the component proper.
- (b) Part B shall be attached either to part A or to another part B by the joints shown above, or in accordance with the requirements of the component proper.
- (c) Grooves for preplaced filler metal are permitted, provided the reduction in cross section due to the grooves is considered in the design.

1.05T, where  $T$  is the design temperature in °F (1.03T, where  $T$  is the design temperature in °C). Neither of these production-type joints shall fail in the braze metal.

#### **NB-4530 FITTING AND ALIGNING OF PARTS TO BE BRAZED**

Parts to be joined by brazing shall be fitted, aligned, and retained in position during the brazing operation within the tolerances specified in the brazing procedure specification. Brazed joints shall be assembled in a sequence which will permit the maximum number of joints to be visually examined on both sides of the joint after brazing.

#### **NB-4540 EXAMINATION OF BRAZED JOINTS**

The completed brazed joints shall be visually examined on all accessible surfaces in accordance with [NB-5275](#).

#### **NB-4600 HEAT TREATMENT**

##### **NB-4610 WELDING PREHEAT REQUIREMENTS**

##### **NB-4611 When Preheat Is Necessary**

The need for and temperature of preheat are dependent on a number of factors, such as the chemical analysis, degree of restraint of the parts being joined, elevated temperature, physical properties, and material thicknesses. Some practices used for preheating are given in Appendix D as a general guide for the materials listed by P-Numbers of Section IX. It is cautioned that the preheating suggested in Appendix D does not necessarily ensure satisfactory completion of the welded joint and that the preheating requirements for individual materials within the P-Number may be more or less restrictive. The Welding Procedure Specification for the material being welded shall specify the minimum preheating requirements under the welding procedure qualification requirements of Section IX.

#### **NB-4612 Preheating Methods**

Preheat for welding or thermal cutting, when employed, may be applied by any method which does not harm the base material or any weld metal already applied, or which does not introduce deleterious material into the welding area which is harmful to the weld.

#### **NB-4613 Interpass Temperature**

Consideration shall be given to the limitations of interpass temperatures for quenched and tempered material to avoid detrimental effects on the mechanical properties.

#### **NB-4620 POSTWELD HEAT TREATMENT**

##### **NB-4621 Heating and Cooling Methods**

Postweld heat treatment (PWHT) may be accomplished by any suitable methods of heating and cooling, provided the required heating and cooling rates, metal temperature, metal temperature uniformity, and temperature control are maintained.

##### **NB-4622 PWHT Time and Temperature Requirements**

**NB-4622.1 General Requirements.**<sup>1</sup> Except as otherwise permitted in [NB-4622.7](#), all welds, including repair welds, shall be postweld heat treated. During postweld heat treatment, the metal temperature shall be maintained within the temperature range and for the minimum holding time specified in [Table NB-4622.1-1](#), except as otherwise permitted in [NB-4622.4\(c\)](#). P-Number groups in [Table NB-4622.1-1](#) are in accordance with QW-420 of Section IX. Except as provided in [NB-4624.3](#), PWHT shall be performed in temperature-surveilled and -calibrated furnaces, or PWHT shall be performed with thermocouples in contact with the material or attached to blocks in contact with the material. In addition, the requirements of the following subparagraphs shall apply.

**NB-4622.2 Time-Temperature Recordings.** Time-temperature recordings of all postweld heat treatments shall be made available for review by the Inspector.

**Table NB-4524-1**  
**Maximum Design Temperatures for Brazing Filler Metal**

Filler Metal Classification	Temperature Below Which Section IX Tests Only Are Required, °F (°C)	Temperature Range Requiring Section IX and Additional Tests, °F (°C)
BCuP	300 (150)	300 - 350 (150 - 175)
BAG	400 (205)	400 - 500 (205 - 260)
BCuZn	400 (205)	400 - 500 (205 - 260)
BCu	400 (205)	400 - 650 (205 - 345)
BAISI	300 (150)	300 - 350 (150 - 175)
BNi	800 (425)	...

GENERAL NOTE: Temperatures based on AWS recommendations.

**Table NB-4622.1-1**  
**Mandatory Requirements for Postweld Heat Treatment of Welds**

P-No. (Section IX, QW-420)	Holding Temperature Range, °F (°C) [Note (1)]	Minimum Holding Time at Temperature for Weld Thickness (Nominal)			
		½ in. (13 mm) or less	Over ½ in. to 2 in. (13 to 50 mm)	Over 2 in. to 5 in. (50 to 125 mm)	Over 5 in. (125 mm)
1, 3	1,100 - 1,250 (595 - 675)	30 min	1 hr/in. (2 min/mm)	2 hr plus 15 min each additional inch (2 h plus 0.5 min/mm) over 2 in. (50 mm)	2 hr plus 15 min each additional inch (2 h plus 0.5 min/mm) over 2 in. (50 mm)
4	1,100 - 1,250 (595 - 675)	30 min	1 hr/in. (2 min/mm)	1 hr/in. (2 min/mm)	5 hr plus 15 min each additional inch (5 h plus 0.5 min/mm) over 5 in. (125 mm)
5A, 5B, 5C, 6 except P-No. 6 Gr. 4	1,250 - 1,400 (675 - 760)	30 min	1 hr/in. (2 min/mm)	1 hr/in. (2 min/mm)	5 hr plus 15 min each additional inch (5 h plus 0.5 min/mm) over 5 in. (125 mm)
6 Gr. 4	1,050 - 1,150 (565 - 620)				
7	1,300 - 1,400 (705 - 760)	30 min	1 hr/in. (2 min/mm)	1 hr/in. (2 min/mm)	5 hr plus 15 min each additional inch (5 h plus 0.5 min/mm) over 5 in. (125 mm)
9A Gr. 1	1,100 - 1,250 (595 - 675)	30 min	1 hr/in. (2 min/mm)	1 hr/in. (2 min/mm)	5 hr plus 15 min each additional inch (5 h plus 0.5 min/mm) over 5 in. (125 mm)
9B Gr. 1	1,100 - 1,175 (595 - 635)				
10F Gr. 1	1,100 - 1,250 (595 - 675)	30 min	1 hr/in. (2 min/mm)	1 hr/in. (2 min/mm)	5 hr plus 15 min each additional inch (5 h plus 0.5 min/mm) over 5 in. (125 mm)
10I Gr. 1	1,300 - 1,400 (705 - 760)				
11A Gr. 4	1,000 - 1,050 (540 - 565)	30 min	1 hr/in. (2 min/mm)	1 hr/in. (2 min/mm)	1 hr/in. (2 min/mm)
15E Gr. 1	1,350 - 1,425 (730 - 775)	30 min	1 hr/in. (2 min/mm)	1 hr/in. (2 min/mm)	5 hr plus 15 min each additional inch (5 h plus 0.5 min/mm) over 5 in. (125 mm)
P-Nos. 8, 34, 42, 43, 45, and hard surfacing on P- No. 1 base metal whose reported carbon content is not more than 0.30%	PWHT neither required nor prohibited				

GENERAL NOTE: Exemptions to the mandatory requirements of this Table are defined in [NB-4622.7](#).

NOTE:

(1) All temperatures are metal temperatures.

Identification on the time-temperature recording shall be to the weld, part, or component, as applicable. A summary of the time-temperature recording may be provided for permanent records in accordance with NCA-4134.17.

**NB-4622.3 Definition of Nominal Thickness Governing PWHT.** Nominal thickness in [Table NB-4622.7\(b\)-1](#) is the thickness of the weld, the pressure-retaining material for structural attachment welds or the thinner of the pressure-retaining materials being joined, whichever is least. It is not intended that nominal thickness include material provided for forming allowance, thinning, or mill overrun when the excess material does not exceed  $\frac{1}{8}$  in. (3 mm). For fillet welds the nominal thickness is the throat thickness, and for partial penetration and material repair welds the nominal thickness is the depth of the weld groove or preparation.

**NB-4622.4 Holding Times at Temperature.**

(a) The holding time at temperature as specified in [Table NB-4622.1-1](#) shall be based on the nominal thickness of the weld. The holding time need not be continuous. It may be an accumulation of the times of multiple postweld heat treat cycles.

(b) Holding time at temperature in excess of the minimum requirements of [Table NB-4622.1-1](#) may be used, provided that specimens so heat treated are tested in accordance with [NB-2200](#), [NB-2400](#), and [NB-4300](#).

(c) Alternatively, when it is impractical to postweld heat treat at the temperature range specified in [Table NB-4622.1-1](#), it is permissible to perform the postweld heat treatment of certain materials at lower temperatures for longer periods of time in accordance with [Table NB-4622.4\(c\)-1](#) and (1), (2), and (3) below.

(1) Except for P-No. 1 materials, when welds in the materials listed in [Table NB-4622.4\(c\)-1](#) are to be postweld heat treated at the lower minimum temperatures, the impact test specimens for the welding procedure qualification required by [NB-4300](#) shall be made using the same minimum temperatures and increased minimum holding time. Welding procedures, qualified at the temperature range and minimum holding time specified in [Table NB-4622.1-1](#) and at the lower temperature and increased minimum holding time permitted by

[Table NB-4622.4\(c\)-1](#), are also qualified for any temperature in between. When such an in-between temperature is used, the minimum holding time shall be interpolated from [Table NB-4622.1-1](#) and the alternative requirements from [Table NB-4622.4\(c\)-1](#).

(2) Except for P-No. 1 materials, when welds in the materials listed in [Table NB-4622.4\(c\)-1](#) are to be postweld heat treated at these lower minimum temperatures, the welding material certification required by [NB-2400](#) shall be made using the same minimum temperature and increased minimum holding time. Welding material certified at the temperature range and minimum holding time specified in [Table NB-4622.1-1](#) and at the lower minimum temperatures and increased minimum holding time permitted by [Table NB-4622.4\(c\)-1](#) are also certified for any temperature in between.

(3) Base material certified in accordance with [NB-2200](#) may be postweld heat treated at the lower minimum temperature ranges and increased minimum holding times without recertification. Postweld heat treatment at these lower minimum temperatures and increased minimum holding times may also be the tempering operation provided a higher tempering temperature is not required by the material specification.

**NB-4622.5 PWHT Requirements When Different P-Number Materials Are Joined.** When materials of two different P-Number groups are joined by welding, the applicable postweld heat treatment shall be that specified in [Table NB-4622.1-1](#) for the material requiring the higher PWHT temperature range.

**NB-4622.6 PWHT Requirements for Nonpressure-Retaining Parts.** When nonpressure-retaining material is welded to pressure-retaining material, the postweld heat treatment temperature range of the pressure-retaining material shall control.

**NB-4622.7 Exemptions to Mandatory Requirements.** Postweld heat treatment in accordance with this Subarticle is not required for:

- (a) nonferrous material;
- (b) welds exempted in [Table NB-4622.7\(b\)-1](#);

(c) welds subjected to temperatures above the PWHT temperature range specified in [Table NB-4622.1-1](#), provided the Welding Procedure Specification is qualified in accordance with Section IX and the base material and the deposited weld filler material have been heat treated at the higher temperature;

(d) welds connecting nozzles to components or branch to run piping provided the requirements in [NB-4622.8](#) are met;

(e) weld repairs to base metal, weld repairs to cladding after final postweld heat treatment, and weld repairs to dissimilar metal welds provided the requirements of [NB-4622.9](#) are met.

**Table NB-4622.4(c)-1  
Alternative Holding Temperatures and Times**

Material P-No.	Alternative Minimum Holding Temperatures, °F (°C)	Alternative Minimum Holding Times [Note (1)]
1, 3, 9A Gr. 1, 9B Gr. 1	1,050 (565)	2 hr/in. (4 min/mm) thick
1, 3, 9A Gr. 1, 9B Gr. 1	1,000 (540)	4 hr/in. (8 min/mm) thick

NOTE:

(1) All other requirements of [NB-4622](#) shall apply.

**Table NB-4622.7(b)-1  
Exemptions to Mandatory PWHT**

P-No. (Section IX, QW-420)		Type of Weld [Note (1)]	Nominal Thickness, in. (mm) (NB-4622.3)	Max. Reported Carbon, % [Note (2)]	Min. Preheat Required, °F (°C)
1	Vessels	Circumferential butt and socket welds connecting pipe and tubes to nozzles where the materials being joined are 1½ in. (38 mm) and less	1¼ (32) and less Over 1¼ to 1½ (32 to 38) ¾ (19) or less Over ¾ to 1½ (19 to 38)	0.30 or less 0.30 or less Over 0.30 Over 0.30	... 200 (95) ... 200 (95)
		Fillet welds	¾ (19) or less	...	200 (95)
		Full and partial penetration welds, provided the welding procedure qualification is made in equal or greater thickness than the production weld [Note (3)]	5/8 (16) or less	0.25 or less	200 (95)
	Other components	All welds where the materials being joined are 1½ in. (38 mm) and less	1¼ (32) and less Over 1¼ to 1½ (32 to 38) ¾ (19) or less Over ¾ to 1½ (19 to 38)	0.30 or less 0.30 or less Over 0.30 Over 0.30	... 200 (95) ... 200 (95)
		All welds in material over 1½ in. (38 mm)	¾ (19) or less	...	200 (95)
1, 3		For repair without required PWHT, see NB-4622.9,	...	...	350 (175)
1 Gr. 1 or Gr. 2		Cladding or repair of cladding [Note (4)] with A-No. 8 or F-No. 43 filler metal on base material of: 1½ in. (38 mm) or less over 1½ in. to 3 in. (38 mm to 75 mm) over 3 in. (75 mm)	... ... ...	0.30 0.30 0.30	100 (38) 200 (95) [Note (5)] 250 (120) [Note (6)]
3 except Gr. 3		All welds, except repair welds in vessels, provided welding procedure qualification is made using equal or greater thickness base material than the production weld [Note (3)]	5/8 (16) or less	0.25 or less	200 (95)
		Attachment welds joining nonpressure-retaining material to pressure-retaining material	½ (13) or less	0.25 or less	200 (95)
		Circumferential butt welds in pipe and tubes	½ (13) or less	0.25 or less	200 (95)
		Socket welds in pipe NPS 2 (DN 50) and less, and tubes with nominal O.D. 2⅜ in. (60 mm) or less	½ (13) or less	0.25 or less	200 (95)
4		All welds in pipe NPS 4 (DN 100) and less, and tubes with nominal O.D. 4.5 in. (114 mm) or less and attachment welds	½ (13) or less	0.15 or less	250 (120)
5A, 5B, 5C		All welds in pipe NPS 4 (DN 100) and less, and tubes with maximum reported chromium 3.00% or less and nominal O.D. 4.5 in. (114 mm) or less and attachment welds	½ in. (13 mm) or less	0.15 or less	300 (150)
6 (for Type 410 S) or 7 Gr. 1 (for Type 405)		Type 405 and 410S welded with A-No. 8, A-No. 9, or F-No. 43 filler metal	3/8 (10) or less	0.08 or less	...



**Table NB-4622.7(b)-1  
Exemptions to Mandatory PWHT (Cont'd)**

P-No. (Section IX, QW-420)	Type of Weld [Note (1)]	Nominal Thickness, in. (mm) (NB-4622.3)	Max. Reported Carbon, % [Note (2)]	Min. Preheat Required, °F (°C)
9A Gr. 1	All welds, provided the procedure qualification is made using equal or greater thickness base material than the production weld [Note (3)]	$\frac{5}{8}$ (16) or less	...	200 (95)
	Attachment welds joining nonpressure-retaining material to pressure-retaining material over $\frac{5}{8}$ in. (16 mm)	$\frac{1}{2}$ (13) or less	...	200 (95)
	Circumferential butt welds in pipe NPS 4 (DN 100) and less, and tubes with nominal O.D. 4.5 in. (114 mm) or less and attachment welds	$\frac{1}{2}$ in. (13 mm) or less	0.15 or less	250 (120)
	Socket welds in pipe and tubes with nominal O.D. $2\frac{3}{8}$ in. (60 mm) or less	$\frac{1}{2}$ (13) or less	0.15 or less	250 (120)
9B Gr. 1	All welds, provided the procedure qualification is made using equal or greater thickness base material than the production weld [Note (3)]	$\frac{5}{8}$ (16) or less	...	200 (95)
	Attachment welds joining nonpressure-retaining material to pressure-retaining material over $\frac{5}{8}$ in. (16 mm)	$\frac{1}{2}$ (13) or less	...	200 (95)
	Circumferential butt welds in pipe NPS 4 (DN 100) and less, and tubes with nominal O.D. 4.5 in. (114 mm) or less and attachment welds	$\frac{1}{2}$ (13) or less	0.15 or less	250 (120)
	Socket welds in pipe NPS 2 (DN 50) and less, and tubes with nominal O.D. $2\frac{3}{8}$ in. (60 mm) or less	$\frac{1}{2}$ (13) or less	0.15 or less	250 (120)
10I Gr. 1	All welds in material $\frac{1}{2}$ in. (13 mm) and less	$\frac{1}{2}$ (13) or less	...	...
11A Gr. 4	All welds in material $\frac{1}{2}$ in. (13 mm) and less	$\frac{1}{2}$ (13) or less	...	250 (120)

GENERAL NOTE: The exemptions noted in this Table do not apply to the following:

- (1) electron beam welds in ferritic materials over  $\frac{1}{8}$  in. (3 mm) in thickness;
- (2) inertia and friction welds in material of any thickness of P-No. 3, P-No. 4, P-No. 5, P-No. 7 (except for Types 405 and 410S), P-No. 10, and P-No. 11 materials.

NOTES:

- (1) Where the thickness of material is identified in the Type of Weld column, it is the thickness of the base material at the welded joint.
- (2) Carbon level of the pressure-retaining materials being joined.
- (3) Weld Procedure Qualification coupon need not exceed 1.5 in. (38 mm) in thickness.
- (4) The maximum resulting hardness of the heat-affected zone in the procedure qualification test plate shall not exceed 35 Rc.
- (5) Intermediate postweld soak at not less than 200°F (95°C) for 2 hr minimum.
- (6) Intermediate postweld soak at not less than 300°F (150°C) for 2 hr minimum.

**NB-4622.8 Requirements for Exempting PWHT of Nozzles to Component Welds and Branch to Run Piping Welds.** Welds connecting nozzles or branch piping of P-No. 1 materials to components or run piping of P-No. 1 or P-No. 3 materials that are not exempted from PWHT in [Table NB-4622.7\(b\)-1](#) need not be given a postweld heat treatment if the requirements of (a) below are met for partial penetration and (b) below are met for full penetration welds.

(a) The partial penetration welds are made with A-No. 8 or non-air-hardening nickel-chromium-iron weld metal after:

(1) the ferritic materials to be joined are buttered or built-up with A-No. 8 or non-air-hardening nickel-chromium-iron weld metal having a minimum thickness of  $\frac{1}{4}$  in. (6 mm), and

(2) the heat affected zones of the buttered or built-up ferritic materials are postweld heat treated in accordance with [NB-4620](#), without the PWHT exemptions being applied, prior to making the final welds.

(b) The full penetration welds are made with A-No. 1 or A-No. 2 weld metal provided that:

(1) the component or run pipe is built-up or buttered in the area of the attachment with A-No. 1 or A-No. 2 metal having a minimum thickness of  $\frac{1}{4}$  in. (6 mm);

(2) the A-No. 1 or A-No. 2 weld metal buildup or buttering is postweld heat treated in accordance with [NB-4620](#) for P-No. 1 or P-No. 3 materials without the PWHT exemptions being applied;

(3) the welds do not penetrate through the component or run pipe thickness;

(4) weld metal with A-No. 1 or A-No. 2 analysis is used to join the nozzle or branch pipe of P-No. 1 material to the weld buildup or buttering;

(5) the nominal thickness of the weld joining the nozzle or branch pipe to the component or run pipe does not exceed  $1\frac{1}{2}$  in. (38 mm) and the maximum reported carbon content of the nozzle or branch piping connection does not exceed 0.30%;

(6) a 200°F (95°C) minimum preheat is maintained during welding whenever the nominal thickness of the weld exceeds:

(-a)  $1\frac{1}{4}$  in. (32 mm) and the maximum reported carbon content of the material of the nozzle or branch pipe is 0.30% or less, or

(-b)  $\frac{3}{4}$  in. (19 mm) and the maximum reported carbon content of material of the nozzle or branch pipe connection exceeds 0.30%.

**NB-4622.9 Temper Bead Weld Repair.** Repairs may be made without PWHT or after the final PWHT under the conditions listed below provided it is impractical to postweld heat treat the area after repair. References in the following paragraphs to "P-No." are to Section IX, QW/QB-422; to "F-No." are to Section IX, QW-432; and to "A-No." are to Section IX, QW-442.

(a) *General Requirements.*

(1) *Repair Welding Procedure.* The WPS shall be prepared and qualified in accordance with Section IX, QW-290 following the impact testing option with the testing performed in accordance with the requirements of [NB-4334](#) and [NB-4335](#).

(2) *Welding Procedure Qualification Test Plate.* The test assembly materials for the welding procedure qualification shall be subjected to heat treatment that is at least equivalent to the time and temperature applied to the material being repaired.

(3) *Neutron Fluence.* If the repair area is to be subjected to a significant fast neutron fluence greater than  $10^{19}$  nvt  $E^O > 1$  MeV, the weld metal Cu content shall not exceed 0.10%.

(4) *Nondestructive Examination Methods.* All nondestructive examination shall be in accordance with [NB-5000](#). Final nondestructive examination of completed weld repairs shall be performed after the weld has been at ambient temperature for a minimum period of 48 hr.

(5) *Preparation of Repair Cavity.* The maximum area of an individual repair based on the finished surface shall be 500 in.<sup>2</sup> (3 230 cm<sup>2</sup>) and the depth of repair shall not be greater than one-third of the base material thickness. The area to be repaired shall be suitably prepared for welding in accordance with a written procedure. Before repair, the surface to be repaired shall be examined by either the magnetic particle or liquid penetrant method.

(6) *Documentation of Weld Repairs.* Documentation of weld repairs shall be in accordance with [NB-4130](#) exclusive of the size requirements.

(7) *Performance Qualifications.* If the repair weld is to be performed where physical obstructions impair the welder's ability to perform, the welder shall also demonstrate the ability to deposit sound metal in the positions required, using the same parameters and simulated physical obstructions as are involved in the repair.

(8) *FCAW and GMAW Welding Electrodes.* The following shall apply except for nickel alloy F-No. 43 or A-No. 8 electrodes:

(-a) FCAW electrodes shall meet the requirements for supplemental designator *H4* indicating that they are very low in diffusible hydrogen as defined in the applicable specifications in Section II, Part C.

(-b) Welding shall begin using a previously unopened container of electrode. When the electrode is not used for more than 4 hr, it shall be removed from the wire feeder and stored in accordance with NQA-1, Subpart 2.2, Level C.

(9) *SMAW Welding Electrodes.* The following shall apply for SMAW welding electrodes:

(-a) Welding electrodes shall be supplied in hermetically sealed containers. After being removed from containers, electrodes shall be stored in a rod oven between 225°F (105°C) and 350°F (175°C).

(-b) Except for nickel alloy F-No. 3 or A-No. 8 electrodes

(-1) electrodes shall meet the requirements for supplemental designators *R* indicating a moisture-resistant coating and *H4* indicating that they are very low in diffusible hydrogen as defined in the specifications in Section II, Part C.

(-2) when electrodes are removed from elevated temperature storage, they may be exposed to the atmosphere in accordance with the following schedule:

(+a) E70XX: 9 hr

(+b) E80XX: 4 hr

(+c) E90XX and higher strength: 2 hr

Electrodes that are exposed to the atmosphere for more than the above time shall be discarded or baked to remove any absorbed moisture for the time and temperature recommended by the electrode manufacturer or the applicable filler metal specification. After baking and before the electrodes are allowed to cool below 225°F (105°C), they shall be transferred into holding ovens at 225°F (105°C) to 350°F (175°C).

(10) *Postweld Hydrogen Bakeout*. For repairs made using SMAW or FCAW, the weld area shall be maintained at a temperature of 450°F (230°C) to 550°F (290°C) for a minimum time of 2 hr after welding is completed for P-No. 1 materials and 4 hr for P-No. 3 materials.

(b) *Repairs to Base Metals and Weld Metal*. Weld repairs to P-No. 1 and P-No. 3 material and A-Nos. 1, 2, 10, or 11 weld metal may be made provided the following additional requirements are met:

(1) The second (temper bead) layer shall be examined by the magnetic particle or liquid penetrant method.

(2) The completed weld shall have the weld reinforcement, including the final layer, removed substantially flush with the surface prior to performing the required nondestructive examination.

(3) The nondestructive examination of the repair weld and base metal for a minimum of 4 in. (100 mm) around the repair shall be in accordance with NB-4453.4. In addition, all repairs shall be ultrasonically examined.

(c) *Repair Welds to Cladding*. Weld repairs may be made to P-No. 8 or P-No. 43 cladding on P-No. 1 and P-No. 3 material after final PWHT. If the defect is removed and there is greater than  $\frac{1}{8}$  in. (3 mm) of A-No. 8 or F-No. 43 weld metal thickness remaining above the cladding weld metal/base metal interface, repair may be made without postweld heat treatment provided the welding process is SMAW or GTAW; where  $\frac{1}{8}$  in. (3 mm) or less of A-8 or F-43 weld metal thickness remains or a process other than SMAW or GTAW is to be used, (a) and the following additional requirements apply:

(1) The depth of the repair cavity into the ferritic base metal shall not be greater than  $\frac{1}{4}$  in. (6 mm) or 10% of the base metal thickness, whichever is less. Areas with cavity depth greater than this shall be repaired in accordance with (b) to within the limit before implementing the cladding repair.

(2) The repairs shall be made using A-No. 8 weld metal for P-No. 8 cladding or F-No. 43 weld metal for either P-No. 8 or P-No. 43 cladding.

(3) The repair weld and base metal for a minimum of 4 in. (100 mm) around the repair shall be examined by the liquid penetrant method.

(d) *Temper Bead Weld Repair to Dissimilar Metal Welds Made With Buttering*. This paragraph applies to welds between P-No. 1 or P-No. 3 and austenitic stainless or nickel base metals where the P-No. 1 or P-No. 3 weld ends have been buttered with A-No. 8 or F-No. 43 filler metal, then heat treated. If the defect is removed and there is greater than  $\frac{1}{8}$  in. (3 mm) of A-No. 8 or F-No. 43 weld metal thickness remaining above the buttering weld metal/base metal interface, repair may be made without postweld heat treatment provided the welding process is SMAW or GTAW; if  $\frac{1}{8}$  in. (3 mm) or less of A-No. 8 or F-No. 43 weld metal thickness remains or a process other than SMAW or GTAW is to be used, (a) and the following additional requirements apply:

(1) If the defect penetrates into P-No. 1 or P-No. 3 base material, repair of that base material may be performed in accordance with this paragraph provided the depth of repair measured in the axial direction does not exceed  $\frac{3}{8}$  in. (10 mm). See Figure NB-4622.9(d)(1)-1. The depth of the repair cavity shall not exceed one-half the joint thickness. In the event that the extent of the repair into the ferritic material in the axial direction exceeds  $\frac{3}{8}$  in. (10 mm), repair shall be made in accordance with (b) prior to replacing the A-No. 8 or F-No. 43 weld metal.

(2) After at least  $\frac{3}{16}$  in. (5 mm) of A-No. 8 or F-No. 43 weld metal has been deposited against the P-No. 1 or P-No. 3 base metal, the repair area shall be given a postweld hydrogen bakeout as described in (a)(10), after which the weld may be completed without further postweld hydrogen baking.

(3) The repair weld and base metal for a minimum of 4 in. (100 mm) around the repair shall be examined by the liquid penetrant method.


(4) The repair shall be examined by the radiographic method and, if practical, by the ultrasonic method.

(5) For repairs to partial penetration welds, the radiographic and ultrasonic examinations specified above need not be performed if meaningful results cannot be obtained. For those cases, liquid penetrant examination shall be performed in accordance with the following:

(-a) For repairs where the depth of the cavity did not exceed  $\frac{3}{16}$  in. (5 mm), liquid penetrant examination shall be performed after the weld is completed.

(-b) For repairs where the depth of the cavity exceeded  $\frac{3}{16}$  in. (5 mm), liquid penetrant examination shall be performed after approximately  $\frac{3}{16}$  in. (5 mm) of weld metal has been deposited and the postweld hydrogen bakeout specified in (a)(10) has been completed. Additional similar incremental deposit thicknesses shall be liquid penetrant examined, but additional postweld hydrogen bakeouts are not required.

**Figure NB-4622.9(d)(1)-1**  
**Dissimilar Metal Repair Cavity Measurement**



### **NB-4623 PWHT Heating and Cooling Rate Requirements**

Above 800°F (425°C) the rate of heating and cooling in any hourly interval shall not exceed 400°F (220°C) divided by the maximum thickness in inches of the material being heat treated, but shall not exceed 400°F (220°C) and need not be less than 100°F (56°C) in any hourly interval. During the heating and cooling period there shall not be a greater variation in temperature than 250°F (140°C) within any 15 ft (4.5 m) interval of weld length. The exceptions of (a) and (b) below are permitted.

(a) P-No. 6 material may be cooled in air from the postweld heat treatment holding temperature specified in Table NB-4622.1-1.

(b) For P-No. 7 material the cooling rate at temperatures above 1,200°F (650°C) shall not exceed 100°F/hr (56°C/hr), after which the rate of cooling shall be sufficiently rapid to prevent embrittlement.

### **NB-4624 Methods of Postweld Heat Treatment**

The postweld heat treatment shall be performed in accordance with the requirements of one of the following subparagraphs.

**NB-4624.1 Furnace Heating — One Heat.** Heating the item in a closed furnace in one heat is the preferred procedure and should be used whenever practical. The furnace atmosphere shall be controlled so as to avoid excessive oxidation and direct impingement of flame on the component or item is prohibited.

**NB-4624.2 Furnace Heating — More Than One Heat.** The item may be heated in more than one heat in a furnace, provided the furnace atmosphere control requirements of NB-4624.1 apply and overlap of the heated sections of the component or item is at least 5 ft (1.5 m). When this procedure is used, the portion of the component or item outside the furnace shall be shielded so that the temperature gradient is not harmful. The cross section

where the component or item projects from the furnace shall not intersect a nozzle or other structural discontinuity.

**NB-4624.3 Local Heating.** Welds may be locally postweld heat treated when it is not practical to heat treat the entire component or item. Local postweld heat treatment shall consist of heating a circumferential band around the component or item at temperature within the ranges specified in this Subarticle. The minimum width of the controlled band at each side of the weld, on the face of the greatest weld width, shall be the thickness of the weld or 2 in. (50 mm), whichever is less. The temperature of the component or item from the edge of the controlled band outward shall be gradually diminished so as to avoid harmful thermal gradients. This procedure may also be used for postweld heat treatment after repairs.

**NB-4624.4 Heating Items Internally.** The component or item may be heated internally by any appropriate means and with adequate indicating and recording temperature devices to aid in the control and maintenance of a uniform distribution of temperature in the item. Previous to this operation, the item should be fully enclosed with insulating material.

### **NB-4630 HEAT TREATMENT OF WELDS OTHER THAN THE FINAL POSTWELD HEAT TREATMENT**

The holding temperature, the time at temperature, the heating rate, and the cooling rate need not conform to the requirements of this Article for heat treatments other than the final postweld heat treatment.

**NB-4650 HEAT TREATMENT AFTER BENDING OR FORMING FOR PIPES, PUMPS, AND VALVES****NB-4651 Conditions Requiring Heat Treatment After Bending or Forming**

(a) Ferritic alloy steel pipe or formed portions of pumps or valves that have been heated for bending or other forming operations shall receive a heat treatment in accordance with [NB-4620](#), a full anneal, a normalizing and tempering treatment, or a quenching and tempering treatment.

(b) Carbon steel pipe or formed portions of pumps or valves with a wall thickness greater than  $\frac{3}{4}$  in. (19 mm) included in group P-No. 1 in Section IX that have been cold bent or formed shall receive heat treatment in accordance with [NB-4620](#).

(c) Ferritic alloy pipe or formed portions of pumps or valves with an outside diameter greater than 4 in. (100 mm) and a wall thickness greater than  $\frac{1}{2}$  in. (13 mm) included in groups P-No. 3 through P-No. 5 in Section IX that have been cold bent or formed shall require a heat treatment in accordance with [NB-4620](#).

**NB-4652 Exemptions From Heat Treatment After Bending or Forming**

If the conditions described in (a) through (d) below are met, heat treatment after bending or forming is not required.

(a) Carbon steel pipe or portions of pumps and valves that have been bent or formed at a temperature of 1,650°F (900°C) or higher shall require no subsequent heat treatment, provided the requirements of [NB-4213](#) have been met.

(b) Austenitic stainless steel pipe, or portions of pumps or valves that have been heated for bending or other forming operations, may be used in the as-bent condition unless the Design Specifications require a heat treatment following bending or forming.

(c) Austenitic stainless steel pipe, or portions of pumps or valves that have been cold bent or formed, may be used in the as-bent condition unless the Design Specifications require a heat treatment following bending or forming.

(d) Carbon steel and ferritic alloy steel pipe, or portions of pumps or valves with sizes and wall thicknesses less than specified in [NB-4651\(b\)](#) and [NB-4651\(c\)](#), may be cold bent or formed without a heat treatment following bending.

**NB-4660 HEAT TREATMENT OF ELECTROSLAG WELDS**

Electroslag welds in ferritic materials over  $1\frac{1}{2}$  in. (38 mm) in thickness at the joints shall be given a grain refining heat treatment.

**NB-4700 MECHANICAL JOINTS****NB-4710 BOLTING AND THREADING****NB-4711 Thread Engagement**

The threads of all bolts or studs shall be engaged in accordance with the design.

**NB-4712 Thread Lubricants**

Any lubricant or compound used in threaded joints shall be suitable for the service conditions and shall not react unfavorably with either the service fluid or any component material in the system.

**NB-4713 Removal of Thread Lubricants**

All threading lubricants or compounds shall be removed from surfaces which are to be seal welded.

**NB-4720 BOLTING FLANGED JOINTS**

In bolting gasketed flanged joints, the contact faces of the flanges shall bear uniformly on the gasket and the gasket shall be properly compressed in accordance with the design principles applicable to the type of gasket used. All flanged joints shall be made up with relatively uniform bolt stress.

**NB-4730 ELECTRICAL AND MECHANICAL PENETRATION ASSEMBLIES**

Tubes or pipes of NPS 2 (DN 50) and less may be joined to a penetration assembly in accordance with the rules of [NB-4350](#).



## ARTICLE NB-5000 EXAMINATION

### NB-5100 GENERAL REQUIREMENTS FOR EXAMINATION

### NB-5110 METHODS, NONDESTRUCTIVE EXAMINATION PROCEDURES, AND CLEANING

#### NB-5111 Methods

Nondestructive examinations shall be conducted in accordance with the examination methods of Section V, except as they may be modified by the requirements of this Article.

(a) *Fabrication.* Radiographic examination shall be performed in accordance with Section V, Article 2, except that fluorescent screens are not permitted for film radiography, the geometric unsharpness shall not exceed the limits of T-274.2, and the image quality indicators (IQIs) of Table NB-5111-1 shall be used in lieu of those shown in Table T-276. The requirements for the retention of electronic and digital radiographic images are the same as that for radiographic film. Ultrasonic examination shall be in accordance with Section V, Article 4; magnetic particle examination shall be in accordance with Section V, Article 7; liquid penetrant examination shall be in accordance with Section V, Article 6; and leak testing shall be in accordance with Section V, Article 10.

(b) *Preservice.* Ultrasonic examinations required for weld preservice examination shall be in accordance with Section XI, Appendix I; eddy current examination shall be in accordance with Section V, Article 8; and surface examinations shall be in accordance with (a).

(c) The examinations required by this Article, or by reference to this Article, shall be performed by personnel who have been qualified as required by this Article. The results of the examinations shall be evaluated in accordance with the acceptance standards of this Article.

#### NB-5112 Nondestructive Examination Procedures

All nondestructive examinations required by this Article shall be performed in accordance with detailed written procedures which have been proven by actual demonstration to the satisfaction of the Inspector. The procedures shall comply with the appropriate Article of Section V for the particular examination method. The digitization of radiographic film and radioscopy images shall meet the requirements of Section V, Article 2, Mandatory Appendix III, "Digital Image Acquisition, Display, and Storage for Radiography and Radioscopy." Written procedures and

records of demonstration of procedure capability and personnel qualification shall be made available to the Inspector on request. At least one copy of the procedure shall be readily available to all applicable nondestructive examination personnel for reference and use.

#### NB-5113 Post-Examination Cleaning

Following any nondestructive examination in which examination materials are applied to the piece, the piece shall be thoroughly cleaned in accordance with applicable material or procedure specifications.

### NB-5120 TIME OF EXAMINATION OF WELDS AND WELD METAL CLADDING

Acceptance examinations of welds and weld metal cladding required by NB-5200 shall be performed at the times stipulated in (a) through (h) below during fabrication and installation.

(a) Radiographic examination of welds shall be performed after an intermediate<sup>30</sup> or final postweld heat treatment, when required, except as provided in (1) and (2) below.

(1) Radiographic examination of welds in piping, pumps, and valves fabricated of P-No. 1 materials may be performed prior to any required postweld heat treatment.

(2) Radiographic examination of welds in vessels fabricated of P-No. 1 materials and all welds in components fabricated of P-No. 3 materials may be performed prior to an intermediate or final postweld heat treatment, provided the welds are ultrasonically examined [NB-5111(a)] after an intermediate or final postweld heat treatment. The ultrasonic examination and acceptance standards shall be in accordance with NB-5331.

(b) Magnetic particle or liquid penetrant examinations of welds shall be performed after any required postweld heat treatment, except that welds in P-No. 1 material may be examined either before or after postweld heat treatment. The magnetic particle or liquid penetrant examination of welds at progressive stages of welding, as required in NB-5245 and NB-5246, may be performed before PWHT. Surface examination of applicable welds in vessels shall be performed as specified in NB-5410(a).

(c) All dissimilar metal weld joints, such as in austenitic or high nickel to ferritic material, or using austenitic or high nickel alloy filler metal to join ferritic materials which penetrate the wall, shall be examined after final postweld heat treatment.



**Table NB-5111-1**  
**Thickness, IQI Designations, Essential Holes, and Wire Diameters**

IQI(s) — Hole or Wire Type [Note (1)]								
Source Side					Film Side			
Single Wall Material Thickness Range, in. (mm)	Designation	Hole Size, in. (mm)	Essential Hole	Required Wire Diameter-IQI, in. (mm)	Designation	Hole Size, in. (mm)	Essential Hole	Required Wire Diameter-IQI, in. (mm)
Up to 0.25 (6.4) incl.	5	0.040 (1.02)	4T	0.006 (0.15)	5	0.040 (1.02)	4T	0.006 (0.15)
Over $\frac{1}{4}$ - $\frac{3}{8}$ (6 - 10)	7	0.040 (1.02)	4T	0.006 (0.15)	7	0.040 (1.02)	4T	0.006 (0.15)
Over $\frac{3}{8}$ - $\frac{1}{2}$ (10 - 13)	10	0.040 (1.02)	4T	0.010 (0.25)	10	0.040 (1.02)	4T	0.010 (0.25)
Over $\frac{1}{2}$ - $\frac{5}{8}$ (13 - 16)	12	0.050 (1.27)	4T	0.013 (0.33)	12	0.050 (1.27)	4T	0.013 (0.33)
Over $\frac{5}{8}$ - $\frac{3}{4}$ (16 - 19)	15	0.060 (1.52)	4T	0.016 (0.41)	12	0.050 (1.27)	4T	0.013 (0.33)
Over $\frac{3}{4}$ - 1 (19 - 25)	20	0.040 (1.02)	2T	0.016 (0.41)	17	0.035 (0.89)	2T	0.013 (0.33)
Over 1 - $1\frac{1}{4}$ (25 - 32)	25	0.050 (1.27)	2T	0.020 (0.51)	17	0.035 (0.89)	2T	0.013 (0.33)
Over $1\frac{1}{4}$ - $1\frac{1}{2}$ (32 - 38)	30	0.060 (1.52)	2T	0.025 (0.64)	20	0.040 (1.02)	2T	0.016 (0.41)
Over $1\frac{1}{2}$ - 2 (38 - 50)	35	0.070 (1.78)	2T	0.032 (0.81)	25	0.050 (1.27)	2T	0.020 (0.51)
Over 2 - $2\frac{1}{2}$ (50 - 64)	40	0.080 (2.03)	2T	0.040 (1.02)	30	0.060 (1.52)	2T	0.025 (0.64)
Over $2\frac{1}{2}$ - 3 (64 - 75)	45	0.090 (2.29)	2T	0.040 (1.02)	35	0.070 (1.78)	2T	0.032 (0.81)
Over 3 - 4 (75 - 100)	50	0.100 (2.54)	2T	0.050 (1.27)	40	0.080 (2.03)	2T	0.040 (1.02)
Over 4 - 6 (100 - 150)	60	0.120 (3.05)	2T	0.063 (1.60)	45	0.090 (2.29)	2T	0.040 (1.02)
Over 6 - 8 (150 - 200)	80	0.160 (4.06)	2T	0.100 (2.54)	50	0.100 (2.54)	2T	0.050 (1.27)
Over 8 - 10 (200 - 250)	100	0.200 (5.08)	2T	0.126 (3.20)	60	0.120 (3.05)	2T	0.063 (1.60)
Over 10 - 12 (250 - 300)	120	0.240 (6.10)	2T	0.160 (4.06)	80	0.160 (4.06)	2T	0.100 (2.54)
Over 12 - 16 (300 - 400)	160	0.320 (8.13)	2T	0.250 (6.35)	100	0.200 (5.08)	2T	0.126 (3.20)
Over 16 - 20 (400 - 500)	200	0.400 (10.16)	2T	0.320 (8.13)	120	0.240 (6.10)	2T	0.160 (4.06)

NOTE:

(1) Hole (plaque)-type IQIs may be used on flat plates and on objects with geometries such that the IQI hole image is not distorted.

(d) The magnetic particle or liquid penetrant examination of weld surfaces that are to be covered with weld metal cladding shall be performed before the weld metal cladding is deposited. The magnetic particle or liquid penetrant examination of weld surfaces that are not accessible after a postweld heat treatment shall be performed prior to the operation which caused this inaccessibility. These examinations may be performed before PWHT.

(e) Weld metal cladding shall be examined after either an intermediate<sup>30</sup> or final postweld heat treatment, except the examination of weld metal cladding on P-Nos. 1, 3, and 11 materials may be performed before or after the intermediate<sup>30</sup> or final postweld heat treatment.

(f) All of the joints in austenitic stainless steel and non-ferrous material shall be examined by the liquid penetrant method after an intermediate or final postweld heat treatment, if any, is performed. This requirement does not apply to tube-to-tubesheet joints.

(g) Ultrasonic examination of electroslog welds in ferritic materials shall be performed after a grain refining heat treatment, when performed, or after final postweld heat treatment.

(h) Required volumetric preservice examination for welds in vessels shall be as specified in NB-5410(b).

### NB-5130 EXAMINATION OF WELD EDGE PREPARATION SURFACES

All full penetration weld edge preparation surfaces for joint Categories A, B, C, D, and similar joints in material 2 in. (50 mm) or more in thickness shall be examined by the magnetic particle or liquid penetrant method. Indications shall be evaluated in accordance with the acceptance standards of (a), (b), and (c) below.

(a) Only indications with major dimensions greater than  $\frac{1}{16}$  in. (1.5 mm) shall be considered relevant imperfections.

(b) Laminar-type imperfections are acceptable without repair if they do not exceed 1 in. (25 mm) in length. The extent of all laminar-type imperfections exceeding 1 in. (25 mm) in length shall be determined by ultrasonic examination. Imperfections exceeding 1 in. (25 mm) in length shall be repaired by welding to a depth of  $\frac{3}{8}$  in. (10 mm) or the depth of the imperfection, whichever is less, unless the ultrasonic examination reveals that additional depth of repair is required to meet the ultrasonic examination requirement for the product form.

(c) Indications of nonlaminar imperfections of (1) through (3) below are unacceptable:

(1) any linear indications greater than  $\frac{3}{16}$  in. (5 mm) long;

(2) rounded indications with dimensions greater than  $\frac{3}{16}$  in. (5 mm);

(3) four or more indications, in a line separated by  $\frac{1}{16}$  in. (1.5 mm) or less, edge to edge.

(d) Weld repairs made to weld edge preparations for Category A, B, C, D, or similar type welds shall be examined by the magnetic particle or liquid penetrant method before the surfaces become inaccessible. The examination may be performed before or after postweld heat treatment.

#### **NB-5140 EXAMINATION OF WELDS AND ADJACENT BASE MATERIAL**

When performing the surface examinations of weld joint Categories A, B, C, and D and the equivalent welded joints in piping, pumps, and valves as required by [NB-5200](#), the external and accessible internal weld surfaces and adjacent base material for at least  $\frac{1}{2}$  in. (13 mm) on each side of the weld shall be included in the examination. Acceptance standards for the weld shall be as stated in this Article while the acceptance standards for base material shall be as stated in [NB-2500](#).

#### **NB-5200 REQUIRED EXAMINATION OF WELDS FOR FABRICATION AND PRESERVICE BASELINE**

#### **NB-5210 CATEGORY A VESSEL WELDED JOINTS AND LONGITUDINAL WELDED JOINTS IN OTHER COMPONENTS**

Category A welded joints in vessels and longitudinal welded joints in other components shall be examined by a volumetric<sup>31</sup> and either the liquid penetrant or magnetic particle method.

#### **NB-5220 CATEGORY B VESSEL WELDED JOINTS AND CIRCUMFERENTIAL WELDED JOINTS IN PIPING, PUMPS, AND VALVES**

##### **NB-5221 Vessel Welded Joints**

Category B welded joints in vessels shall be examined by a volumetric<sup>31</sup> and either the liquid penetrant or magnetic particle method.

##### **NB-5222 Piping, Pump, and Valve Circumferential Welded Joints**

(a) Butt welded joints shall be examined by a volumetric<sup>31</sup> and either the liquid penetrant or magnetic particle method.

(b) Fillet and partial penetration welded joints shall be examined by either the liquid penetrant or magnetic particle method.

(c) Instrument tube butt welds qualified in accordance with [NB-4337](#) shall be examined by the liquid penetrant method.

#### **NB-5230 CATEGORY C VESSEL WELDED JOINTS AND SIMILAR WELDED JOINTS IN OTHER COMPONENTS**

##### **NB-5231 General Requirements**

(a) Category C full penetration butt welded joints in vessels and similar welded joints in other components shall be examined by a volumetric<sup>31</sup> and either the liquid penetrant or magnetic particle method.

(b) Category C full penetration corner welded joints and similar welded joints in other components shall be ultrasonically or radiographically examined and either liquid penetrant or magnetic particle examined.

(c) Type 2 Category C full penetration corner welded joints similar to [Figure NB-4243-1](#) sketches (d), (e), and (f) also require the fusion zone and the parent metal beneath the attachment surface to be ultrasonically examined after welding to verify freedom from lack of fusion and laminar defects.

(d) Category C partial penetration and fillet welded joints, and similar welded joints in other components shall be examined by either the magnetic particle or liquid penetrant method on all accessible surfaces.

#### **NB-5240 CATEGORY D VESSEL WELDED JOINTS AND BRANCH AND PIPING CONNECTIONS IN OTHER COMPONENTS**

##### **NB-5241 General Requirements**

All Category D welded joints in vessels and similar welded joints in other components shall be examined as stated in the following paragraphs.

##### **NB-5242 Full Penetration Butt Welded Nozzles, Branch, and Piping Connections**

Nozzles, branch, and piping connections attached by full penetration butt welded joints as shown in [Figure NB-4244\(a\)-1](#) shall be examined by the radiographic and either the liquid penetrant or magnetic particle method.

##### **NB-5243 Corner Welded Nozzles, Branch, and Piping Connections**

(13)

(a) Full penetration corner welded nozzles in vessels as shown in [Figure NB-4244\(b\)-1](#) shall be examined by either the ultrasonic or the radiographic method, and either the liquid penetrant or magnetic particle method. If radiographed, the weld fusion zone and the vessel parent metal beneath the attachment weld for details shown in [Figure NB-4244\(b\)-1](#) sketches (a) and (b) and the weld fusion zone and parent material beneath the nozzle surface for details shown in [Figure NB-4244\(b\)-1](#) sketches (c), (d), (e), and (g) shall be ultrasonically examined after welding to assure freedom from lack of fusion and laminar defects.

(b) Full penetration corner welded branch and piping connections exceeding NPS 4 (DN 100) in piping, pumps, and valves, as shown in [Figure NB-4244\(b\)-1](#), shall be examined by either the ultrasonic or the radiographic method, and either the liquid penetrant or magnetic particle method.

(c) Full penetration corner welded branch and piping connections less than or equal to NPS 4 (DN 100) in piping, pumps, and valves shall be examined by either the magnetic particle or liquid penetrant method.

**(13) NB-5244 Weld Metal Buildup at Openings for Nozzles, Branch, and Piping Connections**

(a) When weld metal buildup is made to a surface as shown in Step 1 of [Figure NB-4244\(c\)-1](#), the weld metal buildup and the parent metal beneath the weld metal buildup shall be ultrasonically examined. The parent material beneath the weld metal buildup shall be ultrasonically examined to detect laminar defects after weld metal buildup. Nozzles, branch, and piping connections may then be attached by a full penetration weld as shown in Step 2 of [Figure NB-4244\(c\)-1](#). The full penetration butt welded joint shall be examined by either the ultrasonic or radiographic method, and either the liquid penetrant or magnetic particle method and the weld metal buildup shall be examined by either the magnetic particle or liquid penetrant method.

(b) For branch and piping connections less than or equal to NPS 4 (DN 100) in piping, pumps, and valves, full penetration welds shown in [Figure NB-4244\(c\)-1](#) shall be examined in accordance with [NB-5243\(c\)](#).

**(13) NB-5245 Fillet Welded and Partial Penetration Welded Joints**

Fillet welded and partial penetration welded joints, as permitted in [NB-3352.4\(d\)](#) or [NB-3661.3](#), and as shown in [Figures NB-4244\(d\)-1](#) and [NB-4244\(d\)-2](#) sketches (a) through (c) or [Figure NB-4246\(b\)-1](#), shall be examined progressively using either the magnetic particle or liquid penetrant methods. The increments of examination shall be the lesser of one-half of the maximum welded joint dimension measured parallel to the center line of the connection or  $\frac{1}{2}$  in. (13 mm). For [Figure NB-4244\(d\)-2](#) sketch (d), the increments of examination shall be the lesser of one-half of the maximum weld joint dimension measured perpendicular to the center line of the connection or  $\frac{1}{2}$  in. (13 mm). The surface of the finished welded joint shall also be examined by either method.

**(13) NB-5246 Oblique Full Penetration Welded Joints and Weld Buildup for Nozzles, Branch, and Piping Connections**

(a) Full penetration welded joints for oblique nozzles in vessels as shown in [Figure NB-4244\(e\)-1](#) shall be examined by either the ultrasonic or radiographic method,

and either the liquid penetrant or magnetic particle method. If radiographed, the fusion zone and the parent metal beneath the weld metal buildup as shown in [Figure NB-4244\(e\)-1](#), sketches (b) and (c) shall be ultrasonically examined after weld metal buildup to assure freedom from lack of fusion and laminar defects. In addition, the weld fusion zone and the parent material beneath the weld as shown in [Figure NB-4244\(e\)-1](#) sketch (a), shall be ultrasonically examined after welding to assure freedom from lack of fusion and laminar defects.

(b) Full penetration oblique welded joint branch and piping connections in piping, pumps, and valves, as shown in [Figure NB-4244\(e\)-1](#), shall be examined in accordance with the requirements for corner welded branch and piping connections specified in [NB-5243\(b\)](#) and [NB-5243\(c\)](#), as applicable.

**NB-5250 WELD METAL BUILDUPS TO FORM NOZZLES, BRANCH AND PIPING CONNECTIONS AND FOR CLOSURE OPENING REINFORCEMENT**

(13)

When weld metal buildup is made to a surface to form nozzles, branch and piping connections or closure opening reinforcement, the weld metal buildup shall be ultrasonically examined. In addition, the parent base metal beneath the weld metal buildup shall be ultrasonically examined after welding to detect laminar defects.

**NB-5260 FILLET, PARTIAL PENETRATION, SOCKET, AND ATTACHMENT WELDED JOINTS**

**NB-5261 Fillet, Partial Penetration, and Socket Welded Joints**

Fillet and partial penetration welded joints, except for nonstructural attachments ([NB-1132.1](#)), and socket welds shall be examined by the magnetic particle or liquid penetrant method.

**NB-5262 Structural Attachment Welded Joints**

Structural attachment welded joints made to pressure-retaining material shall be examined by either the magnetic particle or liquid penetrant method.

**NB-5270 SPECIAL WELDED JOINTS**

**NB-5271 Welded Joints of Specially Designed Seals**

Welded joints of this type shall be examined by either the magnetic particle or liquid penetrant method.

**NB-5272 Weld Metal Cladding**

Weld metal cladding shall be examined by the liquid penetrant method.

**NB-5273 Hard Surfacing**

Hard surfacing weld metal shall be examined by the liquid penetrant method in accordance with NB-2546, and the acceptance standards applicable to materials less than  $\frac{5}{8}$  in. (16 mm) thick shall apply. Penetrant examination is not required for hard surfacing on valves with inlet connections NPS 4 (DN 100) or less.

**NB-5274 Tube-to-Tubesheet Welded Joints**

Tube-to-tubesheet welded joints shall be examined by the liquid penetrant method.

**NB-5275 Brazed Joints**

Flux and flux residue shall be removed from all surfaces prior to examination. Joints shall be visually examined on all accessible surfaces to determine whether there has been adequate flow of brazing metal through the joint. Optical aids may be employed for indirect visual examination of joints which cannot be directly examined.

**NB-5276 Inertia and Continuous Drive Friction Welds**

(a) When radiographic examination is required by this Article, inertia and continuous drive friction welds shall also be examined by the ultrasonic method to verify bonding over the entire area.

(b) The materials used shall be those assigned a P-Number by Section IX, but shall not include rimmed or semikilled steel.

(c) One of the two parts to be joined must be held in a fixed position and the other part rotated. The two faces to be joined must be symmetrical with respect to the axis of rotation.

(d) The weld between the two members shall be a full penetration weld.

**NB-5277 Electron Beam Welds**

In addition to the requirements for the type of weld being examined, all complete penetration welds made by the electron beam welding process shall be ultrasonically examined.

**NB-5278 Electroslag Welds**

In addition to the requirements for the type of weld being examined, all complete penetration welds made by the electroslag welding process in ferritic materials shall be ultrasonically examined.

**NB-5279 Special Exceptions**

When the joint detail does not permit radiographic examination to be performed in accordance with this article, ultrasonic examination plus liquid penetrant or magnetic particle examination of the completed weld may be substituted for the radiographic examination. The absence of suitable radiographic equipment shall not be justification for such substitution. The substitution of ultrasonic exam-

ination can be made provided the examination is performed using a detailed written procedure which has been proven by actual demonstration to the satisfaction of the Inspector as capable of detecting and locating defects described in this Subsection. The nondestructive examinations shall be in accordance with NB-5110 and meet the acceptance standards of NB-5300.

**NB-5280 PRESERVICE EXAMINATION****NB-5281 General Requirements**

(a) Examinations required by NCA-3252(c) shall be completed prior to completion of the N-5 Data Report.

(b) All volumetric and surface examinations shall be documented with results and identified in a form consistent with those required in NCA-4134.17 for transfer to the Owner.

**NB-5282 Examination Requirements**

(a) Components shall be examined as specified in Section XI, Table IWB-2500-1. The method of examination for the components and parts of the pressure-retaining boundaries shall comply with those tabulated in Table IWB-2500-1. Only the volumetric and surface examinations are required to be performed.

(b) For Control Rod housings, Examination Category B-O, the examination shall be extended to include essentially 100% of the welds in the installed peripheral control rod drive housing only.

**NB-5283 Components Exempt From Preservice Examination**

The following components or parts of components are exempted from the volumetric and surface examination requirements of this subarticle:

(a) piping of NPS 1 (DN 25) and smaller, except for steam generator tubing;

(b) reactor vessel head connections and associated piping, NPS 2 (DN 50) and smaller, made inaccessible by control rod drive penetrations; and

(c) integral attachments of supports and restraints that are inaccessible due to being encased in concrete, buried underground, or encapsulated by guard pipe.

**NB-5300 ACCEPTANCE STANDARDS****NB-5320 RADIOGRAPHIC ACCEPTANCE STANDARDS**

Indications shown on the radiographs of welds and characterized as imperfections are unacceptable under the following conditions:

(a) any indication characterized as a crack or zone of incomplete fusion or penetration;

(b) any other elongated indication which has a length greater than:

(1)  $\frac{1}{4}$  in. (6 mm) for  $t$  up to  $\frac{3}{4}$  in. (19 mm), inclusive

(2)  $\frac{1}{3}t$  for  $t$  from  $\frac{3}{4}$  in. (19 mm) to  $2\frac{1}{4}$  in. (57 mm), inclusive

(3)  $\frac{3}{4}$  in. (19 mm) for  $t$  over  $2\frac{1}{4}$  in. (57 mm)

where  $t$  is the thickness of the thinner portion of the weld;

(c) internal root weld conditions are acceptable when the density change or image brightness difference as indicated in the radiograph is not abrupt; elongated indications on the radiograph at either edge of such conditions shall be unacceptable, as provided in (b) above;

(d) any group of aligned indications having an aggregate length greater than  $t$  in a length of  $12t$ , unless the minimum distance between successive indications exceeds  $6L$ , in which case the aggregate length is unlimited,  $L$  being the length of the largest indication;

(e) rounded indications in excess of that shown as acceptable in Appendix VI.

## **NB-5330 ULTRASONIC ACCEPTANCE STANDARDS**

### **NB-5331 Fabrication**

All imperfections which produce a response greater than 20% of the reference level shall be investigated to the extent that the operator can determine the shape, identity, and location of all such imperfections and evaluate them in terms of the acceptance standards given in (a) and (b) below.

(a) Imperfections are unacceptable if the indications exceed the reference level amplitude and have lengths exceeding:

(1)  $\frac{1}{4}$  in. (6 mm) for  $t$  up to  $\frac{3}{4}$  in. (19 mm), inclusive

(2)  $\frac{1}{3}t$  for  $t$  from  $\frac{3}{4}$  in. (19 mm) to  $2\frac{1}{4}$  in. (57 mm), inclusive

(3)  $\frac{3}{4}$  in. (19 mm) for  $t$  over  $2\frac{1}{4}$  in. (57 mm)

where  $t$  is the thickness of the weld being examined; if a weld joins two members having different thicknesses at the weld,  $t$  is the thinner of these two thicknesses.

(b) Indications characterized as cracks, lack of fusion, or incomplete penetration are unacceptable regardless of length.

### **NB-5332 Preservice Examination**

(a) Components whose volumetric examination reveals flaws that meet the acceptance standards of Section XI, IWB-3000 shall be acceptable. The flaws will be dimensioned and recorded in accordance with Section V, Article 4 and this Subsection.

(b) Components whose volumetric examination reveals flaws that exceed the standards of IWB-3000 are not acceptable for service and shall be repaired.

## **NB-5340 MAGNETIC PARTICLE ACCEPTANCE STANDARDS**

### **NB-5341 Evaluation of Indications**

(a) Mechanical discontinuities at the surface are revealed by the retention of the examination medium. All indications are not necessarily defects, however, since certain metallurgical discontinuities and magnetic permeability variations may produce similar indications which are not relevant.

(b) Any indication that is believed to be nonrelevant shall be reexamined by the same or other nondestructive examination methods to verify whether or not actual defects are present. Surface conditioning may precede the re-examination. After an indication has been verified to be nonrelevant, it is not necessary to reinvestigate repetitive nonrelevant indications of the same type. Nonrelevant indications that would mask defects are unacceptable.

(c) Relevant indications are indications which result from imperfections. Linear indications are indications in which the length is more than three times the width. Rounded indications are indications which are circular or elliptical with the length equal to or less than three times the width.

### **NB-5342 Acceptance Standards**

(a) Only imperfections producing indications with major dimensions greater than  $\frac{1}{16}$  in. (1.5 mm) shall be considered relevant imperfections.

(b) Imperfections producing the following indications are unacceptable:

(1) any cracks and linear indications;

(2) rounded indications with dimensions greater than  $\frac{3}{16}$  in. (5 mm);

(3) four or more rounded indications in a line separated by  $\frac{1}{16}$  in. (1.5 mm) or less edge to edge;

(4) ten or more rounded indications in any 6 in.<sup>2</sup> (4 000 mm<sup>2</sup>) of surface with the major dimension of this area not to exceed 6 in. (150 mm) with the area taken in the most unfavorable location relative to the indications being evaluated.

### **NB-5343 Preservice Examination**

Components whose surface examination reveals flaws that meet the acceptance standards of NB-2500 and NB-5300 shall be acceptable and recorded as required by NB-5281(b).

## **NB-5350 LIQUID PENETRANT ACCEPTANCE STANDARDS**

### **NB-5351 Evaluation of Indications**

(a) Mechanical discontinuities at the surface are revealed by bleeding out of the penetrant; however, localized surface discontinuities, such as may occur from



machining marks, surface conditions, or an incomplete bond between base metal and cladding, may produce similar indications which are nonrelevant.

(b) Any indication which is believed to be nonrelevant shall be reexamined to verify whether or not actual defects are present. Surface conditioning may precede the reexamination. Nonrelevant indications and broad areas of pigmentation which would mask defects are unacceptable.

(c) Relevant indications are indications which result from imperfections. Linear indications are indications in which the length is more than three times the width. Rounded indications are indications which are circular or elliptical with the length equal to or less than three times the width.

### **NB-5352 Acceptance Standards**

(a) Only imperfections producing indications with major dimensions greater than  $\frac{1}{16}$  in. (1.5 mm) shall be considered relevant imperfections.

(b) Imperfections producing the following indications are unacceptable:

- (1) any cracks or linear indications;
- (2) rounded indications with dimensions greater than  $\frac{3}{16}$  in. (5 mm);
- (3) four or more rounded indications in a line separated by  $\frac{1}{16}$  in. (1.5 mm) or less edge to edge;
- (4) ten or more rounded indications in any 6 in.<sup>2</sup> (4 000 mm<sup>2</sup>) of surface with the major dimension of this area not to exceed 6 in. (150 mm) with the area taken in the most unfavorable location relative to the indications being evaluated.

### **NB-5353 Preservice Examination**

Components whose surface examination reveals flaws that meet the acceptance standards of [NB-2500](#) and [NB-5300](#) shall be acceptable and recorded as required by [NB-5281\(b\)](#).

### **NB-5360 EDDY CURRENT PRESERVICE EXAMINATION OF INSTALLED NONFERROMAGNETIC STEAM GENERATOR HEAT EXCHANGER TUBING**

Flaws revealed during preservice examination of installed nonferromagnetic heat exchanger tubing shall be evaluated using the criteria in the Design Specification [NCA-3252(c)].

### **NB-5370 VISUAL ACCEPTANCE STANDARDS FOR BRAZED JOINTS**

Braze metal shall give evidence of having flowed uniformly through a joint by the appearance of an uninterrupted, narrow visible line of brazing alloy at the end of the joint.

### **NB-5380 BUBBLE FORMATION TESTING**

Bubble formation testing shall be in accordance with Section V, Article 10. When vacuum box testing is used, the soak time shall be a minimum of 10 sec. Any indication of leaking, by the formation of bubbles or by the breaking of the continuous soap film by leaks, shall be evidence of an unacceptable condition.

### **NB-5400 FINAL EXAMINATION OF VESSELS**

#### **NB-5410 EXAMINATION AFTER HYDROSTATIC TEST**

After the pressure test of a vessel:

(a) All weld joints and heat affected zones of Categories A, B, C, and D, used to join ferritic material and repair welds in ferritic material that exceed in depth either  $\frac{3}{8}$  in. (10 mm) or 10% of the section thickness, whichever is less, shall be examined when physically accessible by the magnetic particle or liquid penetrant method.

(b) All required volumetric preservice examinations shall be performed.

### **NB-5500 QUALIFICATIONS AND CERTIFICATION OF NONDESTRUCTIVE EXAMINATION PERSONNEL**

#### **NB-5510 GENERAL REQUIREMENTS**

Organizations performing Code required nondestructive examinations shall use personnel competent and knowledgeable to the degree specified by [NB-5520](#). When these services are subcontracted by the Certificate Holder or Quality System Certificate Holder, he shall verify the qualification of personnel to the requirements of [NB-5520](#). All nondestructive examinations required by this Subsection shall be performed by and the results evaluated by qualified nondestructive examination personnel.

#### **NB-5520 PERSONNEL QUALIFICATION, CERTIFICATION, AND VERIFICATION**

##### **NB-5521 Qualification Procedure**

(a) Personnel performing nondestructive examinations shall be qualified in accordance with the recommended guidelines of SNT-TC-1A.<sup>32,33</sup> The ACCP qualified and certified NDE Personnel option shall not be used for Section III. The Employer's<sup>34</sup> written practice, required by paragraph 5 of SNT-TC-1A, shall identify the requirements relative to the recommended guidelines. The recommended guidelines of SNT-TC-1A shall be considered as minimum requirements, except as modified in (1) through (5) below.

(1) Qualification of Level III nondestructive examination personnel shall be by examination.



(-a) The basic and method examinations, paragraphs 8.8.1 and 8.8.2 of SNT-TC-1A, may be prepared and administered by Employer,<sup>34</sup> ASNT, or an outside agency.

(-b) The specific examination, paragraph 8.8.3 of SNT-TC-1A, shall be prepared and administered by the Employer or an outside agency. The Employer or outside agency administering the specific examination shall identify the minimum grade requirement in the written program when the basic and method examinations have been administered by ASNT, which issues grades on a pass/fail basis. In this case, the minimum grade for the specific examination may not be less than 80%.

(2) The written practice identified in paragraph 5 of SNT-TC-1A and the procedures used for examination of personnel shall be referenced in the Employer's Quality Program.

(3) The number of hours of training and experience for nondestructive examination personnel who perform only one operation of a nondestructive examination method that consists of more than one operation, or perform nondestructive examination of limited scope, may be less than that recommended in Table 6.3.1 A and Table 6.3.1 B of SNT-TC-1A. The time of training and experience shall be described in the written practice, and any limitations or restrictions placed on the certification shall be described in the written practice and on the certificate.

The minimum classroom training times identified in Table 6.3.1 A and Table 6.3.1 B of SNT-TC-1A for Level II certification may be reduced from 8 hr and 16 hr to 4 hr and 8 hr, respectively, for visual examination personnel.

(4) For visual examination, the Jaeger Number 1 letters shall be used in lieu of the Jaeger Number 2 letters specified in paragraph 8.2.1 of SNT-TC-1A. The use of equivalent type and size letters is permitted.

(5) An NDE Level I individual shall be qualified to properly perform specific setups, specific calibrations, specific NDE, and specific evaluations for acceptance or rejection determinations according to written instructions, and to record results. The NDE Level I individual shall receive the necessary instruction and supervision from a certified NDE Level II or Level III individual. A Level I individual may independently accept the results of nondestructive examinations when the specific acceptance criteria are defined in the written instructions.

(6) Personnel performing the volumetric preservice examination using the ultrasonic method shall meet the requirements of Section XI, Appendix VII, and Appendix VIII when required by Appendix I.

(b) For nondestructive examination methods not covered by SNT-TC-1A documents, personnel shall be qualified to comparable levels of competency by subjection to comparable examinations on the particular method involved.

(c) The emphasis shall be on the individual's ability to perform the nondestructive examination in accordance with the applicable procedure for the intended application.

(d) For nondestructive examination methods that consist of more than one operation or type, it is permissible to use personnel qualified to perform one or more operations. As an example, one person may be used who is qualified to conduct radiographic examination and another may be used who is qualified to interpret and evaluate the radiographic film.

## **NB-5522 Certification of Personnel**

(a) The Employer retains responsibility for the adequacy of the program and is responsible for certification of Levels I, II, and III nondestructive examination personnel.

(b) When ASNT is the outside agency administering the Level III basic and method examinations [NB-5521(a)(1)(-a)], the Employer may use a letter from ASNT as evidence on which to base the certification.

(c) When an outside agency is the examining agent for Level III qualification of the Employer's personnel, the examination results shall be included with the Employer's record.

## **NB-5523 Verification of Nondestructive Examination Personnel Certification**

The Certificate Holder has the responsibility to verify the qualification and certification of nondestructive examination personnel employed by Material Organizations and qualified by them in accordance with NCA-3820 and subcontractors who provide nondestructive examination services to them.

## **NB-5530 RECORDS**

Personnel qualification records identified in paragraph 9.4 of SNT-TC-1A shall be retained by the Employer.

## ARTICLE NB-6000 TESTING

### NB-6100 GENERAL REQUIREMENTS

#### NB-6110 PRESSURE TESTING OF COMPONENTS, APPURTENANCES, AND SYSTEMS

##### NB-6111 Scope of Pressure Testing

All pressure-retaining components, appurtenances, and completed systems shall be pressure tested. The preferred method shall be a hydrostatic test using water as the test medium. Bolts, studs, nuts, washers, and gaskets are exempted from the pressure test.

##### NB-6112 Pneumatic Testing

A pneumatic test in accordance with [NB-6300](#) may be substituted for the hydrostatic test when permitted by [NB-6112.1\(a\)](#).

##### NB-6112.1 Pneumatic Test Limitations.

(a) A pneumatic test may be used in lieu of a hydrostatic test only when any of the following conditions exists:

(1) when components, appurtenances, or systems are so designed or supported that they cannot safely be filled with liquid;<sup>35</sup>

(2) when components, appurtenances, or systems which are not readily dried are to be used in services where traces of the testing medium cannot be tolerated.

(b) A pneumatic test at a pressure not to exceed 25% of the Design Pressure may be applied, prior to either a hydrostatic or a pneumatic test, as a means of locating leaks.

**NB-6112.2 Precautions to Be Employed in Pneumatic Testing.** Compressed gaseous fluid is hazardous when used as a testing medium. Therefore, it is recommended that special precautions for protection of personnel be taken when a gaseous fluid under pressure is used as a test medium.

##### NB-6113 Witnessing of Pressure Tests

Pressure testing required by this Article shall be performed in the presence of the Inspector, except that testing of each line valve and each pump having piping connections of NPS 4 (DN 100) and less need not be witnessed by the Inspector. For line valves and pumps NPS 4 (DN 100) and less, the Inspector's review and acceptance of the Certificate Holder's test records will be authorization to sign the Data Report Form and take precedence over NCA-5280.

### NB-6114 Time of Pressure Testing

**NB-6114.1 System Pressure Test.** The installed system shall be pressure tested prior to initial operation.

(a) The pressure test may be performed progressively on erected portions of the system.

(b) Systems which are open ended, such as spray systems, may be pressure tested with the nozzle attachment opening plugged. The spray nozzles and their attachment weld joints or mechanical joints need not be pressure tested.

#### NB-6114.2 Component and Appurtenance Pressure Test.

(a) Components and appurtenances shall be pressure tested prior to installation in a system, except as permitted in (b) below.

(b) The system pressure test may be substituted for a component or appurtenance pressure test, provided:

(1) the component can be repaired by welding in accordance with the rules of [NB-4130](#) and [NB-4450](#), if required, as a result of the system pressure test;

(2) the component repair weld can be postweld heat treated in accordance with [NB-4620](#), if required, and non-destructively examined in accordance with the rules of [NB-4130](#) and [NB-4450](#), as applicable;

(3) the component is resubjected to the required system pressure test following the completion of repair and examination if the repair is required to be radiographed by [NB-4453.4](#).

(c) Valves require pressure testing prior to installation in a system in accordance with [NB-3500](#).

(d) Items which, when assembled, form a completed pump or valve may be tested in the form of subassemblies, provided:

(1) the test pressure is in accordance with the requirements of [NB-6221](#);

(2) the pressure test is performed in a manner which, in the subassembly under test, will simulate the loadings present when the completed pump or valve is assembled and pressurized;

(3) the component Certificate Holder approves any pressure test of component subassemblies;

(4) the component Certificate Holder specifies the pressure test requirements and test pressure to be used;

(5) each subassembly pressure test is performed by a Certificate Holder and is performed in the presence of the Authorized Inspector;

(6) each subassembly pressure tested by other than the component Certificate Holder is stamped with the Certification Mark with NPT Designator, except as provided in NCA-8330. The test pressure shall be identified on the Partial Data Report Form.

(7) each subassembly pressure tested by other than the component Certificate Holder is listed on the Code Data Report Form;

(8) the pressure tested subassemblies of pumps or valves are subsequently assembled by mechanical methods only;

(9) welds examined during the subassembly pressure test need not be reexamined during the system pressure test.

**NB-6114.3 Material Pressure Test.** The component or appurtenance pressure test may be used in lieu of any such test required by the material specification for a part or material used in the component or appurtenance, provided:

(a) nondestructive examinations, if required by the material specification, can be performed subsequent to the component or appurtenance pressure test;

(b) the material can be repaired by welding in accordance with the rules of NB-4130, if required, as a result of the pressure test;

(c) postweld heat treatment, when required after repairs, can be performed in accordance with NB-4620.

#### **NB-6115 Machining After Pressure Test**

An additional amount of material, not to exceed 10% of the wall thickness or  $\frac{3}{8}$  in. (10 mm), whichever is less, is permitted on the completed component during pressure testing where machining to critical dimensions and tolerances is required.

#### **NB-6120 PREPARATION FOR TESTING**

##### **NB-6121 Exposure of Joints**

All joints, including welded joints, shall be left uninsulated and exposed for examination during the test.

##### **NB-6122 Addition of Temporary Supports**

Components designed to contain vapor or gas may be provided with additional temporary supports, if necessary, to support the weight of the test liquid.

##### **NB-6123 Restraint or Isolation of Expansion Joints**

Expansion joints shall be provided with temporary restraints, if required, for the additional pressure load under test.

#### **NB-6124 Isolation of Equipment Not Subjected to Pressure Test**

Equipment that is not to be subjected to the pressure test shall be either disconnected from the component or system or isolated during the test by a blind flange or similar means. Valves may be used if the valves with their closures are suitable for the proposed test pressure.

#### **NB-6125 Treatment of Flanged Joints Containing Blanks**

Flanged joints at which blanks are inserted to isolate other equipment during the test need not be retested.

#### **NB-6126 Precautions Against Test Medium Expansion**

If a pressure test is to be maintained for a period of time and the test medium in the system is subject to thermal expansion, precautions shall be taken to avoid excessive pressure.

#### **NB-6127 Check of Test Equipment Before Applying Pressure**

The test equipment shall be examined before pressure is applied to ensure that it is tight and that all low pressure filling lines and other items that should not be subjected to the test have been disconnected or isolated.

### **NB-6200 HYDROSTATIC TESTS**

#### **NB-6210 HYDROSTATIC TEST PROCEDURE**

##### **NB-6211 Venting During Fill Operation**

The component or system in which the test is to be conducted shall be vented during the filling operation to minimize air pocketing.

##### **NB-6212 Test Medium and Test Temperature**

(a) Water or an alternative liquid, as permitted by the Design Specification, shall be used for the hydrostatic test.

(b) It is recommended that the test be made at a temperature that will minimize the possibility of brittle fracture (Appendix G). The test pressure shall not be applied until the component, appurtenance, or system and the pressurizing fluid are at approximately the same temperature.

#### **NB-6220 HYDROSTATIC TEST PRESSURE REQUIREMENTS**

##### **NB-6221 Minimum Hydrostatic Test Pressure**

(a) The installed system shall be hydrostatically tested at not less than 1.25 times the lowest Design Pressure of any component within the boundary protected by the overpressure protection devices which satisfy the requirements of NB-7000.

(b) Valves shall be hydrostatically tested in accordance with the rules of NB-3500.

(c) Components shall be hydrostatically tested at not less than 1.25 times their Design Pressure.

#### **NB-6222 Maximum Permissible Test Pressure**

The stress limits specified in [NB-3226](#) shall be used in determining the maximum permissible test pressure. In multichamber components, pressure may be simultaneously applied to the appropriate adjacent chamber to satisfy these stress limits.

#### **NB-6223 Hydrostatic Test Pressure Holding Time**

The hydrostatic test pressure shall be maintained a minimum of 10 min prior to initiation of the examination for leakage required by [NB-6224](#).

#### **NB-6224 Examination for Leakage After Application of Pressure**

Following the application of the hydrostatic test pressure for the required time ([NB-6223](#)), all joints, connections, and regions of high stress, such as regions around openings and thickness transition sections, shall be examined for leakage. Except in the case of pumps and valves which shall be examined while at test pressure, this examination shall be made at a pressure equal to the greater of the Design Pressure or three-fourths of the test pressure and it shall be witnessed by the Inspector. Leakage of temporary gaskets and seals, installed for the purpose of conducting the hydrostatic test and which will be replaced later, may be permitted unless the leakage exceeds the capacity to maintain system test pressure for the required amount of time. Other leaks, such as those from permanent seals, seats, and gasketed joints in components, may be permitted when specifically allowed by the Design Specification. Leakage from temporary seals or leakage permitted by the Design Specification shall be directed away from the surface of the component to avoid masking leaks from other joints.

### **NB-6300 PNEUMATIC TESTS**

#### **NB-6310 PNEUMATIC TESTING PROCEDURES**

##### **NB-6311 General Requirements**

When a pneumatic test is performed, it shall be conducted in accordance with the requirements of [NB-6100](#) and this Subarticle.

##### **NB-6312 Test Medium and Test Temperature**

(a) The gas used as the test medium shall be nonflammable.

(b) Testing temperature shall be in accordance with [NB-6212\(b\)](#).

#### **NB-6313 Procedure for Applying Pressure**

The pressure in the system shall gradually be increased to not more than one-half of the test pressure, after which the pressure shall be increased in steps of approximately one-tenth of the test pressure until the required test pressure has been reached.

#### **NB-6320 PNEUMATIC TEST PRESSURE REQUIREMENTS**

##### **NB-6321 Minimum Required Pneumatic Test Pressure**

(a) The installed system shall be pneumatically tested at not less than 1.1 times the lowest Design Pressure of any component within the boundary protected by the overpressure protection devices which satisfy the requirements of [NB-7000](#).

(b) Valves shall be pneumatically tested in accordance with the rules of [NB-3500](#).

(c) Components shall be pneumatically tested at not less than 1.1 times their Design Pressure.

##### **NB-6322 Maximum Permissible Test Pressure**

The maximum test pressure shall be limited as defined in [NB-6222](#).

##### **NB-6323 Test Pressure Holding Time**

The test pressure of [NB-6321](#) shall be maintained for a minimum total time of 10 min.

##### **NB-6324 Examination for Leakage After Application of Pressure**

Following the application of pressure for the time specified in [NB-6323](#), the test pressure shall be reduced to a value equal to the greater of the Design Pressure or three-fourths of the test pressure and held for a sufficient time to permit examination as defined in accordance with [NB-6224](#).

### **NB-6400 PRESSURE TEST GAGES**

#### **NB-6410**

##### **NB-6411 Types of Gages to Be Used and Their Location**

Pressure test gages used in pressure testing shall be indicating pressure gages and shall be connected directly to the component. If the indicating gage is not readily visible to the operator controlling the pressure applied, an additional indicating gage shall be provided where it will be visible to the operator for the duration of the test. For systems with a large volumetric content, it is recommended that a recording gage be used in addition to the indicating gages.

#### **NB-6412 Range of Indicating Pressure Gages**

(a) Analog type indicating pressure gages used in testing shall be graduated over a range not less than  $1\frac{1}{2}$  times nor more than 4 times the test pressure.

(b) Digital type pressure gages may be used without range restriction provided the combined error due to calibration and readability does not exceed 1% of the test pressure.

#### **NB-6413 Calibration of Pressure Test Gages**

All test gages shall be calibrated against a standard dead weight tester or a calibrated master gage. The test gages shall be calibrated before each test or series of tests. A series of tests is that group of tests using the same pressure test gage or gages which is conducted at the same site within a period not exceeding 2 weeks.

#### **NB-6600 SPECIAL TEST PRESSURE SITUATIONS**

##### **NB-6610 COMPONENTS DESIGNED FOR EXTERNAL PRESSURE**

Components designed for external pressure only shall be subjected to an internal or external test pressure at 1.25 times the design external pressure. The pressure shall be under proper control so that the required test pressure is never exceeded by more than 6%.

#### **NB-6620 PRESSURE TESTING OF COMBINATION UNITS**

##### **NB-6621 Pressure Chambers Designed to Operate Independently**

Pressure chambers of combination units that have been designed to operate independently shall be hydrostatically tested as separate vessels; that is, each chamber shall be tested without pressure in the adjacent chamber.

##### **NB-6622 Common Elements Designed for a Maximum Differential Pressure**

(a) When pressure chambers of combination units have their common elements designed for the maximum differential pressure that can occur during startup, operation, and shutdown, and the differential pressure is less than the higher of the Design Pressures of the adjacent chambers, the common elements shall be subjected to a hydrostatic test pressure of at least  $1\frac{1}{4}$  times the maximum differential pressure.

(b) Following the test of the common elements, as required by (a) above and their inspection, the adjacent chambers shall be hydrostatically tested (NB-6221). Care must be taken to limit the differential pressure between the chambers to the pressure used when testing the common elements.



## ARTICLE NB-7000 OVERPRESSURE PROTECTION

### NB-7100 GENERAL REQUIREMENTS

#### NB-7110 SCOPE

(a) A system<sup>36</sup> shall be protected from the consequences arising from the application of conditions of pressure and coincident temperature that would cause either the Design Pressure or the Service Limits specified in the Design Specification to be exceeded.

(b) Pressure relief devices<sup>37</sup> are required when the operating conditions considered in the Overpressure Protection Report would cause the Service Limits specified in the Design Specification to be exceeded.

(c) Protection of the system from the effects of pressure increases of extremely short duration, such as water hammer resulting from the rapid closing of a valve, is beyond the scope of this Article. These effects shall be included in the Design Specification.

(d) Rules covering the design of reactor shutdown systems and their application as an integrated part of system overpressure protection are beyond the scope of this Article. Appropriate guidance is found in engineering standards and in requirements of the regulatory and enforcement authorities having jurisdiction at the nuclear power plant site.

#### NB-7111 Definitions

(a) *Overpressure* is that pressure which exceeds the Design Pressure and is caused by increases in system fluid pressure resulting from thermal imbalances, excess pump flow, and other similar phenomena capable of causing a system pressure increase of a sufficient duration to be compatible with the dynamic response characteristics of the pressure relief devices listed in this Article.

(b) The basic definitions of pressure relief devices as specified in this Article are given in ASME PTC 25-2001, Pressure Relief Devices.

(c) *Primary pressure* is the pressure of the fluid at the inlet of the pressure relief device.

(d) *Secondary pressure* is that value of pressure existing in the passage between the actual discharge area and the outlet for which the discharge system of the pressure relief devices shall be designed.

### NB-7120 INTEGRATED OVERPRESSURE PROTECTION

Overpressure protection of the components shall be provided by any of the following as an integrated overpressure protection:

(a) the use of pressure relief devices and associated pressure sensing elements;

(b) the use of the reactor shutdown system;

(c) a design without pressure relief devices that does not exceed the Service Limits specified in the Design Specifications [NB-7110(b)].

### NB-7130 VERIFICATION OF THE OPERATION OF RECLOSING PRESSURE RELIEF DEVICES

#### NB-7131 Construction

(a) Reclosing pressure relief devices shall be constructed so that potential impairment of the overpressure protection function from service exposure to fluids can be determined by test or examination.

(b) Means shall be provided for remote monitoring of valve position (fully open and fully closed). These means may be incorporated in the valve design or its system installation.

(c) Reclosing pressure relief devices and their associated pressure sensing elements shall be so constructed that their correct operation can be demonstrated under service or test conditions, as may be required by regulatory or enforcement authorities having jurisdiction at the nuclear power plant site.

### NB-7140 INSTALLATION

#### NB-7141 Pressure Relief Devices

(a) Pressure relief devices shall be as close as practicable to the major source of overpressure anticipated to arise within the system under the conditions summarized in the Overpressure Protection Report (NB-7200).

(b) The connection between a system and its pressure relief device shall have a minimum inside diameter equal to or greater than the nominal inside diameter of the pressure relief device inlet. The opening in the connection shall be designed to provide direct and unobstructed flow between the system and the pressure relief device.

(c) The connection between a system and its safety valve shall be not longer than the face-to-face dimension of the corresponding tee fitting of the same dimension and pressure rating listed in ASME B16.5, ASME B16.9,



or ASME B16.11. Alternatively the connection shall not result in accumulative line losses greater than 2% of the relieving pressure.

(d) The connection between a system and its safety relief valve or relief valve shall not result in accumulated line losses greater than 3% of the relieving pressure.

(e) Safety, safety relief, and relief valves shall be installed in an upright position.

(f) The flow area of the discharge piping connected to a pressure relief device shall not be less than the flow area of the device outlet. If two or more pressure relief valves discharge into common piping, the area of the common piping shall not be less than the combined outlet area of the valves discharging into it. Back pressure that may exist or develop shall not reduce the relieving capacity of the relieving device(s) below that required to protect the system; potential for flashing shall be considered.

(g) Valve installation not in accordance with (c), (d), (e), and (f) above may be used provided:

(1) the NV Certificate Holder confirms that the valve design is satisfactory for the intended installation and satisfies the requirements of the valve Design Specification;

(2) the valves are adjusted for acceptable performance in conformance with the requirements of the valve Design Specification;

(3) technical justification for the adequacy of the installation is provided in the Overpressure Protection Report, including verification that the requirements of (1) and (2) have been met.

(h) A pressure relief valve certified for steam service may be installed on an inlet water loop seal<sup>38</sup> if the following conditions are met:

(1) the loop seal water purge time is considered and included in the Overpressure Protection Report;

(2) the requirements of NB-7510, NB-7520, and NB-7732.2 as applicable are met and the pressure relief valve set pressure is established on steam.

## NB-7142 Stop Valves

(a) No stop valve or other device shall be placed in such a location relative to a pressure relief device, that it could reduce the overpressure protection below that required by the rules of this Article, unless such stop valves are constructed and installed with controls and interlocks so that the relieving capacity requirements of NB-7300 are met under all conditions of operation of both the system and the stop valves.

(b) Simple administrative control of stop valve position is not acceptable.

(c) Stop valves shall have independent and diverse interlocks to prevent valves from being closed during all conditions of system operation when the pressure relief device is needed to meet the requirements of NB-7300.

(d) Stop valves shall have independent and diverse interlocks to assure that the valves will automatically open and remain open during all conditions of system operation when the pressure relief device is needed to meet the requirements of NB-7300.

(e) Means shall be provided to permit verification of the operation of controls and interlocks.

## NB-7143 Draining of Pressure Relief Devices

(a) A pressure relief device installation shall be fitted with a drain at its lowest point where liquid or residue can collect, if such liquid or residue could interfere with proper relieving operation.

(b) If the design of a pressure relief device permits liquid or residue to collect on the discharge side of the disk and could interfere with the proper relieving operation, the device shall be fitted with a drain to minimize the collection of liquid or residue.

(c) Drains shall discharge to a controlled thermal dissipation or discharge storage system.

## NB-7150 ACCEPTABLE PRESSURE RELIEF DEVICES

### NB-7151 Pressure Relief Valves<sup>39</sup>

Pressure relief valves may be used in accordance with NB-7170 and NB-7500.

### NB-7152 Nonreclosing Pressure Relief Devices<sup>40</sup>

Nonreclosing pressure relief devices may be used in accordance with NB-7170 and NB-7600.

## NB-7160 UNACCEPTABLE PRESSURE RELIEF DEVICES

### NB-7161 Deadweight Pressure Relief Valves

Dead weight valves shall not be used.

## NB-7170 PERMITTED USE OF PRESSURE RELIEF DEVICES

### NB-7171 Safety Valves<sup>41</sup>

Safety valves, meeting the requirements of NB-7510, may be:

- (a) steam service;
- (b) air and gas service.

### NB-7172 Safety Relief Valves<sup>42</sup>

Safety relief valves, meeting the requirements of NB-7510, may be used for:

- (a) steam service;
- (b) air and gas service;
- (c) liquid service.

### NB-7173 Relief Valves<sup>43</sup>

Relief valves, meeting the requirements of NB-7510, may be used for liquid service.

**NB-7174 Pilot Operated Pressure Relief Valves<sup>44</sup>**

Pilot operated pressure relief valves, meeting the requirements of NB-7520, may be used for:

- (a) steam service;
- (b) air and gas service;
- (c) liquid service.

**NB-7175 Power Actuated Pressure Relief Valves<sup>45</sup>**

Power actuated pressure relief valves, meeting the requirements of NB-7530, may be used for:

- (a) steam service;
- (b) air and gas service;
- (c) liquid service.

**NB-7176 Safety Valves With Auxiliary Actuating Devices**

Safety valves with auxiliary actuating devices, meeting the requirements of NB-7540, may be used for steam service.

**NB-7177 Pilot Operated Pressure Relief Valves With Auxiliary Actuating Devices**

Pilot operated pressure relief valves with auxiliary actuating devices, meeting the requirements of NB-7540, may be used for:

- (a) steam service;
- (b) air and gas service;
- (c) liquid service.

**NB-7178 Nonreclosing Devices**

Rupture disk devices<sup>46</sup> may be used on air or gas service in accordance with NB-7600.

**NB-7200 OVERPRESSURE PROTECTION REPORT****NB-7210 RESPONSIBILITY FOR REPORT**

The provisions intended to meet the requirements of this Article shall be the subject of an Overpressure Protection Report prepared by the Owner or his designee.

**NB-7220 CONTENT OF REPORT**

The Overpressure Protection Report shall define the protected systems and the integrated overpressure protection provided. As a minimum, the Report shall include the following:

- (a) identification of specific ASME Section III, Article NB-7000, Edition and Addenda and applicable Code Cases used in the design of the overpressure protection system;
- (b) drawings showing arrangement of protected systems, including the pressure relief devices;
- (c) the range of operating conditions, including the effect of discharge piping back pressure;

(d) an analysis of the conditions that give rise to the maximum pressure relieving requirements, except when the basis for establishing relieving capacity is the loss of the heat sink of the protected system when the thermal output of the reactor is at its rated power;

(e) the relief capacity required to prevent a pressure rise in any component from exceeding the limitations of NB-7300;

(f) the operating controls or safety controls of the protected system upon which the anticipated required relief capacity and the maximum pressure and temperature are predicted;

(g) the redundancy and independence of the pressure relief devices and their associated pressure sensors and controls employed to preclude a loss of overpressure protection in the event of a failure of any pressure relief device, sensing elements, associated controls, or external power sources;

(h) the extent that an individual component can be isolated from the overall system overpressure protection and the analysis of the conditions under which additional individual overpressure protection is necessary;

(i) the design secondary pressure, including a justification of the value identified in the Design Specification for pressure relief devices;

(j) the analysis of pressure transient conditions, including those associated with the response time of pressure relief valves, taking into account the effect of liquid and two-phase flow;

(k) consideration of set pressure and blowdown limitations, taking into account opening pressure tolerances and overpressure of the pressure relief device;

(l) consideration of burst pressure tolerance and manufacturing design range of the rupture disk device;

(m) verification that pressure relief devices are not required, if applicable. Verification shall include reference to each component's Design Report and applicable requirements in NB-3000 that demonstrate that the calculated stress intensity levels do not exceed the Service Limits specified in the component Design Specification for all system service loadings; and

(n) the purge time of the inlet water loop seal, if the pressure relief valve is installed on a loop seal, since the full opening of the valve may not occur until the loop seal is purged of water.

**NB-7230 CERTIFICATION OF REPORT**

The Report, after it has been reconciled with the requirements of this Article, shall be certified by one or more Registered Professional Engineers competent in the applicable field of design and qualified in accordance with the requirements of Appendix XXIII of Section III Appendices.

**NB-7240 REVIEW OF REPORT AFTER INSTALLATION**

(a) Any modification of the installation from that used for the preparation of the Overpressure Protection Report shall be reconciled with the Overpressure Protection Report.

(b) Modifications shall be documented in an addendum to the Overpressure Protection Report. The addendum shall contain a copy of the as-built drawing and shall include either:

(1) a statement that the as-built system meets the requirements of the Overpressure Protection Report; or

(2) a revision to the Overpressure Protection Report to make it agree with the as-built system; or

(3) a description of the changes made to the as-built system to make it comply with the Overpressure Protection Report.

(c) The addendum shall be certified by one or more Registered Professional Engineers competent in the applicable field of design and qualified in accordance with the requirements of Appendix XXIII of Section III Appendices.

**NB-7250 FILING OF REPORT**

A copy of the Overpressure Protection Report shall be filed at the nuclear power plant site prior to the Inspector signing the Owner's Data Report. The report shall be made available to the Authorized Inspector and regulatory and enforcement authorities having jurisdiction at the nuclear plant site.

**NB-7300 RELIEVING CAPACITY****NB-7310 EXPECTED SYSTEM PRESSURE TRANSIENT CONDITIONS<sup>47</sup>****NB-7311 Relieving Capacity of Pressure Relief Devices**

(a) The total relieving capacity of the pressure relief devices (certified in accordance with NB-7700 intended for overpressure protection within the scope of this Subsection and credited in conformance with NB-7500 or NB-7600) shall take into account any losses due to flow through piping and other components.

(b) The total relieving capacity shall be sufficient to prevent a rise in pressure of more than 10% above the Design Pressure of any component within the pressure-retaining boundary of the protected system under any expected system pressure transient conditions as summarized in the Overpressure Protection Report (NB-7200).

**NB-7312 Relieving Capacity of Pressure Relief Devices Used With Pressure-Reducing Devices**

When using pressure-reducing devices, the combined relieving capacity of the pressure relief devices shall be sufficient to meet the requirements of NB-7311, when:

(a) pressure-reducing devices and their bypass valves are fully open; and

(b) all discharge paths are blocked on the low pressure side of the pressure-reducing device.

**NB-7313 Required Number and Capacity of Pressure Relief Devices**

The required relieving capacity for overpressure protection of a system shall be provided by the use of at least two pressure relief devices. In each such group of pressure relief devices when more than one device is used, no device shall have a capacity less than 50% of the device with the largest capacity.

**NB-7314 Required Number and Capacity of Pressure Relief Devices for Isolatable Components**

The required relieving capacity of an isolatable component shall be provided by at least one pressure relief device meeting the requirements of NB-7500 or NB-7600. Alternatively, pressure relief devices are not required if the design of the component, when isolated, is in compliance with NB-7120(c).

**NB-7320 UNEXPECTED SYSTEM EXCESS PRESSURE TRANSIENT CONDITIONS<sup>48</sup>****NB-7321 Relieving Capacity of Pressure Relief Devices**

(a) The total relieving capacity of the pressure relief devices (certified in accordance with NB-7700 intended for overpressure protection within the scope of this Subsection and credited in conformance with NB-7500 or NB-7600) shall take into account any losses due to flow through piping and other components.

(b) The total relieving capacity shall be sufficient to limit the maximum system pressure such that the requirements of (c) are satisfied for each of the components of the system for which overpressure protection is provided, under each of the unexpected system excess pressure transient conditions specified in the Overpressure Protection Report.

(c) The system overpressure established for setting the required total relieving capacity of (b) shall be such that the calculated stress intensity and other design limitations for Service Limit C specified in NB-3000 are not exceeded for each of the components in the protected system.

**NB-7400 SET PRESSURES OF PRESSURE RELIEF DEVICES****NB-7410 SET PRESSURE LIMITATIONS FOR EXPECTED SYSTEM PRESSURE TRANSIENT CONDITIONS**

The stamped set pressure of at least one of the pressure relief devices connected to the system shall not be greater than the Design Pressure of any component within the pressure-retaining boundary of the protected system. Additional pressure relief devices may have higher stamped set pressures, but in no case shall these set pressures be such that the total system pressure exceeds the system limitations specified in [NB-7310](#).

**NB-7420 SET PRESSURE LIMITATION FOR UNEXPECTED SYSTEM EXCESS PRESSURE TRANSIENT CONDITIONS**

The establishment of the stamped set pressure shall take into account the requirements of [NB-7320](#).

**NB-7500 OPERATING AND DESIGN REQUIREMENTS FOR PRESSURE RELIEF VALVES****NB-7510 SAFETY, SAFETY RELIEF, AND RELIEF VALVES****NB-7511 General Requirements**

**NB-7511.1 Spring-Loaded Valves.** Valves shall open automatically by direct action of the fluid pressure as a result of forces acting against a spring.

**NB-7511.2 Balanced Valves.**

(a) Balanced valves, whose operation is independent of back pressure, may be used if means are provided to verify the operability of the balancing device.

(b) Balanced safety valves for steam service shall additionally have a redundant back pressure balancing device.

**NB-7511.3 Antisimmer Type Valves.** Valves which are fitted with antisimmer devices that serve to raise the set pressure of the valve during normal operation of the system may be used, provided:

(a) the design is such that the valve opens automatically and discharges its certified capacity at 110% of the system design pressure in the event any item of the auxiliary loading device should fail;

(b) the operating signal and energy source provisions are such that the valve reverts to its normal set pressure in the event of any failure of signal or loss of energy source;

(c) the auxiliary loading force imposed on such valves does not raise the set pressure of the valve by more than 10%;

(d) the auxiliary loading force that augments the force exerted by the valve spring is automatically unloaded at a pressure not greater than the set pressure of the valve.

**NB-7512 Safety Valve Operating Requirements****NB-7512.1 Antichattering and Lift Requirements.**

Safety valves shall be constructed to operate without chattering and to attain rated lift at a pressure which does not exceed the set pressure by more than 3% or 2 psi (15 kPa), whichever is greater.

**NB-7512.2 Set Pressure Tolerance.**

(a) The set pressure tolerance plus or minus shall not exceed the following: 2 psi (15 kPa) for pressures up to and including 70 psi (480 kPa), 3% for pressures from 70 psi (480 kPa) to 300 psi (2 MPa), 10 psi (70 kPa) for pressures over 300 psi (2 MPa) to 1,000 psi (7 MPa), and 1% for pressures over 1,000 psi (7 MPa). The set pressure tolerance shall apply unless a greater tolerance is established as permissible in the Overpressure Protection Report ([NB-7200](#)) and in the safety valve Design Specification (NCA-3250).

(b) Conformance with the requirements of (a) shall be established for each production valve by test. Steam valves shall be tested on steam.

**NB-7512.3 Blowdown.** Safety valves shall be adjusted to close after blowing down to a pressure not lower than 95% of the set pressure unless a different percentage is specified in the safety valve Design Specification (NCA-3250) and the basis for the setting is covered in the Overpressure Protection Report ([NB-7200](#)). The adjustment shall be determined by test or by proration from the Certificate Holder's blowdown test data.

**NB-7513 Safety Relief and Relief Valve Operating Requirements**

Safety relief and relief valves shall be constructed to attain rated lift at a pressure that does not exceed the set pressure by more than 10% or 3 psi (20 kPa), whichever is greater.

**NB-7513.1 Set Pressure Tolerance.**

(a) The set pressure tolerance plus or minus from the set pressure of safety relief and relief valves shall not exceed 2 psi (15 kPa) for pressures up to and including 70 psi (480 kPa) and 3% for pressure above 70 psi (480 kPa). The set pressure tolerance shall apply unless a greater tolerance is established as permissible in the Overpressure Protection Report ([NB-7200](#)) and in the valve Design Specification (NCA-3250).

(b) Conformance with the requirements of (a) shall be established for each production valve by test. Steam valves shall be tested on steam, air or gas valves on air or gas, and liquid valves on liquid. Alternative fluids may be used as the test media if the requirements of [NB-7550](#) have been met.

**NB-7513.2 Blowdown.** Safety relief and relief valves shall be adjusted to close after blowing down to a pressure not lower than that specified in the valve Design Specification (NCA-3250), and the basis for the setting shall be



covered in the Overpressure Protection Report (NB-7200). The adjustment shall be determined by test or by proration from the Certificate Holder's blowdown test data.

#### **NB-7514 Credited Relieving Capacity**

The credited relieving capacity of safety, safety relief, and relief valves shall be based on the certified relieving capacity. In addition, the capacity can be prorated as in NB-7700.

#### **NB-7515 Sealing of Adjustments**

Means shall be provided in the design of all valves for sealing all adjustments or access to adjustments that can be made without disassembly of the valve. For a pilot operated pressure relief valve, an additional seal shall be provided to seal the pilot and main valve together. Seals shall be installed by the Certificate Holder at the time of initial adjustment. Seals shall be installed in a manner to prevent changing the adjustment or disassembly of the valve without breaking the seal. The seal shall serve as a means of identifying the Certificate Holder making the initial adjustment.

#### **NB-7520 PILOT OPERATED PRESSURE RELIEF VALVES**

##### **NB-7521 General Requirements**

Pilot operated pressure relief valves shall operate independently of any external energy source.

##### **NB-7522 Operating Requirements**

**NB-7522.1 Actuation.** The pilot control device shall be actuated directly by the fluid pressure of the protected system.

**NB-7522.2 Response Time.** The Overpressure Protection Report (NB-7200) shall include the effects of divergence between opening (set) and closing (blowdown) pressures of the pilot valve and the pressures at which the main valve attains rated lift and closes. These divergences are caused by the inherent time delay (e.g., response time) between the operation of the pilot and the main valve, and the rate of the system pressure change. The limits for response time shall be specified in the valve Design Specification (NCA-3250).

**NB-7522.3 Main Valve Operation.** The main valve shall operate in direct response to the pilot control device. The valve shall be constructed to attain rated lift under stable conditions at pressures which do not exceed the set pressure by more than 3% or 2 psi (15 kPa), whichever is greater, for steam, and 10% or 3 psi (20 kPa), whichever is greater, for air, gas, or liquid service.

**NB-7522.4 Sensing Mechanism Integrity.** For other than spring loaded direct acting pilot control devices, means shall be provided to detect failure of the pressure

sensing element, such as bellows, when operation of the pilot control device is dependent upon the integrity of a pressure sensing element.

##### **NB-7522.5 Set Pressure Tolerance.**

(a) The set pressure tolerance shall apply only to the pilot valve.

(b) The set pressure tolerance plus or minus shall not exceed the following: 2 psi (15 kPa) for pressures up to and including 70 psi (480 kPa), 3% for pressures over 70 psi (480 kPa) for liquid valves and 3% for pressures over 70 psi (480 kPa) up to and including 300 psi (2 MPa), 10 psi (70 kPa) for pressures over 300 psi (2 MPa) up to and including 1,000 psi (7 MPa), and 1% for pressures over 1,000 psi (7 MPa) for steam, air, and gas valves. The set pressure tolerance as stated shall apply unless a greater tolerance is established as permissible in the Overpressure Protection Report (NB-7200) and in the valve Design Specification (NCA-3250).

(c) Conformance with the requirements of (b) above shall be established for each production valve by test. Steam valves shall be tested on steam, air or gas valves on air or gas, and liquid valves on liquid. Alternative fluids may be used as the test media if the requirements of NB-7550 have been met.

##### **NB-7522.6 Blowdown.**

(a) The blowdown requirements shall only apply to the pilot valve.

(b) Pilot operated valves shall be adjusted to close after blowing down to a pressure not lower than 95% of the set pressure for steam, unless a different percentage is specified in the valve Design Specification (NCA-3250) and the basis for the setting is covered in the Overpressure Protection Report (NB-7200). For all other fluids, pilot operated valves shall be adjusted to close after blowing down to a pressure not lower than that specified in the valve Design Specification (NCA-3250), and the basis for the setting shall be covered in the Overpressure Protection Report (NB-7200).

(c) Conformance with the requirements of (b) above shall be established for each production valve by test or by proration from the Certificate Holder's blowdown test data. Alternative fluids may be used as the test media if the requirements of NB-7550 have been met.

#### **NB-7523 Credited Relieving Capacity**

The credited relieving capacity of pilot operated pressure relief valves shall be based on the certified relieving capacity. In addition, the capacity may be prorated as permitted in NB-7700.

#### **NB-7524 Sealing of Adjustments**

The sealing requirements of NB-7515 shall apply.

**NB-7530 POWER ACTUATED PRESSURE RELIEF VALVES****NB-7531 General Requirements**

Power actuated pressure relief valves which depend upon an external energy source, such as electrical, pneumatic, or hydraulic systems, may be used provided the requirements of [NB-7530](#) are met.

**NB-7532 Operating Requirements**

**NB-7532.1 Actuation.** Power actuated pressure relief valves shall be actuated in response to signals from protected system fluid pressure sensing devices.

**NB-7532.2 Response Times.**

(a) The *opening response time* is the time delay between the time the pressure sensor recognizes a predetermined system pressure and the time the power actuated pressure relief valve attains its certified capacity.

(b) The *closing response time* is the time delay between the time the pressure sensor recognizes a predetermined system pressure and the time the power actuated pressure relief valve is fully closed.

(c) The Overpressure Protection Report ([NB-7200](#)) shall include an analysis of the effect that opening and closing time responses have on the overpressure protection for the system.

(d) Each production valve shall be tested to verify that the stipulated response time in the Design Specification (NCA-3250) for the valve has been met.

**NB-7532.3 Main Valve Operation.** The main valve shall provide rated flow under stable system conditions at pressures which do not exceed the opening actuation pressure by more than 3% or 2 psi (15 kPa) whichever is greater for steam, and 10% or 3 psi (20 kPa) whichever is greater for air, or gas, or liquid service.

**NB-7532.4 Sensors, Controls, and External Energy Sources.**

(a) The sensors, controls, and external energy sources for valve operation shall have redundancy and independence at least equal to that required for the control and safety protection systems associated with the system being protected.

(b) The pressure sensors shall be capable of controlling the opening actuation pressure to within a tolerance of  $\pm 1\%$  when the automatic control is in use.

(c) When automatic control is in use, the valve closing actuation pressure shall be controlled to a pressure not lower than 95% of the opening actuation pressure unless a different percentage is specified in the Design Specification (NCA-3250) and the basis for the closing actuation pressure is covered in the Overpressure Protection Report ([NB-7200](#)).

(d) Conformance with requirements of (b) and (c) above shall be established through test by the owner or his designee. Steam valves shall be tested on steam, gas

or air valves on gas or air, and liquid valves on liquid. Alternative fluids may be used as the test media if the requirements of [NB-7550](#) have been met.

**NB-7533 Certified Relieving Capacity**

The power actuated pressure relief valve certified relieving capacity and the proration of capacity shall be as determined by [NB-7700](#).

**NB-7534 Credited Relieving Capacity**

**NB-7534.1 Expected System Pressure Transient Conditions.** For expected system pressure transient conditions, the relieving capacity with which these valves are credited shall be not more than:

(a) the certified relieving capacity of the smaller one when two valves are installed;

(b) one-half of total certified relieving capacity when three or more valves are installed.

**NB-7534.2 Unexpected System Excess Pressure Transient Conditions.** For unexpected system excess pressure transient conditions, the credited relieving capacity with which these valves are credited shall be not more than:

(a) the certified relieving capacity of the valve with the smaller certified capacity when two valves are installed;

(b) the certified relieving capacity of all except the valve with the largest certified capacity when three through ten valves are installed;

(c) the certified relieving capacity of all except two valves of the largest certified capacity when more than ten valves are installed.

**NB-7535 Sealing of Adjustments**

Means shall be provided for the sealing of all adjustments which affect valve operation. Seals shall be installed by the owner or his designee at the time of setting. Seals shall be installed in such a manner as to prevent changing the adjustment without breaking the seal and shall serve as a means of identifying the organization responsible for making the adjustment.

**NB-7540 SAFETY VALVES AND PILOT OPERATED PRESSURE RELIEF VALVES WITH AUXILIARY ACTUATING DEVICES****NB-7541 General Requirements**

Safety valves and pilot operated pressure relief valves with auxiliary actuating devices that operate independently of the self-actuating mechanism of the valve may be used provided the requirements of [NB-7510](#) or [NB-7520](#), as applicable, are met, except as modified below.



**NB-7542 Construction**

(a) The construction shall be such that the valve opens automatically by direct action of the fluid at a pressure not higher than the valve set pressure and relieves at the certified relieving capacity in the event of failure of any essential part of the valve's auxiliary devices.

(b) The construction of the auxiliary actuating device shall be such that loss of electrical power or loss of auxiliary actuating pressure to the device will not prevent the valve from closing.

**NB-7543 Auxiliary Device Sensors and Controls**

The sensors, controls, and external energy sources for the auxiliary actuating device shall comply with the requirements of NB-7532.

**NB-7544 Relieving Capacity**

**NB-7544.1 Expected System Pressure Transient Conditions.** For expected system pressure transient conditions, credit for capacity (NB-7544.3) can be taken for valves opening at the setpoint of the auxiliary actuating device in accordance with (a) and (b) below.

(a) When two valves are installed, the valve of the smaller certified capacity is credited with opening at the setpoint of the auxiliary actuating device. The valve with the larger certified capacity is credited with opening at the valve set pressure.

(b) For groups of more than two valves (all of the same certified capacity), half the valves in a group containing an even number of valves or the number of valves in the group minus one divided by two in a group containing an odd number of valves are credited with opening at the setpoint of the auxiliary actuating device. The remainder of the valves in the group are credited with opening at the valve set pressure.

**NB-7544.2 Unexpected System Excess Pressure Transient Conditions.** For unexpected system excess pressure transient conditions, credit for capacity (NB-7544.3) may be taken for valves opening at the setpoint of the auxiliary actuating device in accordance with the following.

(a) When two valves are installed, the valve with the smaller certified capacity may be credited with opening at the setpoint of the auxiliary actuating device. The valve with the larger certified capacity shall be credited with opening at the valve set pressure.

(b) When three through ten valves are installed, credit may be given for opening at the setpoint of the auxiliary actuating device for all valves except one with the largest certified capacity. The valve assumed not to open at the setpoint of the auxiliary actuating device shall be credited with opening at the valve set pressure.

(c) When more than ten valves are installed, credit may be given for opening at the setpoint of the auxiliary actuating device for all valves except for two of the largest cer-

tified capacity. The two valves assumed not to open at the setpoint of the auxiliary actuating device shall be credited with opening at the valve set pressure.

**NB-7544.3 Credited Relieving Capacity.** The credited relieving capacity of these valves shall be:

(a) for valves credited with opening at auxiliary actuating device setpoint, the capacity at the lower relieving pressure as determined by the rules of NB-7700 (this shall specifically include the 90% of average tested capacity inherent in Code certification procedure);

(b) for valves credited with opening at the valve set pressure, the certified capacity as determined by the rules of NB-7700.

**NB-7545 Response Time**

Valves credited with opening at the auxiliary actuating device setpoint, shall comply with the requirements of NB-7532.2.

**NB-7550 ALTERNATIVE TEST MEDIA****NB-7551 General Requirements**

Pressure relief devices may be subjected to set pressure tests using a test medium of a fluid type or temperature other than that for which they are designed, provided the testing complies with NB-7552 through NB-7554. Valves designed for compressible fluid (other than steam) shall be tested with a compressible fluid, and valves designed for non-compressible fluids shall be tested with non-compressible fluid. Valves designed for steam service shall be tested with steam.

**NB-7552 Correlation**

Correlation of pressure relief device operation, with respect to the parameters under test, shall be established for the specified alternative test medium, as compared with the conditions of the operating medium.

**NB-7553 Verification of Correlation Procedure**

The certificate holder shall ensure that the correlation established in accordance with the procedure will be of sufficient accuracy such that the pressure relief device tested or adjusted, or both, using the alternative media, will comply with the operating requirements. Results of the tests performed to verify the adequacy of the alternative test media correlation shall be documented.

**NB-7554 Procedure**

A written procedure shall be prepared by the certificate holder and certified in accordance with the requirements of NB-7553. The procedure shall specify all the test parameters that affect correlation and shall include at least the following:

- (a) specific description of test setup;
- (b) specific requirements for instrumentation;

(c) specific requirements for assist equipment (if any); and

(d) specific requirements for testing conditions, i.e., device temperature, ambient temperature, ambient pressure, etc.

Test parameters shall be listed, i.e., time between openings, number of tests, etc.

## **NB-7600 NONRECLOSING PRESSURE RELIEF DEVICES**

### **NB-7610 RUPTURE DISK DEVICES**

Rupture disk devices certified in accordance with [NB-7720](#) are subject to the following:

(a) rupture disk devices shall not be used as the sole pressure relief devices;

(b) rupture disk devices used in conjunction with pressure relief valves shall be located only on the outlet side of the valve ([NB-7623](#)).

### **NB-7611 Burst Pressure Tolerance**

The burst pressure tolerance at the specified disk temperature<sup>49</sup> shall not exceed  $\pm 2$  psi ( $\pm 15$  kPa) for stamped burst pressure up to and including 40 psi (300 kPa) and  $\pm 5\%$  for stamped burst pressure above 40 psi (300 kPa) as established by the rules of NB-7613, unless other values have been established in the Design Specification and are covered in the Overpressure Protection Report.

### **NB-7612 Tests to Establish Stamped Burst Pressure**

(a) Every rupture disk shall have a stamped burst pressure established by rules of [NB-7611](#) within a manufacturing design range<sup>50</sup> at a specified disk temperature, and shall be stamped with a lot number.

(b) Each lot of rupture disks shall be tested in accordance with one of the following methods. All tests of disks for a given lot shall be made in a holder of the same form and pressure area dimensions as that being used in service.

(1) At least two sample rupture disks from each lot of rupture disks<sup>51</sup> shall be burst at the specified disk temperature. The stamped burst pressure shall be determined so that the sample rupture disk burst pressures are within the tolerance specified by [NB-7611](#).

(2) At least four sample rupture disks, but not less than 5%, from each lot of rupture disks shall be burst at four different temperatures distributed over the applicable temperature range for which the disks will be used. This data shall be used to establish a smooth curve of burst pressure versus temperature for the lot of disks. The burst pressure for each data point shall not deviate from the curve more than the burst pressure tolerance specified in [NB-7611](#).

The value for the stamped burst pressure shall be established from the curve for a specified disk temperature.

(3) For prebulged solid metal disks or graphite disks only, at least four sample rupture disks using one size of disk from each lot of material shall be burst at four different temperatures, distributed over the applicable temperature range for which this material will be used. This data shall be used to establish a smooth curve of burst pressure versus temperature for the lot of material. The burst pressure for each data point shall not deviate from the curve more than the burst pressure tolerance specified in [NB-7611](#).

At least two disks from each lot of disks, made from this lot of material and of the same size as those to be used, shall be burst at the ambient temperature to establish the room rating of the lot of disks. The curve shall be used to establish the stamped rating at the specified disk temperature for the lot of disks.

### **NB-7620 INSTALLATION**

#### **NB-7621 Provisions for Venting or Draining**

When a rupture disk is used in conjunction with a pressure relief valve, the space between the rupture disk and the pressure relief valve shall be vented and/or drained to controlled thermal dissipation or discharge storage systems.

#### **NB-7622 System Obstructions**

Piping and other components downstream of the rupture disk shall be constructed so that bursting of the rupture disk will not impair the function of the pressure relief valve by the release of rupture disk material.

#### **NB-7623 Rupture Disk Devices at the Outlet Side of Pressure Relief Valves**

A rupture disk device may be installed at the outlet side of pressure relief valves if the following provisions are met:

(a) the set pressure of the valve is independent of back pressure, or the set pressure of the valve plus the stamped burst pressure of the rupture disk plus any pressure in the outlet piping does not exceed the limits of [NB-7400](#);

(b) the relieving capacity meets the requirements of [NB-7300](#);

(c) the stamped burst pressure of the rupture disk at the specified disk temperature plus any pressure in the outlet piping from the rupture disk device shall not exceed the secondary Design Pressure of the pressure relief valve and the Design Pressure of any pipe or fittings between the valve and the rupture disk device. However, in no case shall the stamped burst pressure of the rupture disk at the operating temperature plus any pressure in the outlet piping from the rupture disk device exceed the limits of [NB-7400](#);

(d) the opening provided through the rupture disk device after burst is sufficient for the pressure relief valve to flow at its certified capacity.

## **NB-7700 CERTIFICATION**

### **NB-7710 RESPONSIBILITY FOR CERTIFICATION OF PRESSURE RELIEF VALVES**

The Certificate Holder shall be responsible for having the relieving capacity of its valves certified as prescribed in this Subarticle.

### **NB-7720 RESPONSIBILITY FOR CERTIFICATION OF NONRECLOSING PRESSURE RELIEF DEVICES**

The rupture disk Manufacturer shall certify the stamped burst pressure of the disk.

### **NB-7730 CAPACITY CERTIFICATION PRESSURE RELIEF VALVES — COMPRESSIBLE FLUIDS**

#### **NB-7731 General Requirements**

##### **NB-7731.1 Capacity Certification.**

(a) Capacity certification procedures shall be as required in [NB-7732](#) through [NB-7737](#).

(b) For steam at pressures over 1,500 psig (10.4 MPa) and up to 3,200 psig (2.21 MPa), the value of  $K$  used to determine the certified relieving capacity shall be multiplied by:

(U.S. Customary Units)

$$(0.1906P - 1,000) / (0.2292P - 1,061)$$

(SI Units)

$$(27.6P - 1000) / (33.2P - 1061)$$

where

$P$  = set pressure, psig

This correction is also applicable to the certified relieving capacity as determined by the curve method. This correction shall only be used if it is 1.0 or greater.

##### **NB-7731.2 Test Media.**

(a) Capacity certification tests of pressure relief valves for steam service shall be conducted with dry saturated steam. For test purposes, the limits of 98% minimum quality and 20°F (10°C) maximum superheat shall apply. Capacity shall be corrected to the dry saturated condition from within these limits.

(b) Capacity certification tests for pressure relief valves for air and gas service shall be conducted with air, gas, or dry saturated steam.

(c) Demonstration of function tests shall be performed using the same fluid media to which the pressure relief valve is expected to be exposed in service.

##### **NB-7731.3 Test Pressure.**

(a) Capacity certification tests of pressure relief valves (except safety relief valves) for steam service shall be conducted at a pressure which does not exceed the set pressure by more than 3% or 2 psi (15 kPa), whichever is greater, except as permitted in (b).

(b) Capacity certification tests of safety relief valves ([NB-7513](#)) for steam service shall be conducted at a pressure which does not exceed the set pressure by more than 10% or 3 psi (20 kPa), whichever is greater.

(c) Capacity certification tests of pressure relief valves for air or gas shall be conducted at a pressure which does not exceed the set pressure by more than 10% or 3 psi (20 kPa), whichever is greater.

**NB-7731.4 Blowdown.** Valves having an adjustable blowdown construction shall be adjusted prior to capacity certification testing so that the blowdown does not exceed 5% of the set pressure.

**NB-7731.5 Drawings.** Prior to capacity certification and demonstration of function tests, the Certificate Holder shall submit drawings showing the valve construction to the Authorized Observer. The Authorized Observer shall submit the drawings and all test results to the ASME designated organization for review and acceptance.

**NB-7731.6 Design Changes.** When changes are made in the design of a pressure relief valve which affect the flow path, lift, or performance characteristics, new tests shall be performed in accordance with this Subarticle.

#### **NB-7732 Flow Model Test Method**

**NB-7732.1 Flow Capacity.** When test facility limitations make it impossible to perform tests of the full-scale pressure relief valves, flow models of three different sizes may be utilized as a basis for capacity certification. Such flow models shall be sized consistent with the capabilities of the accepted test laboratory where the tests will be conducted and shall accurately model those features which affect flow capacity, such as orifice size, valve lift, and internal flow configuration. The test models need not be functional pressure relief valves, provided that other tests are conducted to demonstrate proper function of the valve design as prescribed in [NB-7732.2](#). The relieving capacity of valve designs certified by the use of flow models shall be established by the coefficient of discharge method similar to that outlined in [NB-7734.1](#) and [NB-7734.2](#). The certified relieving capacity of all sizes and pressures of a given design for which the value of  $K$  has been established, based on flow model tests in accordance with the method of [NB-7734](#), shall not exceed the value calculated by the appropriate equation in [NB-7734.2](#) multiplied by the coefficient  $K$ .

**NB-7732.2 Demonstration of Function.**

(a) The function of three valves of the design to be certified shall be demonstrated by test. The three valves selected shall envelop the largest and smallest combination of inlet size and orifice size of the specific design. Such tests may be performed in conjunction with the capacity certification tests outlined above or as separate tests using production valves.

(b) These tests shall be conducted at a place meeting the requirements of NB-7739 to demonstrate to the satisfaction of a representative from an ASME designated organization that the valves will meet the operating requirements specified in NB-7500 and achieve full lift under the conditions established in (c).

(c) The NV Certificate Holder shall specify the range of pressures, temperatures, and other fluid conditions for which the valves are to be tested. The range shall be sufficient to cover all expected operating fluid conditions. Additionally, tests shall include the range of inlet pressure losses and discharge back pressure conditions for which the valves are expected to be used.

(d) The NV Certificate Holder shall document in the remarks section on the Data Report Form NV-1 that the requirements of this subparagraph have been met.

**NB-7733 Slope Method**

(a) For pressure relief valves of a specific design, four valves of each combination inlet size and orifice size shall be tested. These four valves shall be set at pressures that will cover the appropriate range of pressures for which the valves are to be used or within the range of the authorized test facility.

(b) The instantaneous slope of each test point shall be calculated and averaged, where slope is defined as the measured capacity divided by the absolute inlet pressure. If any of the experimentally determined slopes fall outside of a range of  $\pm 5\%$  of the average slope, the unacceptable valves shall be replaced by two valves of the same size and set pressure. Following a test of these valves, a new average slope shall be determined, excluding the replaced valve test results. If any individual slope is now outside of the  $\pm 5\%$  range, then the tests shall be considered unsatisfactory and shall be cause for the ASME designated organization to refuse certification of the particular valve design. The certified capacity shall be 90% of the average slope multiplied by the flow rating pressure, psia.

(c) In addition, demonstration of function tests shall be conducted as prescribed in NB-7732.2.

**NB-7734 Coefficient of Discharge Method**

A coefficient  $K$  may be established for a specific pressure relief valve design according to the procedure given in the following subparagraphs.

**NB-7734.1 Number of Valves to Be Tested.** For each design, at least three valves for each of three different sizes shall be submitted for test. Each valve of a given size shall be set at a different pressure.

**NB-7734.2 Establishment of Coefficient of Discharge. (13)**

(a) Tests shall be made on each pressure relief valve to determine its lift, opening, blowdown pressures, and capacity in terms of the fluid used in the test. A coefficient of discharge  $K_D$  shall be established for each test run as follows:

$$K_D = \frac{\text{Actual Flow}}{\text{Theoretical Flow}} = \text{Coefficient of Discharge}$$

where Actual Flow is determined quantitatively by test, and Theoretical Flow is calculated by the following equation:

For test with dry saturated steam:

(U.S. Customary Units)

$$W_T = 51.5AP$$

(SI Units)

$$W_T = 5.25AP$$

Pressures over 1,500 psig (10 MPa gage) and up to 3,200 psig (22.1 MPa gage) the value of  $W_T$ , calculated by the above equation, shall be corrected by being multiplied by the following factor (which shall only be used if it is 1.0 or greater):

(U.S. Customary Units)

$$\frac{(0.1906P - 1,000)}{(0.2292P - 1,061)}$$

(SI Units)

$$\frac{(27.6P - 1000)}{(33.2P - 1061)}$$

For test with air:

(U.S. Customary Units)

$$W_T = 356AP \sqrt{\frac{M}{T}}$$

(SI Units)

$$W_T = 27.03AP \sqrt{\frac{M}{T}}$$



For test with gas:

$$W_T = CAP \sqrt{\frac{M}{ZT}}$$

where

$A$  = actual discharge area through the valve at developed lift, in.<sup>2</sup> (mm<sup>2</sup>)

$C$  = constant for gas or vapor which is a function of the ratio of specific heats,  $k$

$k = c_p/c_v$  (see Section III Appendices, Fig. XVIII-1110-1)

$M$  = molecular weight

$P$  = (set pressure  $\times$  1.03) plus atmospheric pressure, psia (kPa abs), or set pressure plus 2 psi (15 kPa) plus atmospheric pressure, whichever is greater, for test pressures determined by NB-7731.3(a)  
 = (set pressure  $\times$  1.10) plus atmospheric pressure, psia (kPa abs), or set pressure plus 3 psi (20 kPa) plus atmospheric pressure, whichever is greater, for test pressures determined by NB-7731.1(b) or (c)

$T$  = absolute temperature at inlet, °F + 460 (K) [°C + 273 (K)]

$W_T$  = theoretical flow, lb/hr (kg/hr)

$Z$  = compressibility factor corresponding to  $P$  and  $T$

The average of the coefficients of discharge  $K_D$  of the tests required shall be multiplied by 0.90, and their product shall be taken as the coefficient  $K$  of that design. The coefficient of the design shall not be greater than 0.878 (the product of  $0.9 \times 0.975$ ).

(b) If any of the experimentally determined coefficients fall outside of a range of  $\pm 5\%$  of the average coefficient, the unacceptable valves shall be replaced by two valves of the same size and set pressure. Following the test of these valves, a new average coefficient shall be determined, excluding the replaced valve test results. If any individual coefficient is now outside of the  $\pm 5\%$  range, then the test shall be considered unsatisfactory and shall be cause for the ASME designated organization to refuse certification of the particular valve design.

#### NB-7734.3 Calculation of Certified Capacity.

(a) The certified capacity of all sizes and pressures of a given design, for which the value of  $K$  has been established under the provisions of NB-7734.2 and which are manufactured subsequently, shall not exceed the value calculated by the appropriate equation multiplied by the coefficient  $K$ .

(b) The coefficient shall not be applied to valves whose beta ratio (the ratio of valve throat and inlet diameter) lies outside the range of 0.15 to 0.75, unless tests have demonstrated that individual coefficients of discharge,  $K_D$ , for valves of the extreme ends of a larger range is within  $\pm 5\%$  of the average coefficient,  $K$ . For designs where lift is used to determine the flow area, all valves shall have the same nominal lift-to-seat diameter ratio ( $L/D$ ).

**NB-7734.4 Demonstration of Function.** Tests shall be conducted as prescribed in NB-7732.2.

#### NB-7735 Single Valve Method

##### NB-7735.1 Valve Capacity Within Test Facility Limits.

(a) When a single valve is to be capacity tested, the certified capacity may be based on three separate tests associated with each set pressure for which capacity certification is required.

(b) The certified capacity associated with each set pressure shall not exceed 90% of the average capacity established by the tests. Failure of the individual test capacities to fall within  $\pm 5\%$  of the average capacity associated with each set pressure shall be cause for rejection of the test. The reason for the failure shall be determined, and the test repeated.

(c) Should additional valves of the same design be constructed at a later date, the results of the tests on the original valve may be included as applicable to the particular test method selected.

**NB-7735.2 Valve Capacity in Excess of Test Facility Limits.** For valves whose capacity exceeds that of the test facility, the certified capacity may be based on a flow coefficient  $K$  (NB-7734.2) determined from either blocked open flow tests or flow model tests, provided the orifice area is such that choked flow conditions are obtained. The certified capacity shall be calculated as directed in NB-7734.3.

**NB-7735.3 Valve Demonstration of Function.** Tests shall be conducted as prescribed in NB-7732.2, except that one valve of the specific inlet size, orifice size, and specific design shall be tested. Should additional valves of the same design be constructed at a later date, the results of the tests on the original valve may be included as applicable to meet the three valve requirement of NB-7732.2.

#### NB-7736 Proration of Capacity

(a) The capacity of a pressure relief valve applied to a system may be prorated to an overpressure greater than the overpressure for which the valve design is certified. This overpressure shall be within the allowable limits of the system.

(b) Depending on the method used for the initial capacity certification:

(1) the prorated capacity shall be 90% of the average slope determined in NB-7733 multiplied by the prorated relieving pressure, psia (kPa abs); or

(2) the prorated capacity shall be calculated using the appropriate equation from NB-7734.2 [where  $P$  is the prorated relieving pressure (psia) multiplied by the coefficient  $K$ ].

**NB-7737 Capacity Conversions**

The relieving capacity of pressure relief valves for fluids other than the fluid used for certification shall be determined by the method of conversion given in Appendix XVIII-1000, except that valves for steam service shall be tested on steam.

**NB-7738 Laboratory Acceptance of Pressure Relieving Capacity Tests**

Tests shall be conducted at a place where the testing facilities, methods, procedures, and Authorized Observer (person supervising the tests) meet the applicable requirements of ASME PTC 25-2001, Pressure Relief Devices. The tests shall be made under the supervision of, and certified by, an Authorized Observer. The testing facilities, methods, procedures, and qualifications of the Authorized Observer shall be subject to the acceptance of the ASME Boiler and Pressure Vessel Committee on recommendation from a representative from an ASME designated organization. Acceptance of the testing facility is subject to review within each 5 year period. Capacity test data shall be submitted to the ASME designated organization for review and acceptance.<sup>52</sup>

**NB-7739 Laboratory Acceptance of Demonstration of Function Tests**

The NV Certificate Holder shall assure that the tests are conducted at a place where the testing facilities, methods, and procedures provide for sufficient testing capacity and range of fluid properties so that the testing requirements of NB-7732.2 are met.

**NB-7740 CAPACITY CERTIFICATION OF PRESSURE RELIEF VALVES—INCOMPRESSIBLE FLUIDS****NB-7741 General Requirements**

**NB-7741.1 Capacity Certification.** Capacity certification procedures shall be as required in NB-7742 through NB-7745.

**NB-7741.2 Test Medium.** The test medium to be used for capacity certification shall be water at a temperature between 40°F (5°C) and 125°F (52°C). Demonstration of function tests shall be performed on water at temperatures representative of those to which the pressure relief valve is expected to be exposed in service.

**NB-7741.3 Test Pressure.** The capacity certification tests shall be conducted at pressures which do not exceed the set pressure by more than 10% or 3 psi (20 kPa), whichever is greater. Demonstration of function tests shall be performed at pressures representative of those to which the pressure relief valve is expected to be exposed in service.

**NB-7741.4 Blowdown.** Blowdown shall be recorded at the time of the capacity certification and demonstration of function tests.

**NB-7741.5 Drawings.** Prior to capacity certification and demonstration of function tests, the Certificate Holder shall submit drawings showing the valve construction to the Authorized Observer. The Authorized Observer shall submit the drawings and all test results to the ASME designated organization for review and acceptance.

**NB-7741.6 Design Changes.** When changes are made in the design of a pressure relief valve in such a manner as to affect the flow path, lift, or performance characteristics of the valve, new tests in accordance with this Subarticle shall be performed.

**NB-7742 Valve Designs in Excess of Test Facility Limits**

(a) For a valve design where test pressures will exceed test facility limits, the certified capacity may be based on a flow coefficient  $K$  (NB-7744.2) determined from blocked open flow tests at four pressures covering the range of the test facility.

(1) For a valve design to be certified at a single size and set pressure, a demonstration of function test shall be conducted as prescribed in NB-7732.2 on one valve at the specified pressure.

(2) For a valve design of a single size to be certified over a range of set pressures, demonstration of function tests shall be conducted as prescribed in NB-7732.2 on two valves covering the minimum set pressure which can be accommodated at the demonstration facility selected for the test.

(b) For a valve design which will be used over a range of set pressures and sizes, where test facility limitations make it impossible to perform tests of full-scale pressure relief valves, flow models of three different sizes may be utilized as a basis for capacity certification. The flow model test method of NB-7732.1 shall be used along with the coefficient of discharge method as outline in NB-7744.

(1) A demonstration of function test for three valves which envelope the smallest and largest combination of inlet size and orifice size shall be performed as prescribed in NB-7732.2

**NB-7743 Slope Method**

(a) Four valves of each combination of pipe size and orifice size shall be tested. These four valves shall be set at pressures that cover the appropriate range of pressures for which the valves are to be used, or within the range of the test facility. The instantaneous slope of each test point shall be calculated and averaged, where slope is defined as the measured capacity divided by the square root of the difference between the flow rating pressure and the valve discharge pressure. If any of the experimentally determined slopes fall outside of a range of  $\pm 5\%$  of the average slope, the unacceptable valves shall be replaced by two valves of the same size and set pressure. Following a test of these valves, a new average slope shall be determined, excluding the replaced valve test results. If any



individual slope is now outside of the  $\pm 5\%$  range, then the tests shall be considered unsatisfactory and shall be cause for the ASME designated organization to refuse certification of the particular valve design. The certified capacity shall be 90 % of the average slope multiplied by the square root of the difference between the flow rating pressure and the valve discharge pressure.

(b) Demonstration of function tests shall be conducted as specified in [NB-7732.2](#).

## NB-7744 Coefficient of Discharge Method

Instead of individual capacity tests or the capacity curve method, a coefficient  $K$  may be established for a specific pressure relief valve design in accordance with the following subparagraphs.

**NB-7744.1 Number of Valves to Be Tested.** For each design, three valves for each of three different sizes shall be tested, for a total of nine valves. Each valve of a given size shall be set at a different pressure.

**NB-7744.2 Establishment of Coefficient of Discharge.**

(a) Tests shall be made on each relief valve to determine its lift, opening and closing pressures, and actual capacity, in terms of pounds of water per hour. A coefficient of discharge  $K_D$  shall be established for each test run as follows:

$$K_D = \frac{\text{Actual Flow}}{\text{Theoretical Flow}} = \text{Coefficient of Discharge}$$

where Actual Flow is determined quantitatively by test, and Theoretical Flow is calculated by the following equation:

For tests with water:

(U.S. Customary Units)

$$W_t = 2,407A \sqrt{(P - P_d)W}$$

(SI Units)

$$W_t = 5.092A \sqrt{(P - P_d)W}$$

where

$A$  = actual minimum discharge area through the valve at developed lift, in.<sup>2</sup> (mm<sup>2</sup>)

$P$  = (set pressure  $\times 1.10$ ) plus atmospheric pressure, psia, or set pressure plus 3 psi (20 kPa) plus atmospheric pressure, whichever is greater, flow rating pressure, psia (kPa abs)

$P_d$  = pressure at discharge from valve, psia (MPa)

$W$  = density of water at valve inlet conditions, lb/ft<sup>3</sup> (kg/m<sup>3</sup>)

$W_t$  = Theoretical Flow, lb/hr (kg/hr)

The average of the coefficients of discharge  $K_D$  of the tests shall be multiplied by 0.90, and the product shall be taken

as the coefficient  $K$  of the design. The coefficient of the design shall not be greater than 0.878 (the product of  $0.9 \times 0.975$ ).

(b) If any of the experimentally determined coefficients fall outside of a range of  $\pm 5\%$  of the average coefficient, the unacceptable valves shall be replaced by two valves of the same size and set pressure. Following the test of these valves, a new average coefficient shall be determined, excluding the replaced valve test results. If any individual coefficient is now outside of the  $\pm 5\%$  range, then the test shall be considered unsatisfactory and shall be cause for the ASME designated organization to refuse certification of the particular valve design.

## NB-7744.3 Calculation of Certified Capacity.

(a) The certified capacity of all sizes and pressures of a given design for which the value of  $K$  has been established under the provisions of [NB-7744.2](#) shall not exceed the value calculated by the theoretical equation above multiplied by the coefficient  $K$ .

(b) The coefficient shall not be applied to valves whose beta ratio (the ratio of valve throat and inlet diameter) lies outside the range of 0.15 to 0.75, unless tests have demonstrated that individual coefficients of discharge,  $K_d$ , for valves of the extreme ends of a larger range is within  $\pm 5\%$  of the average coefficient,  $K$ . For designs where lift is used to determine the flow area, all valves shall have the same nominal lift-to-seat diameter ratio ( $L/D$ ).

**NB-7744.4 Demonstration of Function.** Tests shall be conducted as specified in [NB-7732.2](#).

## NB-7745 Single Valve Method

(a) When a single valve at a single pressure is to be capacity tested, the capacity rating may be based on three separate tests of the single valve at the specified set pressure.

(b) The certified capacity rating of the valve shall not exceed 90% of the average established by the tests. Failure of the individual test capacities to fall within 5% of the average capacity shall be cause for rejection of the test. The reason for the failure shall be determined and the tests repeated.

(c) Should additional valves of the same design be constructed at a later date, the results of the tests on the original valve may be included as applicable to the particular test method selected.

(d) Demonstration of function tests shall be conducted as specified in [NB-7732.2](#) except one valve of the specific inlet size, orifice size, and that specific design shall be tested. Should additional valves of the same design be constructed at a later date, the results of the tests on the original valve may be included as applicable, to meet the three valve requirement of [NB-7732.2](#).

**NB-7746 Laboratory Acceptance of Pressure Relieving Capacity Tests**

Tests shall be conducted at a place where the testing facilities, methods, procedures, and Authorized Observer (person supervising the tests) meet the applicable requirements of ASME PTC 25-2001, Pressure Relief Devices. The tests shall be made under the supervision of, and certified by, an Authorized Observer. The testing facilities, methods, procedures, and qualifications of the Authorized Observer shall be subject to acceptance of the ASME Boiler and Pressure Vessel Committee upon recommendation from a representative from an ASME designated organization. Acceptance of the testing facility is subject to review within each 5 year period. Capacity test data shall be submitted to the ASME designated organization for review and acceptance.

**NB-7747 Proration of Capacity**

(a) The capacity of a pressure relief valve applied to a system may be prorated to an overpressure greater than the overpressure for which the valve design is certified. This overpressure shall be within the allowable limits of the system.

(b) Depending on the method used for the initial capacity certification:

(1) the prorated capacity shall be 90% of the average slope determined in [NB-7743](#) multiplied by the prorated relieving pressure (psia); or

(2) the prorated capacity shall be calculated using the appropriate equation from [NB-7744.2](#) [where  $P$  is the prorated relieving pressure (psia) multiplied by the coefficient  $K$ ].

**NB-7748 Capacity Conversions**

The rated pressure relieving capacity of pressure relief valves for liquids other than the liquids used for certification shall be determined by the method of conversion given in Appendix XVIII-1000. This conversion is not valid for liquid flashing valve operating conditions.

**NB-7749 Laboratory Acceptance of Demonstration of Function Tests**

The NV Certificate Holder shall assure that the tests are conducted at a place where the testing facilities, methods, and procedures provide for sufficient testing capacity and range of fluid properties so that the requirements of [NB-7732.2](#) are met.

**NB-7800 MARKING, STAMPING WITH CERTIFICATION MARK, AND DATA REPORTS****NB-7810 PRESSURE RELIEF VALVES****NB-7811 Marking and Stamping with Certification Mark**

Each pressure relief valve shall be plainly marked by the Certificate Holder with the required data below in such a way that the marking will not be obliterated in service. The data shall be in characters not less than  $\frac{3}{32}$  in. (2.5 mm) high. The marking shall be placed on the valve or on a nameplate securely fastened to the valve. The Certification Mark shall be stamped on the valve or nameplate, but the other required data may be stamped, etched, impressed, or cast. The marking shall include the following:

- (a) the name, or an acceptable abbreviation, of the Certificate Holder;
- (b) Certificate Holder's design or type number;
- (c) size \_\_\_\_ NPS (DN) of the valve inlet;
- (d) set pressure \_\_\_\_ psi (kPa);
- (e) certified capacity and overpressure in percent or psi (kPa):

(1) lb/hr (kg/hr) of saturated steam for valves certified on steam; or

(2) scfm (standard cubic feet per minute) at 60°F (15°C) and 14.7 psia (101 kPa) of air for valves certified on air or gas; or

(3) gal/min of water at 70°F (20°C) for valves certified on water.

(f) applicable official Certification Mark, as shown in Table NCA-8100-1.

In addition to the above, each pressure relief valve shall have a separate nameplate attached to the component that includes the marking requirements of NCA-8220 and [NB-3593.2](#).

**NB-7812 Report Form for Pressure Relief Valves**

A Data Report Form NV-1 shall be filled out and signed by the Certificate Holder, and signed by the Inspector for each safety and safety relief valve stamped with the Certification Mark with NV Designator.

**NB-7820 RUPTURE DISK DEVICES****NB-7821 Rupture Disks**

Every rupture disk shall be plainly marked by the manufacturer in such a way that the marking will not be obliterated in service. The rupture disk marking may be placed on the flange of the rupture disk or on a metal tab permanently attached thereto.<sup>53</sup> The marking shall include the following:

- (a) the name or identifying trademark of the manufacturer
- (b) manufacturer's design or type number
- (c) lot number

- (d) size \_\_\_\_NPS (DN)
- (e) stamped bursting pressure \_\_\_\_psi (kPa)
- (f) specified disk temperature \_\_\_\_°F (°C)
- (g) capacity \_\_\_\_lb/hr (kg/hr) of saturated steam or \_\_\_\_standard ft<sup>3</sup> (m<sup>3</sup>) of air (60°F and 14.7 psia)/min (15°C and 101 kPa/min)
- (h) year built

**NB-7822 Disk Holders (If Used)**

Rupture disk holders shall be marked with the following:

- (a) the name or identifying trademark of the manufacturer

- (b) manufacturer's design or type number
- (c) size \_\_\_\_NPS (DN)
- (d) year built
- (e) serial number

**NB-7830 CERTIFICATE OF AUTHORIZATION TO USE CERTIFICATION MARK**

Each pressure relief valve within the scope of this Article shall be constructed by a Manufacturer possessing a Certification Mark with NV Designator and valid Certificate of Authorization. Pressure relief valves shall have the Certification Mark with NV Designator applied in accordance with the rules of [NB-8100](#).

## **ARTICLE NB-8000 NAMEPLATES, STAMPING WITH CERTIFICATION MARK, AND REPORTS**

### **NB-8100 GENERAL REQUIREMENTS**

The requirements for nameplates, stamping with Certification Mark, and reports shall be as given in NCA-8000.

INTENTIONALLY LEFT BLANK

## ENDNOTES

- 1 Any postweld heat treatment time that is anticipated to be applied to the material or item after it is completed shall be specified in the Design Specification. The Certificate Holder shall include this time in the total time at temperature specified to be applied to the test specimens.
- 2 In addition to providing a basis for acceptance standards for material, the test data are designated to be used as a basis for establishing inservice operation and for use in fracture prevention evaluation [NB-3211(d) and Appendix G].
- 3 The requirements for impact testing of the heat-affected zone (NB-4335.2) may result in reduced test temperatures or increased toughness requirements for the base material.
- 4 The methods given in the Appendix of SFA-5.9, Specification for Corrosion Resisting Chromium and Chromium-Nickel Steel Welding Rods and Bare Electrodes, shall be used to establish a welding and sampling method for the pad, groove, or other test weld to ensure that the weld deposit being sampled will be substantially free of base metal dilution.
- 5 The volumetric examinations required by this paragraph need only be conducted from one surface.
- 6 The direction of ultrasonic examinations referenced is the direction of sound propagation.
- 7 Lowest service temperature is the minimum temperature of the fluid retained by the component or, alternatively, the calculated volumetric average metal temperature expected during normal operation, whenever pressure within the component exceeds 20% of the preoperational system hydrostatic test pressure.
- 8 This definition of stress intensity is not related to the definition of stress intensity applied in the field of Fracture Mechanics.
- 9 *Equivalent linear stress* is defined as the linear stress distribution which has the same net bending moment as the actual stress distribution.
- 10 See Tables NB-3217-1 and NB-3217-2 and Note (2) of Figure NB-3221-1.
- 11 The concept of stress differences discussed in NB-3216 is essential to determination to the maximum range, since algebraic signs must be retained in the computation. Note that this limitation on range is applicable to the entire history of normal Service Conditions, not just to the stresses resulting from each individual transient.
- 12 As is stated in NB-3223, for components operating within the temperature limits of this Subsection, Service Loadings for which Level B Limits are designated must be considered as though Level A Limits were designated in evaluating exemptions from fatigue analysis.
- 13 Adjacent points are defined in (a), (b), and (c) below.
  - (a) For surface temperature differences on surfaces of revolution in the meridional direction, adjacent points are defined as points that are less than the distance  $2\sqrt{Rt}$ , where  $R$  is the radius measured normal to the surface from the axis of rotation to the midwall and  $t$  is the thickness of the part at the point under consideration. If the product  $Rt$  varies, the average value of the points shall be used.
  - (b) For surface temperature differences on surfaces of revolution in the circumferential direction and on flat parts, such as flanges and flat heads, adjacent points are defined as any two points on the same surface.
  - (c) For through-thickness temperature differences, adjacent points are defined as any two points on a line normal to any surface.
- 14 *Normal service* is defined as service, other than startup and shutdown, resulting in specified Service Loadings for which Level A Limits, Level B Limits, or Testing Limits are designated.
- 15 The algebraic range of the difference shall be used.
- 16 It is permissible to use  $1.5S_m$  whenever it is greater than  $S_y$ .



- 17 *Communicating chambers* are defined as portions of the vessel which intersect the shell or heads of a vessel and form an integral part of the pressure-retaining closure, e.g., sumps.
- 18 *Side plates of a flat sided vessel* are defined as any of the flat plates forming an integral part of the pressure-retaining enclosure.
- 19 These requirements for the acceptability of a valve design are not intended to ensure the functional adequacy of the valve. However, for pressure relief valves the Designer is cautioned that the requirements of NB-7000 relative to set pressure, lift, blowdown, and closure shall be met.
- 20 The severity and frequency of specified fluid temperature variations may be such that the period of calculated pressure integrity is less than plant design life. In such cases it is the responsibility of the Certificate Holder to state these conditions in the Design Report (NB-3560).
- 21 Special features such as wear surfaces or seating surfaces may demand special alloys or proprietary treatments. The absence of such materials from Section II, Part D, Subpart 1, Tables 2A and 2B shall not be construed to prohibit their use and such materials do not require approval under Section III Appendices, Mandatory Appendix IV (NB-2121).
- 22 A listed pressure rated valve is one listed in the tables of ASME B16.34. A nonlisted pressure rated valve is one whose Design Pressure and Temperature do not specifically appear in those tables (NB-3543).
- 23 For all listed pressure ratings except Class 150, the Pressure Rating Class Index is the same as the pressure rating class designation. For Class 150 use 115 for the Pressure Rating Class Index.
- 24 *Adjacent points* are defined as points which are spaced less than the distance  $2\sqrt{Rt}$  from each other, where  $R$  and  $t$  are the mean radius and thickness, respectively, of the vessel, nozzle, flange, or other component in which the points are located.
- 25 For piping products, such as tees and branch connections, the second term of eqs. NB-3652(9), NB-3653.1(a)(10), and NB-3653.2(a)(11), namely that containing  $M_b$  is to be calculated as referred to in NB-3683.1(d).
- 26 Socket welds shall not be used where the existence of crevices could accelerate corrosion.
- 27 The flexibility of a curved pipe or welding elbow is reduced by *end effects*, provided either by the adjacent straight pipe or by the proximity of other relatively stiff members which inhibit ovalization of the cross section. In certain cases, these end effects may also reduce the stress.
- 28  $t$  equals nominal wall thickness.
- 29 Welds that are exposed to corrosive action should have a resistance to corrosion that is not substantially less than that of the cladding. The use of filler metal that will deposit weld metal which is similar to the composition of the cladding material is recommended. If weld metal of different composition is used, it should have properties compatible with the application.
- 30 An *intermediate postweld heat treatment* for this purpose is defined as a postweld heat treatment performed on a weld within a temperature range not lower than the minimum holding temperature range to which the weld shall be subjected during the final postweld heat treatment.
- 31 A radiographic examination [NB-5111(a)] is required; a preservice examination [NB-5111(b)] may or may not be required for compliance to the Design Specification [NCA-3252(c)].
- 32 SNT-TC-1A is a Recommended Practice for Nondestructive Testing Personnel Qualification and Certification published by the American Society for Nondestructive Testing, 1711 Arlingate Lane, P.O. Box 28518, Columbus, OH 43228-0518.
- 33 Personnel qualified by examination and certified to the previous editions of SNT-TC-1A are considered to be qualified to the edition referenced in Table NCA-7100-2 when the recertification is based on continuing satisfactory performance. All reexaminations and new examinations shall be in accordance with the edition referenced in Table NCA-7100-2.
- 34 *Employer* as used in this Article shall include: N Certificate Holders; Quality System Certificate Holders; Material Organizations who are qualified in accordance with NCA-3842; and organizations who provide subcontracted nondestructive examination services to organizations described above.
- 35 These tests may be made with the item being tested partially filled with liquid, if desired.

- 36 Wherever the word *system* appears in this Article, it refers to the component or group of components for which overpressure protection is provided as described in the Overpressure Protection Report.
- 37 A *pressure relief device* is designed to open to prevent a rise of internal fluid pressure, greater than a specified value, resulting from exposure to pressure transient conditions. It may be a pressure relief valve or a nonreclosing pressure relief device.
- 38 An inlet water loop seal consists of valve inlet piping that is configured to form a water seal below the pressure relief valve seat which separates the normal system relieving fluid (steam) from the valve seat.
- 39 A *pressure relief valve* is a pressure relief device that is designed to reclose and prevent the further flow of fluid after normal conditions have been restored.
- 40 A *nonreclosing pressure relief device* is a pressure relief device designed to remain open after operation.
- 41 A *safety valve* is a pressure relief valve actuated by inlet static pressure and characterized by rapid opening or pop action.
- 42 A *safety relief valve* is a pressure relief valve characterized by rapid opening pop action, or by opening generally proportional to the increase in pressure over the opening pressure.
- 43 A *relief valve* is a pressure relief valve actuated by inlet static pressure and having a gradual lift generally proportional to the increase in pressure over the opening pressure.
- 44 A *pilot operated pressure relief valve* is a pressure relief valve in which the major relieving device is combined with and is controlled by a self-actuated auxiliary pressure relief valve.
- 45 A *power actuated pressure relief valve* is a pressure relief valve in which the major relieving device is combined with and controlled by a device requiring an external source of energy.
- 46 A *rupture disk device* is a nonreclosing pressure relief device actuated by inlet static pressure and designed to function by the bursting of a pressure-containing disk.
- 47 *Expected system pressure transient conditions* are those associated with normal system transient operation, such as loss of feedwater or loss of load.
- 48 *Unexpected system excess pressure transient conditions* are those associated with unusual or abnormal system transients, but still considered to be within the design basis, such as loss of load with failure of reactor scram.
- 49 The specified disk temperature supplied to the rupture disk manufacturer shall be the expected temperature of the disk when the disk is expected to burst.
- 50 The *manufacturing design range* is a range of pressure within which the stamped burst pressure must fall. This range is included in the Design Specification and the Overpressure Protection Report.
- 51 A *lot of rupture disks* is those disks manufactured of material at one time, of the same size, thickness, type, heat, and manufacturing process, including heat treatment.
- 52 Valve capacities published in "Pressure Relief Device Certifications." This publication may be obtained from the National Board of Boiler and Pressure Vessel Inspectors, 1055 Crupper Avenue, Columbus, OH 43229.
- 53 In lieu of marking all of the listed items on the flange or tab of each rupture disk, the marking may consist of a Manufacturer's coding number sufficient to identify each rupture disk with a certificate or tab which includes the required information and is supplied with each lot of rupture disks.

INTENTIONALLY LEFT BLANK

INTENTIONALLY LEFT BLANK

# 2013 ASME Boiler and Pressure Vessel Code

AN INTERNATIONAL CODE



The ASME Boiler and Pressure Vessel Code (BPVC) is "An International Historic Mechanical Engineering Landmark," widely recognized as a model for codes and standards worldwide. Its development process remains open and transparent throughout, yielding "living documents" that have improved public safety and facilitated trade across global markets and jurisdictions for nearly a century.

ASME also provides BPVC users with integrated suites of related offerings:

- referenced standards
- training and development courses
- related standards and guidelines
- ASME Press books and journals
- conformity assessment programs
- conferences and proceedings

You gain unrivaled insight direct from the BPVC source, along with the professional quality and real-world solutions you have come to expect from ASME.

For additional information and to order:

Phone: 1.800.THE.ASME (1.800.843.2763)

Email: [customercare@asme.org](mailto:customercare@asme.org)

Website: [go.asme.org/bpvc13](http://go.asme.org/bpvc13)

ISBN 978-0-7918-3457-2



60003B

[www.iran-mavad.com](http://www.iran-mavad.com)

مرجع دانشجویان و مهندسين مواد